

APPENDICIES

Appendix A - WNH Asset Condition Assessment (ACA) Report

Appendix B - 2021 Material Capital Investments

Appendix C - KWCG IRRP Report (2015)

Appendix D - KWCG RIP Report (2015)

Appendix E - KWCG Needs Assessment Report (2018)

Appendix F - KWCG IRRP Scoping Assessment Outcome Report (2019)

Appendix G - KWCG Regional Planning Status Letter

Appendix H - WNH Renewable Energy Generation (REG) Investment Plan

Appendix I - IESO REG Letter of Comment

Appendix J - WNH System Supply and Capacity Study

Appendix K - WNH Distribution System Reliability Report

Appendix L - WNH Customer Engagement Reports

Appendix M - WNH Fleet Management Plan

Appendix N - WNH Information Technology Management Plan

Appendix O - WNH Facilities Management Plan

Appendix P - WNH Operations Maintenance Report

Appendix Q - OEB Appendix 5-A Unit Cost Metrics

Appendix R - OEB Chapter 2 Appendix 2-AA

Appendix A:

WNH Asset Condition Assessment (ACA) Report

Appendix A:

WNH Asset Condition Assessment (ACA) Report



Waterloo North Hydro Inc.

DISTRIBUTION ASSETS
CONDITION ASSESSMENT
REPORT (ACA)

June 23, 2020

Version 1.0

TABLE OF CONTENTS

TABLE OF CONTENTS	2
LIST OF TABLES	5
LIST OF FIGURES	7
GLOSSARY	8
1 INTRODUCTION	11
1.1 Assets Under Study	11
1.2 Asset Condition Assessment Methodology	12
2 ASSET CONDITION ASSESSMENTS	15
2.1 HIGH VOLTAGE STATION PRIMARY SWITCHES (230 kV and 115 kV).....	16
2.1.1 Asset Demographics	16
2.1.2 Condition Assessment Criteria	16
2.1.3 Condition Assessment.....	17
2.1.4 Data Availability Indicator	18
2.1.5 Analysis of Results	18
2.2 STATION TRANSFORMERS (230 kV and 115 kV)	19
2.2.1 Asset Demographics	19
2.2.2 Condition Assessment Criteria	20
2.2.3 Condition Assessment.....	21
2.2.4 Data Availability Indicator	22
2.2.5 Analysis of Results	22
2.3 STATION (TS) SWITCHGEAR	23
2.3.1 Asset Demographics	23
2.3.2 Condition Assessment Criteria	23
2.3.3 Condition Assessment.....	24
2.3.4 Data Availability Indicator	25
2.3.5 Analysis of Results	25
2.4 STATION (TS) CIRCUIT BREAKERS.....	26
2.4.1 Asset Demographics	26
2.4.2 Condition Assessment Criteria	28
2.4.3 Condition Assessment.....	29
2.4.4 Data Availability Indicator	31
2.4.5 Analysis of Results	31
2.5 STATION (TS) FEEDER CABLES.....	33
2.5.1 Asset Demographics	33
2.5.2 Condition Assessment Criteria	34

2.5.3	Condition Assessment.....	35
2.5.4	Data Availability Indicator	37
2.5.5	Analysis of Results	37
2.6	STATION (TS) PROTECTION RELAYS	39
2.6.1	Asset Demographics	39
2.6.2	Condition Assessment Criteria	40
2.6.3	Condition Assessment.....	41
2.6.4	Data Availability Indicator	42
2.6.5	Analysis of Results	42
2.7	DISTRIBUTION STATION (DS) TRANSFORMERS	43
2.7.1	Asset Demographics	43
2.7.2	Condition Assessment Criteria	43
2.7.3	Condition Assessment.....	45
2.7.4	Data Availability Indicator (DAI)	45
2.7.5	Analysis of Results	45
2.8	POLES	47
2.8.1	Asset Demographics	47
2.8.2	Condition Assessment Criteria	50
2.8.3	Condition Assessment.....	51
2.8.4	Data Availability Indicator (DAI)	53
2.8.5	Analysis of Results	53
2.9	PRIMARY UNDERGROUND DISTRIBUTION CABLES	55
2.9.1	Asset Demographics	55
2.9.2	Condition Assessment Criteria	59
2.9.3	Condition Assessment.....	60
2.9.4	Data Availability Indicator (DAI)	61
2.9.5	Analysis of Results	62
2.10	DISTRIBUTION TRANSFORMERS.....	64
2.10.1	Asset Demographics	64
2.10.2	Condition Assessment Criteria	64
2.10.2.1	PCB's	68
2.10.3	Condition Assessment.....	69
2.10.4	Data Availability Indicator (DAI)	70
2.10.5	Analysis of Results	70
2.11	REVENUE METERS	71
2.11.1	Asset Demographics	71
2.11.2	Condition Assessment Criteria	73

2.11.3 Condition Assessment.....	75
2.11.4 Data Availability Indicator	76
2.11.5 Analysis of Results	76
2.12 MANUAL LOADBREAK SWITCHES	78
2.12.1 Asset Demographics	78
2.12.2 Condition Assessment Criteria	78
2.12.3 Condition Assessment.....	79
2.12.4 Data Availability Indicator (DAI)	80
2.12.5 Analysis of Results	80
3 Asset Replacement Recommendations	81

LIST OF TABLES

Table 2-1: TS HV Circuit Switches.....	16
Table 2-2: TS HV Circuit Switches (TUL).....	16
Table 2-3: TS HV Circuit Switches Condition Assessment Criteria.....	17
Table 2-4: TS HV Circuit Switches Condition Assessments	17
Table 2-5: TS Large Power Transformer Demographics.....	19
Table 2-6: TS Step Up / Step Down Transformer Demographics.....	19
Table 2-7: TS Station Transformer (TUL).....	20
Table 2-8: TS Transformer Condition Assessment Criteria	20
Table 2-9: Health Index Condition Categories.....	21
Table 2-10: TS Transformer Health Condition Assessments	21
Table 2-11: TS Switchgear Demographics.....	23
Table 2-12: TS Switchgear (TUL).....	23
Table 2-13: TS Switchgear Condition Assessment Criteria.....	24
Table 2-14: TS Switchgear Condition Assessments	24
Table 2-15: TS Main Bank and Tie Breaker Demographics	26
Table 2-16: TS Feeder Breaker Demographics.....	27
Table 2-17: TS Main Bank and Tie Breaker (TUL)	28
Table 2-18: TS Breaker Condition Assessment Criteria	28
Table 2-19: HMSTS"A" Breaker Condition Assessments.....	29
Table 2-20: ERTS Breaker Condition Assessments.....	29
Table 2-21: HMSTS"B" Breaker Condition Assessments.....	30
Table 2-22: HMSTS"B" Breaker Condition Assessments.....	31
Table 2-23a: TS Feeder Cable Demographics	33
Table 2-23b: TS Feeder Cable Demographics	34
Table 2-24: TS Feeder Cables (TUL)	34
Table 2-25: TS Feeder Cables Assessment Criteria	35
Table 2-26a: TS Feeder Cable Condition Assessments.....	35
Table 2-26b: TS Feeder Cable Condition Assessments.....	36
Table 2-26c: TS Feeder Cable Condition Assessments.....	37
Table 2-27: TS Protection Systems Age and Condition	39

Table 2-28: TS Protection Systems (TUL).....	40
Table 2-29: Protection Relay Condition Assessment Criteria	41
Table 2-30: Protection Relay Condition Assessments.....	41
Table 2-31: WNH Municipal and Distribution Stations	43
Table 2-32: DS Transformers (TUL).....	43
Table 2-33: DS Transformers Condition Assessment Criteria.....	44
Table 2-34: DS Transformers Health Condition Assessments	45
Table 2-35: Pole Population by Type	47
Table 2-36: Pole Population Demographics by Municipality.....	47
Table 2-37: Pole Population Urban / Rural.....	48
Table 2-38: Pole Utilization	48
Table 2-39: Pole Age.....	49
Table 2-40: Poles (TUL)	50
Table 2-41: Recommended Health Index Assessment Criteria.....	51
Table 2-42: Recommended Health Index.....	52
Table 2-43: Pole Health Index distribution by Number of Circuits	53
Table 2-44: Pole Replacement Recommendation	54
Table 2-45: Cable Population by Type	55
Table 2-46: Cable Population by Installation Method	56
Table 2-47: Cable Population by System Voltage	57
Table 2-48: Cable Population Demographics.....	57
Table 2-49: Cable TUL by Type	59
Table 2-50: WNH Cable Assessment Criteria.....	60
Table 2-51: Condition Assessment Results	60
Table 2-52: Primary Cable Replacement Recommendation	63
Table 2-53: WNH Distribution Transformer Population by Type.....	64
Table 2-54: WNH Distribution Transformer TUL's.....	65
Table 2-55: Recommended Health Index Assessment Criteria.....	66
Table 2-56: WNH Transformer Average Age	66
Table 2-57: WNH PCB Transformers	68
Table 2-58: WNH Distribution Transformer HI.....	69

Table 2-59: Meters by Application	71
Table 2-60: WNH Meters by Age	72
Table 2-61: Metering Asset (TUL)	73
Table 2-62: Meter Condition Assessment Criteria	73
Table 2-63: Meter Condition Assessments	75
Table 2-64: Load Break Switch (TUL)	78
Table 2-65: Load Break Switch Assessment Criteria.....	79
Table 2-66: Manual Load Break Switch Age Profile	79
Table 2-67: Manual Load Break Switch Age Profile	80
Table 3-1: WNH Recommended Asset Replacement Plan	81

LIST OF FIGURES

Figure 2-1: WNH Pole Population Age Profile.....	50
Figure 2-2: WNH Pole Population HI Distribution.....	52
Figure 2-3: XLPE Age Profile	58
Figure 2-4: TRXLPE Age Profile	58
Figure 2-5: WNH Cable Population HI Profile	61
Figure 2-6: Transformer Age Profile.....	67
Figure 2-7: WNH Distribution Transformer Utilization (%)	67
Figure 2-8: WNH Distribution Transformer Population HI Profile	69
Figure 2-9: WNH Meter Installations by Age	72
Figure 2-10: Load Break Switch Population by % TUL.....	78

GLOSSARY

- 1) ACA – Asset Condition Assessment
- 2) ACSR – Aluminum Conductor Steel-Reinforced
- 3) AM – Asset Management
- 4) AMI – Advanced Metering Infrastructure
- 5) AMP – Asset Management Process
- 6) BIL – Basic Impulse Level
- 7) CSA – Canadian Standards Association
- 8) DG – Distributed Generation
- 9) DGA – Dissolved Gas Analysis
- 10) DS – Distribution Station
- 11) DSC – Distribution System Code
- 12) DSP – Distribution System Plan
- 13) EOL – End of Life
- 14) ESA – Electrical Safety Authority
- 15) FLISR – Fault Location, Isolation and Service Restoration
- 16) GATR – Guelph Area Transmission Reinforcement
- 17) GIS – Geographic Information System
- 18) GS – General Service
- 19) HI - Health Indices
- 20) HONI – Hydro One Networks Inc.
- 21) IESO – Independent Electricity System Operator
- 22) IT – Information Technology
- 23) KPI – Key Performance Indicator

- 24) kW - kilowatt
- 25) KWCG – Kitchener – Waterloo – Cambridge – Guelph
- 26) KWHI – Kitchener-Wilmot Hydro Inc.
- 27) LDC – Local Distribution Company
- 28) LDG – Load Displacement Generation
- 29) LOS – Loss of Supply
- 30) LTLT – Long Term Load Transfer
- 31) LTR – Limited Time Rating
- 32) MC – Measurement Canada
- 33) NWA - Non-wires alternatives
- 34) O/H or OH - Overhead
- 35) O&M – Operation & Maintenance
- 36) O&M – Operation, Maintenance & Administration
- 37) ONAN - Oil Natural Air Natural
- 38) ONAF - Oil Natural Air Forced
- 39) ODS – Operational Data Store
- 40) OEB – Ontario Energy Board
- 41) OMS – Outage Management System
- 42) OPA – Ontario Power Authority
- 43) ORTAC – Ontario Resource and Transmission Assessment Criteria
- 44) OT – Operation Technology
- 45) REG – Renewable Energy Generation
- 46) RIP – Regional Infrastructure Planning
- 47) ROE – Return on Equity

- 48) RRFE – Renewed Regulatory Framework for Electricity Distributors
- 49) RTU – Remote Terminal Units
- 50) SCADA – Supervisory Control and Data Acquisition
- 51) SEI – Serious Electrical Incidents
- 52) the Board – Ontario Energy Board
- 53) the City – City of Waterloo
- 54) the Region – Region of Waterloo
- 55) TPSS – Traction Power Substations
- 56) TRXLPE – Tree-Retardant Cross-Linked Polyethylene
- 57) TUL – Typical Useful Life
- 58) TS – Transmission Station or Transformer Station
- 59) U/G or UG – Underground
- 60) ULTC – Under-Load Tap Changing
- 61) URD – Underground Residential Distribution
- 62) USF – Utilities Standards Forum
- 63) WNHI / WNH – Waterloo North Hydro Inc.
- 64) XFMR – Transformer
- 65) XLPE – Cross-Linked Polyethylene

1 INTRODUCTION

This Asset Condition Assessment (ACA) report was prepared by Waterloo North Hydro Inc. (WNH) to provide a consolidated view of the condition of WNH's key station and distribution assets. WNH utilized the METSCO Energy Solutions Inc. (METSCO) Asset Analysis, Prioritization and Optimization Tool (ENGIN) and Health Index Frameworks in the preparation of this DSP. The results of this report inform WNH's Distribution System Plan (DSP) which provides the basis for WNH's investment plans for the years 2021 to 2025 inclusive. This report also informs the senior executive team (Executive) at WNH in developing WNH's overall Corporate Investment Plan and supports WNH's 2021 Cost of Service application. The findings of the report are based on data collected up to and including December 31, 2019.

1.1 Assets Under Study

The scope of this ACA covers the following assets owned by WNH:

Grid Connected Transformer Stations (230 kV & 115 kV)

- High Voltage Primary Switches
- Station Transformers
- Switchgear
- Circuit Breakers
- Feeder Cables
- Station Protection Relays

Distribution System

- Distribution Station Transformers
- Poles
- Primary Underground Cables
- Distribution Transformers
- OH Load Break switches
- Revenue Meters

Fleet, Information Technology and Facilities assets are addressed in their own ACA Reports and are not included within the scope of this report. They can be found in the following DSP Appendices;

Appendix M - Fleet Management Plan

Appendix N – Information Technology Management Plan

Appendix O - Facilities Management Plan

1.2 Asset Condition Assessment Methodology

WNH's Asset Condition Assessment methodology involves the continuous collection of asset condition data, establishment of asset end-of-life (EOL) criteria, analysis of performance and/or condition data against EOL criteria and the development of quantitative asset Health Indices (HI) that help identify and rank assets at greatest risk; all to inform WNH's capital and maintenance investment plans.

Health Indices are quantified condition scores of the asset relative to its EOL criteria. The major elements to health indexing include;

- Demographics – the foundation of WNH's ACA process is based on its extensive Asset Registry Database. Demographic information includes but is not limited to asset types, features, ratings, age, and quantity for each of the asset classes under study.
- Degradation processes – identifying how each asset type deteriorates in condition, performance and ultimately fails.
- End-Of-Life Criteria (Degradation Factors) – are developed by understanding the degradation and failure processes for each asset and quantifying typical-useful-life (TUL) and maximum-useful-life (MUL) parameters. WNH has relied on results of the Kinectrics Inc. Report No: K-418033-RA-001-R000, April 28, 2010, Kinectrics Inc. (Kinectrics Report) in this report.
- Health Index Framework – establishing a quantitative Health Index score by establishing the relative weight (importance) each degradation factor has in

establishing the health of an asset and calculating the normalized sum of each weighted degradation factor. Assets are classified in one of five asset conditions: Very Good, Good, Fair, Poor, or Very Poor. The asset health conditions set the ground work for developing a data driven asset replacement program.

- In order to create a Health Index Framework, a series of inputs are required including:
- Internal Knowledge: Understanding of key asset classes and sub-classes with specialized characteristics that result in elevated failure probabilities that must be captured as part of health index formulation;
- Maintenance Practices: In-field inspection data will be captured from current maintenance practices to support health index quantification;
- Subject-Matter Experts: These experts represent a key component in the development and validation of the HI formulation and include equipment manufacturers' recommendations, WNH's expertise, judgement and experience.
- Consultant Experience: Industry-defined degradation parameters can be produced where current-state data remains limited. WNH has utilized both the Kinectrics report and METSCO's Health Index Frameworks as the basis of developing its own framework as presented in this report.
- Condition/Performance Assessments - the collection of condition/performance data through inspections, testing and maintenance, that relate to the degradation processes guided by the Health Index Framework.

For poles and underground cable, WNH utilized ENGIN, a software application developed by METSCO Energy Solutions Inc. (METSCO). ENGIN is an Asset Analysis, Prioritization and Optimization Tool used in developing the asset assessment Health Indices for the replacement analysis recommendations in this report. WNH is working with METSCO to implement a fully risk-based asset management system for all of its key asset classes.

For the remainder of the assets under study, the asset condition assessments were

developed by WNH, aided by Health Index Frameworks developed by METSCO Energy Solutions Inc. (METSCO). Where necessary, WNH tailored these frameworks to reflect WNH's specific asset types and their key degradation factors. These frameworks utilize the asset degradation and weighting factors to develop the Health Indices for the assets studied in this report.

Commonly the following guidelines are used to determine asset replacement.

- Assets in service and identified as in immediate danger of failure are assigned to WNH's Proactive Renewal Program. Depending on the condition, assets are planned for replacement anywhere from next day to 12 months.
- Assets in service and in very poor or poor condition are assigned to WNH's System Renewal Plan. Depending on the condition and risk assessments, assets are normally replaced anywhere from 1 to 2 years.
- Assets in Fair condition are monitored and may be revaluated in the upcoming 2 to 5 years to determine their rate of degradation. This may require additional inspection and testing.
- All assets are revaluated as new inspection, testing, performance and financial data become available. Replacement of assets evaluated in Good and Very Good condition generally fall outside the current 5-year renewal plan.

In addition to the aforementioned health indices, additional asset demographic information and metrics are provided including total population, age distribution, and average data availability indicators (DAI). An analysis of results is provided with each asset group that assists in the development of a renewal strategy for the asset class.

2 ASSET CONDITION ASSESSMENTS

WNH maintains an extensive asset register and has established comprehensive data collection, asset inspection, testing and maintenance programs to provide condition assessments for its major distribution system assets.

Factors such as condition assessment data, age, typical useful life (TUL), and asset performance are evaluated with respect to condition and performance targets to develop a condition rating.

Each asset condition assessment outlined in this report includes the following;

1. Asset Demographics – includes a description of the assets in each asset group, quantities, age, ratings,
2. Condition Assessment Criteria – the degradation factors and measures by which asset Health Indices are calculated.
3. Typical Useful Life – used to provide age demographics and inform the asset condition assessments. Reference in this report is made frequently to Kinectrics Inc. Report No: K-418033-RA-001-R000, April 28, 2010, Kinectrics Inc. (Kinectrics Report).
4. Health Index Scoring – the total of all evaluated degradation factors multiplied by their individual weighting
5. Health Index Condition Categories – the categorization of Health Index scoring into five categories from Very Good to Very Poor.
6. Data Availability Indicator - is a measure of the completeness of the data set required to calculate the Health Indices and assess the overall condition of the asset group. The DAI is a weighted average of the quantity of asset data used for the HI calculations and the relative evaluation weighting of data, expressed as a percent of the maximum.
7. Analysis of Results – provides an overview of the asset condition assessments and assets flagged for action.

2.1 HIGH VOLTAGE STATION PRIMARY SWITCHES (230 kV and 115 kV)

2.1.1 Asset Demographics

This asset group is made up of 8 outdoor high voltage air break switches and SF6/Vacuum interrupter circuit switchers. These devices are used to separate and isolate the main station power transformers from the transmission system.

Table 2-1: TS HV Circuit Switches

#	TRANSFORMER STATION	HV (kV)	SWITCH ID	IN SERVICE	TYPE
1	HMSTS 'A'	230	T1	2006	Air Break
2			T2	2006	Air Break
3	HMSTS 'B'	230	T3	1986	Air Break
4			T4	1988	Air Break
5	MTS #3	230	T1	2001	Circuit Switcher
6			T2	2001	Circuit Switcher
7	ERTS	115	T1	2012	Circuit Switcher
8			T2	2012	Circuit Switcher

2.1.2 Condition Assessment Criteria

WNH has adopted a TUL of 30 years for these assets. This is consistent with the Kinectrics Report and WNH's own experience.

Table 2-2: TS HV Circuit Switches (TUL)

	KINECTRICS REPORT		WNH
Min UL	TUL	Max UL	TUL
30	45	60	30

Table 2-3: TS HV Circuit Switches Condition Assessment Criteria

Degradation Factor	Type	Weight	Ranking	Numerical Grade	Max Grade
Age	ALL	8	A,B,C,D,E	4,3,2,1,0	32
Timing/Travel Tests	All	3	A,B,C,D,E	4,3,2,1,0	12
Visual Inspection	All	8	A,B,C,D,E	4,3,2,1,0	32
Disconnect Live Parts*	All	3	A,B,C,D,E	4,3,2,1,0	12
Contact Resistance	All	3	A,B,C,D,E	4,3,2,1,0	12
Infrared Scan (IR)	All	6	A,C,E	4,2,0	24
Vacuum Loss	Air Break	6	A,B,C,D,E	4,3,2,1,0	24
SF6 Leaks and their severity	SF6/Vac	6	A,B,C,D,E	4,3,2,1,0	24
Total Score		Air Break	124	SF6/Vacuum	172
*Note: Disconnect condition only applies if there is an integrated disconnect in the circuit switcher assembly					

2.1.3 Condition Assessment

Table 2-4 provide age and Health Index scores for WNH's TS high voltage station switches.

Table 2-4: TS HV Circuit Switches Condition Assessments

TRANSFORMER STATION	HV (kV)	SWITCH ID	AGE	HI SCORE	Max HI SCORE	% TUL	% HI	CONDITION
HMSTS 'A'	230	T1	14	102	124	47%	82%	Good
		T2	14	102	124	47%	82%	Good
HMSTS 'B'	230	T3	34	83	172	113%	48%	Poor
		T4	32	86	172	107%	50%	Fair
MTS #3	230	T1	19	126	172	63%	73%	Good
		T2	19	126	172	63%	73%	Good
ERTS	115	T1	8	134	172	27%	78%	Good
		T2	8	134	172	27%	78%	Good

2.1.4 Data Availability Indicator

WNH's DAI for WNH's TS high voltage station switches condition assessment data is 100%. Travel timing tests have yet to be completed on the four air break switches. These tests will be scheduled at the time of their next maintenance outage.

2.1.5 Analysis of Results

Although HMSTS "B" air break switches have exceeded their TUL, their operational performance, inspection and maintenance results have been satisfactory. The T4 air break switches are rated in fair condition and have their next scheduled maintenance in 2020. The T3 switches are rated in poor condition mainly due to a poor contact resistance reading and contact pitting on the red phase. This will be addressed during the 2020 scheduled maintenance after which the condition rating is expected to increase to Fair.

Currently there are no indications the switches will not meet an extended service date of 2025 with regular maintenance. It is recommended that in 2024, WNH conduct another thorough condition assessment to inform the next investment cycle with either a life extension or replacement plan.

There are no replacements forecast for any of these assets prior to 2025.

2.2 STATION TRANSFORMERS (230 kV and 115 kV)

2.2.1 Asset Demographics

WNH owns a fleet of 8 large power transformers (**Table 2-5**) connected to the HONI transmission system. With an average age of 27.6 years, approximately 81% of WNH's total electrical supply flows through these assets. Due to their importance, asset condition is frequently monitored and assessed. These are high valued capital assets and WNH invests in comprehensive inspection and maintenance programs to ensure their useful lives are maximized.

Table 2-5: TS Large Power Transformer Demographics

# Tx	Transformer Stations	Owned & Operated by	Supplied By	HONI TX Line	Station Location	HV (kV)	LV (kV)	Tx ID	Tx Full Cooled Rating (MVA)	10 day LTR (MVA)	Age
1	HMSTS 'A'	WNH	HONI Tx	D6V	Waterloo	230	13.8	T1	50.0	69	51
2				D7V				T2	50.0		51
3	HMSTS 'B'	WNH	HONI Tx	D7V	Waterloo	230	13.8	T3	83.0	110	34
4				D6V				T4	83.0		32
5	MTS #3	WNH	HONI Tx	D6V	Waterloo	230	27.6	T1	67.0	85	19
6				D7V				T2	67.0		19
7	ERTS	WNH	HONI Tx	D10H	Waterloo	115	13.8	T1	50.0	75	7
8				D8S				T2	50.0		8

WNH also owns 4 step up/down transformers (**Table 2-6**). These transformers allow WNH to interconnect 4 feeders between the 13.8 kV and 27.6 kV stations providing for greater utilization of station capacity.

Table 2-6: TS Step Up / Step Down Transformer Demographics

# Tx	Transformer Stations	Owned & Operated by	Supplied By	Station Location	Primary (kV)	Secondary (kV)	Tx ID	Tx Full Cooled Rating (MVA)	Overload Rating	Age
1	HMSTS 'B'	WNH	HS19	Waterloo	13.8	27.6	T5	33.0		28
2			HS26		13.8	27.6	T6	33.0		32
3	MTS #3	WNH	3F62 (3F50)	Waterloo	27.6	13.8	T3	16.0		19
4			3F67 (3F51)		27.6	13.8	T4	16.0		19

2.2.2 Condition Assessment Criteria

WNH has adopted a TUL of 50 years for its large station power transformers and step up/down transformers. This is consistent with the Kinectrics Report and WNH's own experience.

Table 2-7: TS Station Transformer (TUL)

	KINECTRICS REPORT		WNH
Min UL	TUL	Max UL	TUL
30	45	60	50

Table 2-8 provides a summary of the asset assessment criteria used to calculate the Heath indices for WNH's station transformers.

Table 2-8: TS Transformer Condition Assessment Criteria

	Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade	Tx's with OLTC	Tx's without OLTC
1	Dissolved Gas Analysis*	10	A,B,C,D,E	4,3,2,1,0	40	40	40
2	Load History	10	A,B,C,D,E	4,3,2,1,0	40	40	40
3	Insulation Power Factor*	10	A,B,C,D,E	4,3,2,1,0	40	40	40
4	Oil Quality	6	A,C,E	4,2,0	24	24	24
5	Degree of Polymerization (or Service Age)	10	A,B,C,D,E	4,3,2,1,0	40	40	40
6	Turns Ratio	5	A,B,C,D,E	4,3,2,1,0	20	20	20
7	Winding Resistance	6	A,B,C,D,E	4,3,2,1,0	24	24	24
8	Tap Changer DGA (if applicable)	6	A,B,C,D,E	4,3,2,1,0	24	24	N / A
9	Tap Changer Oil Quality (if applicable)	3	A,B,C,D,E	4,3,2,1,0	12	12	N / A
10	Tap Changer Operations	5	A,B,C,D,E	4,3,2,1,0	20	20	N / A
11	Overall Bushings	2	A,B,C,D,E	4,3,2,1,0	8	8	8
12	Infrared Scan (IR)*	10	A,B,C,D,E	4,3,2,1,0	40	40	40
13	Overall Inspection Condition	8	A,B,C,D,E	4,3,2,1,0	32	32	32
14	Overall LTC (if applicable)	5	A,B,C,D,E	4,3,2,1,0	20	20	20
Total Score		No LTC	280	With LTC	384	384	328
*Note: If conditions are E, divide the overall health index by 2.							

Table 2-9: Health Index Condition Categories

Health Index	% HI Range	Scoring Thresholds	
		Tx's with OLTC	Tx's without OLTC
Very Good	85-100	326	279
Good	70-85	269	230
Fair	50-70	192	164
Poor	30-50	115	98
Very Poor	0-30	0	0

2.2.3 Condition Assessment

Table 2-10 provides the age and Health Index scores for all WNH TS transformers.

Table 2-10: TS Transformer Health Condition Assessments

STATION	TRANSFORMER	HEALTH INDEX SCORE	MAX HI SCORE	% TUL	HI % SCORE	CONDITION
HMSTS 'A'	T1	302	400	102%	76%	Good
HMSTS 'A'	T2	296	400	102%	74%	Good
HMSTS 'B'	T3	235	400	68%	59%	Fair
HMSTS 'B'	T4	240	400	64%	60%	Fair
MTS#3	T1	305	400	38%	76%	Good
MTS#3	T2	334	400	38%	84%	Good
ERTS	T1	344	400	14%	86%	Very Good
ERTS	T2	325	400	16%	81%	Good
HMSTS 'B'	T5	270	328	56%	82%	Good
HMSTS 'B'	T6	255	328	56%	78%	Good
MTS#3	T3	282	328	38%	86%	Very Good
MTS#3	T4	244	328	38%	74%	Good

2.2.4 Data Availability Indicator

WNH's DAI for Substation Transformer condition assessment data is 99%. High voltage bushing power factor tests have yet to be completed on 4 of WNH's youngest station transformers. These tests will be scheduled at the time of their next maintenance outage.

2.2.5 Analysis of Results

HMSTS"A" T1 and T2 reached their TUL in 2019 however ongoing condition assessments indicate that these assets will outperform this date. Recent tap changer maintenance, HV bushing condition assessments and oil condition analysis are all positive. Due to their age; however, it is prudent for WNH to monitor their condition closely. The planned addition of on-line DGA monitoring is an important step towards that achievement. Replacement of these transformers is forecast to be after 2025.

HMSTS"B" T3 and T4 have been evaluated to be in Fair condition at approximately two-thirds, of their TUL. This is lower than expected and it is recommended that more analysis be performed over the next 5 years to better quantify the rate of health decline in forecasting EOL.

There are no replacements forecast for any of these assets prior to 2025.

2.3 STATION (TS) SWITCHGEAR

2.3.1 Asset Demographics

WNH maintains 8 lineups of metalclad switchgear and 2 lineups of SF6 gas insulated switchgear at its grid connected transformer stations. Each of the stations are constructed in a standard “Jones” configuration having one bus per transformer with a connecting tie breaker in between. HMSTS “B” is constructed in a “Bermondsey” configuration with dual secondary windings on the power transformers. Each winding is connected to one of four buses with each bus pair having a connecting tie breaker in between.

Table 2-11: TS Switchgear Demographics

# SWGR	Transformer Stations	LV (kV)	BUS ID	Bus Rating (A)	In Service	Age
1	HMSTS 'A'	13.8	B	3000	1969	51
2			Y	3000	1969	51
3	HMSTS 'B'	13.8	H	2500	1986	34
4			J	2500	1986	34
5			Q	2500	1988	32
6			T	2500	1988	32
7	MTS #3	27.6	B1	2400	2001	19
8			B2	2400	2001	19
9	ERTS	13.8	B1	3000	1996	24
10			B2	3000	1996	24

2.3.2 Condition Assessment Criteria

WNH has adopted a TUL of 30 years for its TS metalclad switchgear. This is consistent with the Kinectrics Report and WNH's own experience.

Table 2-12: TS Switchgear (TUL)

	KINECTRICS REPORT		WNH
Min UL	TUL	Max UL	TUL
30	50	60	30

Table 2-13 provides a summary of the asset assessment criteria used to calculate the Health indices for WNH's station switchgear.

Table 2-13: TS Switchgear Condition Assessment Criteria

Degradation Factor	Type	Weight	Ranking	Numerical Grade	Max Grade
Service Age	All	3	A,B,C,D,E	4,3,2,1,0	12
Insulation Resistance Tests	All	3	A,C,E	4,2,0	12
SF6 Gas Tests	SF6	3	A,E	4,2,0	12
Metal Clad Cubicle and Components	All	3	A,B,C,D,E	4,3,2,1,0	12
Control & Operating Mechanism Components	All	3	A,B,C,D,E	4,3,2,1,0	12
Overall Physical Condition	All	4	A,B,C,D,E	4,3,2,1,0	16
SF6 Leaks	SF6	2	A,B,C,D,E	4,3,2,1,0	8
Total Score				Air	64
				SF6	84

2.3.3 Condition Assessment

Table 2-14 provides the age and Health index scores for all WNH TS switchgear.

Table 2-14: TS Switchgear Condition Assessments

Station	Bus	HI Score	Max HI Score	% TUL	% HI	Condition Rating
HMSTS A	Bus B	39	64	170%	61%	Fair
HMSTS A	Bus Y	39	64	170%	61%	Fair
HMSTS B	Bus H	45	64	113%	70%	Good
HMSTS B	Bus J	45	64	113%	70%	Good
HMSTS B	Bus Q	45	64	113%	70%	Good
HMSTS B	Bus T	45	64	113%	70%	Good
ERTS	Bus B1	48	64	80%	75%	Good
ERTS	Bus B2	48	64	80%	75%	Good
MTS#3	Bus B1	65	84	67%	77%	Good
MTS#3	Bus B2	65	84	67%	77%	Good

2.3.4 Data Availability Indicator

WNH's DAI for TS switchgear is data is 95%. There are no recent SF6 gas quality tests available for MTS #3 switchgear. The switchgear bus is sealed, and gas pressures are monitored with no indication of leaks. These tests will be scheduled at the time of the next maintenance outage.

2.3.5 Analysis of Results

HMSTS "A" switchgear originally went into service in 1969. In 2006 after 37 years, the switchgear underwent a life extension refurbishment, which also provided Arc Resistant 'B' enhancements for safety and reliability. Forecasted to extend the asset life for an additional 20 years, the switchgear is currently forecast to reach EOL in 2026. Currently the switchgear condition is assessed as Fair partly due to signs of partial discharge damage during the most recent inspection. There are no indications the switchgear will not meet its expected 2026 EOL date; however, additional proactive maintenance will need to be taken over the forecast period. It is recommended that WNH make repairs and monitor the switchgear closely for further deterioration. It is recommended that another detailed condition assessment be performed in approximately four years to inform the next investment cycle with either a further life extension or replacement plan.

HMSTS "B" switchgear originally went into service in two stages, in 1986 and 1988. In 2015 with the oldest equipment having reached the age of 31 years, deterioration of the switchgear busbar insulation system was found. This rehabilitation work along with detailed internal inspections were completed in 2017. Currently the switchgear condition is assessed in Good condition and there have been no discernible issues. Upgrading the arc resistance rating of the HMSTS "B" switchgear is being planned for the 2024 – 2027 timeframe. This work along with regular inspections and maintenance is expected to extend the service life of the switchgear into 2044 period at which time the oldest lineup will be approximately 60 years old.

ERTS are MTS#3 switchgear have been assessed in Good condition and no material investments are forecast prior to 2025.

2.4 STATION (TS) CIRCUIT BREAKERS

2.4.1 Asset Demographics

There are 70 assets in this group including spare units and they are divided into two categories; main bank / tie breakers and feeder breakers. The population also contains several vintages of breakers including air insulated with vacuum interrupters, air insulated with SF6 interrupters and SF6 insulated with vacuum interrupters.

WNH maintains the 15 main bank and tie circuit breakers listed in **Table 2-15**.

Table 2-15: TS Main Bank and Tie Breaker Demographics

# Brk	Transformer Stations	LV (kV)	Breaker ID	Breaker Rating (A)	In Service	Age	Insulation / Interrupter
1	HMSTS 'A'	13.8	B	3000	2006	14	Air / Vacuum
2			Y	3000	2006	14	Air / Vacuum
3			BY	3000	2006	14	Air / Vacuum
4	HMSTS 'B'	13.8	H	2500	2015	5	Air / Vacuum
5			J	2500	1986	34	Air / SF6
6			HJ	2500	1986	34	Air / SF6
7			Q	2500	1986	34	Air / SF6
8			T	2500	1986	34	Air / SF6
9			QT	2500	1986	34	Air / SF6
10	MTS #3	27.6	B1	2400	2001	19	Air / Vacuum
11			B2	2400	2001	19	Air / Vacuum
12			B1B2	2400	2001	19	Air / Vacuum
13	ERTS	13.8	B1	3000	1996	24	SF6 / Vacuum
14			B2	3000	1996	24	SF6 / Vacuum
15			B1B2	3000	1996	24	SF6 / Vacuum

Table 2-16: TS Feeder Breaker Demographics

# Tx	Transformer Stations	LV (kV)	Breaker ID	Breaker Rating (A)	In Service	Age	Insulation / Interrupter
1	HMSTS 'A'	13.8	HS 7	1200	2006	14	Air / Vacuum
2		13.8	HS 8	1200	2006	14	Air / Vacuum
3		13.8	HS 9	1200	2006	14	Air / Vacuum
4		13.8	HS 10	1200	2006	14	Air / Vacuum
5		13.8	HS 11	1200	2006	14	Air / Vacuum
6		13.8	HS 12	1200	2006	14	Air / Vacuum
7		13.8	HS 13	1200	2006	14	Air / Vacuum
8		13.8	HS 14	1200	2006	14	Air / Vacuum
9	HMSTS 'B'	13.8	HS 15	1200	1995	25	Air / SF6
10		13.8	HS 16	1200	1996	24	Air / SF6
11		13.8	HS 17	1200	2014	6	Air / Vacuum
12		13.8	HS 18	1200	1994	26	Air / SF6
13		13.8	HS 19	1200	1993	27	Air / SF6
14		13.8	HS 20	1200	1986	34	Air / SF6
15		13.8	HS 21	1200	1986	34	Air / SF6
16		13.8	HS 22	1200	2009	11	Air / Vacuum
17		13.8	HS 23	1200	1989	31	Air / SF6
18		13.8	HS 24	1200	1986	34	Air / SF6
19		13.8	HS 25	1200	2012	8	Air / Vacuum
20		13.8	HS 26	1200	1993	27	Air / SF6
21		13.8	HS 27	1200	2009	11	Air / Vacuum
22		13.8	HS 28	1200	1994	26	Air / SF6
23		13.8	HS 29	1200	1992	28	Air / SF6
24		13.8	HS 30	1200	1992	28	Air / SF6
25	MTS #3	27.6	3F-60	1200	2001	19	SF6 / Vacuum
26		27.6	3F-61	1200	2001	19	SF6 / Vacuum
27		27.6	3F-62	1200	2001	19	SF6 / Vacuum
28		27.6	3F-63	1200	2001	19	SF6 / Vacuum
29		27.6	3F-64	1200	2001	19	SF6 / Vacuum
30		27.6	3F-65	1200	2001	19	SF6 / Vacuum
31		27.6	3F-66	1200	2001	19	SF6 / Vacuum
32		27.6	3F-67	1200	2001	19	SF6 / Vacuum
33		27.6	3F-68	1200	2001	19	SF6 / Vacuum
34		27.6	3F-69	1200	2001	19	SF6 / Vacuum
35		27.6	3F-50	1200	2001	19	SF6 / Vacuum
36		27.6	3F-51	1200	2001	19	SF6 / Vacuum
37	ERTS	13.8	ER-41	1200	1996	24	Air / Vacuum
38		13.8	ER-42	1200	1996	24	Air / Vacuum
39		13.8	ER-43	1200	1996	24	Air / Vacuum
40		13.8	ER-44	1200	1996	24	Air / Vacuum
41		13.8	ER-45	1200	1996	24	Air / Vacuum
42		13.8	ER-46	1200	1996	24	Air / Vacuum
43		13.8	ER-47	1200	1996	24	Air / Vacuum
44		13.8	ER-48	1200	1996	24	Air / Vacuum

2.4.2 Condition Assessment Criteria

WNH has adopted a TUL of 30 years for its TS circuit breakers. This is consistent with the Kinectrics Report and WNH's own experience.

Table 2-17: TS Main Bank and Tie Breaker (TUL)

	KINECTRICS REPORT		WNH
Min UL	TUL	Max UL	TUL
30	50	60	30

Table 2-18: TS Breaker Condition Assessment Criteria

Degradation Factor	Type	Weight	Ranking	Numerical Grade	Max Grade	Metalclad Vacuum Breaker	Metal Clad SF6 Breaker	GIS Vacuum Breaker
Service Age (indoor circuit breaker)	Air, Vacuum, SF6	2	A,B,C,D,E	4,3,2,1,0	8	8	8	8
Timing / Travel Tests	Air, Vacuum, SF6	2	A,B,C,D,E	4,3,2,1,0	8	8	8	8
Insulation resistance test (Closed Contacts)	Air, Vacuum, SF6	2	A,B,C,D,E	4,3,2,1,0	8	8	8	8
Insulation resistance test (Open Contacts)	Air, SF6	2	A,B,C,D,E	4,3,2,1,0	8		8	
Vacuum Bottle Integrity	Vacuum	2	A,E	4,0	8	8		8
Contact Resistance Tests	Air, Vacuum, SF6	2	A,B,C,D,E	4,3,2,1,0	8	8	8	8
SF Leaks	SF6	4	A,B,C,D,E	4,3,2,1,0	16		16	16
Control & Operating Mechanism Components	Air, Vacuum, SF6	2	A,B,C,D,E	4,3,2,1,0	8	8	8	8
Overall Condition	Air, Vacuum, SF6	4	A,B,C,D,E	4,3,2,1,0	16	16	16	16
Total Score						64	80	80

2.4.3 Condition Assessment

Table 2-19: HMSTS”A” Breaker Condition Assessments

STATION	BREAKER	RATING (A)	HEALTH INDX SCORE	MAX HI SCORE	% TUL	HI % SCORE	CONDITION
HMSTS'A'	7	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	8	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	9	1200	108	112	46.7%	96%	Very Good
HMSTS'A'	10	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	11	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	12	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	13	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	14	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	T1B	3000	104	112	46.7%	93%	Very Good
HMSTS'A'	T2Y	3000	56	112	46.7%	50%	Fair
HMSTS'A'	BY	3000	68	112	46.7%	61%	Fair
HMSTS'A'	SPARE	1200	104	112	46.7%	93%	Very Good
HMSTS'A'	SPARE	3000	108	112	46.7%	96%	Very Good

Table 2-20: ERTS Breaker Condition Assessments

STATION	BREAKER	RATING (A)	HEALTH INDX SCORE	MAX HI SCORE	% TUL	HI % SCORE	CONDITION
ERTS	41	1200	100	112	80.0%	89%	Very Good
ERTS	42	1200	100	112	80.0%	89%	Very Good
ERTS	43	1200	100	112	80.0%	89%	Very Good
ERTS	44	1200	100	112	80.0%	89%	Very Good
ERTS	45	1200	100	112	80.0%	89%	Very Good
ERTS	46	1200	100	112	80.0%	89%	Very Good
ERTS	47	1200	100	112	80.0%	89%	Very Good
ERTS	48	1200	100	112	80.0%	89%	Very Good
ERTS	T1B1	3000	78	112	80.0%	70%	Fair
ERTS	T2B2	3000	108	112	80.0%	96%	Very Good
ERTS	B1B2	3000	108	112	80.0%	96%	Very Good
ERTS	SPARE	1200	104	112	80.0%	93%	Very Good
ERTS	SPARE	3000	112	112	80.0%	100%	Very Good

Table 2-21: HMSTS"B" Breaker Condition Assessments

STATION	BREAKER	RATING	HEALTH INDX SCORE	MAX HI SCORE	% TUL	HI % SCORE	CONDITION
HSMTS"B"	15	1200	96	112	13.3%	86%	Very Good
HSMTS"B"	16	1200	112	112	16.7%	100%	Very Good
HSMTS"B"	17	1200	96	112	20.0%	86%	Very Good
HSMTS"B"	18	1200	112	112	33.3%	100%	Very Good
HSMTS"B"	19	1200	92	112	6.7%	82%	Good
HSMTS"B"	20	1200	88	112	33.3%	79%	Good
HSMTS"B"	21	1200	92	112	6.7%	82%	Good
HSMTS"B"	22	1200	92	112	30.0%	82%	Good
HSMTS"B"	23	1200	108	112	16.7%	96%	Very Good
HSMTS"B"	24	1200	92	112	30.0%	82%	Good
HSMTS"B"	25	1200	92	112	6.7%	82%	Good
HSMTS"B"	26	1200	84	112	6.7%	75%	Good
HSMTS"B"	27	1200	96	112	20.0%	86%	Very Good
HSMTS"B"	28	1200	96	112	20.0%	86%	Very Good
HSMTS"B"	29	1200	78	112	36.7%	70%	Fair
HSMTS"B"	30	1200	96	112	13.3%	86%	Very Good
HSMTS"B"	31	1200	96	112	16.7%	86%	Very Good
HSMTS"B"	32	1200	92	112	30.0%	82%	Good
HSMTS"B"	T4H	3000	108	112	16.7%	96%	Very Good
HSMTS"B"	T3J	3000	92	112	13.3%	82%	Good
HSMTS"B"	T3Q	3000	92	112	10.0%	82%	Good
HSMTS"B"	T4T	3000	92	112	13.3%	82%	Good
HSMTS"B"	JH	3000	92	112	6.7%	82%	Good
HSMTS"B"	QT	3000	92	112	6.7%	82%	Good
HSMTS"B"	SPARE	1200	84	112	36.7%	75%	Good
HSMTS"B"	SPARE	1200	84	112	26.7%	75%	Good
HSMTS"B"	SPARE	1200	108	112	33.3%	96%	Very Good
HSMTS"B"	SPARE	3000	92	112	6.7%	82%	Good
HSMTS"B"	SPARE	3000	92	112	10.0%	82%	Good

Table 2-22: HMSTS”B” Breaker Condition Assessments

STATION	BREAKER	RATING	HEALTH INDX SCORE	MAX HI SCORE	% TUL	HI % SCORE	CONDITION
MTS#3	50	1200	76	80	66.7%	95%	Very Good
MTS#3	51	1200	76	80	66.7%	95%	Very Good
MTS#3	60	1200	76	80	66.7%	95%	Very Good
MTS#3	61	1200	76	80	66.7%	95%	Very Good
MTS#3	62	1200	76	80	66.7%	95%	Very Good
MTS#3	63	1200	76	80	66.7%	95%	Very Good
MTS#3	64	1200	76	80	66.7%	95%	Very Good
MTS#3	65	1200	76	80	66.7%	95%	Very Good
MTS#3	66	1200	76	80	66.7%	95%	Very Good
MTS#3	67	1200	76	80	66.7%	95%	Very Good
MTS#3	68	1200	76	80	66.7%	95%	Very Good
MTS#3	69	1200	76	80	66.7%	95%	Very Good
MTS#3	T1B1	3000	76	80	66.7%	95%	Very Good
MTS#3	T2B2	3000	76	80	66.7%	95%	Very Good
MTS#3	B1B2	3000	76	80	66.7%	95%	Very Good

2.4.4 Data Availability Indicator

WNH’s DAI for station circuit breaker condition assessment data is 95%. The documentation on five test results could not be located. These tests will be scheduled at the time of their next maintenance outage.

2.4.5 Analysis of Results

HMSTS”A” station has reached its short-circuit rating limits on the station’s feeder breakers. Although in very good condition, they will need to be replaced before the actual ratings are exceeded. The fault contribution from existing connected embedded generation, Hydro One’s transmission system upgrade as part of the Guelph Area Transmission Reinforcement (GATR) project, and transmission connected REGs have contributed to the increase in short circuit levels. In addition, WNH has forecast a significant increase in load displacement generation within the next 12 – 36 months. More information on this can be found in the DSP and **Appendix H - WNH Renewable Energy Generation (REG) Investment Plan**. WNH

has investigated the problem and has determined that the most cost effective solution will be to replace the feeder breakers at the station. WNH is moving forward with the work to reduce the risk of catastrophic failure of the circuit breakers during a fault clearing event. The project will be executed over 2 years. WNH has included the cost to replace these circuit breakers, \$230,244 in 2020 and \$209,762 in 2021, in their capital investment program. A secondary benefit will be the increase of 6,630 kW of REG generation capacity at this station.

HMSTS"B" circuit breakers were originally installed in various stages starting in 1984. Beginning in 2011, at 27 years of age WNH began to experience incidents of component damage and elevated contact resistance on individual breakers. From 2014 to 2018 WNH conducted a breaker life extension project with the original manufacturer. The circuit breakers were rotated out of service and overhauled, retested and returned to service. Forecasted to extend the asset life for an additional 20 years, the breakers are currently forecast to reach EOL starting in 2034.

Currently in the asset group, all breakers are rated in Good to Very Good condition except for 4 which are rated in Fair condition. Currently there are no indications the breakers rated in Fair condition will require replacement before 2025 and it is recommended that in 2024, WNH conduct another thorough condition assessment to inform the next investment cycle with either a further life extension or replacement plan.

For the remainder of the asset group, here are no replacements forecast prior to 2025.

2.5 STATION (TS) FEEDER CABLES

2.5.1 Asset Demographics

WNH feeder cables are managed separately from the remainder of its cable assets due to the criticality of these assets in overall system reliability. The feeder cables population is comprised of two cable types, the older XLPE cable and the newer TRXLPE cable.

There are a total of 44 sets of three phase, 600A feeder cables emanating from WNH TS's of various age and circuit lengths. Older feeder cable insulation levels are 15 kV, 133% while the newer cables are 28 kV, 133%. The higher insulation level is expected to provide longer cable life for these critical assets.

Table 2-23a: TS Feeder Cable Demographics

# FDR	Transformer Stations	LV (kV)	Feeder ID	Cable Rating (A)	In Service	Age
1	HMSTS 'A'	13.8	HS 7	600	2011	9
2		13.8	HS 8	600	2011	9
3		13.8	HS 9	600	2011	9
4		13.8	HS 10	600	2011	9
5		13.8	HS 11	600	2013	7
6		13.8	HS 12	600	2013	7
7		13.8	HS 13	600	2013	7
8		13.8	HS 14	600	2013	7
9	HMSTS 'B'	13.8	HS 15	600	1992	28
10		13.8	HS 16	600	1991	29
11		13.8	HS 17	600	2014	6
12		13.8	HS 18	600	2009	11
13		13.8	HS 19	600	1992	28
14		13.8	HS 20	600	1986	34
15		13.8	HS 21	600	1986	34
16		13.8	HS 22	600	1987	33
17		13.8	HS 23	600	1989	31
18		13.8	HS 24	600	1986	34
19		13.8	HS 25	600	2009	11
20		13.8	HS 26	600	1992	28
21		13.8	HS 27	600	1996	24
22		13.8	HS 28	600	1993	27
23		13.8	HS 29	600	1992	28
24		13.8	HS 30	600	1991	29

Table 2-23b: TS Feeder Cable Demographics

# FDR	Transformer Stations	LV (kV)	Feeder ID	Cable Rating (A)	In Service	Age
25	MTS #3	27.6	3F-60	600	2003	17
26		27.6	3F-61	600	2002	18
27		27.6	3F-62	600	2002	18
28		27.6	3F-63	600	2002	18
29		27.6	3F-64	600	2016	4
30		27.6	3F-65	600	2003	17
31		27.6	3F-66	600	2002	18
32		27.6	3F-67	600	2002	18
33		27.6	3F-68	600	2002	18
34		27.6	3F-69	600	2016	4
35		27.6	3F-50	600	2002	18
36		27.6	3F-51	600	2002	18
37	ERTS	13.8	ER-41	600	1996	24
38		13.8	ER-42	600	1996	24
39		13.8	ER-43	600	1996	24
40		13.8	ER-44	600	1996	24
41		13.8	ER-45	600	1996	24
42		13.8	ER-46	600	1996	24
43		13.8	ER-47	600	1996	24
44		13.8	ER-48	600	1996	24

2.5.2 Condition Assessment Criteria

WNH has adopted a TUL of 35 years for XLPE medium voltage station feeder cables. The technologies incorporated into the TRXLPE cable and the improvements in cable manufacturing process have led WNH to adopt a longer TUL for the TRXLPE. Both are consistent with the Kinectrics Report and WNH's experience.

Table 2-24: TS Feeder Cables (TUL)

	KINETRICS REPORT			WNH
	Min UL	TUL	Max UL	TUL
XLPE	35	40	55	35
TRXLPE	35	40	55	45

Table 2-25: TS Feeder Cables Assessment Criteria

Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade
Service Age (XLPE)	5	A,B,C,D,E	4,3,2,1,0	20
Service Age (TRXLPE)	5	A,B,C,D,E	4,3,2,1,0	20
Insulation Rating (13.8 kV Operating Voltage)	7	A,B,C,D,E	4,3,2,1,0	28
Insulation Rating (27.6 kV Operating Voltage)	7	A,B,C,D,E	4,3,2,1,0	28
Loading History	2	A,B,C,D,E	4,3,2,1,0	8
Failure Rates	5	A,B,C,D,E	4,3,2,1,0	20
Field Tests - Insulation Resistance	5	A,B,C,D,E	4,3,2,1,0	20
Field Tests - Polarization Index	5	A,B,C,D,E	4,3,2,1,0	20
Condition of Concentric Neutral / Taped Shield	3	A,C,D,E	4,2,1,0	12
Visual Inspection of Cable Terminators & Splices	1	A,C,E	4,2,0	4
Total Score			Max	180

2.5.3 Condition Assessment

Table 2-26a: TS Feeder Cable Condition Assessments

Station	Feeder	Calendar Age	% TUL	HI % SCORE	CONDITION
HS'A'	7	7	16%	91%	Very Good
HS'A'	8	7	16%	95%	Very Good
HS'A'	9	7	16%	96%	Very Good
HS'A'	10	10	22%	96%	Very Good
HS'A'	11	10	22%	91%	Very Good
HS'A'	12	10	22%	95%	Very Good
HS'A'	13	10	22%	89%	Very Good
HS'A'	14	10	22%	96%	Very Good

Table 2-26b: TS Feeder Cable Condition Assessments

Station	Feeder	Age	% TUL	HI % SCORE	CONDITION
HS 'B'	15	29	83%	73%	Good
HS 'B'	16	28	80%	54%	Fair
HS 'B'	17	7	20%	86%	Very Good
HS 'B'	18	11	24%	83%	Good
HS 'B'	19	28	80%	82%	Good
HS 'B'	T5 to Recloser	16	46%	92%	Very Good
HS 'B'	T5 from Recloser	4	9%	96%	Very Good
HS 'B'	20	34	97%	45%	Poor
HS 'B'	21	34	97%	42%	Poor
HS 'B'	22	33	94%	24%	Very_Poor
HS 'B'	23	31	89%	58%	Fair
HS 'B'	24	34	97%	52%	Fair
HS 'B'	25	11	24%	96%	Very Good
HS 'B'	26	28	80%	78%	Good
HS 'B'	T6 to Recloser	7	16%	96%	Very Good
HS 'B'	T6 from Recloser	16	46%	92%	Very Good
HS 'B'	27	24	69%	71%	Good
HS 'B'	28	27	77%	71%	Good
HS 'B'	29	28	80%	71%	Good
HS 'B'	30	29	83%	73%	Good
MTS#3 3F-	50	19	42%	96%	Very Good
MTS#3 3F-	51	19	42%	95%	Very Good
MTS#3 3F-	60	19	42%	96%	Very Good
MTS#3 3F-	61	19	42%	72%	Good
MTS#3 3F-	62	19	42%	96%	Very Good
MTS#3 3F-	T3 Secondary	19	42%	96%	Very Good
MTS#3 3F-	63	19	42%	89%	Very Good
MTS#3 3F-	64	5	11%	92%	Very Good
MTS#3 3F-	65	19	42%	96%	Very Good
MTS#3 3F-	66	19	42%	96%	Very Good
MTS#3 3F-	67	19	42%	96%	Very Good
MTS#3 3F-	T4 Secondary	19	42%	95%	Very Good
MTS#3 3F-	68	19	42%	96%	Very Good
MTS#3 3F-	69	5	11%	96%	Very Good
MTS#3	T1 Secondary	19	42%	100%	Very Good
MTS#3	T2 Secondary	19	42%	100%	Very Good

Table 2-26c: TS Feeder Cable Condition Assessments

Station	Feeder	Age	% TUL	HI % SCORE	CONDITION
ERTS	41	24	53%	74%	Good
ERTS	42	24	53%	57%	Fair
ERTS	43	24	53%	82%	Good
ERTS	44	24	53%	84%	Good
ERTS	45	24	53%	80%	Good
ERTS	46	24	53%	74%	Good
ERTS	47	24	53%	63%	Fair
ERTS	48	24	53%	82%	Good
ERTS	T1 Secondary	24	53%	73%	Good
ERTS	T2 Secondary	24	53%	76%	Good

2.5.4 Data Availability Indicator

WNH's DAI for TS feeder cables data is 100%.

2.5.5 Analysis of Results

There are 48 sets of station feeder cables.

At HMTS"A", WNH replaced the original 1969 feeder cables between 2010 and 2013. All cables have been assessed to be in Very Good condition.

HMSTS"B"'s has WNH's oldest station feeder cables. HS 22 feeder is in Very Poor condition due to age, poor insulation readings and a recent cable failure. Currently out of service, this set of 15 kV, XLPE feeder cables should be considered for rejuvenation or replacement before the end of 2020.

HS20 and HS21 feeder cables have been found to be in Poor condition due to age, poor insulation readings and neutral corrosion. These two sets of 15 kV, XLPE feeder cables should be considered for rejuvenation or replacement within the next 12 – 36 months.

Three feeders, HS16, HS23, and HS24 have been assessed in Fair condition. These 15 kV, XLPE feeder cables should be reassessed over the forecast period with possible rejuvenation or replacement.

At ERTS, feeder cables for ER42 and ER47 have been assessed in Fair condition. These 15 kV, TRXLPE feeder cables should be reassessed over the forecast period.

The remaining station feeder cables are in Good or Very Good condition and no further action is expected over the forecast period.

2.6 STATION (TS) PROTECTION RELAYS

2.6.1 Asset Demographics

Table 2-27: TS Protection Systems Age and Condition

# Tx	Transformer Stations	Line Protections	Transformer Protection	Bus Protections	Feeder Protections	Ave Age	WNH TUL (yrs.)	% TUL
1	HMSTS 'A'	2009	2009	2009	2009	11	15	73%
2	HMSTS 'B'	2015	2014	2014	2011	7	15	43%
3	MTS #3	2001/2019	2001/2019	2001/2019	2001/2015	19/5/1	15	127%
4	ERTS	2012	2012	2012	2012	8	15	53%

Overall, WNH's TS Protection Relays have provided accurate and reliable service. The exception is a group of relays from a particular vendor that have experienced a 15% failure rate over the last 5 years. WNH has managed this population of relays through component replacements however each failure costs 25% to 50% of the cost of new relay. More concerning is that certain modes of failure have caused power outages, one a total station outage and one a four-feeder station bus outage. Numerous outages have been avoided through WNH's inspection and maintenance programs, however most relay failures are random. In 2019, WNH initiated a multi-year program to replace the problematic relays that will extend into the forecast period.

Protection relays at HMSTS"B" and ERTS, have experienced failures; however, WNH has been able to repair the relays with component replacements.

At MTS#3, the protection relays reached their TUL in 2016 and began exhibiting an increasing number of component failures. Due to the age of these relays, new components are not supported in the old relays. WNH started on a multi year project to replace the original relays and harvest components from the failed relays to keep the remainder in service until full replacement has been completed. Half of the bulk protection relays were replaced in 2019 while the other half are scheduled in 2020. The remaining 10 original feeder protections will be replaced in 2021.

Similar to MTS#3, WNH's protection relays at HMSTS“A” have experienced failures over the last 5 years. These relays have been in service for 11 years and will reach their TUL in 2024. WNH has been repairing these relays with replacement components to keep them in service; however, will begin a 3-year program in 2022 to replace the problematic relays.

All TS protections systems are able to support WNH's grid modernization program such as Feeder Fault Detection, Isolation and Restoration (FLISR).

2.6.2 Condition Assessment Criteria

The expected TUL of 15 years is based on WNH's experience with electronic and first generation programmable microprocessor protection relays.

Table 2-28: TS Protection Systems (TUL)

	KINECTRICS REPORT		WNH
Min UL	TUL	Max UL	TUL
15	20	20	15

In addition to on-board health diagnostics, the accuracy and functionality of these assets are reverified every 2 – 4 years depending on the protection group. WNH's assessment criteria for the reverification of protective relays comes in part from the Transmitter (HONI), the IESO (Transmission System Code), vendor recommendations and WNH's experience and expertise. Any relay that fails to meet a performance or non-performance requirement, or that possesses a defect which could affect its ability to meet specified requirements, is removed from service.

Table 2-29 provides summary of degradation factors WNH takes into account when assessing the overall condition of the relays.

Table 2-29: Protection Relay Condition Assessment Criteria

Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade
Service Age	4	A,B,C,D,E	4,3,2,1,0	16
Defect and Test Reports	2	A,B,C,D,E	4,3,2,1,0	8
Mean Time Between Failures	5	A,B,C,D,E	4,3,2,1,0	20
Visual Inspections	3	A,B,C,D,E	4,3,2,1,0	12
Non-Discretionary Obsolescence	5	A,E	4,0	20
Discretionary Obsolescence	1	A,B,C,D,E	4,3,2,1,0	4
Total Score				80

2.6.3 Condition Assessment

WNH has found that the microprocessor based protection relays do not experience declining health in the same manner as other assets. They tend to operate within functional and accuracy standards or they fail. Some relay types are modular with replaceable parts, while others must be returned to the manufacture for repair. Obsolescence is the main driver forcing most protective relays into end-of life.

Table 2-30: Protection Relay Condition Assessments

Station	Bus	Age	% TUL	% HI	Condition Rating
HMSTS A	Bus B	11	73%	69%	Fair
HMSTS A	Bus Y	11	73%	69%	Fair
HMSTS B	Bus H	6	40%	76%	Good
HMSTS B	Bus J	6	40%	76%	Good
HMSTS B	Bus Q	6	40%	76%	Good
HMSTS B	Bus T	6	40%	76%	Good
ERTS	Bus B1	8	53%	76%	Good
ERTS	Bus B2	8	53%	76%	Good
MTS#3	Bus B1	19	127%	31%	Poor
MTS#3	Bus B2	19	127%	31%	Poor

2.6.4 Data Availability Indicator

WNH's DAI for TS protection relays condition evaluation data is 100%.

2.6.5 Analysis of Results

HMSTS"A" protection relays have experienced failures that have or potentially would have caused power outages. The relays will also reach their TUL during the forecast period. Based on current performance and age, these relays have been scheduled for replacement during the forecast period.

The original MTS#3 protection relays were placed into service 19 years ago and reached their TUL in 2016. With increasing component failures, lack of compatible components due to their age, WNH entered into a replacement program to replace the bulk protection relays between 2019 – 2020 and the remaining 10 feeder relays in 2021. The oldest relays will be 20 years old when replaced, reaching their maximum useful life as outlined in the Kinectrics report.

Given the current performance and age of the relays at HMSTS" B" and ERTS, it is recommended to manage these relays through close monitoring and repair of occasional failures. Should the failure rate increase, a replacement strategy should be considered. WNH does not expect to make any material investments in these protection systems over the forecast period.

2.7 DISTRIBUTION STATION (DS) TRANSFORMERS

2.7.1 Asset Demographics

WNH has 6 remaining distribution stations <50 kV operating throughout the rural areas of its service area. This group of assets is being phased out over time as WNH's System Renewal investments replace 8.32 kV lines in poor condition and with new lines operating at 27.6 kV.

Table 2-31: WNH Municipal and Distribution Stations

# Tx	MS/DS	Owned & Operated by	Supplied By	Location	HV (kV)	LV (kV)	Tx ID	Transformer Rating (MVA)	In Service	Age
1	DS#26	WNH	WNH Dx	Wellesley	27.6	8.32	T1	5.6	1990	30
2	DS#27	WNH	WNH Dx	Wallenstein	27.6	8.32	T1	3.6	1947	73
3	DS#28	WNH	WNH Dx	Floradale	27.6	8.32	T1	5.0	1996	24
4	DS#29	WNH	WNH Dx	St Jacobs	27.6	8.32	T1	3.6	1948	72
5					27.6	8.32	T2	3.6	1954	66
6	DS#30	WNH	WNH Dx	Zubers Corners	44.0	8.32	T1	5.0	1976	44
7	DS#31	WNH	WNH Dx	Bloomingtondale	27.6	8.32	T1	5.0	1980	40

2.7.2 Condition Assessment Criteria

WNH has adopted a TUL of 60 years for its DS transformers. This is consistent with the Kinectrics Report and WNH's own experience.

Table 2-32: DS Transformers (TUL)

	KINETRICS REPORT		WNH
Min UL	TUL	Max UL	TUL
30	45	60	60

Table 2-33: DS Transformers Condition Assessment Criteria

Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade	Tx's with OLTC	Tx's without OLTC
Age	10	A,B,C,D,E	4,3,2,1,0	40	40	40
Dissolved Gas Analysis*	10	A,B,C,D,E	4,3,2,1,0	40	40	40
Load History	10	A,B,C,D,E	4,3,2,1,0	40	40	40
Insulation Power Factor*	10	A,B,C,D,E	4,3,2,1,0	40	40	40
Oil Quality	6	A,C,E	4,2,0	24	24	24
Turns Ratio	5	A,B,C,D,E	4,3,2,1,0	20	20	20
Winding Resistance	6	A,B,C,D,E	4,3,2,1,0	24	24	24
Tap Changer DGA (if applicable)	6	A,B,C,D,E	4,3,2,1,0	24	24	N / A
Tap Changer Oil Quality (if applicable)	3	A,B,C,D,E	4,3,2,1,0	12	12	N / A
Tap Changer Operations	5	A,B,C,D,E	4,3,2,1,0	20	20	N / A
Overall Bushings	2	A,B,C,D,E	4,3,2,1,0	8	8	8
Infrared Scan (IR)*	10	A,B,C,D,E	4,3,2,1,0	40	40	40
Overall Inspection Condition	8	A,B,C,D,E	4,3,2,1,0	32	32	32
Overall LTC (if applicable)	5	A,B,C,D,E	4,3,2,1,0	20	20	20
Total Score	No LTC	328	With LTC	384	384	328
*Note: If conditions are E, divide the overall health index by 2.						

2.7.3 Condition Assessment

Table 2-34: DS Transformers Health Condition Assessments

STATION	TRANSFORMER	HEALTH INDEX SCORE	MAX HI SCORE	% TUL	HI % SCORE	CONDITION
DS 26 / WELLESLEY	T1	298	384	50%	78%	Good
DS 27 / WALLENSTEIN	T1	250	328	122%	76%	Good
DS 28 / FLORADALE	T1	265	328	40%	81%	Good
DS 29 / ST JACOBS	T1	262	328	120%	80%	Good
	T2	224	328	110%	68%	Fair
DS 30 / ZUBERS CORNERS	T1	282	384	73%	73%	Good
DS 31 / BLOOMINGDALE	T1	221	384	67%	58%	Fair

2.7.4 Data Availability Indicator (DAI)

WNH's DAI for DS transformers condition evaluation data is 93%. Degree of polymerization tests have not been performed.

2.7.5 Analysis of Results

This is an aging asset group with an average age of 50 years and a maximum of 73 years. To avoid the recapitalization of these assets and to mitigate the increasing risk associated with their age, WNH has the following measures in place:

1. WNH owns and maintains a mobile unit substation (MUS) to provide temporary supply to any 4.16 kV or 8.32 kV station within 4 hours.
2. WNH maintains one spare 44 kV and 27.6 kV transformer (used) that can be pressed into service in case of failure.
3. WNH salvages serviceable equipment from retired stations to maintain operability.

Additionally, these stations are also operating at reduced capacity as a result of the 8.32

kV load that has been transitioning over to 27.6 kV lines.

The condition assessments reveal the transformers are in relatively good condition in spite of their age and other than DS26, which will be retired at the end of 2020, the remaining stations are expected to remain in service to at least 2025.

2.8 POLES

2.8.1 Asset Demographics

WNH has a population of approximately 22,000 poles, 97.6% of which are wood. **Table 2-35** provides a breakdown of WNH's pole population by pole type.

Table 2-35: Pole Population by Type

Pole Type	Waterloo	Woolwich	Wellesley	Wellington	Total	%
Pine	4,178	7,739	4,540	96	16,553	75.9%
Cedar	2,853	1,237	638	-	4,728	21.7%
Unknown	-	10	-	-	10	0.0%
Wood Poles	7,031	8,986	5,178	96	21,291	97.6%
Concrete	212	44	1	-	257	1.2%
Steel	167	87	1	-	255	1.2%
Composite	-	4	-	-	4	0.0%
Total # Poles	7,410	9,121	5,180	96	21,807	100%
% of Total Pole Population	34%	42%	24%	0.4%	100%	

Due to the size of its service area, WNH's pole population is large relative to the number of customers served.

Table 2-36: Pole Population Demographics by Municipality

Measure	Waterloo	Woolwich	Wellesley	Wellington	Perth	Cambridge	Total
Area (sq. km)	65	328	271	13	5	0.1	683
% of total area	10%	48%	40%	2%	0.7%	0%	100%
# Customers	44,507	9,806	3,484	67	10	1	57,875
% of total customers	77%	17%	6%	0%	0%	0%	100%
Customer Density (customer/sq. km)	683	30	13	5	2	7	84.8
Pole Density (p/sq. km)	114	28	19	7	N/A	N/A	31.9
Customers / pole	6.0	1.1	0.7	0.7			2.7

WNH's rural area accounts for 66% of its total pole population but only services approximately 23% of WNH's customer base. This is illustrated in **Table 2-37**.

Table 2-37: Pole Population Urban / Rural

Measure	Urban	%	Rural	%	TOTAL
Area (sq. km)	65	9.5%	618	90.5%	683
# Customers	44,657	77.3%	13,112	22.7%	57,769
Customer Density (customer/sq. km)	685		21		85
# Poles	7,410	34.0%	14,397	66.0%	21,807

Wood, and more specifically treated pine poles, have become the major pole type used at WNH. Western Red Cedar poles tend to be used in applications where their lighter weight is an advantage such as in tall pole line or rear lot applications. WNH has minor populations of concrete and steel poles which are on the decline. Concrete poles have not been found to have greater longevity than wood and are used only sparingly for aesthetic reasons. Steel poles become uneconomical in recent years and are no longer used.

Table 2-38 provides a breakdown of poles by their function in the distribution system.

Table 2-38: Pole Utilization

Pole Type	# Poles	%
Primary Distribution Poles	17,714	81%
Secondary Distribution Poles	1,947	9%
Support Poles (guying)	2,146	10%
Total	21,807	100%

Table 2-39 summarizes, by calendar age and effective age, the number of poles that are currently past TUL and those that will exceed their TUL by 2025. Effective age differs from calendar age in that effective age takes into account the impact of the degradation factors utilized in the condition analysis. An asset's effective age being greater than its calendar age is an indication that the asset is deteriorating at a faster rate than expected.


Although WNH's replacement program for poles is based on condition, age is still an important indicator of asset lifecycle behaviour. Comparing the total number of poles both past and approaching TUL, indicates that based on condition 1,295 poles, or 6% of the population are degrading at a faster rate than expected.

Table 2-39: Pole Age

Age Criteria	# Poles	Current %
CALENDER AGE		
Past TUL (> 45 YRS)	3,183	14.6%
Approaching TUL (5 year)	793	3.6%
Not Near TUL	17,831	81.8%
Total Under Evaluation	21,807	100.0%
EFFECTIVE AGE		
Past TUL (> 45 YRS)	4,387	20.1%
Approaching TUL (5 year)	884	4.1%
Not Near TUL	16,536	75.8%
Total Under Evaluation	21,807	100.0%

Figure 2-1 provides an age profile of WNH's pole population. Poles past 75 years of age are highlighted in red as these poles exceed the typical maximum useful life as outlined in the Kinectrics Report. Currently there are only 31 poles past the Max TUL, however 333 will reach that state within the next 5 years. The weighted mean age of WNH's pole population is 23.5 years.

Figure 2-1: WNH Pole Population Age Profile



2.8.2 Condition Assessment Criteria

Table 2-40 provides a summary of the TUL's WNH has adopted for all of its pole types

Table 2-40: Poles (TUL)

		KINETRICS Report		WNH
Pole Type	Min UL	TUL	Max UL	TUL
Wood Poles	35	45	75	45
Concrete Poles	50	60	80	60
Steel Poles	60	60	80	60
Composite Poles	N/A	N/A	N/A	60

Table 2-41 provides a summary of the main asset management criteria used to calculate the Health Indices for WNH's pole population.

Table 2-41: Recommended Health Index Assessment Criteria

Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade
Service Age	15	A,B,C,D,E	4,3,2,1,0	60
Pole Treatment	5	A,C,E	4,2,0	20
Remaining Strength*, **	20	A,B,C,D,E	4,3,2,1,0	80
Crossarm Condition	1	A,C,E	4,2,0	4
Pole Top Condition*	1	A,C,D,E	4,2,1,0	4
Shell Condition and Environment	7	A,C,D,E	4,2,1,0	28
Total Score	Pole	196	Pole < 30 years	116
*Note: If conditions are E, divide the overall health index by 2.				
**Only applicable for poles subject to WNH pole testing (> 30 years old).				
Hardware	0	A,C,E	4,2,0	0
Insulator	0	A,C,E	4,2,0	0
Arrestor	0	A,C,E	4,2,0	0
Conductor	0	A,C,E	4,2,0	0
Guy line	0	A,C,E	4,2,0	0
Grounding	0	A,C,E	4,2,0	0
Crossarm	0	A,C,E	4,2,0	0

2.8.3 Condition Assessment

WNH has used METSCO'S ENGIN analytical software to develop Health Indices for its pole population and develop a recommended pole replacement program for period 2020 - 2025. **Table 2-42**, provides a summary of the condition assessment results. Condition assessments resulted in the development of Health Indices for approximately 85% of WNH's pole population or 18,442 poles. Of the remaining 3,365 poles, 2,212 were too new to have condition assessment data other than age and are assumed to be in Very Good condition. The remaining 1,153 poles have insufficient data, a deficiency that will be corrected by WNH as part of the 2020 inspection and pole testing program.

Currently approximately 3,100 poles or 15% of the pole population has been evaluated to be in Very Poor or Poor Condition. Those poles that are currently in Poor condition are expected to degrade to Very Poor condition over the forecast period. In addition, WNH has forecast another 212 poles currently in Fair condition that are expected to degrade into Poor

condition between 2020 and 2025.

Table 2-42: Recommended Health Index

HEALTH INDICIES	# Poles	Current %
Very Poor	1,435	7%
Poor	1,659	8%
Fair	5,257	24%
Good	3,028	14%
Very Good	7,063	32%
Total Poles Under Evaluation	18,442	85%
Poles Not Under Evaluation	3,365	15%
Total Poles	21,807	100%
Poles <= 6 yrs.	2,212	10%
Poles > 6 yrs. No HI Data	1,153	5%
Total	3,365	15%

In Figure 2-2, illustrates WNH's pole population Health Index distribution. The average HI of WNH's pole population is 60% or Fair condition

Figure 2-2: WNH Pole Population HI Distribution




Table 2-43 breaks out the health indices of WNH's pole population by number of circuits they can impact. In WNH's investment prioritization process, multi-circuit lines which have larger customer impact are weighted more heavily for replacement than single phase lines.

Table 2-43: Pole Health Index distribution by Number of Circuits

# Circuits	# Poles	Average HI	HI Category
All poles	21,807	60%	Fair
Support Poles, No Circuits	4,090	62%	Fair
Single Circuit, Single Phase	5,418	47%	Poor
Single Circuit, Multi Phase	8,119	63%	Fair
Two Circuit, Multi Phase	3,477	66%	Fair
Three Circuit, Multi Phase	638	70%	Fair
Four Circuit, Multi Phase	65	75%	Good

2.8.4 Data Availability Indicator (DAI)

WNH's DAI for pole condition assessment data is 85%. Referring to **Table 2-42**, of the remaining 15%, 10% of the poles were too new of have condition assessment data other than age and are assumed to be in Very Good condition. Using age as the only condition assessment for the newest of poles, the DAI would rise to 95%.

The remaining 5% of the poles have insufficient data, a deficiency that will be corrected by WNH as part of the 2020 inspection and pole testing program.

2.8.5 Analysis of Results

Over the historic period, WNH replaced approximately 589 poles per year due to condition and approximately 100 poles per year due to non-condition related reasons such as

relocations, motor vehicle accidents, service upgrades and storm damage.

Currently, there are approximately 1,435 poles with a health index of Very Poor that present a high risk of failure. These poles are recommended for replacement over the next 1 to 3 years. Another 1,659 poles with a Health Index of Poor are recommended to be replaced within the next 3-6 years or prior to 2025. In addition, poles in Fair condition should be closely monitored for any transition into the Poor or Very Poor category.

Table 2-44 provides a summary of the recommend pole replacements between 2020 and 2025.

Table 2-44: Pole Replacement Recommendation

HEALTH INDICIES	Total Replacement (Poles) 2020 - 2025	Annual Replacement (Poles) 2020 - 2025
Very Poor	1,435	239
Poor	1,659	277
Fair		
Good		
Very Good		
Condition Based Replacements	3,094	516
Other Replacements	600	100
Total Poles	3,694	616

Based on the ACA results, WNH is forecasting a need to replace approximately 620 poles per year between 2020 and 2025.

2.9 PRIMARY UNDERGROUND DISTRIBUTION CABLES

2.9.1 Asset Demographics

WNH's underground distribution system consists of 9,383 cables for a total length of approximately 697 km. The cable population is segmented into two cable types (XLPE and TRXLPE) and two installation types (direct buried and ducted). **Table 2-45** provides a breakdown of the cable population by type and service area.

Table 2-45: Cable Population by Type

CABLE TYPE	Waterloo	Woolwich	Wellesley	Total	%
XLPE	177	10	1	188	27%
TRXLPE	392	100	16	508	73%
Total Cable (km)	569	110	17	697	100%
%	82%	16%	2%	100%	

Cross Linked Polyethylene Cable (XLPE)

WNH's population of XLPE cable was installed between 1966 and 1993. These cables were constructed with polymeric insulation, and for the most part polyvinyl chloride (PVC) jacketing. These cables were also constructed with copper conductor and copper, 100% concentric neutrals which were not encapsulated by the jacketing material. There may still be a small population of unjacketed cable direct buried cable in the oldest parts of the distribution system, however most has been replaced.

Water treeing is the most significant degradation process for polymeric cables. By today's standards, the designs of these cables were poor, allowing water to penetrate and literally run between the jacket and the insulation and through the interstices of the conductor to come into contact with the insulation from both sides. In the presence of electric fields water migration results in the formation of water trees, partial discharge in the insulation and ultimately electrical breakdown. The rate of growth of water trees is dependent on the quality of the polymeric insulation and the manufacturing process. Again, by today's standards, manufacturing processes, especially those before 1980 were poor, allowing for contamination, voids or discontinuities in the insulation which become sites for partial

discharge to begin. This is assumed to be the reason for poor reliability and relatively short lifetimes of early (non-tree retardant) polymeric cables.

Tree Retardant Cross Linked Polyethylene Cable (TRXLPE)

WNH's TRXLPE cable has been installed since 1993. WNH's TRXLPE cables come with a number of features which make it superior to XLPE cables and expected to bring longer life. With water treeing being the most significant degradation process for polymeric cables, a cable insulation more resistant to water treeing is the most significant feature. WNH also specifies its cable with strand blocking technology to prevent water ingress into the cable. Also included is an encapsulated polyethylene jacket which is mechanically stronger and more impervious to water ingress. Lastly, improved cable manufacturing in recent years has reduced contaminants and imperfections in cable insulation extruding making it less susceptible to failure due to partial discharge. WNH utilizes a copper conductor on its 600A station and main feeder trunk cable however transitioned to aluminum conductor on its 200A Underground Residential Distribution (URD) cable.

Table 2-46 provides a breakdown of cable population by installation method. It can be seen that 80% of the cable population is installed in duct. The transition from direct buried to duct installation came about in 1988-1989 for most underground distribution. Station feeder cables have always been ducted as part of WNH's station design standards.

Table 2-46: Cable Population by Installation Method

INSTALLATION METHOD	Direct Buried	Duct	Total	%
XLPE	138	50	188	27%
TRXLPE	0	508	508	73%
Total Cable (km)	138	559	697	100%
%	20%	80%	100%	0%

Table 2-47 provides breakdown of cable population by System Voltage.

Table 2-47: Cable Population by System Voltage

VOLTAGE CLASS	15 kV	28 kV	Total	%
XLPE	178	11	188	27%
TRXLPE	64	444	508	73%
Total Cable (km)	242	455	696	100%
%	35%	65%	100%	0%

Table 2-48: Cable Population Demographics


AGE	XLPE	TRXLPE
TUL	35.0	45.0
Oldest Cable (yrs.)	54.0	26.0
Earliest Year Installed	1966	1994
Weighted Mean Age (Total Population)	33.0	14.0
km > TUL	51.2	0.0
km within 5 yrs. of TUL	95.7	0.0

All cable from the mid-1960s to 1977 has been replaced as part of WNH's past System Renewal investments. This population consisted mostly of 5 kV butyl rubber cable operating on the 4.16 kV system.

Figure 2-3 provides an age profile of WNH's current XLPE cable population. Represented is 188 km of cable, all direct buried except for the newest 50 km which is in installed duct.


Figure 2-4 provides an age profile of WNH's current TRXLPE cable population. Represented is 508 km of cable, all of which is in installed duct.

Figure 2-3: XLPE Age Profile



Age Profile	Very Good	Good	Approaching TUL	Past TUL
-------------	-----------	------	-----------------	----------

Figure 2-4: TRXLPE Age Profile



2.9.2 Condition Assessment Criteria

Prior to 2019, WNH utilized a TUL of 35 years for its entire medium voltage primary cable population. WNH has since evaluated the cable population's demographics and performance, and has determined that an adjustment in the expected life of these cable is warranted. This adjustment is based on a number of factors including

- WNH has retired the oldest portion of its cable population which consisted mostly of 5 kV butyl rubber cable operating on the 4.16 kV system.
- WNH's TRXLPE cables now make up 73% of WNH's total cable population. Constructed to a higher standard and fully ducted, a longer TUL is expected from these cables.

Table 2-49 provides a breakdown of TUL's by cable type. These are consistent with the Kinectrics Report and WNH's own experience.

Table 2-49: Cable TUL by Type

Cable Type	KINETRICS REPORT			WNH 2016	WNH 2019	%
	Min UL	TUL	Max UL	TUL	TUL	Pop
Primary XLPE Cables - Direct Buried	20	25	30	35	35	20%
Primary XLPE Cables - In Duct	20	25	30	35	35	7%
Primary TRXLPE Cables - Direct Buried	25	30	35	35	N/A	0%
Primary TRXLPE Cables - In Duct	35	40	55	35	45	73%

Table 2-50 provides a summary of the main asset management criteria used to calculate the Health Indices for WNH's cable population.

Table 2-50: WNH Cable Assessment Criteria

Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade
Service Age (XLPE)	5	A,B,C,D,E	4,3,2,1,0	20
Service Age (TRXLPE)	5	A,B,C,D,E	4,3,2,1,0	20
Loading History	2	A,B,C,D,E	4,3,2,1,0	8
Failure Rates	5	A,B,C,D,E	4,3,2,1,0	20
Field Tests (Cable Q condition, if available)	5	A,C,E	4,2,0	20
Condition of Concentric Neutral	4	A,C,D,E	4,2,1,0	16
Visual Inspection of splices or terminations and elbows	1	A,C,E	4,2,0	4
Total Score				88

2.9.3 Condition Assessment


WNH has used METSCO'S ENGIN analytical software to develop Health Indices for its cable population and develop a recommended cable replacement program for the period 2020 - 2025. **Table 2-51**, provides a summary of the condition assessment results.

Table 2-51: Condition Assessment Results

HEALTH INDICIES	km of UG Cable	%
Very Poor		0.0%
Poor	5	0.7%
Fair	117	16.7%
Good	70	10.0%
Very Good	505	72.5%
Total Under Evaluation	697	100.0%

Condition assessments resulted in the development of Health Indices for 100% of WNH's cable population. Currently, 5 km of XLPE cable has been evaluated in Poor condition. There are no cables that have been evaluated to be in Very Poor condition. A population of 117 km of cable has been evaluated in Fair condition. Figure 2-5 provides a breakdown of the cable population by HI.

Figure 2-5: WNH Cable Population HI Profile



From **Table 2-47**, 51 km of XLPE cable is past TUL and another 96 km will be passing TUL within the next 5 years. Each represent 7% and 14% of the total cable population respectively.

2.9.4 Data Availability Indicator (DAI)

WNH's DAI for cable condition assessment data is 100%.

2.9.5 Analysis of Results

WNH has a population of 9,380 cables for a total length of 697 km, most problematic of which are the 138 km of direct buried cable and associated underground transformers and vaults. WNH's direct buried cables are XLPE type with a TUL of 35 years. Currently 5 km (0.7%) of direct buried cable is in Poor condition and 117 km (17%) are in Fair condition.

It is recommended to replace all direct buried underground cables (5 km) in Poor condition.

In addition, it is recommended to proactively replace approximately 37.5 km (20%) of direct buried cable currently rated in Fair condition. WNH should be concerned with the large number of XLPE cables past TUL (51 km) and the even larger quantity (96 km) approaching TUL. The cables being targeted are those approaching the Poor condition and are expected to reach this condition over the forecast period. These direct buried cables currently have an average age of 34 years with the oldest being 46 years of age. Their replacement, along with the associated submersible concrete vaults and transformers, is logistically difficult, disruptive for customers in the area and time consuming.

Over the forecast period, WNH plans to replace approximately 7.1 km of direct buried cable annually. This is consistent with WNH's historical pace of cable replacement activity. For the entire population of cable in Fair condition, this represents approximately 17 years of work at this pace. The youngest cable currently in this group would be 44 years of age at the completion of the program. As with all programs, WNH will evaluate annually and adjust the pace accordingly.

Lastly, 80% of WNH's cable population is now in duct. This allows WNH to replace cables on an individual basis with much less cost and disruption. The vast amount of cable in duct is of the TRXLPE type with a TUL of 45 years. There are no planned replacements of cable in duct over the forecast period.

Table 2-52 provides a summary of the recommended cable replacements between 2020 and 2025.

Table 2-52: Primary Cable Replacement Recommendation

HEALTH INDICIES	Total Replacement (km)	Annual Replacement (km)
	2020 - 2025	2020 - 2025
Very Poor		
Poor	5.0	0.8
Fair	37.5	6.3
Good		-
Very Good		-
Condition Based Replacements	42.5	7.1
Other Replacements	0.0	-
Total Cable Replacement (km)	42.5	7.1

This is WNH's oldest underground infrastructure. Concrete vaults have found to be flooding and physically deteriorating due to salt and corrosion and secondary cable insulation is showing signs of embrittlement; a sign of oncoming failure. Numerous vaults are located in sidewalks and boulevards where physical deterioration can present a public safety hazard. Although the primary cable is in Fair condition the direct buried nature of this infrastructure makes it much costlier and time consuming to repair, replace in piecemeal, or replace in whole on a reactive basis. WNH has determined that the best course of action is to replace this infrastructure in a planned manner, coordinated with our customers.

2.10 DISTRIBUTION TRANSFORMERS

2.10.1 Asset Demographics

WNH has a population of approximately 7,829 distribution transformers installations. These are comprised of single phase installations and three phase installations, some of which are comprised of 3 individual single phase transformers banked together. In addition, approximately 325 transformers are in inventory at any one time; most in advance of System Renewal and System Access projects with the remainder reserved for emergency replacement stock. **Table 2-53** provides a breakdown of WNH's distribution transformer population by type.

Table 2-53: WNH Distribution Transformer Population by Type

Transformer Population	1 phase	3 phase	Total	%
Polemount	3,150	789	3,939	50.31%
Padmount	3,353	249	3,602	46.01%
Submersible	124	1	125	1.60%
Vault	94	3	97	1.24%
Step Down	62	4	66	1%
Total Overhead	3,212	793	4,005	51.16%
Total Underground	3,571	253	3,824	48.84%
Total Transformers	6,783	1,046	7,829	
%	87%	13%		

2.10.2 Condition Assessment Criteria

WNH has adopted a TUL of 45 years for overhead transformers and 35 years for underground transformers. **Table 2-54** provides a comparison with the Kinectrics Report.

Table 2-54: WNH Distribution Transformer TUL's

		KINECTRICS REPORT		WNH
Transformer Type	Min UL	TUL	Max UL	TUL
Overhead (polemount & step down) & Vault Room Txs	30	40	60	45
Padmount & Submersible Txs	25	40	45	35

WNH has found that underground transformers (padmount and submersible) have shorter TUL's primarily due the extensive corrosion from salt and moisture at and below ground level.

Overhead transformers have less exposure to corrosion due to their height above ground. The TUL for poles and distribution transformers are aligned as most overhead transformers are replaced during renewal projects. They may or may not be able to be reused depending on age, condition and compliance to Ontario Reg. 22/04. The practice of using new transformers on new construction also reduces customer interruption minutes during the transfer of customer services. Otherwise, WNH's strategy is to run the transformers to failure.

The degradation factors outlined in **Table 2-55** and are noted during inspections and flagged for action. Transformers found in poor condition through WNH's regular inspection programs are replaced.

Table 2-55: Recommended Health Index Assessment Criteria


Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade	OH Tx	UG Tx
Service Age	3	A,B,C,D,E	4,3,2,1,0	12	12	12
Peak Loading	3	A,B,C,D,E	4,3,2,1,0	12	12	12
Infrared Scan (IR)	4	A,B,C,D,E	4,3,2,1,0	16	16	16
Condition of Civil Structure	4	A,C,E	4,2,0	16		16
Cabinet and/or Tank Condition	2	A,B,C,D,E	4,3,2,1,1	8	8	8
Oil Leaks	2	A,B,C,D,E	4,3,2,1,0	8	8	8
Access to Tx	2	A,C,E	4,2,0	8	8	8
Bushing	2	A,C,E	4,2,0	8	8	8
HV/LV Spade	2	A,C,E	4,2,0	8	8	8
Termination/Elbow	4	A,C,E	4,2,0	16		16
Arrestor	2	A,C,E	4,2,0	8	8	8
Lock Bolt	2	A,C,E	4,2,0	8		8
Total Score				128	88	128

WNH has service age information on 99% of its transformer installations. **Table 2-56** and **Figure 2-6** provide age related information on WNH's distribution transformer population.

Table 2-56: WNH Transformer Average Age


Transformer Population	# Transformers	Average Age	# > TUL	%
Pole Mount	3,939	20	121	1.55%
Padmount	3,602	18	82	1.05%
Submersible	125	27	33	0.42%
Vault	97	21	6	0.08%
Step Down	66	20	0	0.00%
Total Overhead	4,005	20	121	1.55%
Total Underground	3,824	18	121	1.55%
Total Transformers	7,829	19	242	

Figure 2-6: Transformer Age Profile



Transformer peak loading information can be calculated for each transformer from customer hourly consumption or demand data from WNH's AMI system. **Figure 2-7** provides a loading profile for WNH's transformer population.

Figure 2-7: WNH Distribution Transformer Utilization (%)



Transformers undergo regular infrared thermography and inspections as part WNH's Inspection and maintenance program. While padmount, vault and submersible transformer inspections can be performed up close, overhead transformer inspections are normally performed from the ground unless there is reason for concern.

2.10.2.1 PCB's

WNH maintains an active program to eliminate PCB's from all of its distribution equipment. Transformers are the last asset class known to contain PCB's at WNH.

The PCB Regulations (SOR/2008-273) came into force on September 5, 2008. The most recent amendments to the regulations came into force on January 1, 2015. The purpose of the regulations is to protect the health of Canadians and the environment by preventing the release of polychlorinated biphenyls (PCBs) to the environment, and by accelerating the phasing out of these substances. The regulations set a deadline of December 31, 2025 to eliminate concentrations of PCB's greater than 50 ppm in electrical transformers. The regulations also prohibit the release of PCBs into the environment in concentrations of 2 ppm or greater.

WNH's PCB Reduction Program has eliminated all oil filled equipment with PCB concentrations greater than 50 ppm. The program is now focused on reducing PCB concentrations to less than 2 ppm by the end of 2025.

Over the historical period, 117 transformers containing PCB's were eliminated, mostly through attrition. Currently, 167 transformers remain with PCB concentrations greater than 2 ppm. The average age of this population is 45 years.

Table 2-57: WNH PCB Transformers

PCB's (ppm)	Units	% of Tx Population
ppm > 2 < 50	167	2.1%


2.10.3 Condition Assessment

WNH utilizes age and transformer loading to develop Health Indices for its distribution transformers. **Table 2-58** and **Figure 2-8** provide HI related information on WNH's distribution transformer population. The average HI for WNH's entire Tx population is 61% or Fair.

Table 2-58: WNH Distribution Transformer HI

HEALTH INDICIES	# of Transformers	%
Very Poor	295	4%
Poor	2,430	31%
Fair	2,871	37%
Good	1,634	21%
Very Good	599	8%
Total Under Evaluation	7,829	100%

Figure 2-8: WNH Distribution Transformer Population HI Profile



2.10.4 Data Availability Indicator (DAI)

WNH's DAI for distribution transformer condition assessment data is 98%. There are 44 transformers with no install date. This data will be recovered during the next scheduled round of inspections

2.10.5 Analysis of Results

WNH's distribution transformer population has an overall HI of 61% which is in Fair condition. There are 295 transformers assessed in very poor condition.

There are 13 transformers over the age of 60 years that consideration should be given for proactive replacement.

The remaining 125 submersible transformers will be replaced as part of WNH's underground cable System Renewal program.

Over the forecast period, WNH plans to remove from service, 167 transformers containing more than 2 ppm of PCB's. These are some of the oldest transformers in WNH's distribution system and WNH estimates that approximately 110 will be eliminated through the normal course of work (service changes and System Renewal projects), or attrition. The remaining, 57 will be flagged for planned replacement prior to 2025.

Normally peak loads up to 125% are considered acceptable since most transformer load profiles have a low enough Load Factor to allow for sufficient cooling. There are 74 transformers with peak loads of between 121% and 130% which should be considered for proactive replacement with a larger transformer or load balancing with nearby transformers if possible.

There are an additional 300 transformers with peak loads of between 100 and 120% which should be monitored regularly over the forecast period.

Taking into account there is some overlap in drivers for transformer replacement, WNH estimates a total of 574 transformers, or 115 annually are planned for replacement over the forecast period.

2.11 REVENUE METERS

2.11.1 Asset Demographics

WNH's meter population is divided into 3 groups:

1. Residential
2. Commercial & Industrial (C&I)
3. Wholesale

The meter population is then further subdivided into self-contained and transformer rated meters. This categorization is important due to the fact that transformer rated meters are part of a metering installation that includes additional equipment such as instrument transformers, communications and auxiliary equipment. Metering installations generally live through several generations of meters and have a longer TUL. **Table 2-59** provides a high level listing of WNH metering assets.

Table 2-59: Meters by Application

Asset Type	# Meters
Residential Meters	51,239
C&I Meters < 50 kW	5,827
C&I Meters >= 50 kW	748
MicroFIT / FIT	605
Transformer Discount	56
Wholesale Meters	43
Total	58,518


Table 2-60 provides a breakdown of WNH's meter population by year of installation. Evident is the transition to smart metering that occurred from 2009 to 2012 for residential meters and 2012 for C&I meters. The meters replaced during this time were forced out of service due to government regulation and not condition or performance.

Table 2-60: WNH Meters by Age

Year of Installation	Meters	Meters	%
2009	35,733	35,733	61.06%
2010	13,182	48,915	22.53%
2011	990	49,905	1.69%
2012	4,188	54,093	7.16%
2013	701	54,794	1.20%
2014	705	55,499	1.20%
2015	699	56,198	1.19%
2016	593	56,791	1.01%
2017	610	57,401	1.04%
2018	601	58,002	1.03%
2019	516	58,518	0.88%
Total	58,518	58,518	100%

Figure 2-9 provides a breakdown of WNH's meter installations by age. Approximately 7% or 164 installations have exceeded their TUL of 50 years and 0.1% or 2 installations exceed their maximum useful life of 60 years.

Figure 2-9: WNH Meter Installations by Age



2.11.2 Condition Assessment Criteria

Table 2-61 provides a listing of the TULs used by WNH for Metering assets.

Table 2-61: Metering Asset (TUL)

Asset Type	KINECTRICS REPORT		WNH TUL
	Min UL	TUL	
Smart Meters (Res)	5	(*)	15
Smart Meters (C&I)	5	(*)	15
Wholesale Meters	15	(*)	15
Metering Installations	30	(*)	50
TGB / Repeaters	15	(*)	15

(*) Not defined in Kinectrics REPORT

Table 2-62: Meter Condition Assessment Criteria

Degradation Factor	Weight	Ranking	Numerical Grade	Max Grade
Service Age	4	A,B,C,D,E	4,3,2,1,0	16
Defect and Test Reports	4	A,B,C,D,E	4,3,2,1,0	16
Mean Time Between Failures	3	A,B,C,D,E	4,3,2,1,0	12
Visual Inspections	3	A,B,C,D,E	4,3,2,1,0	12
Non-Discretionary Obsolescence	5	A,C,E	4,2,0	20
Discretionary Obsolescence	1	A,B,C,D,E	4,3,2,1,0	4
Total Score				80

WNH's condition assessment criteria for electricity meters comes in part from Measurement Canada's (MC) regulations under the *Electricity and Gas Inspection Act (the ACT)*. All electricity meters must conform to all of the performance and non-performance requirements of an approved pattern (design, features, functions, marking, etc.).

The owner of the meter remains legally responsible for ensuring meters' compliance with the Act and related MC policies and programs. Meter owners shall also subject meters to monitoring programs established by MC. Any meter that fails to meet a performance or non-

performance requirement, or that possesses a defect which could affect its ability to meet specified requirements, shall be classified as nonconforming and is removed from service. WNH ensures conformity to MC regulations by having the meters tested by a MC accredited meter verifier.

Metering installations are predominately meter commercial / industrial customers. They are inspected for condition and tested for accuracy (cross-phased) once every 8 - 10 years as required by Measurement Canada. In the case of WNH's larger customers, WNH attempts to gain access to inspect and test metering installations at least once every 5 years. Any degraded installation components are normally replaced at that time. Records of installation inspection and testing are maintained and subject to Measurement Canada inspection.

For WNH's in-service metering installations that have not been replaced during inspections, the age of the instrument transformers is utilized as the primary degradation factor. Installations greater than 50 years of age are scheduled for replacement over the next 5-year period.

In addition, many of the failure modes of meter or meter installation components are monitored and reported through WNH's Advanced Metering Infrastructure (AMI). Reports are monitored daily, and remediation is scheduled as soon as possible.

2.11.3 Condition Assessment

Table 2-63: Meter Condition Assessments

Year in Service	# Meters placed in Service	Age	% TUL	Score	Max Score	% HI	Condition Rating
2009	35,733	11	73%	52	80	65%	Fair
2010	13,182	10	67%	56	80	70%	Good
2011	990	9	60%	56	80	70%	Good
2012	4,188	8	53%	56	80	70%	Good
2013	701	7	47%	59	80	74%	Good
2014	705	6	40%	59	80	74%	Good
2015	699	5	33%	63	80	79%	Good
2016	593	4	27%	63	80	79%	Good
2017	610	3	20%	67	80	84%	Good
2018	601	2	13%	70	80	88%	Very Good
2019	516	1	7%	70	80	88%	Very Good

In 2009 and 2010 WNH installed approximately 48,915 smart meters with a seal period of 10 years. WNH has found that the electronic meters do not experience declining health such as other assets. They tend to function within Measurement Canada compliance standards and remain in service or they fail and are discarded. Early attempts to return failed meters to the manufacture for repair failed. The manufacturer could not repair or found it costlier to repair than to replace the meter. There is no effective maintenance option with these meters. For these reasons WNH has not developed Health indices for its electronic Smart meter population.

WNH replaces approximately 200 smart meters (0.34%) annually due to failure. The meter's radio communications or displays are the main source of failure and not the metrology. This failure rate has been stable over the historical period.

WNH has chosen to implement a re-verification sampling plan for its first generation residential smart meters. The sampling plan was developed in accordance with Measurement Canada Specifications. The sample testing program is used to track meter performance and to allow for seal period extensions without 100% re-verification testing of the meter population. Sample testing performed between 2015 and 2019 have shown that the meters continue to perform within Measurement Canada specifications and there is no concern with accuracy.

2.11.4 Data Availability Indicator

WNH has 100% data availability on its meter population. Every meter, as required by Measurement Canada has a test record completed by an accredited meter verifier.

2.11.5 Analysis of Results

In 2018 and 2019, WNH completed final reverification testing on 10 groups (36,195) of meters. All 10 groups achieved test results which qualified for the maximum Level 1 (8 year) meter seal extension.

Final re-verification testing for 6 groups (19,016 meters) will be completed between 2020 and 2025. WNH expects these meters to have similar test results and will also qualify for a Level 1 (8 year) seal extension.

There has yet to be a failure profile established for this generation of smart meters. WNH has been experiencing constant random failures of approximately 0.34% as the meter population matures. This is considered to be low; however, WNH will need to continue sample testing its meter population and trend its annual meter failure rates to serve as leading indicators that EOL is approaching.

Much like WNH's microprocessor based protection relays, electronic revenue meters (Smart Meters) are also subject to functional obsolescence, the most serious of which is of the communication system. The meter's communications are integrated into the smart meters both physically and operationally. The loss of the current smart meter communications

platform could trigger a wholesale upgrade of all the meters, despite their good performance in accuracy.

Given that these meters fully passed Measurement Canada reverification requirements, and that there are no indications of an increasing failure rate, WNH expects them to remain in Good condition past 2025 and into the next investment cycle.


There are 2 meter installations past their maximum useful life of 60 years and they are scheduled for replacement in 2020. In addition, there are 162 meter installations currently over the TUL of 50 years. These are recommended for replacement between 2020 and 2025.

2.12 MANUAL LOADBREAK SWITCHES

2.12.1 Asset Demographics

WNH has a population of 353 manual load break switches it maintains on its overhead distribution system. **Figure 2-10** provides a profile of the asset population by % TUL.

Figure 2-10: Load Break Switch Population by % TUL



2.12.2 Condition Assessment Criteria

WNH has adopted a TUL of 45 years for its manual load break switches. This is consistent with the Kinectrics Report and WNH's own experience.

Table 2-64: Load Break Switch (TUL)

KINETRICS REPORT			WNH
Min UL	TUL	Max UL	TUL
30	45	55	45

WNH's Health Index formulation for manual load break switches uses service age, visual inspections, and IR scan results as condition parameters. WNH's preventative maintenance programs for switches is scheduled as part of WNH's OEB inspection cycles. Infrared (IR) thermography of overhead plant is completed once per year on all overhead 3-phase feeders. During this process all equipment installed on the same structure is checked for hot spots and general deficiencies of the facilities. At the time of this ACA, WNH has only service age recorded in its data base: therefore, the Health Index Formulation is based on age only.

Table 2-65: Load Break Switch Assessment Criteria

Degradation Factor Criteria	
Service Age	
Ranking	Corresponding Condition
A	0 to 25%
B	26% to 50%
C	51% to 75%
D	76% to 100%
E	Over 100%

2.12.3 Condition Assessment

Table 2-66: Manual Load Break Switch Age Profile

Degradation Factor Criteria		
Corresponding Condition (% TUL)	# Switches	% of Population
0 to 25%	213	60%
26% to 50%	67	19%
51% to 75%	45	13%
76% to 100%	17	5%
Over 100%	11	3%
Total	353	100%

2.12.4 Data Availability Indicator (DAI)

WNH's DAI for manual load break switch condition assessment data is 54%. Of the 353 switches, only 190 had specific install dates. The install dates for remaining switches were based on the age of pole. It is recommended to collect more degradation parameters during future inspection cycles to improve data accuracy.

2.12.5 Analysis of Results

Table 2-67: Manual Load Break Switch Age Profile

Ranking	Corresponding Condition (%TUL)	Health Index	% HI Range	# Switches	% of Population
A	0 to 25%	Very Good	85-100	213	60%
B	26% to 50%	Good	70-85	67	19%
C	51% to 75%	Fair	50-70	45	13%
D	76% to 100%	Poor	30-50	17	5%
E	Over 100%	Very Poor	0-30	11	3%
			Total	353	100%

Annually WNH replaces approximately 8 load break switches due to condition or operational deficiencies found during inspection and maintenance programs. Whenever possible, switch replacement is coordinated with overhead line renewal projects to prevent the duplication of labour to replace the switch. It is recommended that the 11 switches past TUL be coordinated for replacement over the forecast period.

3 Asset Replacement Recommendations

The analysis of results from the ACA process were presented at the end of each asset section. **Table 3-1** summarizes the recommended number of asset replacements resulting from the ACA. The replacements outlined in **Table 3-1** are include in WNH's capital investment plan.

Table 3-1: WNH Recommended Asset Replacement Plan

Year	2021	2022	2023	2024	2025
TS Station Transformers	0	0	0	0	0
TS Switchgear	0	0	0	1 , (Note1)	1 , (Note1)
TS Circuit Breakers	4	0	0	0	0
TS Feeder Cables	0	2	0	0	0
TS Station Protection Relays	10	10	5	5	0
TS Station Batteries	0	0	0	0	0
DS Transformers	0	0	0	0	0
Capacitor Banks	0	0	0	0	0
Wood Poles	620	620	620	620	620
Primary Underground Cables (km)	7.1	7.1	7.1	7.1	7.1
Submersible Transformers	25	25	25	25	25
Polemount Transformers	70	70	70	70	70
Padmount Transformers	30	30	30	30	25
Meters	200	200	200	200	200
Meter Installations	30	30	30	30	30
Manual Load Break Switches (historical proactive replacement from inspection & maintenance report)	8	8	8	8	8

Note 1: HSTS"B" one bus for refurbishment

Appendix B:

2021 Material Capital Investments

Appendix B:

2021 Material Capital Investments



Waterloo North Hydro Inc.

2021 Capital Project Summary Index

Category	Project Name	Page #
<u>System Access</u>	Non-Public Service Works on Highways Act (Non-PSWHA) Relocations	1
	Public Service Works on Highways Act (PSWHA) Relocations	4
	Customer Connections	7
	Expansions (Subdivisions)	10
	Expansions (Lines)	13
	Retail Meters	16
<u>System Renewal</u>	Overhead Line Renewal	19
	Underground Line Renewal	23
	Overhead Line Renewal - Failing Conductor	27
	Overhead Line Renewal (8kV)	31
	Reactive Renewal	35
	Proactive Renewal	38
<u>System Service</u>	Contingency Enhancement	41
	Grid Modernization	44
	Grid Resiliency	48
	Station Equipment Upgrades	51
<u>General Plant</u>	Fleet - Trucks	54
	Information Technology Asset Life Cycle	57
	Operation Technology Software	60
	Building and Furniture Improvements	63
	MS/DS Decommissioning	66

General Information on the project/program (5.4.3.2.A)

Project Name	Non-Public Service Works on Highways Act (Non-PSWHA) Relocations																		
OEB Investment Category	System Access																		
Project Description	This category represents capital expenditures required to comply with statutory obligations related to the relocation of overhead and underground facilities installed within municipal or provincial road allowances. Unlike projects that fall under the Public Service Works on Highways Act (PSWHA) , R.S.O. 1990, CHAPTER P.49, this program includes projects where an alternative cost arrangement is followed. The most common types of project in this category are overhead to underground line conversions driven by a municipality. Where the road authority directs WNH to replace aged overhead plant with underground, the road authority funds the cost difference between overhead and underground systems, typically between 75%-85% of total project cost, otherwise the cost recovery reaches up to 100%.																		
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																		
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN08</td><td>12</td><td>Bridgeport Rd - Albert to King (Electrical)</td><td>\$118,425</td></tr><tr><td>06EN08</td><td>19</td><td>Dorset Dr - Bridgeport to Albert (Civil)</td><td>\$305,628</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 424,053</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN08	12	Bridgeport Rd - Albert to King (Electrical)	\$118,425	06EN08	19	Dorset Dr - Bridgeport to Albert (Civil)	\$305,628			Total	\$ 424,053
WNH Project	Sub Project	Project Name	Total																
06EN08	12	Bridgeport Rd - Albert to King (Electrical)	\$118,425																
06EN08	19	Dorset Dr - Bridgeport to Albert (Civil)	\$305,628																
		Total	\$ 424,053																
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$424,053																	
	O&M Costs (if applicable)	\$0 Not Applicable																	
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																	
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	80																	
	Customer Load (peak KVA)	393																	
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Apr-2021																	
	Expected In-Service Date	Dec-2021																	
	Expenditure Timing	<table><tr><td>2021 Q1</td><td>10%</td><td>\$42,405</td></tr><tr><td>2021 Q2</td><td>40%</td><td>\$169,621</td></tr><tr><td>2021 Q3</td><td>40%</td><td>\$169,621</td></tr><tr><td>2021 Q4</td><td>10%</td><td>\$42,405</td></tr></table>		2021 Q1	10%	\$42,405	2021 Q2	40%	\$169,621	2021 Q3	40%	\$169,621	2021 Q4	10%	\$42,405				
2021 Q1	10%	\$42,405																	
2021 Q2	40%	\$169,621																	
2021 Q3	40%	\$169,621																	
2021 Q4	10%	\$42,405																	
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	The timing of this project is dictated by the road authority and not dictated by WNH. Close coordination is required between the local, regional, and provincial authorities. Regular progress meetings take place which helps WNH anticipate project timing and allows planning of this work amongst WNH driven projects.																		
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows: <table><tr><td>2016:</td><td>\$10,860,810</td><td rowspan="5">In 2016 WNH was required to relocate an abnormally large amount of infrastructure to accommodate Light Rail Transit project for the Region of Waterloo. The remaining historical years are more representative of typical expenditures and their variance driven by road authority requests as well as servicing complexity.</td></tr><tr><td>2017:</td><td>\$1,238,871</td></tr><tr><td>2018:</td><td>\$396,465</td></tr><tr><td>2019:</td><td>\$60,941</td></tr><tr><td>2020:</td><td>\$177,212</td></tr></table>			2016:	\$10,860,810	In 2016 WNH was required to relocate an abnormally large amount of infrastructure to accommodate Light Rail Transit project for the Region of Waterloo. The remaining historical years are more representative of typical expenditures and their variance driven by road authority requests as well as servicing complexity.	2017:	\$1,238,871	2018:	\$396,465	2019:	\$60,941	2020:	\$177,212					
2016:	\$10,860,810	In 2016 WNH was required to relocate an abnormally large amount of infrastructure to accommodate Light Rail Transit project for the Region of Waterloo. The remaining historical years are more representative of typical expenditures and their variance driven by road authority requests as well as servicing complexity.																	
2017:	\$1,238,871																		
2018:	\$396,465																		
2019:	\$60,941																		
2020:	\$177,212																		
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																		
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																		

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	These projects are mandatory. Scope and timelines are dictated by the road authority.
Related Objectives/Performance Targets	WNN Strategic Imperative 3 (Customer Service) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Request from the road authority
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	WNN works the appropriate local, regional and provincial authorities to ensure that required relocations are completed in a timely manner. WNN also reviews its Long Term System Plan to ensure that the relocated distribution assets are built in alignment with WNN's long term needs as well.
Investment Priority (5.4.3.2.B.1.c)	System Access investments are ranked as top priority, as they are mandated by regulation or code. This project is ranked 1 out of 16. Refer to Table 4-22 of the DSP for further details.
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	The relocation of distribution assets is mandatory and is based on the proposed design within the road allowance. WNN provides input to the road authority (or their agents) on the most economical alternatives for distribution asset relocation, but ultimately the road authority must make the final determination based on the impact to the design and other road allowance users. Hence, WNN is not in control of project outcomes or alternatives selected.
Effect on system operation efficiency and cost effectiveness (first bullet)	Overhead line relocations provide no net improvement on the efficiency of utility operations. The installation of underground cable versus overhead wires avoids future operating and maintenance costs associated with tree contacts, animal contacts, weather-related events (ice storm, wind storm, etc.) and issues associated with clearance to buildings and signs. Relocation projects typically require the old assets to be replaced with new ones. It is common that the assets being replaced are not fully depreciated and not in the poorest condition. Stranded asset costs are minimized by cost recovery principles described in the Conditions of Service and working with the requesting party to minimize the scope of work.
Net benefits accruing to customers (second bullet)	Other than noted in the next paragraph, relocation projects have little benefit to existing customers. Overhead to underground line burial projects can improve the aesthetics of the distribution system.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	The replacement of older distribution assets with new distribution assets built to the latest standards reduces the risk of failures. Newer assets are able to withstand increased adverse weather conditions and increased clearances around the conductors assist in both the frequency and duration of outages. Since many of the assets being replaced are not normally at end-of-life, any increase in reliability is small. Overhead to underground line burial projects have a positive effect on weather resiliency, however underground assets take longer to locate and repair or replace compared to overhead assets in the event of failure.
Scheduling Alternatives	These projects are mandatory. Scope and timelines are based on requirements put forth by the applicable road authority.
Ownership and/or Funding Alternatives	These projects are constructed in the public right-of-way and will consist solely of WNN's assets. There are no ownership alternatives. As mentioned above, funding is negotiated on a case by case basis with the applicable road authority.

Safety (5.4.3.2.B.2)

The intention of these types of projects are not to address safety concerns, although, at times, replacement of end of life assets may also result in elimination of safety hazards.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

Coordination with the road authorities, their agents, contractors, subcontractors and other utilities is on-going throughout the year, which helps with respect to relocation project coordination. WNN works closely with parties involved providing input on project alternatives in order to minimize costs.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

New lines generally incorporate larger conductor, increased strength, and where available, higher voltages. As a result, system is better able to withstand poor weather conditions; provide increased capacity and siting options for the connection of renewable energy generation, electric vehicles, energy storage; provide increased physical space for third party communications and smart grid devices; and reduce power quality issues and losses.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Factors Affecting Project Timing/Priority (5.4.3.2.C.a. first bullet)

The timing of individual projects is based on scheduling provided by the road authority or their agents. WNH works closely with all stakeholders via regular progress meetings to ensure sufficient notice is provided to WNH and work is completed in a timeframe required by the road authority. As explained in section 5.4.3.2.B.1.c, this work is top priority.

Factors Relating to Customer or 3rd Party Preference (5.4.3.2.C.a. second bullet)

WNH works closely with the road authority and their agents to ensure the relocation of distribution assets is acceptable. All local utilities (communication companies, gas, water, sewer, etc.) work together to minimize costs and disruption, both in design and construction.

Factors Affecting Final Project Costs (5.4.3.2.C.a. third bullet)

Factors affecting the cost of these relocation projects include number of circuits involved, the length of relocation required, number and type of customers connected to the line(s), depth of burial (for underground projects), unexpected subsurface conditions and level of traffic management needed during construction, many of these factors are not known until the road authority finalizes their design.

Controllable Cost Minimization (5.4.3.2.C.a. fourth bullet)

Costs are minimized through effective coordination of design and construction scheduling of work. Cost sharing for these projects is negotiated on a per project basis and WNH recovers the cost according to the terms defined in our Conditions of Service.

Other Planning Objectives Met (5.4.3.2.C.a. fifth bullet)

Where applicable, other planning objectives being considered include higher poles in some locations to address new framing standards or installation of additional ductwork in alignment with WNH long term system needs. WNH may also be able to change the schedule of a renewal project to align with the road authority's work to maximize these benefits.

Other Project Design or Implementation Options Considered (5.4.3.2.C.a. sixth bullet)

Feasible options are discussed with the road authority, their consultants and other stakeholders as the project develops. First and foremost, opportunities to avoid relocations are identified. Secondly, where relocations must occur due to conflicts, WNH works with stakeholders to minimize the extent and cost of relocations.

Summary of Analysis for "Least Cost" and "Cost Efficient" Options (5.4.3.2.C.a. seventh bullet)

See Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d) section above.

Results of the Final Economic Evaluation (5.4.3.2.C.a. eighth bullet)

The Economic Evaluation is not applicable.

Nature and Magnitude of System Impacts, Costs and Cost Recovery (5.4.3.2.C.a. ninth bullet)

There are no expected long term impacts from projects in this category, however WNH's distribution system may be reconfigured during construction.

WNH negotiates cost recovery terms above and beyond the stipulated formula in the Public Service Works on Highways Act (PSWHA), R.S.O. 1990, CHAPTER P.49 for projects in this category. Cost recovery varies with the nature of specific relocation work and can vary between 25% and 100%. In 2021, WNH is expected to recover approximately 98% of the over all costs for the entire project as compared to approximately 30% under PSWHA.

General Information on the project/program (5.4.3.2.A)

Project Name	Public Service Works on Highways Act (PSWHA) Relocations																															
OEB Investment Category	System Access																															
Project Description	This category represents capital expenditures required to comply with statutory obligations related to the relocation of overhead and underground facilities installed within municipal or provincial road allowances. Based on a legislated cost sharing formula under the Public Service Works on Highways Act (PSWHA) , R.S.O. 1990, CHAPTER P.49, road authority contributes 50% of labour and labour saving devices.																															
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																															
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN05</td><td>15</td><td>Weber St - Benjamin Rd to Lobsinger Ln</td><td>\$285,355</td></tr><tr><td>06EN05</td><td>6</td><td>Northfield Dr - Bridge to University</td><td>\$240,089</td></tr><tr><td>06EN05</td><td>21</td><td>Sawmill Rd (RR17) & Ebycrest - Round Abouts</td><td>\$148,725</td></tr><tr><td>06EN05</td><td>23</td><td>Line 86 & Floradale Rd - Round Abouts</td><td>\$148,725</td></tr><tr><td>06EN05</td><td>32</td><td>Lorindale St - Hillside to EOL</td><td>\$96,766</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 919,660</td></tr></table>				WNH Project	Sub Project	Project Name	Total	06EN05	15	Weber St - Benjamin Rd to Lobsinger Ln	\$285,355	06EN05	6	Northfield Dr - Bridge to University	\$240,089	06EN05	21	Sawmill Rd (RR17) & Ebycrest - Round Abouts	\$148,725	06EN05	23	Line 86 & Floradale Rd - Round Abouts	\$148,725	06EN05	32	Lorindale St - Hillside to EOL	\$96,766			Total	\$ 919,660
WNH Project	Sub Project	Project Name	Total																													
06EN05	15	Weber St - Benjamin Rd to Lobsinger Ln	\$285,355																													
06EN05	6	Northfield Dr - Bridge to University	\$240,089																													
06EN05	21	Sawmill Rd (RR17) & Ebycrest - Round Abouts	\$148,725																													
06EN05	23	Line 86 & Floradale Rd - Round Abouts	\$148,725																													
06EN05	32	Lorindale St - Hillside to EOL	\$96,766																													
		Total	\$ 919,660																													
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$919,660																														
	O&M Costs (if applicable)	\$0 Not Applicable																														
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																														
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	1,295																														
	Customer Load (peak KVA)	5,210																														
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021																														
	Expected In-Service Date	Dec-2021																														
	Expenditure Timing																															
	2021 Q1	20%	\$183,932																													
	2021 Q2	30%	\$275,898																													
	2021 Q3	30%	\$275,898																													
	2021 Q4	20%	\$183,932																													
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	The timing of this project is dictated by the road authority and not dictated by WNH. Close coordination is required between the local, regional, and provincial authorities. Regular progress meetings take place which helps WNH anticipate project timing and allows planning of this work amongst WNH driven projects.																															
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																															
	2016:	\$1,603,936	The historical years are representative of typical expenditures and of their variance driven by road authority requests.																													
	2017:	\$466,405																														
	2018:	\$1,958,852																														
	2019:	\$615,954																														
	2020:	\$1,411,093																														
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																															
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																															

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	These projects are mandatory. Scope and timelines are dictated by the road authority.
Related Objectives/Performance Targets	WNH Strategic Imperative 3 (Customer Service) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Request from the road authority under the Public Service Works on Highways Act, R.S.O. 1990, CHAPTER P.49.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	WNH works the appropriate local, regional and provincial authorities to ensure that required relocations are completed in a timely manner. WNH also reviews its Long Term System Plan to ensure that the relocated distribution assets are built in alignment with WNH's long term needs as well.
Investment Priority (5.4.3.2.B.1.c)	System Access investments are ranked as top priority, as they are mandated by regulation or code. This project is ranked 1 out of 16. Refer to Table 4-22 of the DSP for further details.
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	The relocation of distribution assets is mandatory and is based on the proposed road design. WNH provides input to the road authority (or their agents) on the most economical alternatives for distribution asset relocation, but ultimately the road authority must make the final determination based on the impact to the road design and other road allowance users. Hence, WNH is not in control of project outcomes or alternatives selected.
Effect on system operation efficiency and cost effectiveness (first bullet)	Overhead line relocations provide no net improvement the efficiency of utility operations. Relocation projects typically require the old assets to be replaced with new ones. It is common that the assets being replaced are not fully depreciated and not in the poorest condition. As LDC's can only recover 50% labour and labour saving devices, relocations are not an efficient means of renewing infrastructure. WNH works with the road authorities to minimize the scope of work and stranded asset costs.
Net benefits accruing to customers (second bullet)	Other than noted in the next paragraph, relocation projects have little benefit to existing customers.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	The replacement of older distribution assets with new distribution assets built to the latest standards reduces the risk of failures. Newer assets are able to withstand increased adverse weather conditions and increased clearances around the conductors assist in both the frequency and duration of outages. Since many of the assets being replaced are not normally at end-of-life, any increase in reliability is small.
Scheduling Alternatives	These projects are mandatory. Scope and timelines are based on requirements put forth by the applicable road authority.
Ownership and/or Funding Alternatives	These projects are constructed in the public right-of-way and will consist solely of WNH's assets. There are no ownership alternatives. As mentioned above, funding is non-negotiable as it must follow the prescribed formula in the Public Service Works on Highways Act, R.S.O. 1990, CHAPTER P.49.

Safety (5.4.3.2.B.2)

The intention of these types of projects are not to address safety concerns, although at times end of life assets are replaced which may involve elimination of safety hazards.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

Coordination with the road authorities, their agents, contractors, subcontractors and other utilities is on-going throughout the year, which helps with respect to road relocation project coordination. WNH works closely with parties involved providing input on project alternatives in order to minimize costs.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

New lines generally incorporate larger conductor, increased strength, and where available, higher voltages. As a result, system is better able to withstand poor weather conditions; provide increased capacity and siting options for the connection of renewable energy generation, electric vehicles, energy storage; provide increased physical space for third party communications and smart grid devices; and reduce power quality issues and losses.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Factors Affecting Project Timing/Priority (5.4.3.2.C.a. first bullet)

The timing of individual projects is based on scheduling provided by the road authority or their agents. WNH works closely with all stakeholders via regular progress meetings to ensure sufficient notice is provided to WNH and work is completed in a timeframe required by the road authority. As explained in section 5.4.3.2.B.1.c, this work is top priority.

Factors Relating to Customer or 3rd Party Preference (5.4.3.2.C.a. second bullet)

WNH works closely with the road authority and their agents to ensure the relocation of distribution assets is acceptable. All local utilities (communication companies, gas, water, sewer, etc.) work together to minimize costs and disruption, both in design and construction.

Factors Affecting Final Project Costs (5.4.3.2.C.a. third bullet)

Factors affecting the cost of these relocation projects include number of circuits involved, the length of relocation required, number and type of customers connected to the line(s), depth of burial (for underground projects), unexpected subsurface conditions and level of traffic management needed during construction, the latter ones are not known until the road authority finalizes their design. Cost sharing for these projects is as per the stipulated formula in the Public Service Works on Highways Act (PSWHA), R.S.O. 1990, CHAPTER P.49.

Controllable Cost Minimization (5.4.3.2.C.a. fourth bullet)

Costs are minimized through effective coordinated design and construction scheduling or work. Cost sharing for these projects is as per the stipulated formula in the Public Service Works on Highways Act (PSWHA), R.S.O. 1990, CHAPTER P.49.

Other Planning Objectives Met (5.4.3.2.C.a. fifth bullet)

Where applicable, other planning objectives being considered include higher poles in some locations to address new framing standards or installation of additional ductwork in alignment with WNH long term system needs. WNH may also be able to change the schedule of a renewal project to align with the road authority's work to maximize these benefits.

Other Project Design or Implementation Options Considered (5.4.3.2.C.a. sixth bullet)

Feasible options are discussed with the road authority, their consultants and other stakeholders as the project develops. First and foremost, opportunities to avoid relocations are identified. Secondly, where relocations must occur due to conflicts, WNH works with stakeholders to minimize the extent and cost of relocations.

Summary of Analysis for "Least Cost" and "Cost Efficient" Options (5.4.3.2.C.a. seventh bullet)

See Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d) section above.

Results of the Final Economic Evaluation (5.4.3.2.C.a. eighth bullet)

Not Applicable

Nature and Magnitude of System Impacts, Costs and Cost Recovery (5.4.3.2.C.a. ninth bullet)

There are no expected long term impacts from projects in this category, however WNH's distribution system may be reconfigured during construction. Costs are recovered from road authorities according to the stipulated formula in the Public Service Works on Highways Act (PSWHA), R.S.O. 1990, CHAPTER P.49.

General Information on the project/program (5.4.3.2.A)

Project Name	Customer Connections																										
OEB Investment Category	System Access																										
Project Description	This category represents capital expenditures on the overhead and underground primary and secondary systems necessary to rehabilitate and/or expand infrastructure to service new customers or maintain existing customers.																										
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																										
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN07</td><td>1</td><td>New Overhead Service Connections/Upgrades</td><td>\$386,175</td></tr><tr><td>06EN11</td><td>1</td><td>New Underground Service Connections/Upgrades</td><td>\$1,569,683</td></tr><tr><td>11DG01</td><td>2</td><td>Net Metering Generator Connections</td><td>\$56,244</td></tr><tr><td>11DG01</td><td>4</td><td>Load Displacement Generator Connections</td><td>\$156,277</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 2,168,379</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN07	1	New Overhead Service Connections/Upgrades	\$386,175	06EN11	1	New Underground Service Connections/Upgrades	\$1,569,683	11DG01	2	Net Metering Generator Connections	\$56,244	11DG01	4	Load Displacement Generator Connections	\$156,277			Total	\$ 2,168,379
WNH Project	Sub Project	Project Name	Total																								
06EN07	1	New Overhead Service Connections/Upgrades	\$386,175																								
06EN11	1	New Underground Service Connections/Upgrades	\$1,569,683																								
11DG01	2	Net Metering Generator Connections	\$56,244																								
11DG01	4	Load Displacement Generator Connections	\$156,277																								
		Total	\$ 2,168,379																								
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$2,168,379																									
	O&M Costs (if applicable)	\$0 Not Applicable																									
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																									
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	Various - demand driven																									
	Customer Load (peak KVA)	Various - demand driven																									
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021																									
	Expected In-Service Date	Dec-2021																									
	Expenditure Timing																										
	2021 Q1	15%	\$325,257																								
	2021 Q2	20%	\$433,676																								
	2021 Q3	40%	\$867,352																								
	2021 Q4	25%	\$542,095																								
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	This work is very routine for WNH and covered by well established processes which mitigates issues around customer or developer driven timing risks. Timelines are strictly monitored and enforced to ensure obligations set forth in the DSC are met and that customer satisfaction is maintained.																										
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																										
	2016:	\$3,165,396	The historical years are representative of typical expenditures and of their variance driven by developer requests as well servicing complexity.																								
	2017:	\$2,249,709																									
	2018:	\$2,020,785																									
	2019:	\$2,983,162																									
	2020:	\$2,450,707																									
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	This project category includes strictly connection costs of distributed energy resources. While the quantity of projects is low, the size and complexity of the projects are increasing, which increases connection costs. The REG related connection costs are fully recovered from the customer.																										
	There are no improvements to the system's ability to accommodate the connection of REG facilities as a result of these projects.																										
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																										

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	These projects are mandatory. Scope and timelines are based on requirements put forth by customers and/or obligations set forth for connecting customers in the DSC.
Related Objectives/Performance Targets	WNN Strategic Imperative 3 (Customer Service) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Request for service and obligations set forth in the DSC.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	WNN ensures that the connection of new customers allows for a flexible and resilient distribution system that also supports future growth. This includes considerations such as primary loops (installed or provisioned for future), sizing of equipment to meet both the current and projected needs of the load and any future loads it may impact, careful selection of equipment placement in a location that is accessible and easy to maintain, alignment with long term system needs including securing of easements, provisions for remote SCADA monitoring or control of equipment on site as well as overall coordination with municipalities and third parties to optimize design and construction costs for all.
Investment Priority (5.4.3.2.B.1.c)	System Access investments are ranked as top priority, as they are mandated by regulation or code. This project is ranked 1 out of 16. Refer to Table 4-22 of the DSP for further details.
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	Customer connection projects are driven by customer requests and the specific requirements of the customer. Design and methodology for such projects are standardized through WNN policies and practices and in line with WNN Conditions of Service. Alternatives are limited as servicing options are standardized, but if alternatives exist, they are normally the choice of the customer.
Effect on system operation efficiency and cost effectiveness (first bullet)	Asset additions in this project category will add to the inspection, maintenance and testing programs placing upward pressure on O&M expenditures.
Net benefits accruing to customers (second bullet)	There are no significant net benefits accruing to customers as a result of this investment.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	New customers are connected (or provisioned for future connection) to looped systems to maintain system reliability performance.
Scheduling Alternatives	These projects are mandatory. Scope and timelines are based on requirements put forth by customers and/or obligations set forth for connecting customers in the DSC.
Ownership and/or Funding Alternatives	Under certain scenarios, according to WNN's Conditions of Service, ownership of assets is available to the Customer or WNN. When this is the case, the decision is left to the customer.

Safety (5.4.3.2.B.2)

All new distributed energy resource projects follow the prescribed process in the Distribution System Code and WNN's internal processes to ensure new connections are connected with the proper safety features present.

All new services are installed in accordance with WNN standards, WNN's Conditions of Service and meet the safety requirements of Ontario Regulation 22/04.

Cyber-security, Privacy (5.4.3.2.B.3)

When connecting new customers that require remote monitoring or teleprotection, WNN owned infrastructure is used. These networks use various forms and levels of security to minimize the risk of cyber-security attacks including, but not limited to, encryption, authentication access and firewalls.

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

WNN meets regularly with the area Utility Coordinating Council comprised of municipal and third party stakeholders. WNN exchanges project details with other stakeholders for mutual benefit.

WNN also works very closely with the local municipalities to understand the municipal zoning and/or site plan requirements and their impact on WNN's standardized servicing options. WNN has developed a process through the City of Waterloo to communicate servicing requirements to developers in the very early design stages of site plan development, which ultimately leads to shortened review and approval processes at the City level as well as a smoother service connection process for developer.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

New residential subdivisions are designed with capacity and capability to permit behind the meter customer generation and electric vehicle charging. Each service to a new residential building is sized for 200A to facilitate customer load growth.

All new distributed energy resource projects are equipped with provisions for future monitoring or control of the facility.

Based on WNN's long term system plans, future operational requirements are addressed on a case by case basis when sizing equipment, securing easements and provisioning for remote monitoring/control of the equipment on site.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Factors Affecting Project Timing/Priority (5.4.3.2.C.a. first bullet)

Scope and timelines are based on requirements put forth by customers and/or obligations set forth for connecting customers in the DSC. As explained in section 5.4.3.2.B.1.c, this work is top priority.

Factors Relating to Customer or 3rd Party Preference (5.4.3.2.C.a. second bullet)

These projects are initiated by customers and are designed to meet the needs of the customer requirements.

Factors Affecting Final Project Costs (5.4.3.2.C.a. third bullet)

Main factors that affect final costs are size of service, type of service (overhead, underground), type of transformer required (overhead, padmounted, vault room), distance between demarcation point of WNH existing main distribution system, subsurface conditions, and size and type of generation (monitoring or teleprotection requirements). Final costs of individual projects cannot be determined until the specific requirements of the proposed work is shared with WNH. Charges to the customer are based on fixed and variable costs that are updated annually.

Controllable Cost Minimization (5.4.3.2.C.a. fourth bullet)

The design and connection of services is standardized and therefore costs are controlled through well established processes, the use of standard material, and the efficiencies established through WNH's experience in connecting such projects.

Other Planning Objectives Met (5.4.3.2.C.a. fifth bullet)

WNH ensures through planning and connection design requirements that the long term needs of the system are met. This includes future load growth of the site as well as incorporating the needs of WNH's long term system plan into the design and requirements of the site.

Other Project Design or Implementation Options Considered (5.4.3.2.C.a. sixth bullet)

Customers have options with respect to servicing, however, feasible options must be reviewed on a project by project basis, which cannot start until each project is initiated.

Summary of Analysis for "Least Cost" and "Cost Efficient" Options (5.4.3.2.C.a. seventh bullet)

WNH is not in control of project outcomes or alternatives selected. The customers select the best value option for their development, which may be the highest cost option for WNH.

Results of the Final Economic Evaluation (5.4.3.2.C.a. eighth bullet)

Economic evaluations are only carried out if distribution system expansion work is required as per section 3.2 of the DSC. The results of this evaluation varies based on work required and forecasted demand.

Nature and Magnitude of System Impacts, Costs and Cost Recovery (5.4.3.2.C.a. ninth bullet)

Projects in this category include connections to the existing main distribution system only. If line expansions are needed to connect new customers, they are done under a different program. Cost recovery follows the DSC.

General Information on the project/program (5.4.3.2.A)

Project Name	Expansions (Subdivisions)																										
OEB Investment Category	System Access																										
Project Description	This project category represents the capital work required to build and connect new subdivisions driven by developer demand. The investment levels are based on information obtained through municipal and customer consultations. The expenditure represents all costs to expand WNH's main distribution system within the public right of way as well as electrical systems on private property up to the demarcation point (meter base).																										
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																										
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN10</td><td>24</td><td>Waterloo - New Subdivisions</td><td>\$152,558</td></tr><tr><td>06EN10</td><td>25</td><td>Woolwich - New Subdivisions</td><td>\$653,486</td></tr><tr><td>06EN10</td><td>26</td><td>Wellesley - New Subdivisions</td><td>\$73,866</td></tr><tr><td>06EN10</td><td>27</td><td>Waterloo West side Employment Lands (side road loop)</td><td>\$202,036</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 1,081,946</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN10	24	Waterloo - New Subdivisions	\$152,558	06EN10	25	Woolwich - New Subdivisions	\$653,486	06EN10	26	Wellesley - New Subdivisions	\$73,866	06EN10	27	Waterloo West side Employment Lands (side road loop)	\$202,036			Total	\$ 1,081,946
WNH Project	Sub Project	Project Name	Total																								
06EN10	24	Waterloo - New Subdivisions	\$152,558																								
06EN10	25	Woolwich - New Subdivisions	\$653,486																								
06EN10	26	Wellesley - New Subdivisions	\$73,866																								
06EN10	27	Waterloo West side Employment Lands (side road loop)	\$202,036																								
		Total	\$ 1,081,946																								
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$1,081,946																									
	O&M Costs (if applicable)	\$0 Not Applicable																									
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																									
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	286 lots																									
	Customer Load (peak KVA)	Information not available until time of work																									
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021																									
	Expected In-Service Date	Dec-2021																									
	Expenditure Timing																										
	2021 Q1	10%	\$108,195																								
	2021 Q2	30%	\$324,584																								
	2021 Q3	30%	\$324,584																								
	2021 Q4	30%	\$324,584																								
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	This work is very routine for WNH and covered by well established processes which mitigates issues around customer or developer driven timing risks. Timelines are strictly monitored and enforced to ensure obligations set forth in the DSC are met and that customer satisfaction is maintained. If developer requirements are shorter than material delivery times, WNH defers underground renewal project(s) and re-purposes that material for customer driven work.																										
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																										
	2016:	\$967,227	The historical years are representative of typical expenditures and of their variance driven by developer requests.																								
	2017:	\$1,015,261																									
	2018:	\$924,406																									
	2019:	\$782,768																									
	2020:	\$644,645																									
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																										
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																										

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	These projects are mandatory. Scope and timelines are based on requirements put forth by customers and/or obligations set forth for connecting customers in the DSC.
Related Objectives/Performance Targets	WNN Strategic Imperative 3 (Customer Service) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Request for service and obligations set forth in the DSC.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	WNN ensures that the connection of new customers allows for a flexible and resilient distribution system that also supports future growth. This includes considerations such as primary loops (installed or provisioned for future), sizing of equipment to meet both the current and projected needs of the load and any future loads it may impact, careful selection of equipment placement in a location that is accessible and easy to maintain, alignment with long term system needs including securing of easements as well as overall coordination with municipalities and third parties to optimize design and construction costs for all.
Investment Priority (5.4.3.2.B.1.c)	System Access investments are ranked as top priority, as they are mandated by regulation or code. This project is ranked 1 out of 16. Refer to Table 4-22 of the DSP for further details.
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	Subdivision projects are driven by developer requests. Design and methodology for such projects are standardized through WNN's policies and practices, although it differs from project to project based on developer specific requirements. Alternatives are considered based on individual project details as they are brought forth.
Effect on system operation efficiency and cost effectiveness (first bullet)	Asset additions in this project category will add to the inspection, maintenance and testing programs placing upward pressure on O&M expenditures.
Net benefits accruing to customers (second bullet)	There are no significant net benefits accruing to customers as a result of this investment.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	New customers are connected (or provisioned for future connection) to looped systems to maintain system reliability performance.
Scheduling Alternatives	These projects are mandatory. Scope and timelines are based on requirements put forth by customers and/or obligations set forth for connecting customers in the DSC.
Ownership and/or Funding Alternatives	WNN is responsible for all system design and ultimate ownership of the distribution plant it operates. Developers are given the option of scheduling, funding and constructing the underground distribution system to WNN's standards, subject to WNN inspection, provided it can be done without working on WNN's energized system. If this option is selected, the developer is required to transfer ownership of the plant to WNN prior to being connected to the energized system by WNN.

Safety (5.4.3.2.B.2)

Safety is not a driver for this project. Safety is a key Strategic Imperative for WNN as identified in Exhibit 1.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

This work is very routine for WNN and covered by standardized and well established processes between the developer, municipality, WNN, and other utilities. Through this standardization, coordination and joint use trenching opportunities are maximized. Differences in project requirements requested by developers are addressed with municipalities and other utilities via meetings, drawing exchange, and the Utilities Coordinating Council. WNN meets regularly with the area Utility Coordinating Council comprised of municipal and third party stakeholders.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

New residential subdivisions are designed with capacity and capability to permit behind the meter customer generation and electric vehicle charging. Each service to a new residential building is sized for 200A to facilitate customer load growth.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)
Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)
Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Factors Affecting Project Timing/Priority (5.4.3.2.C.a. first bullet)

The timing of individual projects is based on scheduling provided by the developer or their agents. WNH works closely with all stakeholders via regular progress meetings to ensure sufficient notice is provided to WNH and work is completed in the required timeframe. As explained in section 5.4.3.2.B.1.c, this work is top priority.

Factors Relating to Customer or 3rd Party Preference (5.4.3.2.C.a. second bullet)

These projects are initiated by developers and are designed to meet the needs of the proposed development in compliance with applicable standards and regulations.

Factors Affecting Final Project Costs (5.4.3.2.C.a. third bullet)

Final costs of each subdivision cannot be determined until the project is brought forth to WNH. The conditions of the land being developed, the number of lots and type of residence being proposed are the largest factors that affect project costs. Cost recovery from the developer is governed by the economic evaluation process as prescribed in the DSC.

Controllable Cost Minimization (5.4.3.2.C.a. fourth bullet)

The design of subdivision projects is standardized and therefore costs are controlled through well established processes, the use of standard material, and the efficiencies established through WNH's experience in connecting such projects. The developer also has the right to contest various parts of the required work as provided for in the DSC.

Other Planning Objectives Met (5.4.3.2.C.a. fifth bullet)

As most new subdivisions are constructed in stages, WNH plans for and requires each developer to make provisions for servicing subsequent stages of development.

Other Project Design or Implementation Options Considered (5.4.3.2.C.a. sixth bullet)

Feasible options are discussed with municipalities, developers, their consultants and other utilities and stakeholders as the project develops.

Summary of Analysis for "Least Cost" and "Cost Efficient" Options (5.4.3.2.C.a. seventh bullet)

Alternatives are considered, however, the analysis is completed on a project by project basis after the project is initiated.

Results of the Final Economic Evaluation (5.4.3.2.C.a. eighth bullet)

Capital contributions toward these projects are collected and calculated based on the economic evaluation methodology in accordance with the DSC and WNH's Conditions of Service. Detailed results for each project can only be available after the project is initiated, however, due to the high level of standardization of these projects, capital contribution levels for budgetary purposes are estimated based on averages from actual results on previous projects.

Nature and Magnitude of System Impacts, Costs and Cost Recovery (5.4.3.2.C.a. ninth bullet)

As WNH's system is not constrained, and municipalities are striving to confine urban sprawl resulting in limited options for new subdivisions. These types of projects have very little impact on the system once they are complete. If development of a new subdivision is staged, the construction of the main distribution system may not be fully complete, resulting in system segregation and lesser ability to restore power quickly.

Costs for these projects are fairly predictable based on standardized processes and materials, and are partially recovered through economic evaluations as prescribed in the DSC.

General Information on the project/program (5.4.3.2.A)

Project Name	Expansions (Lines)														
OEB Investment Category	System Access														
Project Description	<p>This project category represents the capital work required to expand the main overhead or underground distribution system to facilitate connection of new customers or upgrades for existing customers. The expenditure represents all costs associated with constructing new assets within the public right of way. The projects may involve greenfield construction, where no prior assets existed, or upgrading an existing line to increase the number of circuits or to increase the capacity by upgrading the wire size and/or the voltage level.</p> <p>The 2021 project includes installing underground primary conductor to support a new commercial development on the west side of the City of Waterloo where there is currently no existing electrical infrastructure.</p>														
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:														
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN08</td><td>14</td><td>Platinum Dr - Erb St to Columbia St (Electrical)</td><td>\$470,395</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 470,395</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN08	14	Platinum Dr - Erb St to Columbia St (Electrical)	\$470,395			Total	\$ 470,395
WNH Project	Sub Project	Project Name	Total												
06EN08	14	Platinum Dr - Erb St to Columbia St (Electrical)	\$470,395												
		Total	\$ 470,395												
Capital Investment (5.4.3.2.A.first bullet)	Total Capital \$470,395														
	O&M Costs (if applicable) \$0 Not Applicable														
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution \$0														
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#): Various - demand driven Customer Load (peak KVA) Various - demand driven														
Project Timing (5.4.3.2.A.fourth bullet)	Start Date Jan-2021 Expected In-Service Date Dec-2021 Expenditure Timing 2021 Q1 10% \$47,040 2021 Q2 30% \$141,119 2021 Q3 30% \$141,119 2021 Q4 30% \$141,119														
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	This work is very routine for WNH and covered by well established processes which mitigates issues around customer or developer driven timing risks. Timelines are strictly monitored and enforced to ensure obligations set forth in the DSC are met and that customer satisfaction is maintained.														
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows: <table><tr><td>2016:</td><td>\$313,048</td><td rowspan="5">The historical years are representative of typical expenditures and of their variance driven by developer or individual customer requests as well servicing complexity.</td></tr><tr><td>2017:</td><td>\$663,800</td></tr><tr><td>2018:</td><td>\$164,534</td></tr><tr><td>2019:</td><td>\$1,022,289</td></tr><tr><td>2020:</td><td>\$458,889</td></tr></table>			2016:	\$313,048	The historical years are representative of typical expenditures and of their variance driven by developer or individual customer requests as well servicing complexity.	2017:	\$663,800	2018:	\$164,534	2019:	\$1,022,289	2020:	\$458,889	
2016:	\$313,048	The historical years are representative of typical expenditures and of their variance driven by developer or individual customer requests as well servicing complexity.													
2017:	\$663,800														
2018:	\$164,534														
2019:	\$1,022,289														
2020:	\$458,889														
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable														
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable														

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	These projects are mandatory. Scope and timelines are based on requirements put forth by customers and/or obligations set forth for connecting customers in the DSC.
Related Objectives/Performance Targets	WNH Strategic Imperative 3 (Customer Service) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Request for service and obligations set forth in the DSC.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	WNH ensures that the connection of new customers allows for a flexible and resilient distribution system that also supports future growth. This includes considerations such as primary loops (installed or provisioned for future), sizing of equipment to meet both the current and projected needs of the load and any future loads it may impact, careful selection of equipment placement in a location that is accessible and easy to maintain, alignment with long term system needs including securing of easements, provisions for remote SCADA monitoring or control of equipment on site as well as overall coordination with municipalities and third parties to optimize design and construction costs for all.
Investment Priority (5.4.3.2.B.1.c)	System Access investments are ranked as top priority, as they are mandated by regulation or code. This project is ranked 1 out of 16. Refer to Table 4-22 of the DSP for further details.
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>These projects are driven by developer or individual customer requests and requirements. Design and methodology for such projects are standardized through WNH's policies, practices, and standards. Options that meet or exceed WNH's standards are provided to the customer based on their requirements and WNH's existing infrastructure. These may include overhead or underground circuits, grid modernization/microgrid integration, equipment capabilities or redundancy options. When the developer or individual customer chooses an option that exceeds the cost of a standard service, they must fund the difference.</p> <p>For the specific project in 2021, WNH calculated the cost to build this expansion overhead, and when discussing project specifics, the developer chose to construct this area using underground circuits instead. As a result of this they are funding the difference between the overhead and underground costs.</p> <p>Effect on system operation efficiency and cost effectiveness (first bullet)</p> <p>The effects on system operation efficiency are highly dependent on the project details. If additional redundancy options are implemented as part of these projects, they may contribute toward greater reconfiguration options for the system as a whole, having a positive effect on reliability. Similar impact could be experienced by installation of additional circuits on existing lines or upgrading voltage of existing circuits. These projects may also have a positive effect on WNH's ability to rebalance the load between phases and improve power quality from a voltage performance point of view.</p> <p>The installation of underground cable versus overhead wires avoids future operating and maintenance costs associated with tree contacts/tree trimming, animal contacts, weather-related events (ice storm, wind storm, etc.) and issues associated with clearance to buildings and signs.</p> <p>Options selected by developers above WNH's standard level of service are funded by the developer or individual customer, but sometimes may benefit additional customers.</p> <p>Net benefits accruing to customers (second bullet)</p> <p>The benefits accruing to existing customers are highly dependent on the project details and as a result may have a positive effect on reliability, power quality, and aesthetics.</p> <p>Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)</p> <p>The impact on reliability performance is highly dependent on project details. If replacement of older distribution assets with new distribution assets built to the latest standards is part of the solution, then risk of future failures is reduced. Newer assets are able to withstand increased adverse weather conditions and incorporate increased clearances around the conductors, which assist in both the frequency and duration of outages.</p> <p>Overhead to underground line burial projects have a positive effect on weather resiliency, however underground assets take longer to locate and repair or replace compared to overhead assets in the event of failure.</p> <p>Scheduling Alternatives</p> <p>These projects are mandatory. Scope and timelines are based on requirements put forth by customers and/or obligations set forth for connecting customers in the DSC.</p> <p>Ownership and/or Funding Alternatives</p> <p>WNH is responsible for all system design and ultimate ownership of the distribution plant it operates.</p> <p>Developers or individual customers are given the option of scheduling, funding and constructing the required expansion of the distribution system to WNH's standards, subject to WNH's inspection, provided it can be done without working on WNH's energized system. If this option is selected, the developer or individual customer is required to transfer ownership of the plant to WNH prior to being connected to the energized system by WNH.</p>

Safety (5.4.3.2.B.2)

Safety is not a driver for this project. Safety is a key Strategic Imperative for WNH as identified in Exhibit 1.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

This work is covered by standardized and well established processes between the developers or individual customers, municipality, WNH, and other utilities. Through this standardization, coordination and joint use trenching opportunities are maximized. Differences in project requirements requested by developers or individual customers are addressed with municipalities and other utilities via meetings, drawing exchange, and the Utilities Coordinating Council. WNH meets regularly with the area Utility Coordinating Council comprised of municipality and third party stakeholders.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

For all projects WNH ensures the Long Term System Plan objectives are incorporated and that provisions are made for grid modernization.

Other options for consideration of future technological functionality or operational requirements are highly dependent on the details of the project. If voltage or conductor upgrading form part of the project, this also has the added benefit of increasing capacity for future generation connections. This is not the case of for this project.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Factors Affecting Project Timing/Priority (5.4.3.2.C.a. first bullet)

The timing of individual projects is based on scheduling provided by the developer, the individual customer, or their agents. WNH works closely with all stakeholders via regular progress meetings to ensure sufficient notice is provided to WNH and work is completed in the required timeframe. As explained in section 5.4.3.2.B.1.c, this work is top priority.

Factors Relating to Customer or 3rd Party Preference (5.4.3.2.C.a. second bullet)

These projects are initiated by developers or individual customers and are designed to meet their needs in compliance with applicable standards and regulations.

Factors Affecting Final Project Costs (5.4.3.2.C.a. third bullet)

Final costs of each project cannot be determined until the project is brought forth to WNH. The distance, complexity and infrastructure required for the expansion as well as the customers expected new load as result of the expansion all vary from project to project. Cost recovery is governed by the economic evaluation process as prescribed in the DSC.

Controllable Cost Minimization (5.4.3.2.C.a. fourth bullet)

The design of these projects is standardized, regardless of if it is overhead or underground, and therefore costs are controlled through well established processes, the use of standard material, and the efficiencies established through WNH's experience in connecting such projects. The developer or individual customer also has the right to contest various parts of the required work as provided for in the DSC.

Other Planning Objectives Met (5.4.3.2.C.a. fifth bullet)

For all projects WNH ensures the Long Term System Plan objectives are incorporated and that provisions are made for grid modernization.

Other Project Design or Implementation Options Considered (5.4.3.2.C.a. sixth bullet)

Feasible options are discussed with the developers or individual customers, their consultants and other stakeholders as the project develops.

Summary of Analysis for "Least Cost" and "Cost Efficient" Options (5.4.3.2.C.a. seventh bullet)

WNH is not always in control of project outcomes or alternatives selected. The customers select the best value option for their development, which may be the highest cost option for WNH.

Results of the Final Economic Evaluation (5.4.3.2.C.a. eighth bullet)

Capital contributions toward these projects are collected and calculated based on the economic evaluation methodology in accordance with the DSC and WNH's Conditions of Service. Detailed results for each project can only be available after the project is initiated, and are difficult to forecast on a program basis due to the large variance in these types of projects.

For the specific 2021 project, cost recovery approaches 100%.

Nature and Magnitude of System Impacts, Costs and Cost Recovery (5.4.3.2.C.a. ninth bullet)

Please see Section 5.4.3.2.B.1.d for general information on projects in this category.

For the 2021 project, since at this point WNH's system is not constrained, this project is not forecasted to have a large effect on WNH's distribution system.

Costs for these projects are fairly predictable based on standardized processes and materials, and are partially recovered through economic evaluations as prescribed in the DSC.

General Information on the project/program (5.4.3.2.A)

Project Name	Retail Meters																										
OEB Investment Category	System Access																										
Project Description	This program includes the installation of WNH's metering assets in compliance with Measurement Canada (MC) standards and the Distribution System Code (DSC). The work includes inspection and replacement of defective meters, procurement, testing, and installation of meters for new or upgraded residential and commercial services, and required supporting infrastructure to measure, record and transfer electricity consumption data.																										
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																										
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>13MT06</td><td>1</td><td>Residential Meters (Retail)</td><td>\$182,674</td></tr><tr><td>13MT06</td><td>2</td><td>Suite Metering</td><td>\$147,665</td></tr><tr><td>13MT07</td><td>2</td><td>C&I Meters > 50kW (Retail)</td><td>\$301,356</td></tr><tr><td>13MT07</td><td>1</td><td>C&I Meters < 50kW (Retail)</td><td>\$32,904</td></tr><tr><td colspan="3">Total</td><td>\$ 664,599</td></tr></table>			WNH Project	Sub Project	Project Name	Total	13MT06	1	Residential Meters (Retail)	\$182,674	13MT06	2	Suite Metering	\$147,665	13MT07	2	C&I Meters > 50kW (Retail)	\$301,356	13MT07	1	C&I Meters < 50kW (Retail)	\$32,904	Total			\$ 664,599
WNH Project	Sub Project	Project Name	Total																								
13MT06	1	Residential Meters (Retail)	\$182,674																								
13MT06	2	Suite Metering	\$147,665																								
13MT07	2	C&I Meters > 50kW (Retail)	\$301,356																								
13MT07	1	C&I Meters < 50kW (Retail)	\$32,904																								
Total			\$ 664,599																								
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$664,599																									
	O&M Costs (if applicable)	\$0 Not Applicable																									
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																									
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	Various - demand driven																									
	Customer Load (peak KVA)	Various - demand driven																									
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021																									
	Expected In-Production Date	Dec-2021																									
	Expenditure Timing																										
	2021 Q1	25%	\$166,150																								
	2021 Q2	25%	\$166,150																								
	2021 Q3	25%	\$166,150																								
	2021 Q4	25%	\$166,150																								
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	This work is very routine for WNH and covered by well established processes which mitigates issues around customer or developer driven timing risks. Timelines are strictly monitored and enforced to ensure obligations set forth in the DSC are met and that customer satisfaction is maintained.																										
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																										
	2016:	\$464,804	2017 through 2020 included the replacement of general service customer meters to comply with DSC amendment EB-2013-0311. Investment also increased to comply with MC recommendations for phasing out non blonde compliant metering installations and are expected to continue at this level.																								
	2017:	\$590,504																									
	2018:	\$621,715																									
	2019:	\$760,887																									
	2020:	\$707,852																									
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																										
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																										

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a) These projects are mandatory. For new or upgraded services, scope and timelines are based on the requirements put forth by customers and/or obligations set forth for connecting customers in the DSC. For replacement of existing meters, scope of work and timelines are based on the regulatory requirements established by MC and/or the DSC.

Related Objectives/Performance Targets WNH Strategic Imperative 3 (Customer Service) as identified in Exhibit 1

Source and Nature of the Information Used to Justify the Investment Request for service and obligations set forth in the DSC and MC regulations

Secondary Driver(s) (5.4.3.2.B.1.a) Not Applicable

Related Objectives/Performance Targets Not Applicable

Source and Nature of the Information Used to Justify the Investment Not Applicable

Good Utility Practice (5.4.3.2.B.1.b) WNH utilizes the Sensus Flexnet Metering and Communication network as its Advanced Metering Infrastructure (AMI) solution. The Sensus AMI system is used for reading both residential, C&I and MIST meters. The meters that WNH deploys come equipped with basic power quality monitoring, configurable alarms and encrypted communications. These additional features provide key data points for managing outages and reliability metrics as follows:
a) integrating power outage / restore messages with the Outage Management System (OMS)
b) integrating power outage / restore messages with FLISR for automated switching operations and reduced outage time
c) integrating power outage / restore messages with WNH's online outage map
d) integrating smart meter data into WNH's distribution planning systems, load flow software and transformer load analysis.
e) remote interrogation of meters (via pinging) for diagnosing power related issues.

Investment Priority (5.4.3.2.B.1.c) System Access investments are ranked as top priority, as they are mandated by regulation or code.

This project is ranked 1 out of 16. Refer to Table 4-22 of the DSP for further details.

Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)

Customer connection projects are driven by customer requests and the specific requirements of the customer. Design and methodology for such projects are standardized through WNH policies and practices and in line with WNH Conditions of Service. Alternatives are limited as metering options are standardized, but if alternatives exist, they are normally the choice of the customer.

Management of existing metering assets is governed by MC regulations. WNH uses a meter sample testing and reverification programs to ensure billing accuracy and compliance with MC regulations. Metering equipment is typically replaced on a like-for-Like bases. This is the preferred option as it allows for fast replacement with minimal disruption to the customer and continuity of billing services.

Effect on system operation efficiency and cost effectiveness (first bullet) Smart interval meters with remote communications enabled are now the standard installation for WNH, and facilitates the following:
a) eliminates manual meter reading
b) eliminates scheduled appointments to read difficult to access meters
c) reduces outage time by integrating meter alarm messages with the OMS and GIS systems to improve situational awareness
d) improved load monitoring capabilities for distribution transformers and system analysis.

Refer to Section 2.4 of the DSP for more detail.

Net benefits accruing to customers (second bullet) Meter alarm monitoring and data analytics allow WNH to respond to malfunctioning meters and power quality issues in a timely and efficient manner. Making interval data available to the customer will facilitate customer awareness of electricity consumption and will aid in managing energy to reduce or shift demand to off-peak periods. Future initiatives include providing customers with emailed notifications for power outages, power restores, high consumption and low consumption.

Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet) The metering program is expected to help reduce the duration of outages on WNH's distribution system. This is accomplished through the collection of meter alarms and integrating the data with the utility's Outage Management System (OMS). WNH's AMI system supports two way communications. This feature allows system operators to remotely interrogate power quality information from the meters and perform basic troubleshooting without dispatching crews. Refer to Section 2.4 of the DSP for more detail.

Scheduling Alternatives These projects are mandatory. Scope and timelines are based on requirements put forth by customers and/or obligations set forth for in the DSC and MC codes and regulations.

Ownership and/or Funding Alternatives These projects will consist solely of WNH's assets. There are no ownership or funding alternatives available at this time.

Safety (5.4.3.2.B.2)

These projects are not intended to address any existing safety concerns, but are expected to have safety related added benefits. This metering program leverages meter alarm functionality to identify potentially hazardous conditions including fire hazards, situations involving theft of power and loss of power conditions.

Cyber-security, Privacy (5.4.3.2.B.3)

WNH's Smart Meter and related AMI have been procured through Sensus. Sensus' system supports a multi-layered security approach including: access control, authorization, authentication and data integrity protocols. It also includes a robust AES-256 based encryption. As part of its continuous improvement model, WNH collaborates with other Ontario Sensus Customers to perform periodic security assessments and identify opportunities for enhanced system hardening.

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

Coordination with utilities and regional planning is not required. WNH coordinates with customers, contractors, and Electrical Safety Authority as required based on the scope of work for each project.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

A component of this program supports the capital investments required for the ongoing operation, maintenance, and installation of the AMI. Refer to Section 2.4 of the DSP for more detail.

Environmental Benefits (5.4.3.2.B.5)

The Smart Meter infrastructure supports Time of Use billing and the province's conservation culture. The AMI system also provides environmental benefits by reducing vehicle run time associated with manual meter reading.

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Factors Affecting Project Timing/Priority (5.4.3.2.C.a. first bullet)

New and replacement meters are provided on demand to address new load growth, meter failures and distributed generation.

Factors Relating to Customer or 3rd Party Preference (5.4.3.2.C.a. second bullet)

Metering for new and upgraded connection projects are customer initiated and are designed to meet customer identified requirements.

Factors Affecting Final Project Costs (5.4.3.2.C.a. third bullet)

Main factors that affect final costs are size of service, type of service (overhead, underground), and metering location (primary, secondary). Final costs of individual projects cannot be determined until the proposed work is requested by customers and/or a failed/defective metering asset is found.

Controllable Cost Minimization (5.4.3.2.C.a. fourth bullet)

The design and connection of services are standardized and, therefore, costs are controlled through well established processes, the use of standard material, and the efficiencies established through WNH's experience in executing such projects.

Other Planning Objectives Met (5.4.3.2.C.a. fifth bullet)

The change-over of walk read to interval meters for general service customers will improve operating efficiency and support MIST billing using the Hourly Ontario Energy Price. The meter replacements were completed over a four year period between 2017 and 2020 in compliance with the Ontario Energy Board's timelines as set out in EB-2013-0311.

Other Project Design or Implementation Options Considered (5.4.3.2.C.a. sixth bullet)

WNH operates a Sensus AMI system and procures meters from Sensus as well as other meter manufacturers who have the ability to equip their meters with the Sensus AMI communication module. WNH deploys Elster meters equipped with a Sensus AMI communication module for all general service customers. The Elster meter meets the DSC requirements for interval and demand billing and allows collection of meter data over the existing Sensus AMI system that is used for residential smart meters.

Summary of Analysis for "Least Cost" and "Cost Efficient" Options (5.4.3.2.C.a. seventh bullet)

WNH is not always in control of project outcomes or alternatives selected. The customers select the best value option for their development, which may be the highest cost option for WNH.

Results of the Final Economic Evaluation (5.4.3.2.C.a. eighth bullet)

Not Applicable

Nature and Magnitude of System Impacts, Costs and Cost Recovery (5.4.3.2.C.a. ninth bullet)

Not Applicable

General Information on the project/program (5.4.3.2.A)

Project Name	Overhead Line Renewal																																										
OEB Investment Category	System Renewal																																										
Project Description	<p>This program involves the planned rebuilding of overhead lines in poor condition. Typically these lines involve assets that are past their typical useful life (TUL), cannot be refurbished and if not replaced represent a risk to public safety and customer power reliability.</p> <p>These lines were originally installed between the 1966 and 1980, are 40 to 54 yrs. of age, and have Health Index ratings in the Poor and Very Poor category. These ratings were developed through age, field inspection and pole testing criteria. In 2021, the program consists of 8 individual projects involving the replacement of 288 poles, 93 transformers and 11 km of overhead line. The lines being replaced have 470 customers directly connected to them and another 3117 customers connected down stream.</p> <p>The project scope includes design, construction and installation of new taller poles designed to conform to O. Reg. 22/04 compliant standards as well as new wire, insulators, transformers and equipment. Newer construction standards and materials provide for more weather resilient assets to help maintain safety and reliability.</p> <p>Projects within this program are prioritized based on condition of the assets from WNH's 2019 ACA results. Projects are scheduled and executed over the course of the year based on coordination with third parties and available resources. Overall this program is prioritized and paced in coordination with WNH's overall Capital Investment Plan.</p>																																										
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																																										
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN04</td><td>16</td><td>Kumpf Dr - Randall to Northfield</td><td>\$349,873</td></tr><tr><td>06EN04</td><td>18</td><td>Randall Dr/Conrad Pl</td><td>\$454,385</td></tr><tr><td>06EN04</td><td>24</td><td>Bluevale Rd - Bridgeport to Mayfield Ave</td><td>\$199,372</td></tr><tr><td>06EN04</td><td>32</td><td>Dutton Dr - Weber to OMSF</td><td>\$89,208</td></tr><tr><td>06EN04</td><td>34</td><td>Bridge St W - University Ave to Lexington Rd</td><td>\$489,080</td></tr><tr><td>06EN04</td><td>35</td><td>Boomer Ln - Kressler Rd to Herrgott Rd</td><td>\$542,023</td></tr><tr><td>06EN04</td><td>41</td><td>Katherine St (RR23) - Lundy Rd to Crowsfoot Rd</td><td>\$639,811</td></tr><tr><td>06EN04</td><td>73</td><td>Downtown Maryhill (St. Charles St & Maryhill Rd</td><td>\$417,594</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 3,181,346</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN04	16	Kumpf Dr - Randall to Northfield	\$349,873	06EN04	18	Randall Dr/Conrad Pl	\$454,385	06EN04	24	Bluevale Rd - Bridgeport to Mayfield Ave	\$199,372	06EN04	32	Dutton Dr - Weber to OMSF	\$89,208	06EN04	34	Bridge St W - University Ave to Lexington Rd	\$489,080	06EN04	35	Boomer Ln - Kressler Rd to Herrgott Rd	\$542,023	06EN04	41	Katherine St (RR23) - Lundy Rd to Crowsfoot Rd	\$639,811	06EN04	73	Downtown Maryhill (St. Charles St & Maryhill Rd	\$417,594			Total	\$ 3,181,346
WNH Project	Sub Project	Project Name	Total																																								
06EN04	16	Kumpf Dr - Randall to Northfield	\$349,873																																								
06EN04	18	Randall Dr/Conrad Pl	\$454,385																																								
06EN04	24	Bluevale Rd - Bridgeport to Mayfield Ave	\$199,372																																								
06EN04	32	Dutton Dr - Weber to OMSF	\$89,208																																								
06EN04	34	Bridge St W - University Ave to Lexington Rd	\$489,080																																								
06EN04	35	Boomer Ln - Kressler Rd to Herrgott Rd	\$542,023																																								
06EN04	41	Katherine St (RR23) - Lundy Rd to Crowsfoot Rd	\$639,811																																								
06EN04	73	Downtown Maryhill (St. Charles St & Maryhill Rd	\$417,594																																								
		Total	\$ 3,181,346																																								
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$3,181,346																																									
	O&M Costs (if applicable)	\$0 Not Applicable																																									
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																																									
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	3,587																																									
	Customer Load (peak KVA)	21,198																																									
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Sep-2020 Engineering Jan-2021 Construction																																									
	Expected In-Service Date	Dec-2021																																									
	Expenditure Timing	<table><tr><td>2021 Q1</td><td>20%</td><td>\$636,269</td></tr><tr><td>2021 Q2</td><td>30%</td><td>\$954,404</td></tr><tr><td>2021 Q3</td><td>30%</td><td>\$954,404</td></tr><tr><td>2021 Q4</td><td>20%</td><td>\$636,269</td></tr></table>		2021 Q1	20%	\$636,269	2021 Q2	30%	\$954,404	2021 Q3	30%	\$954,404	2021 Q4	20%	\$636,269																												
2021 Q1	20%	\$636,269																																									
2021 Q2	30%	\$954,404																																									
2021 Q3	30%	\$954,404																																									
2021 Q4	20%	\$636,269																																									
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	<p>Sub project numbers 16, 18, and 32 are located in commercial/industrial areas. WNH's past experience with similar projects has found that scheduling outages with commercial customers is challenging due to the impact on their operations. WNH engages in extensive communication with each individual site owner to minimize impacts and delays.</p> <p>Sub project numbers 24 and 34 are both located in established urban areas containing a substantial population of mature trees. WNH has past experience with similar projects and has found that greater public consultation is required to avoid the risk of project delays due to public objections. To help mitigate this risk, WNH reaches out to all customers well in advance of the project to inform them of upcoming work, provide options and to take customer input into consideration in the final design. Continuous communication prior to and throughout construction also takes place.</p> <p>Sub project numbers 35 and 73 have no significant risk factors associated with their execution.</p> <p>Part of sub project number 41 runs under a Hydro One Networks Inc. (HONI) transmission line. Rebuilding the line within HONI's right of way requires special conditions and authorization which can take time to work out. WNH is familiar with the requirements of this work and has experience obtaining the appropriate approvals prior to finalizing the of the design.</p>																																										

Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:	
	2016: \$	179,585
	2017: \$	608,222
	2018: \$	514,169
	2019: \$	1,117,214
	2020: \$	235,928
	In 2016, WNH deferred some projects to free resources for a major System Access project. Planned renewal of pole lines in poor condition is divided between 4 categories: Overhead Line Renewal, Failing Conductor Renewal, Line Renewal (4kV), and Line Renewal (8kV). The 4kV line renewal program is now complete and the 8kV line renewal needs are now reduced. On a go forward basis, majority of pole line rebuild projects without failing conductor will be classified as Overhead Line Renewal, with the remaining being in the 8kV renewal category.	
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable	
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable	

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for these project is the age and condition of the existing plant.
Related Objectives/Performance Targets	WNH Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>The source of the information used to justify this investment is the ACA, as further detailed in Appendix A of the DSP. These lines were originally installed between the 1966 and 1980, are 40 to 54 years of age, and 181 poles have Health Index ratings in the Poor and Very Poor category with another 62 in fair condition. These ratings were developed through WNH's 2019 ACA results.</p> <p>WNH's ACA program uses asset degradation factors such as age, pole treatment, inspection and testing data to develop a Health Index (HI) for each of its pole assets. The HI is converted into a condition rating that can range from Very Good to Very Poor. Assets in Poor and Very Poor condition are identified and grouped into executable projects. Depending on their criticality to customer impact, assets in fair condition may also be grouped into executable projects and evaluated through the WNH asset management and prioritization process described in Section 3.1 and Section 4.2.2 of the DSP.</p> <p>The projects selected for execution in 2021, in addition to having a substantial number of poles in very poor, poor, or approaching poor condition, also have higher customer impact of failure compared to other identified pole lines in poor condition. Subprojects 16, 18, and 32 are supplying power to commercial and industrial areas. All other subproject are along critical tie lines between feeders or stations. In addition, Subproject 24 is in a section of one of WNH's worst performing feeders.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	<p>WNH utilizes Utility Standards Forum design standards. These standards are based on CSA C22.3 No 1-15 Overhead Systems Heavy Weather Loading design standards. Newer construction standards and materials provide for more weather resilient assets to help maintain safety and reliability. WNH overhead designs facilitates the future incorporation of grid modernization equipment and renewable energy generation. WNH conducts annual inspection and testing programs, evaluates the results and reprioritizes the replacement of assets if required.</p> <p>Although pole condition is normally the main driver for overhead renewal projects, other assets such as transformers, insulators, wire, arrestors are also replaced as part of pole line rebuild. These assets are nearing end of life and would not normally survive a second life cycle. Replacing these assets all at the same time is more cost effective and less disruptive than waiting until individual assets fail or reach end of life.</p>
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>System Renewal assets are prioritized by the health condition of the assets developed through its ACA program. Assets found at risk of imminent failure or high public safety risk are prioritized for immediate replacement.</p> <p>WNH is utilizing METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN to aid in prioritizing asset replacement. Assets flagged for replacement are geospatially grouped to create constructible projects.</p> <p>Projects are ranked by taking into account their overall health condition, customer impact, alignment with WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) such as reliability, safety, financial or environmental risk and additional drivers and benefits. In addition to the aforementioned this can include improvements in power quality, system loss reduction (voltage conversion), operational flexibility, accessibility to operate and maintain, ability to address future system growth or restoration needs, and regulatory compliance. The greater the customer impact or the more drivers or benefits that are attributed to a project the higher its priority.</p> <p>Investments in System Service and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 8 out of 16. Refer to Table 4-22 of the DSP for further details.</p>

Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)

All pole line sections under this project have been identified as being in poor condition and in need of replacement. In light of this fact, WNH considered the following alternatives:

- a) Do Nothing** - this option results in the perpetuation of operational issues, increased risk of safety incidents, and further deterioration resulting in a decrease in reliability, and is therefore not considered appropriate.
- b) Refurbish the Lines** - these line sections are not appropriate candidates for refurbishment as most poles are too short and structurally too weak to comply with today's safety standards as required by O. Reg. 22/04
- c) Replace the Lines with Underground Lines** - in most situations overhead line burial is technically feasible but often cost prohibitive. WNH's typical line burial costs range between 5x (for local single phase lines) to 10x (for three phase trunk circuits) the equivalent overhead rebuild costs. Due to cost impacts this option is not considered feasible.
- d) Replace Like for Like to New Standards** - this is the preferred option for those line sections already operating at their ultimate planned voltage (all subprojects except for 41 and 73). Today's safety standards require same class and height of poles for 8kV as for higher voltage systems and certain 8kV components are no longer available from manufacturers as they are considered obsolete technology. For all these reasons, the Replace Like for Like option is not considered appropriate nor technically feasible for lines presently operating at 8kV (subprojects 41 and 73).
- e) Replace Like for Like with Provisions for Operation at Higher Voltages** - this option allows for replacement of aged or unsafe equipment, allows for ultimate conversion to higher operating voltage with minimal equipment change when conversion takes place, ultimately eliminates the need for expensive station upgrades, provides operational flexibility by ultimately harmonizing the system voltage, improves power quality from a voltage performance point of view, and is therefore, the preferred option for subprojects 41 and 73.

Effect on system operation efficiency and cost effectiveness (first bullet) The renewal of sub project numbers 41 and 73 will ultimately permit the operation of lines at 27.6kV, which will increase flexibility of the system as a whole in outage scenarios and day to day switching. It will also contribute to a small reduction of line loss on the system.

Net benefits accruing to customers (second bullet) The renewal of this infrastructure will have the following benefits: the aversion of potentially adverse effects on reliability and safety, avoidance of an increase to maintenance costs, ultimately provide for increased flexibility of the system via harmonization of the distribution voltages, a small decrease in line losses, and a small increase in capacity for connection of DERs.

Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet) These projects ensure the elimination of safety hazards and that reliability is maintained. Additionally, the standards to which pole lines must be built today compared to the existing pole lines ensures they are able to withstand more adverse weather conditions and increases the clearances around the conductors to assist in both the frequency and duration of outages.

Scheduling Alternatives System Renewal investments are instrumental in reducing the risk of critical asset failures, maintaining reliability and safety performance measures and keeping expensive reactive maintenance activities to a minimum.

Scheduling changes within the calendar year due to weather, coordination with third parties and resource constraints can usually be accommodated for smaller projects. Rescheduling larger projects can increase costs due to the reassignment of labour and materials and the risk of asset failure. WNH evaluates the risk and cost of rescheduling any project to achieve the most cost effective outcome.

Ownership and/or Funding Alternatives These projects are constructed in the public right-of-way and will consist solely of WNH's assets. There are no ownership or funding alternatives.

Safety (5.4.3.2.B.2)

The new construction standards make work on pole lines much safer for all workers due to increased separation of high voltage conductors between themselves as well as from low voltage conductors. The replacement also minimizes the risk of unexpected pole failures in these areas, decreasing risk to the public.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

WNH will meet with the area Utility Coordinating Council and municipal staff (where applicable) as well as third party stakeholders to exchange project details to coordinate construction. Since these are 2021 projects, this coordination will most likely occur in Q3-Q4 2020.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

New lines generally incorporate larger conductor, increased strength, and where available, higher voltages. As a result, system is better able to withstand poor weather conditions; provide increased capacity and siting options for the connection of renewable energy generation, electric vehicles, energy storage; provide increased physical space for third party communications and smart grid devices; and reduce power quality issues and losses.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Relationship between the Characteristics of Targeted Assets and the Consequences of Asset Failure (5.4.3.2.C.b.first bullet)

Asset Performance Targets and Asset Lifecycle Optimization Policies and Practices (5.4.3.2.C.b.first bullet.first dash)

The majority of the poles, conductors and equipment have been found to be in poor condition by WNH's ACA program and past their TUL.

Asset Condition Relative to Typical Life Cycle (5.4.3.2.C.b.first bullet.second dash)

The majority of the poles, conductors and equipment are past their TUL of 45 years and generally in poor condition. Intermixed, there may be poles that are newer but lack the required height and structural strength to meet today's safety standards required by O. Reg. 22/04. Pole lines are evaluated in their entirety when being considered for replacement.

Number of Customers in Each Class Potentially Affected (5.4.3.2.C.b.first bullet.third dash)

This project affects 3245 residential customers, 52 generation customers, 250 small commercial customers and 40 large commercial customers.

Quantitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fourth dash)

Quantitative customer impact and risk are not available. WNH is working with vendors of existing software platforms (OMS, AMI, and CIS) to develop data capture capabilities to be integrated with METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN. This process is expected to be substantially completed before WNH's next cost of service filing.

Qualitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fifth dash)

The renewal of these assets will ensure future level of reliability is maintained, eliminate safety issues and allow for increased flexibility of the operation of the grid. All of this will maintain or improve customer satisfaction.

Value of Customer Impact (5.4.3.2.C.b.first bullet.sixth dash)

Customer impact in terms of potential failure is medium. These projects supply a mix of residential, commercial, industrial and farm services. Although costs of repair of failed assets are high, the problem can be located quickly, and the risk of prolonged outages is low.

Other Factors Affecting Project Timing (5.4.3.2.C.b.second bullet)

There are no factors that may affect the timing of the proposed projects that have not already been addressed above.

Consequences for System O&M costs (5.4.3.2.C.b.third bullet)

There will be no immediate material impact to O&M costs for distribution lines. Without these projects, assets will transition from poor condition to failure, increasing future O&M costs.

Reliability and Safety Factors (5.4.3.2.C.b.fourth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.B.2 above.

Analysis of Project Benefits, Cost, Alternatives and Timing (5.4.3.2.C.b.fifth bullet)

The projects identified are in poor condition, near or past their TUL. Further deferral carry an increased risk of negative impacts to safety and reliability. Alternatives selected where additional benefits cannot be readily quantified do not come at significant cost increases.

Like for Like Renewal Analysis (5.4.3.2.C.b.sixth bullet)

Projects in this category fall as closely as possible to the Like for Like definition given the technical obsolescence of 8kV components. Alternatives selected where additional benefits cannot be readily quantified do not come at significant cost increases.

General Information on the project/program (5.4.3.2.A)

Project Name	Underground Line Renewal																		
OEB Investment Category	System Renewal																		
Project Description	<p>This project category is comprised of direct buried underground lines, transformers and switches approaching or past their typical useful life (TUL).</p> <p>These lines and associated equipment were originally installed between late 1970's and mid 1980's. At the time of initial installation, WNH followed a common practice of placing normal overhead transformers in below-grade vaults. Over the years this has proven to have several serious shortcomings, including safety risks for the crews due to the placement of exposed high voltage transformer connections, frequent failures of the transformers due to water and moisture issues causing premature corrosion as well as associated environmental concerns with oil leaks due to rusted transformers. Many are located in sidewalks and boulevards where physical deterioration can present a public safety hazard. The replacement of these assets is being planned as they are costly and time consuming to repair on a reactive basis.</p> <p>The project scope includes design, construction and installation of new primary cables in conduits as well as replacement of existing below grade transformers with padmounted style ones, resulting in improved reliability as well as safety. Section 2.1.1.1 of the DSP describes the plan to pace WNH's direct buried underground cable replacements. This approach was developed to lower the risk to WNH as the timing of asset failure is never a certainty and with a large approaching population of assets near end-of-life, even a small sudden change in failure rates could be overwhelming.</p> <p>The new underground primary system will be converted from existing voltages to 27.6 kV as part of the overall system planning strategy. Rebuilds in the Northlake area have already been started and support the system need to offload Scheifele B Transformer Station as described in the WNH System Supply Capacity Study (Appendix J of the DSP). As construction and conversion from 13.8kV to 27.6kV proceeds, the looped supplies on the 13.8kV side are severed and the project must continue until new looped supplies are re-established at the 27.6kV system level. Rebuilds in the Golf Course area support rebuild and voltage conversion of an 8.32kV pole line to 27.6kV, which in turn enhances contingency options for supplying one of WNH's distribution stations.</p>																		
Detailed Listing of Affected Line Sections	<p>The following individual projects are covered by this project category:</p> <table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN09</td><td>24</td><td>Northlake - Phase 3 (Area 4)</td><td>\$1,054,932</td></tr><tr><td>06EN09</td><td>26</td><td>Golf Course Rd Voltage Conversion</td><td>\$380,515</td></tr><tr><td colspan="3">Total</td><td>\$ 1,435,447</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN09	24	Northlake - Phase 3 (Area 4)	\$1,054,932	06EN09	26	Golf Course Rd Voltage Conversion	\$380,515	Total			\$ 1,435,447
WNH Project	Sub Project	Project Name	Total																
06EN09	24	Northlake - Phase 3 (Area 4)	\$1,054,932																
06EN09	26	Golf Course Rd Voltage Conversion	\$380,515																
Total			\$ 1,435,447																
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$1,435,447																	
	O&M Costs (if applicable)	\$0 Not Applicable																	
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																	
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	406																	
	Customer Load (peak KVA)	1,189																	
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Apr-2021																	
	Expected In-Service Date	Dec-2021																	
	Expenditure Timing																		
	2021 Q1	10%	\$143,545																
	2021 Q2	30%	\$430,634																
	2021 Q3	30%	\$430,634																
	2021 Q4	30%	\$430,634																
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	<p>There will be no significant schedule risks anticipated since work in these neighbourhoods has already started with no issues. However, there is a risk of scope increase due to condition of secondary cable triggering spot replacement. Further field investigations are required, however, based on work done in this neighbourhood in 2019, it appears that some of the newer secondary cables may be in worse condition than older ones. Given that this is an anticipated risk, WNH is prepared to address this with additional contract resources.</p>																		
Comparative Information (5.4.3.2.A.sixth bullet)	<p>Comparable investments in previous years are as follows:</p> <table><tr><td>2016:</td><td>\$1,536,029</td><td rowspan="5">The historical years are representative of typical expenditures. 2021 projects, although budgeted lower, carry a risk of scope increase due to the condition of secondary conductor.</td></tr><tr><td>2017:</td><td>\$1,602,516</td></tr><tr><td>2018:</td><td>\$1,630,817</td></tr><tr><td>2019:</td><td>\$1,953,607</td></tr><tr><td>2020:</td><td>\$1,770,943</td></tr></table>			2016:	\$1,536,029	The historical years are representative of typical expenditures. 2021 projects, although budgeted lower, carry a risk of scope increase due to the condition of secondary conductor.	2017:	\$1,602,516	2018:	\$1,630,817	2019:	\$1,953,607	2020:	\$1,770,943					
2016:	\$1,536,029	The historical years are representative of typical expenditures. 2021 projects, although budgeted lower, carry a risk of scope increase due to the condition of secondary conductor.																	
2017:	\$1,602,516																		
2018:	\$1,630,817																		
2019:	\$1,953,607																		
2020:	\$1,770,943																		
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																		
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																		

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The assets targeted by this program are direct buried cables near end of typical useful life. In Northlake additional drivers include age and condition of existing below grade transformers and termination connection accessories.
Related Objectives/Performance Targets	WNH Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>The majority of the proposed work involves the replacement of approximately 7.1 km of direct buried XLPE primary cables approaching poor condition along with associated transformers and devices. The submersible transformers, vaults and devices have also been found to be physically deteriorating due to salt and corrosion. Many are located in sidewalks and boulevards where physical deterioration can present a public safety hazard. The replacement of these assets is being planned as they are costly and time consuming to repair on a reactive basis.</p> <p>WNH has total 138 km directly buried primary cable with 35.5 km of directly buried cable approaching poor condition. WNH looks beyond the 5-year forecast period to determine the rate of approaching asset replacements and develops a pace of replacement that attempts to levelize capital expenditures and resources. At the proposed pace, it will take 17 years in order for completely replace the total population of the directly buried cables. This approach lowers the risk to WNH as the timing of asset failure is never a certainty and with a large population of assets approaching end-of-life, even a small sudden change in failure rates could be overwhelming.</p> <p>Please refer to Section 2.1.1.1 of the DSP for additional details as well as Section 3.1 of the DSP for WNH's asset management process.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary drivers for this program are operational efficiency and restoration of reliability standards.
Related Objectives/Performance Targets	WNH Strategic Imperatives 6 (Organizational Effectiveness) & 1 (Supply & Reliability) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>The new underground primary system will be converted from existing voltages to 27.6 kV as part of the overall system planning strategy. WNH incorporates voltage conversion as part of the renewal program where appropriate. Distribution systems at higher voltages increase load transfer capability to improve reliability of supply and allow a higher penetration of distributed energy resources.</p> <p>Rebuilds in the Northlake area have already been started and support the system need to offload Scheifele B Transformer Station as described in the WNH System Supply Capacity Study (Appendix J of the DSP). As construction and conversion from 13.8kV to 27.6kV proceeds, the looped supplies on the 13.8kV side are severed and the project must continue until new looped supplies are re-established at the 27.6kV system level.</p> <p>Rebuilds in the Golf Course Rd area support rebuild and voltage conversion of an 8.32kV pole line to 27.6kV, which in turn enhances contingency options for supplying one of WNH's distribution stations.</p> <p>Please refer to Section 3.1 of the DSP for further details on WNH's asset management process.</p>
Good Utility Practice (5.4.3.2.B.1.b)	<p>Replacing deteriorated assets with those that meet today's standards improves safety, maintains reliability, increases resilience, and facilitates connection of new innovative technologies to the grid.</p> <p>WNH ensures that renewal of underground residential subdivisions allows for a flexible and resilient distribution system that also supports future growth. This includes considerations such as primary loops (installed or provisioned for future), sizing of equipment to meet current and any future loads, careful selection of equipment placement in a location that is accessible and easy to maintain, and alignment with long term system needs including securing of easements.</p>
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>System Renewal assets are prioritized by the health condition of the assets developed through its ACA program. Assets found at risk of imminent failure or high public safety risk are prioritized for immediate replacement.</p> <p>WNH is utilizing METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN to aid in prioritizing asset replacement. Assets flagged for replacement are geospatially grouped to create constructible projects.</p> <p>Projects are ranked by taking into account their overall health condition, customer impact, alignment with WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) such as reliability, safety, financial or environmental risk and additional drivers and benefits. In addition to the aforementioned this can include improvements in power quality, system loss reduction (voltage conversion), operational flexibility, accessibility to operate and maintain, ability to address future system growth or restoration needs, and regulatory compliance. The greater the customer impact or the more drivers or benefits that are attributed to a project the higher its priority.</p> <p>Investments in System Service and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 7 out of 16. Refer to Table 4-22 of the DSP for further details.</p>

Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)

a) Do Nothing - this option results in the perpetuation of operational issues, increased risk of safety incidents, environmental concerns due to oil leaks, and further deterioration resulting in decrease in reliability. It also would not contribute to addressing greater system needs such as load rebalancing and contingency enhancements, and is therefore not considered appropriate.

b) Replace with Overhead Lines - this option was investigated and considered not viable as it violates conditions applied to subdivision approvals requiring the burial of hydro services, as secured through a legally binding agreement pursuant to the Planning Act that remains binding after the completion of the subdivision. It also is in direct contradiction to the preferences communicated by customers regarding tree trimming. Adding new overhead lines in previously underground areas with many mature trees increases substantially tree trimming. Approximately 90% of WNH customers would like to see same or less tree trimming as detailed in the Customer Engagement Survey Report in Appendix L of the DSP.

c) Refurbish the Lines - WNH considered the option of cable rejuvenation and found that it was not a good fit for this neighbourhood because of the advanced deterioration of the cable as well as a large number of splice locations, some under driveways, considerably driving up rejuvenation and restoration costs. Through the analysis of this option, WNH also learned that the initial cable installation consisted of unjacketed cable, which over time resulted in deterioration of the neutral conductors. In addition, this option would perpetuate operational, safety, environmental, efficiency, and reliability risks associated with below-grade transformers. It also would not contribute to addressing greater system needs such as load rebalancing and contingency enhancements, and for these reasons, was not considered appropriate.

d) Replace Like for Like to New Standards - Today's standard for WNH underground construction call for use of padmounted transformers. This option adequately addresses the operational, safety, environmental, and reliability risks, but it does not contribute to better utilization of existing 27.6kV capacity and does not align with long term system plans. It is important to note that for WNH, the costs for renewal of underground infrastructure in residential subdivisions is approximately the same for 27.6kV as for 13.8kV. A number of years ago, WNH surveyed the marketplace and concluded that it was cheaper to standardize on 27.6kV cable and use it in 13.8kV applications than to buy separate quantities of each. Hence, WNH only stocks 28kV class underground cable and associated terminations. This is not the preferred option as it fails to reap the benefits of operation at 27.6kV voltage at no additional cost and it does not align with long term system plans.

e) Replace Like for Like at Higher Operating Voltages - this option adequately addresses the operational, safety, environmental, reliability, efficiency, and system needs and is the preferred solution.

Effect on system operation efficiency and cost effectiveness (first bullet) The replacement of below-grade transformers is expected to have a positive effect on the efficiency of operations in this neighbourhood for day to day switching as well as during unplanned outage scenarios. This is because WNH must follow extra steps to address safety concerns with exposed high voltage connections in below-grade transformers that are not required for switching padmounted transformers. As the below-grade transformers are often submersed in water, extra time is needed to deal with this concern when connection changes at a transformer are needed, especially in colder months when the water freezes.

Renewal of the subdivisions at 27.6kV will make more efficient use of capacity available at this voltage, reduce losses, address greater system needs such as load rebalancing and contingency enhancements.

Net benefits accruing to customers (second bullet) The renewal of this infrastructure will have the following benefits: reduction of the number and duration of outages, improvements in operational efficiency due to removal of extra steps required to deal with safety risks of below-grade transformers, avoidance of an increase to maintenance costs, better utilization of existing infrastructure, a decrease in line losses, and reduced environmental risks due to oil spills from leaky rusty below grade transformers.

Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet) Many existing aging below-grade transformers have experienced failing primary and secondary connection accessories due to exposure to water and moisture. Accessing those connection points for repair is normally time consuming as described above. The renewal of this infrastructure is expected to have a positive effect on reliability to the customers in these subdivisions.

Scheduling Alternatives System Renewal investments are instrumental in reducing the risk of critical asset failures, maintaining reliability and safety performance measures and keeping expensive reactive maintenance activities to a minimum.

Scheduling changes within the calendar year due to weather, coordination with third parties and resource constraints can usually be accommodated for smaller projects. Rescheduling larger projects can increase costs due to the reassignment of labour and materials and the risk of asset failure as well as defers immediate benefits to the system and to customers. WNH evaluates the risk and cost of rescheduling any project to achieve the most cost effective outcome.

Ownership and/or Funding Alternatives These projects are constructed in the public right-of-way and will consist solely of WNH's assets. There are no ownership or funding alternatives.

Safety (5.4.3.2.B.2)

All pad mounted transformers built to CSA Standards have no exposed live components. Replacing below-grade overhead type transformers with pad mounted transformers mitigates electrical contact risk and increases operational safety to utility workers.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

WNH meets with the area Utility Coordinating Council and municipal staff (where applicable) as well as third party stakeholders to exchange project details to coordinate construction. As portions this projects have already started prior to 2021, this coordination is on-going.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

This project is in direct support of the WNH short term and long term system needs. If full replacement of secondary service conductors becomes a part of this project, new residential services are designed with capacity and capability to permit behind the meter customer generation and electric vehicle charging. Each new service to a residential building is sized 200A to facilitate customer load growth.

Environmental Benefits (5.4.3.2.B.5)

Reduced risk of oil spills due to leaking transformers.

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Relationship between the Characteristics of Targeted Assets and the Consequences of Asset Failure (5.4.3.2.C.b.first bullet)

Asset Performance Targets and Asset Lifecycle Optimization Policies and Practices (5.4.3.2.C.b.first bullet.first dash)

Section 2.1.1.1 of the DSP describes the plan to pace WNH's direct buried underground cable replacements. This approach was developed to lower the risk to WNH as the timing of asset failure is never a certainty and with a large population of assets approaching end-of-life, even a small sudden change in failure rates could be overwhelming. Thoughtfully paced asset replacement strategy is the only viable alternative.

Asset Condition Relative to Typical Life Cycle (5.4.3.2.C.b.first bullet.second dash)

Some assets planned for replacement in this program are deteriorated beyond repair and in some cases contain critical design flaws. These factors pose failure and safety risks to the system, customers, and field crews. This will continue to drive O&M costs if not addressed.

Number of Customers in Each Class Potentially Affected (5.4.3.2.C.b.first bullet.third dash)

This project affects 401 residential customers, 5 small commercial customers.

Quantitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fourth dash)

Quantitative customer impact and risk are not available. WNH is working with vendors of existing software platforms (OMS, AMI, and CIS) to develop data capture capabilities to be integrated with METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN. This process is expected to be substantially completed before WNH's next cost of service filing.

Qualitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fifth dash)

The renewal of this section of line will ensure that the number and duration of outages are reduced, future level of reliability is maintained, eliminate safety issues, make efficient use of existing infrastructure, and support future system needs. All of this will maintain or improve customer satisfaction.

Value of Customer Impact (5.4.3.2.C.b.first bullet.sixth dash)

Customer impact in terms of potential failure is medium. Even though this area is predominately residential and loss of economic productivity is not a significant factor, asset failures are often hard to find, cannot be repaired quickly (require excavation, emergency locates, etc.) and therefore, lead to prolonged outages.

Other Factors Affecting Project Timing (5.4.3.2.C.b.second bullet)

Subproject 24 is part of a multi-year program to rebuild and convert the Lakeshore North subdivision to 27.6kV. Delays in the 2020 portion of the work may be added to the scope of the 2021 work. Subproject 26 must be done in tandem with the rebuild of Sawmill Rd described in Overhead Renewal (8kV) program.

Consequences for System O&M costs (5.4.3.2.C.b.third bullet)

There will be no immediate material impact to O&M costs for distribution lines. Without these projects taking place, O&M costs are expected to rise over time at an increasing rate due to increase of below-grade transformer failures, oil spills, and associated environmental cleanup costs.

Reliability and Safety Factors (5.4.3.2.C.b.fourth bullet)

Without these projects, assets will transition from poor condition to failure increasing system interruptions and customer outage minutes. Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.B.2 above.

Analysis of Project Benefits, Cost, Alternatives and Timing (5.4.3.2.C.b.fifth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d above. Alternatives selected where additional benefits cannot be readily quantified do not come at significant cost increases.

Like for Like Renewal Analysis (5.4.3.2.C.b.sixth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d above.

General Information on the project/program (5.4.3.2.A)

Project Name	Overhead Line Renewal - Failing Conductor																							
OEB Investment Category	System Renewal																							
Project Description	<p>This project category is comprised of overhead lines that pose a safety risk and are in poor condition. These lines have small conductors which have a tendency to become brittle as they age and fail prematurely, especially during storms. Such failures result in significant safety risk to workers and general public such as energization of the earth near the fallen conductor (which could lead to electrocution of any person or livestock nearby), fire on the ground as well as at the pole, and falling debris due to fire.</p> <p>These lines are also in need of complete replacement due to their age (early 1960's to late 1980's), condition, or inadequacy to meet today's standards. In 2021, the program consists of 3 individual projects involving the replacement of 89 poles, 30 transformers and 5.8 km of overhead line. The lines being replaced have 35 customers directly connected to them.</p> <p>The project scope includes design, construction and installation of new taller poles framed to conform to O. Reg. 22/04 compliant standards as well as new wire, insulators, transformers and equipment. Newer construction standards and materials provide for more weather resilient assets to help maintain safety and reliability.</p> <p>Projects within this program are prioritized based on condition of the assets from WNH's 2019 ACA results. Projects are scheduled and executed over the course of the year based on coordination with third parties and available resources. Overall this program is prioritized and paced in coordination with WNH's overall Capital Investment Plan.</p>																							
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																							
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN04</td><td>29</td><td>Floradale Rd - Arthur St to Cedar Spring</td><td>\$406,813</td></tr><tr><td>06EN04</td><td>30</td><td>Lerch Rd - Downstream of Tx 7693</td><td>\$128,417</td></tr><tr><td>06EN04</td><td>31</td><td>Maryhill Rd - Crowsfoot Rd to FC-8-826</td><td>\$318,757</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 853,987</td></tr></table>				WNH Project	Sub Project	Project Name	Total	06EN04	29	Floradale Rd - Arthur St to Cedar Spring	\$406,813	06EN04	30	Lerch Rd - Downstream of Tx 7693	\$128,417	06EN04	31	Maryhill Rd - Crowsfoot Rd to FC-8-826	\$318,757			Total	\$ 853,987
WNH Project	Sub Project	Project Name	Total																					
06EN04	29	Floradale Rd - Arthur St to Cedar Spring	\$406,813																					
06EN04	30	Lerch Rd - Downstream of Tx 7693	\$128,417																					
06EN04	31	Maryhill Rd - Crowsfoot Rd to FC-8-826	\$318,757																					
		Total	\$ 853,987																					
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$853,987																						
	O&M Costs (if applicable)	\$0 Not Applicable																						
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																						
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	35																						
	Customer Load (peak KVA)	128																						
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	May-2021																						
	Expected In-Service Date	Nov-2021																						
	Expenditure Timing	<table><tr><td>2021 Q1</td><td>20%</td><td>\$170,797</td></tr><tr><td>2021 Q2</td><td>30%</td><td>\$256,196</td></tr><tr><td>2021 Q3</td><td>30%</td><td>\$256,196</td></tr><tr><td>2021 Q4</td><td>20%</td><td>\$170,797</td></tr></table>			2021 Q1	20%	\$170,797	2021 Q2	30%	\$256,196	2021 Q3	30%	\$256,196	2021 Q4	20%	\$170,797								
2021 Q1	20%	\$170,797																						
2021 Q2	30%	\$256,196																						
2021 Q3	30%	\$256,196																						
2021 Q4	20%	\$170,797																						
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	These projects have no significant risk factors associated with their execution. As some of these projects are located within narrow right of ways, negotiations for anchoring easements on private properties may be required. This is a factor that is identified early in the design process to ensure sufficient time is available for coordination with land owners.																							
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																							
	2016:	\$30,618	2016 expenditures were unusually low. Please see Section 4.3.4 of the DSP for an explanation. In 2018, through asset inspection programs, additional segments of rural lines with failing conductor were identified and program expenditures increased to \$900,000 per year. One of the planned 2019 projects started very late in the year and is being completed in 2020.																					
	2017:	\$405,673																						
	2018:	\$312,801																						
	2019:	\$647,791																						
	2020:	\$1,245,812																						
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																							
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																							

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for these project is the increased safety risk due to premature conductor failure.
Related Objectives/Performance Targets	WNH Strategic Imperative 2 (Health, Safety, & Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Field inspections, asset condition data, and WNH prior experience with conductors falling to the ground (consistent with experience of other LDCs in Ontario).
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary driver for these projects is the age and condition of the existing plant.
Related Objectives/Performance Targets	WNH Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>The source of the information used to justify this investment is the ACA, as further detailed in Appendix A of the DSP. WNH's ACA program uses asset degradation factors such as age, pole treatment, inspection and testing data to develop a Health Index (HI) for each of its pole assets. The HI is converted into a condition rating that can range from Very Good to Very Poor. Assets in Poor and Very Poor condition are identified and grouped into executable projects.</p> <p>Most of the infrastructure being replaced was originally put in service from early 1960's, with some poles replaced in the early 80's. The older poles have been identified through regular inspection as being in poor condition. The newer poles lack the required height and structural strength for accommodating a larger wire and meeting today's standards, and must also be replaced. The combination of the primary and secondary drivers adds a level of urgency to this specific category of projects.</p>
Good Utility Practice (5.4.3.2.B.1.b)	<p>WNH utilizes Utility Standards Forum design standards. These standards are based on CSA C22.3 No 1-15 Overhead Systems Heavy Weather Loading design standards. Newer construction standards and materials provide for more weather resilient assets to help maintain safety and reliability. WNH overhead designs facilitates the future incorporation of grid modernization equipment and renewable energy generation. WNH conducts annual inspection and testing programs, evaluates the results and reprioritizes the replacement of assets if required.</p> <p>For these projects, conductor condition is the main driver, however, other assets such as poles, transformers, insulators, arrestors are also replaced. These assets are nearing end of life and would not normally survive a second life cycle. Replacing these assets all at the same time is more cost effective and less disruptive than waiting until individual assets fail or reach end of life.</p>
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>System Renewal assets are prioritized by the health condition of the assets developed through its ACA program. Assets found at risk of imminent failure or high public safety risk are prioritized for immediate replacement.</p> <p>WNH is utilizing METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN to aid in prioritizing asset replacement. Assets flagged for replacement are geospatially grouped to create constructible projects.</p> <p>Projects are ranked by taking into account their overall health condition, customer impact, alignment with WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) such as reliability, safety, financial or environmental risk and additional drivers and benefits. In addition to the aforementioned this can include improvements in power quality, system loss reduction (voltage conversion), operational flexibility, accessibility to operate and maintain, ability to address future system growth or restoration needs, and regulatory compliance. The greater the customer impact or the more drivers or benefits that are attributed to a project the higher its priority.</p> <p>Investments in System Service and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 3 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>All pole line sections under this project have been identified as posing a safety risk to workers and general public, being at the end of their useful life, and in need of replacement. In light of this fact, WNH considered the following alternatives:</p> <p>a) Do Nothing - this option results in an increased risk of serious safety incidents and further deterioration in reliability. Given the severity of the safety risks to general public, the Do Nothing option could be considered negligent, and for all these reasons, is not considered appropriate.</p> <p>b) Refurbish the Lines - these line sections are not appropriate candidates for refurbishment as most poles are too short and structurally too weak to comply with today's safety standards as required by O. Reg. 22/04.</p> <p>c) Replace the Lines with Underground Lines - in most situations overhead line burial is technically feasible but often cost prohibitive. WNH's typical line burial costs range between 5x (for local single phase lines) to 10x (for three phase trunk circuits) the equivalent overhead rebuild costs. Due to cost impacts this option is not considered feasible.</p> <p>d) Replace Like for Like to New Standards - this option would perpetuate the premature conductor failure issues in the future. Today's safety standards require same class and height of poles for 8kV as for higher voltage systems and certain 8kV components are no longer available from manufacturers as they are considered obsolete technology. Overall material costs of 8kV systems are in line with 27.6kV systems. For these reasons, the Replace Like for Like option is not considered appropriate nor technically feasible for lines presently operating at 8kV.</p> <p>e) Replace Like for Like with Provisions for Operation at Higher Voltages - this option allows for replacement of aged or unsafe equipment, allows for ultimate conversion to higher operating voltage with minimal equipment change when conversion takes place, ultimately eliminates the need for expensive station upgrades, provides operational flexibility by ultimately harmonizing the system voltage, improves power quality from a voltage performance point of view, and is therefore, the preferred option for subprojects 29 and 31.</p> <p>f) Replace Like for Like at Higher Operating Voltages - this option allows for replacement of aged or unsafe equipment, allows for conversion to higher operating voltage, ultimately eliminates the need for expensive station upgrades, provides operational flexibility by harmonizing the system voltage, improves power quality from a voltage performance point of view, and is therefore, the preferred option for subproject 30.</p>
Effect on system operation efficiency and cost effectiveness (first bullet)	The installation of larger conductors allows WNH better control of the voltage regulation on these lines, and hence, improves the power quality to all customers supplied by these lines through better voltage performance at each customer connection point. In addition, where higher operating voltages are available, the line renewal is planned to be done at the higher operating voltage (27.6kV as appropriate), which increases flexibility of the system as a whole in outage scenarios and day to day switching and contributes to a small reduction of line loss on the system.

Net benefits accruing to customers (second bullet)	The renewal of this infrastructure will have the following benefits: the aversion of potentially adverse effects on reliability and safety, avoidance of an increase to maintenance costs, ultimately provide for increased flexibility of the system via harmonization of the distribution voltages, a small decrease in line losses, and a small increase in capacity for connection of DERs.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	These projects ensure the elimination of safety hazards and that reliability is maintained. Additionally, the standards to which pole lines must be built today compared to the existing pole lines ensures they are able to withstand more adverse weather conditions and increases the clearances around the conductors to assist in both the frequency and duration of outages.
Scheduling Alternatives	<p>System Renewal investments are instrumental in reducing the risk of critical asset failures, maintaining reliability and safety performance measures and keeping expensive reactive maintenance activities to a minimum.</p> <p>Scheduling changes within the calendar year due to weather, coordination with third parties and resource constraints can usually be accommodated for smaller projects. Rescheduling larger projects can increase costs due to the reassignment of labour and materials and the risk of asset failure as well as defers immediate improvement to public safety. WNH evaluates the risk and cost of rescheduling any project to achieve the most cost effective outcome.</p>
Ownership and/or Funding Alternatives	These projects are constructed in the public right-of-way and will consist solely of WNH's assets. There are no ownership or funding alternatives.
<u>Safety (5.4.3.2.B.2)</u> The new construction standards make work on pole lines much safer for all workers due to increased separation of high voltage conductors between themselves as well as from low voltage conductors. The replacement also minimizes the risk of unexpected pole failures in these areas, decreasing risk to the public.	
<u>Cyber-security, Privacy (5.4.3.2.B.3)</u> Not Applicable	
<u>Co-ordination, Interoperability (5.4.3.2.B.4)</u>	
Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a) WNH will meet with the area Utility Coordinating Council and municipal staff (where applicable) as well as third party stakeholders to exchange project details to coordinate construction. Since these are 2021 projects, this coordination will most likely occur in Q3-Q4 2020.	
Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b) New lines generally incorporate larger conductor, increased strength, and where available, higher voltages. As a result, system is better able to withstand poor weather conditions; provide increased capacity and siting options for the connection of renewable energy generation, electric vehicles, energy storage; provide increased physical space for third party communications and smart grid devices; and reduce power quality issues and losses.	
<u>Environmental Benefits (5.4.3.2.B.5)</u> Not Applicable	
<u>Conservation and Demand Management (5.4.3.2.B.6)</u>	
Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet) Not Applicable	
Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet) Not Applicable	
How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet) Not Applicable	

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Relationship between the Characteristics of Targeted Assets and the Consequences of Asset Failure (5.4.3.2.C.b.first bullet)

Asset Performance Targets and Asset Lifecycle Optimization Policies and Practices (5.4.3.2.C.b.first bullet.first dash)

A significant number of the poles, conductors and equipment have been found through inspection to be in poor condition and pose a safety hazard, and therefore, are considered no longer fit for the purpose they were intended to do. The conductor used on these line sections is small, which makes it more susceptible for corrosion and brittleness to cause failure compared to larger size conductors of the same vintage.

Asset Condition Relative to Typical Life Cycle (5.4.3.2.C.b.first bullet.second dash)

A significant number of the poles, conductors and equipment are over 40 years of age and generally in poor condition. The poles that are newer lack the required height and structural strength to meet today's safety standards required by O. Reg. 22/04. Hence, these pole lines must be considered in their entirety and are considered past their useful life.

Number of Customers in Each Class Potentially Affected (5.4.3.2.C.b.first bullet.third dash)

These project affects 35 customers in total, which consists of 22 residential customers, 9 commercial customers, and 4 generation customers.

Quantitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fourth dash)

Quantitative customer impact and risk are not available. WNH is working with vendors of existing software platforms (OMS, AML, and CIS) to develop data capture capabilities to be integrated with METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN. This process is expected to be substantially completed before WNH's next cost of service filing.

Qualitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fifth dash)

The renewal of this section of line will ensure future level of reliability is maintained, eliminate safety issues and allow for increased flexibility of the operation of the grid. All of this will maintain or improve customer satisfaction.

Value of Customer Impact (5.4.3.2.C.b.first bullet.sixth dash)

Customer impact in terms of potential failure is high, mostly due to the severity of safety risks associated with conductor failure. Given the history of failures for lines in this project category, the probability of failure is high compared to other line sections. Although costs of repair of failed assets are high, the problem can be located quickly, and the risk of prolonged outages is lower.

Other Factors Affecting Project Timing (5.4.3.2.C.b.second bullet)

There are no factors that may affect the timing of the proposed projects that have not already been addressed above.

Consequences for System O&M costs (5.4.3.2.C.b.third bullet)

There will be no immediate material impact to O&M costs for distribution lines. Without these projects, assets will transition from poor condition to failure, increasing future O&M costs.

Reliability and Safety Factors (5.4.3.2.C.b.fourth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.B.2 above.

Analysis of Project Benefits, Cost, Alternatives and Timing (5.4.3.2.C.b.fifth bullet)

The projects identified are in poor condition, near or past their TUL. There are no risks to execution that have not already been addressed. Further deferral carry an increased risk of negative impacts to safety and reliability. Alternatives selected where additional benefits cannot be readily quantified do not come at significant cost increases.

Like for Like Renewal Analysis (5.4.3.2.C.b.sixth bullet)

Projects in this category cannot fall as closely as possible to the Like for Like replacement as this would perpetuate the premature conductor failure issues in the future. These projects fall as closely as possible to the Like for Like replacement to new standards given the technical obsolescence of 8kV components. Alternatives selected where additional benefits cannot be readily quantified do not come at significant cost increases.

General Information on the project/program (5.4.3.2.A)

Project Name	Overhead Line Renewal (8kV)																		
OEB Investment Category	System Renewal																		
Project Description	<p>This project category is comprised of overhead lines in poor condition and past their typical useful life (TUL). These lines were originally installed in 1960's and have Health Index ratings in the Poor and Very Poor category. These ratings were developed through age, field inspection and pole testing criteria.</p> <p>Presently these lines are operating at 8.32kV, some with small conductors that have shown a tendency to become brittle and fail. Field inspections have determined that complete replacement of the assets is required. As part of the renewal project, WNH will take the opportunity to gain efficiencies uprate the operating voltage to 27.6kV.</p> <p>In 2021, the program consists of 2 individual projects involving the replacement of 111 poles, 26 transformers and 6.1 km of overhead line. The lines being replaced have 230 customers connected to them.</p> <p>The project scope includes design, construction and installation of new taller poles designed to conform to O. Reg. 22/04 compliant standards as well as new wire, insulators, transformers and equipment. Newer construction standards and materials provide for more weather resilient assets to help maintain safety and reliability.</p>																		
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																		
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN04</td><td>10</td><td>Hutchinson Rd - William Hastings to EOL</td><td>\$125,543</td></tr><tr><td>06EN04</td><td>57</td><td>Sawmill Rd - Golf Course Rd to Katherine St</td><td>\$577,533</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 703,076</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN04	10	Hutchinson Rd - William Hastings to EOL	\$125,543	06EN04	57	Sawmill Rd - Golf Course Rd to Katherine St	\$577,533			Total	\$ 703,076
WNH Project	Sub Project	Project Name	Total																
06EN04	10	Hutchinson Rd - William Hastings to EOL	\$125,543																
06EN04	57	Sawmill Rd - Golf Course Rd to Katherine St	\$577,533																
		Total	\$ 703,076																
Capital Investment (5.4.3.2.A.first bullet)	Total Capital \$703,076																		
	O&M Costs (if applicable) \$0 Not Applicable																		
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution \$0																		
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#): 230 Customer Load (peak KVA) 919																		
Project Timing (5.4.3.2.A.fourth bullet)	Start Date Jan-2021 Expected In-Service Date Dec-2021 Expenditure Timing 2021 Q1 40% \$281,230 2021 Q2 25% \$175,769 2021 Q3 25% \$175,769 2021 Q4 10% \$70,308																		
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	These projects have no significant risk factors associated with their execution. As some of these projects are located within narrow right of ways, negotiations for anchoring easements on private properties may be required. This is a factor that is identified early in the design process to ensure sufficient time is available for coordination with land owners.																		
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows: <table><tr><td>2016:</td><td>\$1,514,370</td><td rowspan="5">The effort of 8kV overhead line renewal and upgrade to 27.6kV was consistent is the past. The increase in the capital expense in 2020 is because of the decommissioning of one 8 kV rural station in WNH service territory, which results of accelerate 8kV line upgrade to 27.6kV.</td></tr><tr><td>2017:</td><td>\$1,527,537</td></tr><tr><td>2018:</td><td>\$2,148,877</td></tr><tr><td>2019:</td><td>\$1,970,758</td></tr><tr><td>2020:</td><td>\$3,252,494</td></tr></table>			2016:	\$1,514,370	The effort of 8kV overhead line renewal and upgrade to 27.6kV was consistent is the past. The increase in the capital expense in 2020 is because of the decommissioning of one 8 kV rural station in WNH service territory, which results of accelerate 8kV line upgrade to 27.6kV.	2017:	\$1,527,537	2018:	\$2,148,877	2019:	\$1,970,758	2020:	\$3,252,494					
2016:	\$1,514,370	The effort of 8kV overhead line renewal and upgrade to 27.6kV was consistent is the past. The increase in the capital expense in 2020 is because of the decommissioning of one 8 kV rural station in WNH service territory, which results of accelerate 8kV line upgrade to 27.6kV.																	
2017:	\$1,527,537																		
2018:	\$2,148,877																		
2019:	\$1,970,758																		
2020:	\$3,252,494																		
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																		
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																		

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for these projects are the age and condition of the existing plant.
Related Objectives/Performance Targets	WNN Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>The source of the information used to justify this investment is the ACA, as further detailed in Appendix A of the DSP. These lines were originally installed between 1950's and 1960's and vast majority have Health Index ratings in the Poor and Very Poor category. These ratings were developed through WNN's 2019 ACA results..</p> <p>WNN's ACA program uses asset degradation factors such as age, pole treatment, inspection and testing data to develop a Health Index (HI) for each of its pole assets. The HI is converted into a condition rating that can range from Very Good to Very Poor. Assets in Poor and Very Poor condition are identified and grouped into executable projects. Projects are evaluated through the WNN asset management and prioritization process described in Section 3.1 and Section 4.2.2 of the DSP.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary driver is upgrading these lines to higher and more efficient operating voltages.
Related Objectives/Performance Targets	WNN Strategic Imperatives 5 (Productivity and Cost Reduction) & 6 (Organizational Effectiveness) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>Upgrading lines to higher more efficient voltages provides for increased flexibility of the system via harmonization of distribution voltages, a small decrease inline losses, a small increase in capacity for connection of DERs, and improved power quality from a voltage performance point of view. Over time, each project under this category contributes to the ultimate retirement of distribution transformer stations that may otherwise be in need of expensive upgrades.</p> <p>Please refer to Section 3.1 of the DSP for further details on WNN's asset management process.</p>
Good Utility Practice (5.4.3.2.B.1.b)	<p>WNN utilizes Utility Standards Forum design standards. These standards are based on CSA C22.3 No 1-15 Overhead Systems Heavy Weather Loading design standards. Newer construction standards and materials provide for more weather resilient assets to help maintain safety and reliability. WNN overhead designs facilitates the future incorporation of grid modernization equipment and renewable energy generation. WNN conducts annual inspection and testing programs, evaluates the results and reprioritizes the replacement of assets if required.</p> <p>Although pole condition is normally the main driver for overhead renewal projects, other assets such as transformers, insulators, wire, arrestors are also replaced as part of pole line rebuild. These assets are nearing end of life and would not normally survive a second life cycle. Replacing these assets all at the same time is more cost effective and less disruptive than waiting until individual assets fail or reach end of life.</p> <p>Projects in this category are also benefiting the operation of the system by eliminating older, inefficient operating voltages, providing better power quality to customers, contributing toward ultimate removal of older and inefficient distribution stations, and aligning with WNN's Long Term System Plans.</p>
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>System Renewal assets are prioritized by the health condition of the assets developed through its ACA program. Assets found at risk of imminent failure or high public safety risk are prioritized for immediate replacement.</p> <p>WNN is utilizing METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN to aid in prioritizing asset replacement. Assets flagged for replacement are geospatially grouped to create constructible projects.</p> <p>Projects are ranked by taking into account their overall health condition, customer impact, alignment with WNN Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) such as reliability, safety, financial or environmental risk and additional drivers and benefits. In addition to the aforementioned this can include improvements in power quality, system loss reduction (voltage conversion), operational flexibility, accessibility to operate and maintain, ability to address future system growth or restoration needs, and regulatory compliance. The greater the customer impact or the more drivers or benefits that are attributed to a project the higher its priority.</p> <p>Investments in System Service and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNN Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 6 out of 16. Refer to Table 4-22 of the DSP for further details.</p>

Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)

All pole line sections under this project have been identified as being in poor condition and in need of replacement. In light of this fact, WNN considered the following alternatives:

- a) Do Nothing** - this option results in the perpetuation of operational issues, increased risk of safety incidents, further deterioration resulting in a decrease in reliability, and failure to take the opportunity to address future system needs. Therefore, this option considered not appropriate.
- b) Refurbish the Lines** - these line sections are not appropriate candidates for refurbishment as most poles are too short and structurally too weak to comply with today's safety standards as required by O. Reg. 22/04.
- c) Replace the Lines with Underground Lines** - in most situations overhead line burial is technically feasible but often cost prohibitive. WNN's typical line burial costs range between 5x (for local single phase lines) to 10x (for three phase trunk circuits) the equivalent overhead rebuild costs. Due to cost impacts this option is not considered feasible.
- d) Replace Like for Like to New Standards** - Today's safety standards require same class and height of poles for 8kV as for higher voltage systems and certain 8kV components are no longer available from manufacturers as they are considered obsolete technology. Overall material costs of 8kV systems are in line with 27.6kV systems. For these reasons, the Replace Like for Like option is not considered appropriate nor technically feasible for lines presently operating at 8kV.
- e) Replace Like for Like at Higher Operating Voltages** - this option allows for replacement of aged or unsafe equipment, allows for conversion to higher operating voltage, ultimately eliminates the need for expensive station upgrades, provides operational flexibility by harmonizing the system voltage, improves power quality from a voltage performance point of view, and is therefore, the preferred option.

Effect on system operation efficiency and cost effectiveness (first bullet)	The renewal on this project will permit the operation of lines at 27.6kV, which increases flexibility of the system as a whole in outage scenarios and day to day switching, contributes to a small reduction of line loss on the system, and provides for future system needs. Over time, it supports distribution station retirement to help avoid expensive station upgrades.
Net benefits accruing to customers (second bullet)	The renewal of this infrastructure will have the following benefits: the aversion of potentially adverse effects on reliability and safety, avoidance of an increase to maintenance costs, provide for increased flexibility of the system via harmonization of the distribution voltages, improvement in power quality from a voltage performance point of view, a small decrease in line losses, and a small increase in capacity for connection of DERs.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	The completion of this project is expected to have a positive effect on reliability over time for the following reasons: a) voltage harmonization allowing greater flexibility in responding to distribution system events b) reduced risk of prolonged outages associated with aged station equipment needing replacement c) pole lines built to today's standards are able to withstand more adverse weather conditions and have increased clearances around the conductors to assist in reducing the frequency and duration of outages.
Scheduling Alternatives	System Renewal investments are instrumental in reducing the risk of critical asset failures, maintaining reliability and safety performance measures and keeping expensive reactive maintenance activities to a minimum. Scheduling changes within the calendar year due to weather, coordination with third parties and resource constraints can usually be accommodated for smaller projects. Rescheduling larger projects can increase costs due to the reassignment of labour and materials and the risk of asset failure as well as defers immediate benefits to the system and to customers. WNH evaluates the risk and cost of rescheduling any project to achieve the most cost effective outcome.
Ownership and/or Funding Alternatives	These projects are constructed in the public right-of-way and will consist solely of WNH's assets. There are no ownership or funding alternatives.
<u>Safety (5.4.3.2.B.2)</u>	
These projects also involve replacement of small conductors which are prone to failure due to brittleness, and presents a hazard to the public and all workers. The failure can result in hazards such as energization of the earth near the fallen conductor potentially electrocuting any person nearby, fire on the ground as well as at the pole, and falling debris due to fire.	
Presently hazards associated with undersized conductors for WNH workers are managed by appropriate safety policies and procedures. The new construction standards make work on pole lines much safer for all workers due to increased separation of high voltage conductors between themselves as well as from low voltage conductors.	
<u>Cyber-security, Privacy (5.4.3.2.B.3)</u>	
Not Applicable	
<u>Co-ordination, Interoperability (5.4.3.2.B.4)</u>	
Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)	
WNH will meet with the area Utility Coordinating Council and municipal staff (where applicable) and third party stakeholders to exchange project details to coordinate construction. Since this is a 2021 project this coordination will most likely occur in Q3-Q4 2020.	
Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)	
New lines generally incorporate larger conductor, increased strength, and higher voltages. As a result, system is better able to withstand poor weather conditions; provide increased capacity and siting options for the connection of renewable energy generation, electric vehicles, energy storage; provide increased physical space for third party communications and smart grid devices; and reduce power quality issues and losses.	
<u>Environmental Benefits (5.4.3.2.B.5)</u>	
Albeit small, these projects may have a positive environmental benefit due to reduction in power generation requirements, and hence greenhouse gases, as follows: a) reduction in losses due to voltage upgrade b) increased capacity for green generation due to voltage upgrade c) provision for sharing transformer station capacity with neighbouring utilities.	
<u>Conservation and Demand Management (5.4.3.2.B.6)</u>	
Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)	
Not Applicable	
Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)	
Not Applicable	
How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)	
Not Applicable	

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Relationship between the Characteristics of Targeted Assets and the Consequences of Asset Failure (5.4.3.2.C.b.first bullet)

Asset Performance Targets and Asset Lifecycle Optimization Policies and Practices (5.4.3.2.C.b.first bullet.first dash)

The majority of the poles, conductors and equipment have been found to be in poor condition by WNH's ACA program and past their TUL.

Asset Condition Relative to Typical Life Cycle (5.4.3.2.C.b.first bullet.second dash)

The majority of the poles, conductors and equipment are past their TUL of 45 years and generally in poor condition. Intermixed, there may be poles that are newer but lack the required height and structural strength to meet today's safety standards required by O. Reg. 22/04. Pole lines are evaluated in their entirety when being considered for replacement.

Number of Customers in Each Class Potentially Affected (5.4.3.2.C.b.first bullet.third dash)

This project affects total 230 customers, 7 small commercial customers, 1 large commercial customer, 2 generation customers and 219 residential customers.

Quantitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fourth dash)

Quantitative customer impact and risk are not available. WNH is working with vendors of existing software platforms (OMS, AML, and CIS) to develop data capture capabilities to be integrated with METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN. This process is expected to be substantially completed before WNH's next cost of service filing.

Qualitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fifth dash)

The renewal of this section of line will ensure future level of reliability is maintained, eliminate safety issues and allow for increased flexibility of the operation of the grid as well as improvements in power quality from a voltage regulation point of view. All of this will maintain or improve customer satisfaction.

Value of Customer Impact (5.4.3.2.C.b.first bullet.sixth dash)

Customer impact in terms of potential failure is low. These line sections supply a mix of residential and farm services. Although costs of repair of failed assets are high, the problem can be located quickly, and the risk of prolonged outages is low.

Other Factors Affecting Project Timing (5.4.3.2.C.b.second bullet)

Subproject 57 must be done in tandem with the rebuild of Golf Course Rd described in Underground Renewal program.

Consequences for System O&M costs (5.4.3.2.C.b.third bullet)

There will be no immediate material impact to O&M costs for distribution lines.

The renewal of the 8kV system as a whole will help reduce equipment failure, eliminate safety hazards, and correct substandard conditions prevalent with this vintage of assets, all of which will help reduce future O&M costs. The elimination of the 8kV system also as a whole will result in increased operational flexibility, increased reliability through greater redundancy and options for the resupply of customers formerly in the 8kV area from 27.6kV sources, reduced line losses, reduced inventory levels and carrying costs, all of which will help reduce O&M costs. Eventually, System O&M resources that were dedicated to the 8kV issues on these lines will be available for other O&M tasks at WNH.

Reliability and Safety Factors (5.4.3.2.C.b.fourth bullet)

There will be no immediate material impact on reliability, however, the 8kV renewal as a whole will help reduce interruptions related to failed equipment. The elimination of safety hazards were considered to be important factors of the project.

Analysis of Project Benefits, Cost, Alternatives and Timing (5.4.3.2.C.b.fifth bullet)

The projects identified are in poor condition, near or past their TUL. There are no risks to execution that have not already been addressed. Further deferral carry an increased risk of negative impacts to safety and reliability. Alternatives selected where additional benefits cannot be readily quantified do not come at significant cost increases.

Like for Like Renewal Analysis (5.4.3.2.C.b.sixth bullet)

Like for Like Renewal was determined not to be appropriate. See Section 5.4.5.2.B.1.c above for further details.

General Information on the project/program (5.4.3.2.A)

Project Name	Reactive Renewal																		
OEB Investment Category	System Renewal																		
Project Description	Reactive renewal projects represent small unplanned projects over the year that consist of assets that are failed, are about to fail, or present a safety hazard to the public. The commonality in these projects is that they are small (typically 5 poles or less), typically have caused an outage or a safety hazard to the general public, require immediate replacement, and for the most part, are unforeseen. These projects typically arise from trouble calls, storm damage, dig-in damage, accidents, fires, etc. as well as information provided from third parties (ESA, customers, communication companies).																		
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																		
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN04</td><td>2</td><td>Storm & Equipment Damage</td><td>\$183,045</td></tr><tr><td>06EN04</td><td>5</td><td>Reactive Renewal</td><td>\$103,095</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 286,140</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN04	2	Storm & Equipment Damage	\$183,045	06EN04	5	Reactive Renewal	\$103,095			Total	\$ 286,140
WNH Project	Sub Project	Project Name	Total																
06EN04	2	Storm & Equipment Damage	\$183,045																
06EN04	5	Reactive Renewal	\$103,095																
		Total	\$ 286,140																
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$286,140																	
	O&M Costs (if applicable)	\$0 Not Applicable																	
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																	
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	Information not available until time of work																	
	Customer Load (peak KVA)	Information not available until time of work																	
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021																	
	Expected In-Service Date	Dec-2021																	
	Expenditure Timing																		
	2021 Q1	25%	\$71,535																
	2021 Q2	25%	\$71,535																
	2021 Q3	25%	\$71,535																
	2021 Q4	25%	\$71,535																
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	A risk with this project is the inherent uncertainty. The investment amount is based on historical investment levels. WNH assigns required internal and/or external resources to have the work completed when the need arises.																		
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																		
	2016:	\$716,750	2016: major ice storm as well as wind storms. The remaining historical years are more representative of typical expenditures with the downward trend expected to continue into 2021.																
	2017:	\$426,202																	
	2018:	\$355,266																	
	2019:	\$331,260																	
	2020:	\$304,485																	
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																		
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																		

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver behind the majority of these projects is the requirement to replace failed assets or end of life assets that were not scheduled for replacement, but due to their present condition must be replaced immediately to ensure that safety and reliability are not further compromised.
Related Objectives/Performance Targets	WNN Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Asset condition at the time of discovery and consequences of not doing anything provide the justification required. Please refer to Section 3.1 of the DSP for further details on WNN's asset management process.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	Good utility practice is to react and respond immediately to remove the public safety hazards and replace damaged assets to meet current safety Code and Standards. Investigate and apply engineering measures to reduce and mitigate the risk of public safety should this type of unforeseeable events occur.
Investment Priority (5.4.3.2.B.1.c)	System Access investments are ranked as top priority, as they are mandated by regulation or code. System Renewal assets are prioritized by the health condition of the assets developed through its ACA program. Assets found at risk of imminent failure or high public safety risk are prioritized for immediate replacement. WNN is utilizing METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN to aid in prioritizing asset replacement. Assets flagged for replacement are geospatially grouped to create constructible projects. Projects are ranked by taking into account their overall health condition, customer impact, alignment with WNN Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) such as reliability, safety, financial or environmental risk and additional drivers and benefits. In addition to the aforementioned this can include improvements in power quality, system loss reduction (voltage conversion), operational flexibility, accessibility to operate and maintain, ability to address future system growth or restoration needs, and regulatory compliance. The greater the customer impact or the more drivers or benefits that are attributed to a project the higher its priority. Investments in System Service and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNN Engineering, Operations, IT and Finance staff. Based on the outcome of this process, this project ranks 2 out of 16. Refer to Table 4-22 of the DSP for further details.

Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)

Alternatives are rarely considered for these projects due to the urgency of the need. Majority of the projects involve like for like replacements to current safety standards. At times, pole heights will be adjusted to align to future needs and transformer sizing may be increased or decreased based on actual loading information. Both adjustments are made to avoid future costs.

Effect on system operation efficiency and cost effectiveness (first bullet)	To ensure safety and reliability are not further compromised, projects in this category require immediate replacement. As a result WNN does not have control over when the replacement happens. This can lead to increased costs when the replacement is done outside regular working hours.
Net benefits accruing to customers (second bullet)	All projects ensure the elimination of safety hazards and that reliability is maintained.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	Reliability may be impacted by failed assets involved in these projects. Replacement of failed assets will help improve reliability in the future.
Scheduling Alternatives	There is no schedule alternatives for projects in this category. The projects in this category require immediate replacement.
Ownership and/or Funding Alternatives	These projects consist of immediate replacement of WNN assets to restore power or eliminate a public safety risk. There are no ownership and/or funding alternatives considered.

Safety (5.4.3.2.B.2)

Projects in this category are to eliminate any undue hazard to the public and mitigate potential safety risks should unforeseeable events occur.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

Not Applicable

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

Please see answers provided to Section 5.4.3.2.B.1.d above.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Relationship between the Characteristics of Targeted Assets and the Consequences of Asset Failure (5.4.3.2.C.b.first bullet)

Asset Performance Targets and Asset Lifecycle Optimization Policies and Practices (5.4.3.2.C.b.first bullet.first dash)

The majority of assets involved with these projects are replaced because they have failed or are close to failure, and therefore, in line with lifecycle optimization policies and practices.

Asset Condition Relative to Typical Life Cycle (5.4.3.2.C.b.first bullet.second dash)

The majority of assets involved with these projects are replaced because they have failed or are close to failure, and therefore, have reached the end of their useful life. The asset condition relative to typical life varies project by project due to the unpredictable nature of the source of failure (storm, automobile impact, premature deterioration, vandalism, etc.).

Number of Customers in Each Class Potentially Affected (5.4.3.2.C.b.first bullet.third dash)

The number of customers varies project by project.

Quantitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fourth dash)

Quantitative customer impact varies project by project.

Qualitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fifth dash)

The renewal of these assets will typically result in outage restoration activities being immediately undertaken, eliminate safety issues, and ensure future level of reliability is maintained. All of which will maintain or improve customer satisfaction.

Value of Customer Impact (5.4.3.2.C.b.first bullet.sixth dash)

Value of customer impact varies project by project.

Other Factors Affecting Project Timing (5.4.3.2.C.b.second bullet)

Due to the nature of the projects, they are done immediately or scheduled very quickly.

Consequences for System O&M costs (5.4.3.2.C.b.third bullet)

These projects do not materially impact future system O&M costs.

Reliability and Safety Factors (5.4.3.2.C.b.fourth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.B.2 above.

Analysis of Project Benefits, Cost, Alternatives and Timing (5.4.3.2.C.b.fifth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d above.

Like for Like Renewal Analysis (5.4.3.2.C.b.sixth bullet)

The majority of the assets replaced in this category fall as close as possible to like-for-like renewal, adjusted only by requirement to adhere to current safety standards or to provide pole space for future circuits, which do not come at significant cost increases.

General Information on the project/program (5.4.3.2.A)

Project Name	Proactive Renewal																																						
OEB Investment Category	System Renewal																																						
Project Description	Proactive renewal projects represent small unplanned projects over the year that consist of assets that are found in very poor condition or present a safety hazard. The commonality in these projects is that they are identified through regular inspection and testing programs, require immediate replacement, are small in scope, are at several different locations, and for the most part, are unforeseen. These type of projects typically arise from equipment maintenance, system inspection, testing programs and have not yet caused an outage or a safety hazard to the general public.																																						
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																																						
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN04</td><td>6</td><td>Proactive Renewal</td><td>\$72,721</td></tr><tr><td>06OH01</td><td>2</td><td>Depreciated Pole Replacement</td><td>\$142,259</td></tr><tr><td>06OH01</td><td>3</td><td>Overhead Transformer Replacement</td><td>\$83,292</td></tr><tr><td>06OH01</td><td>1</td><td>Loadbreak Replacement</td><td>\$75,251</td></tr><tr><td>06OH01</td><td>4</td><td>Re-Insulate Overhead Lines</td><td>\$70,719</td></tr><tr><td>07OU01</td><td>2</td><td>Underground Transformer Replacement</td><td>\$267,320</td></tr><tr><td>07OU01</td><td>1</td><td>Underground Switch Cubicle Replacement</td><td>\$40,544</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 752,106</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN04	6	Proactive Renewal	\$72,721	06OH01	2	Depreciated Pole Replacement	\$142,259	06OH01	3	Overhead Transformer Replacement	\$83,292	06OH01	1	Loadbreak Replacement	\$75,251	06OH01	4	Re-Insulate Overhead Lines	\$70,719	07OU01	2	Underground Transformer Replacement	\$267,320	07OU01	1	Underground Switch Cubicle Replacement	\$40,544			Total	\$ 752,106
WNH Project	Sub Project	Project Name	Total																																				
06EN04	6	Proactive Renewal	\$72,721																																				
06OH01	2	Depreciated Pole Replacement	\$142,259																																				
06OH01	3	Overhead Transformer Replacement	\$83,292																																				
06OH01	1	Loadbreak Replacement	\$75,251																																				
06OH01	4	Re-Insulate Overhead Lines	\$70,719																																				
07OU01	2	Underground Transformer Replacement	\$267,320																																				
07OU01	1	Underground Switch Cubicle Replacement	\$40,544																																				
		Total	\$ 752,106																																				
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$752,106																																					
	O&M Costs (if applicable)	\$0 Not Applicable																																					
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																																					
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	Information not available until time of work																																					
	Customer Load (peak KVA)	Information not available until time of work																																					
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021																																					
	Expected In-Service Date	Dec-2021																																					
	Expenditure Timing																																						
	2021 Q1	25%	\$188,027																																				
	2021 Q2	25%	\$188,027																																				
	2021 Q3	25%	\$188,027																																				
	2021 Q4	25%	\$188,027																																				
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	The investment amount is based on historical investment levels. WNH assigns required internal and/or external resources to have the work completed when the need arises.																																						
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																																						
	2016:	\$681,056	The historical years are representative of typical expenditures.																																				
	2017:	\$664,943																																					
	2018:	\$882,231																																					
	2019:	\$913,294																																					
	2020:	\$843,109																																					
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																																						
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																																						

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver behind the majority of these projects is the requirement to replace end of life assets that were not scheduled for replacement, but due to their present condition must be replaced immediately to ensure that safety and reliability are not compromised.
Related Objectives/Performance Targets	WNN Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Asset condition at the time of discovery and consequences of not doing anything provide the justification required. Please refer to Section 3.1 of the DSP for further details on WNN's asset management process.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	WNN conducts annual inspection and testing programs, evaluates the results and prioritizes the replacement of assets. Replacing deteriorated assets with those that meet today's standards improves safety, maintains reliability, increases resilience, and facilitates connection of new innovative technologies to the grid.
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>System Renewal assets are prioritized by the health condition of the assets developed through its ACA program. Assets found at risk of imminent failure or high public safety risk are prioritized for immediate replacement.</p> <p>WNN is utilizing METSCO's Asset Analysis, Prioritization, and Optimization Tool, ENGIN to aid in prioritizing asset replacement. Assets flagged for replacement are geospatially grouped to create constructible projects.</p> <p>Projects are ranked by taking into account their overall health condition, customer impact, alignment with WNN Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) such as reliability, safety, financial or environmental risk and additional drivers and benefits. In addition to the aforementioned this can include improvements in power quality, system loss reduction (voltage conversion), operational flexibility, accessibility to operate and maintain, ability to address future system growth or restoration needs, and regulatory compliance. The greater the customer impact or the more drivers or benefits that are attributed to a project the higher its priority.</p> <p>Investments in System Service and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNN Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 4 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>Alternatives are often not considered for these projects due to the urgency of the need. Majority of the projects involve like for like replacements to current safety standards. At times, pole heights will be adjusted to align to future needs and transformer sizing may be increased or decreased based on actual loading information. Some load break switches may be replaced with automated switches and in other cases consideration may be given to relocating the equipment at the time of replacement if accessibility is an issue. All adjustments are made to avoid future costs.</p>
Effect on system operation efficiency and cost effectiveness (first bullet)	By proactively planning the replacement of poles rather than forced replacement at the time of failure, the cost per pole is managed as the replacement can be scheduled during regular working hours.
Net benefits accruing to customers (second bullet)	All projects ensure the elimination of safety hazards and that reliability is maintained.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	These projects involve replacement of assets at very high risk of failure. Replacing these assets will not improve reliability, however, without these projects reliability will be compromised.
Scheduling Alternatives	There is no schedule alternatives for projects in this category. The projects in this category require urgent execution.
Ownership and/or Funding Alternatives	These projects consist of urgent replacement of WNN assets to restore power or eliminate a public safety risk. There are no ownership and/or funding alternatives considered.

Safety (5.4.3.2.B.2)

The majority of these projects involve assets that are about to fail, and therefore, the work almost always involves eliminating a soon to be safety hazard.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

Not Applicable

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

In certain circumstances, manual load break switches flagged for action during inspection may be replaced with automated switches instead if such would be in line with the grid modernization strategy.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Relationship between the Characteristics of Targeted Assets and the Consequences of Asset Failure (5.4.3.2.C.b.first bullet)

Asset Performance Targets and Asset Lifecycle Optimization Policies and Practices (5.4.3.2.C.b.first bullet.first dash)

The majority of assets involved with these projects are replaced because they are close to failure, and therefore, in line with lifecycle optimization policies and practices.

For assets requiring attention, WNH considers all three options: replacement, refurbishment, and maintenance and chooses the most cost effective option from those technically available for each asset category. This investment category is for assets where replacement is the only or best viable option.

Asset Condition Relative to Typical Life Cycle (5.4.3.2.C.b.first bullet.second dash)

The majority of assets involved with these projects are replaced because they are close to failure, and therefore, have reached the end of their useful life. Replacement of assets sooner than their Typical Life Cycle is not uncommon.

Number of Customers in Each Class Potentially Affected (5.4.3.2.C.b.first bullet.third dash)

The number of customers varies project by project.

Quantitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fourth dash)

Quantitative customer impact varies project by project.

Qualitative Customer Impact and Risk (5.4.3.2.C.b.first bullet.fifth dash)

The renewal of these assets will ensure future level of reliability is maintained, eliminate safety issues and allow for increased flexibility of the operation of the grid. All of this will maintain or improve customer satisfaction.

Value of Customer Impact (5.4.3.2.C.b.first bullet.sixth dash)

Value of customer impact varies project by project.

Other Factors Affecting Project Timing (5.4.3.2.C.b.second bullet)

There are no factors that may affect the timing of the proposed projects that have not already been addressed above.

Consequences for System O&M costs (5.4.3.2.C.b.third bullet)

There will be no immediate material impact to O&M costs for distribution lines. Without these projects, assets will transition from poor condition to failure, increasing future O&M costs.

Reliability and Safety Factors (5.4.3.2.C.b.fourth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.B.2 above.

Analysis of Project Benefits, Cost, Alternatives and Timing (5.4.3.2.C.b.fifth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d above.

Like for Like Renewal Analysis (5.4.3.2.C.b.sixth bullet)

The majority of the assets replaced in this category fall as close as possible to like-for-like renewal, adjusted only by requirement to adhere to current safety standards or to provide pole space for future circuits, which do not come at significant cost increases.

General Information on the project/program (5.4.3.2.A)

Project Name	Contingency Enhancement														
OEB Investment Category	System Service														
Project Description	<p>This project category represents investments required to make improvements to feeders in existing electrical distribution system where full capability to re-route power to nearby feeders is constrained. The needs are normally identified through system load flow analysis and operational reports, with a special focus on areas of large load concentration, and where the reconfiguration of existing wires and/or installation of additional switching points is insufficient to address the problem.</p> <p>These investments provide upgraded or additional circuits to improve load transfer capabilities between transformer stations and feeders reduce the risk of prolonged outages for customers. These improvements will also reduce customer restoration times during certain transmission, station and distribution loss of supply contingencies, ease congestion points on the distribution system during abnormal configurations and increase the opportunities to remove equipment from service for maintenance without interrupting the supply to customers.</p> <p>Projects in this category consist of rebuilding existing pole lines which are in poor condition or near the end of their useful life with ones that carry additional circuits in order to provide required tie and sectionalizing points. The trigger driver of such investments is the constrained ability of the system to provide consistent services, and the project has accordingly been classified as system service, despite having elements of system renewal.</p> <p>The project scope includes design, construction and installation of new taller poles designed to conform to O. Reg. 22/04 compliant standards as well as new wire, insulators, transformers and equipment. Newer construction standards and materials provide for more weather resilient assets to help maintain safety and reliability.</p>														
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:														
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN06</td><td>16</td><td>Weber St - Randall to Benjamin</td><td>\$291,280</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 291,280</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN06	16	Weber St - Randall to Benjamin	\$291,280			Total	\$ 291,280
WNH Project	Sub Project	Project Name	Total												
06EN06	16	Weber St - Randall to Benjamin	\$291,280												
		Total	\$ 291,280												
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$291,280													
	O&M Costs (if applicable)	\$0 Not Applicable													
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0													
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	1,776													
	Customer Load (peak KVA)	6,075													
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Feb-2021													
	Expected In-Service Date	Dec-2021													
	Expenditure Timing														
	2021 Q1	20%	\$58,256												
	2021 Q2	40%	\$116,512												
	2021 Q3	40%	\$116,512												
	2021 Q4	0%	\$0												
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	These projects have no significant risk factors associated with their execution.														
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:														
	2016:	\$282,615	2016 and 2017 represent typical expenditures in this category.												
	2017:	\$275,020	From 2018-2020, in conjunction with a road project, WNH												
	2018:	\$595,881	constructed additional tie lines in congested urban area.												
	2019:	\$978,392													
	2020:	\$615,740													
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable														
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable														

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for these projects are to improve system performance under contingency situations for areas of large load concentration, such as a distribution station or a large subdivision.
Related Objectives/Performance Targets	WNN Strategic Imperative 1 (Supply & Reliability) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>The system capacity constraints are normally identified through system load flow analysis. The Lakeshore north subdivision is being rebuilt due to asset condition and also upgraded from 13.8kV to 27.6kV to help with load balancing needs of the system. Refer WNN System Supply and Capacity Study in Appendix J of the DSP for further detail.</p> <p>As a result of system conversion from 13.8kV to 27.6kV, the Lakeshore subdivision no longer has adequate levels of redundancy. New 27.6kV tie line need to be constructed to restore the level of service that was present prior to system upgrades as well as to comply with standard level of redundancy provided to all underground subdivision customers.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary driver for these projects are the age and condition of the existing plant. A significant portion of the infrastructure being replaced was originally put in service since mid 1970's and has been identified through regular inspection as being in poor condition.
Related Objectives/Performance Targets	WNN Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	The source of the information used to justify this investment is the ACA, as further detailed in Appendix A of the DSP. WNN's ACA program uses asset degradation factors such as age, pole treatment, inspection and testing data to develop a Health Index (HI) for each of its pole assets. The HI is converted into a condition rating that can range from Very Good to Very Poor. Assets in Poor and Very Poor condition are identified and grouped into executable projects.
Good Utility Practice (5.4.3.2.B.1.b)	<p>WNN makes investments to attain reliable, resilient, and flexible grid that also supports future needs by:</p> <ul style="list-style-type: none"> a) reducing the number of distribution systems by voltage conversions to harmonize and optimize the capacity of supply b) investing to provide upgraded or additional circuits to improve load transfer capabilities and build adequate system ties c) installing or making provisions for innovative technologies that establish flexible switching capabilities under normal and abnormal conditions d) ensuring project alignment with WNN long term system plans e) utilizing newer construction standards and materials that provide for more weather resilient assets to help maintain safety and reliability.
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the System Service category, WNN identifies project opportunities to address service level issues based on a detailed review of the WNN Distribution System Reliability Report, expected or known system constraints, post-mortem analysis of large outages, introducing functionality to address operational objectives or system performance issues and then develops a list of solutions. The solutions that can be implemented quickly and/or inexpensively are prioritized for faster execution. To prioritize the remaining projects in this category, WNN takes into account alignment with WNN Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1), customer impact, and additional drivers or benefits from each project. These include criticality of assets, safety issues, health index of asset(s), improved condition assessments, system loss reduction (voltage conversion), alignment with WNN's long term distribution system plan, relocation requirements (WNN or municipally driven), or replacement for regulatory compliance. The greater the alignment with WNN Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a solution, the higher the priority.</p> <p>Investments in System Renewal and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNN Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 11 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>a) Do Nothing - this option will perpetuate issues over time leading to notable deterioration of reliability, therefore, it is not an acceptable option.</p> <p>b) Add new circuits to pole lines build with provisions for additional circuits - in some cases WNN renews existing lines with provisions for future circuits in accordance with our long term system plans. If such pole lines exist between desired interconnection points, this option is executed as soon as possible as it requires very little design time and relatively short construction times.</p> <p>c) Upgrade Existing Lines - this option consists of identifying line sections between desired interconnection points that presently operate at lower voltages and/or utilize undersized conductors. Reinsulation or reconductoring projects are very quick to design and relatively quick to construct. These options are only executed if they sufficiently address the need and if the remaining life of the poles is sufficient to justify off-cycle replacement of insulators or conductors.</p> <p>d) Renew and Expand Existing Lines - this option consists of renewing line sections between desired interconnection points and installing additional wires. This option is primarily considered for line sections that are approaching or at the end of their useful life and the additional circuitry is required as per the long term system plan. If absolutely no other technical solutions exist to address the contingency enhancement requirements, this option may be executed if long term system plans can be adjusted to take advantage of the new circuits.</p> <p>e) System Expansion - this option consists of building new pole lines where none exist today. This option is only executed if it is required by the long term system plan. If no other technical solution exists to address the contingency issue at hand, this option may be executed if long term system plans can be adjusted to take advantage of the new circuits.</p> <p>f) Combination of Alternatives b) thru e) - Most often, the adequate technical solution requires the use of a combination of the above identified alternatives. It involves identifying various line sections where multiple trigger drivers or benefits can be realized and forming a solution comprised of various steps. This may result in providing a technical solution that is not along the shortest path of desired interconnection points, but is always the one that minimizes overall and future costs, avoids the possibility of renewing pole lines that are not approaching end of life, and minimizes the risk of stranded assets on a long term basis.</p> <p>In 2021, option d) above best addresses required needs.</p>
Effect on system operation efficiency and cost effectiveness (first bullet)	The line section selected for renewal and contingency enhancement under this project category will provide a tie between two transformer stations to increase operational flexibility for day to day switching, expand window of time when outages for maintenance purposes are possible increasing flexibility in scheduling maintenance work.

Net benefits accruing to customers (second bullet)	Upon completion of this project, standard levels of redundancy of supply for underground residential subdivisions will be restored for the customers affected the by Northlake underground renewal program.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	The completion of this project is expected to have a significant positive effect on reliability for the localized areas these projects are meant to address as a result of significantly reducing the risk of prolonged outages for these areas. On a system level, these projects will have some positive effect over time due to: a) providing additional system ties in urban area between two transformer stations b) improved interconnection capabilities for day to day use c) reduction of failure risk associated with aging assets.
Scheduling Alternatives	This project is also part of the ongoing voltage conversion plan in Lakeshore North urban area. If projects with a higher priority arise during the year, there is some potential to defer, however, delaying this project will sacrifice supply redundancy for the entire Lakeshore North subdivision.
Ownership and/or Funding Alternatives	These projects are constructed in the public right-of-way and will consist solely of WNH's assets. There are no ownership or funding alternatives.
<u>Safety (5.4.3.2.B.2)</u>	
The intention of these types of projects are not to address safety concerns, although at times end of life assets are replaced which may involve elimination of safety hazards.	
<u>Cyber-security, Privacy (5.4.3.2.B.3)</u>	
Not Applicable	
<u>Co-ordination, Interoperability (5.4.3.2.B.4)</u>	
Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)	
WNH will meet with the area Utility Coordinating Council and municipal staff (where applicable) as well as third party stakeholders to exchange project details to coordinate construction. Since these are 2021 projects, this coordination will most likely occur in Q3-Q4 2020.	
Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)	
New lines generally incorporate larger conductor, increased strength, and where available, higher voltages. As a result, system is better able to withstand poor weather conditions; provide increased capacity and siting options for the connection of renewable energy generation, electric vehicles, energy storage; provide increased physical space for third party communications and smart grid devices; and reduce power quality issues and losses.	
<u>Environmental Benefits (5.4.3.2.B.5)</u>	
Not Applicable	
<u>Conservation and Demand Management (5.4.3.2.B.6)</u>	
Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)	
Not Applicable	
Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)	
Not Applicable	
How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)	
Not Applicable	

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

<u>Assessment of the Benefits of the Project for Customers and Customer Costs (5.4.3.2.C.c.first bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.A.first bullet above.
<u>Information on Regional Planning (5.4.3.2.C.c.second bullet)</u>
Although not directly related to the Regional Planning process, the individual projects identified above support the concept of addressing system service issues with distribution level solutions.
<u>How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.C.c.third bullet)</u>
Integration of Advanced Technology is always considered when looking for solutions to system service issues. For projects that consist primarily of renewing existing lines, this level of analysis will be performed at the individual project level during detailed design.
<u>System Benefits to Reliability, Efficiency, Safety and Coordination (5.4.3.2.C.c.fourth bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d above regarding Reliability and Efficiency, Section 5.4.3.2.B.2 above regarding Safety and Section 5.4.3.2.B.4 above regarding Coordination
<u>Factors Affecting Implementation Timing/Priority (5.4.3.2.C.c.fifth bullet)</u>
Please see answers provided in Section 5.4.3.2.B.1.c above regarding Priority as well as Section 5.4.3.2.A.fifth bullet and Section 5.4.3.2.B.1.d regarding Implementation Timing.
<u>Summary of Options Analysis (5.4.3.2.C.c.sixth bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d above.

General Information on the project/program (5.4.3.2.A)

Project Name	Grid Modernization																						
OEB Investment Category	System Service																						
Project Description	<p>WNH covers a relatively large and diverse service territory and as a result system disturbances can lead to prolonged outages as manual switching times are dependent on potentially long travel distances, crew call out and response times are dependant on the time of day, as well as long setup times in urban areas where access can be slow and difficult due to traffic, lack of detailed information about the disturbance location, and the need to patrol the entire feeder prior to power restoration.</p> <p>In response to this, starting in 2010, with a larger scale deployment beginning in 2014 WNH has been installing automated switching devices to address these issues.</p> <p>WNH has also implemented Survalent's Fault Location, Isolation, and Service Restoration (FLISR) software application that combined with SCADA and other grid modernization devices reroutes power in the event of a fault to restore power to as many customers as possible, as quickly as possible. These technologies provide automatic self-healing on the portions of the system unaffected by the fault, ultimately improving restoration times.</p> <p>Approximately one-third of WNH's customer base does not yet fully benefit from the reliability improvements made by WNH's grid modernization investments, which is why over the next 5 years WNH is continuing their investment in this area. These include the installation of automated switching devices (recloser and Vista Gear) which expand self-healing networks and increase the number of customers benefitting from this technology and also enhance the capabilities of other grid modernization technologies such as WNH's Outage Management System (OMS) and FLISR. These devices, along with a targeted deployment of fault indicators, also improve situational awareness for operating staff during power outage events leading to more informed, effective and efficient restoration of power to customers.</p> <p>WNH's strategy for urban feeders is to segment it into two parts supplemented by remote tie switches on either side of the segmentation device. For rural feeders, due to typically long lengths, the strategy is to segment the feeder into three parts supplemented by remote tie switches on either side of all segmentation devices. This also allows WNH to have an improved response and flexibility to better minimize the impact to customers when severe weather events interrupt power.</p> <p>This project category consists of design, installation, and commissioning of remotely controlled reclosers (switches with ability to act like breakers), fault indicators, and remote operating capabilities for select existing underground switchgear.</p>																						
Detailed Listing of Individual Projects	The following individual projects are covered by this project category:																						
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN06</td><td>13</td><td>2021 Recloser Program</td><td>\$460,957</td></tr><tr><td>07OU01</td><td>4</td><td>Fault Indicator Deployment</td><td>\$57,400</td></tr><tr><td>06EN08</td><td>26</td><td>Vistagear SCADA Control Deployment</td><td>\$390,863</td></tr><tr><td colspan="3">Total</td><td>\$ 909,220</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN06	13	2021 Recloser Program	\$460,957	07OU01	4	Fault Indicator Deployment	\$57,400	06EN08	26	Vistagear SCADA Control Deployment	\$390,863	Total			\$ 909,220
WNH Project	Sub Project	Project Name	Total																				
06EN06	13	2021 Recloser Program	\$460,957																				
07OU01	4	Fault Indicator Deployment	\$57,400																				
06EN08	26	Vistagear SCADA Control Deployment	\$390,863																				
Total			\$ 909,220																				
Capital Investment (5.4.3.2.A.first bullet)	Total Capital \$909,220																						
	O&M Costs (if applicable) \$0 Not Applicable																						
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution \$0																						
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#): various - depends on locations Customer Load (peak KVA) various - depends on locations																						
Project Timing (5.4.3.2.A.fourth bullet)	Start Date Jan-2021 Expected In-Service Date Dec-2021 Expenditure Timing 2021 Q1 5% \$45,461 2021 Q2 20% \$181,844 2021 Q3 50% \$454,610 2021 Q4 25% \$227,305																						

Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	There are two major risk factors to this program: lead time of specialized equipment and inadequate communication systems coverage.		
	Due to the specialized nature of the equipment WNH uses to remotely control devices, lead times of up to 26 weeks have been experienced. To mitigate this risk, WNH identifies installation locations in the prior year. The equipment has been previously approved, reviewed and is standardized, allowing the processing/approval time between WNH and suppliers to be minimized to have production of units start quicker. Design and commissioning have also been standardized over previous years, allowing WNH to establish a workflow that ensures devices will be operational in their intended year.		
	The second major risk is inadequate communication system coverage for parts or the entire WNH service area. The planned communication infrastructure for these projects is either via wireless communication devices or dark fiber, both of which use WNH owned infrastructure. The largest risk areas are the Uptown Core and the university neighbourhoods, where redevelopment resulting in high rise buildings may cause the existing radio frequency technology to no longer be adequate in the long term and there may not be dark fiber readily available. To mitigate this risk, WNH has placed many repeater points within the city to expand coverage of the wireless network, is reserving space on the rooftops of high rise buildings for wireless infrastructure, and is expanding dark fiber infrastructure in Waterloo. WNH also performs radio signal tests when determining locations of remote devices to confirm coverage prior to installation.		
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:		
	2016:	\$1,133,013	In 2017 WNH deferred projects involving reclosers and tie lines into 2018 to mitigate the rate impact of the LRT project. Project spend since 2018 has been fairly level.
	2017:	\$125,488	
	2018:	\$758,099	
	2019:	\$909,408	
	2020:	\$856,313	
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable		
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable		

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)	
Main Driver (5.4.3.2.B.1.a)	The main driver for these projects is improvement in distribution system reliability performance.
Related Objectives/Performance Targets	WNH Strategic Imperatives 1 (Supply & Reliability) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	System disturbances in WNH's large and diverse service territory can lead to prolonged outages as manual switching times to restore power are dependent on potentially long travel distances, crew call out and response times are dependant on the time of day as well as long setup times in urban areas where access can be slow and difficult due to traffic. Please see the Distribution System Reliability Report for more information (Appendix K of the DSP). Reliable power is also a top priority for WNH's customers (Appendix L of the DSP).
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary driver for these projects are the improved situational awareness for operating staff during power outage events.
Related Objectives/Performance Targets	WNH Strategic Imperatives 6 (Organizational Effectiveness) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>Improved situational awareness for operating staff during power outage events leads to more informed, effective and efficient restoration of power to customers. In storm scenarios, this results in faulted sections and customer impacts being identified quickly enabling faster informed prioritization of line patrols of shorter lengths and quicker, more focused, and more strategic development of power restoration plans.</p> <p>Please refer to Section 3.1 of the DSP for further details on WNH's asset management process.</p>
Good Utility Practice (5.4.3.2.B.1.b)	WNH has been investing in grid modernization technologies on a larger scale since 2014. These investments have made WNH's distribution system more reliable, resilient, flexible and better prepared for the future. The continued investment in this category is for the one-third of WNH customers that do not yet realize the full benefit of WNH's grid modernization investments.
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the System Service category, WNH identifies project opportunities to address service level issues based on a detailed review of the WNH Distribution System Reliability Report, expected or known system constraints, post-mortem analysis of large outages, introducing functionality to address operational objectives or system performance issues and then develops a list of solutions. The solutions that can be implemented quickly and/or inexpensively are prioritized for faster execution. To prioritize the remaining projects in this category, WNH takes into account alignment with WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1), customer impact, and additional drivers or benefits from each project. These include criticality of assets, safety issues, health index of asset(s), improved condition assessments, system loss reduction (voltage conversion), alignment with WNH's long term distribution system plan, relocation requirements (WNH or municipally driven), or replacement for regulatory compliance. The greater the alignment with WNH Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a solution, the higher the priority.</p> <p>Investments in System Renewal and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 9 out of 16. Refer to Table 4-22 of the DSP for further details.</p>

Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)

a) Do Nothing

This option results in the perpetuation of poor reliability issues as well as customer dissatisfaction. Over time, with risk of increased frequency of failures due to aging infrastructure and associated prolonged outages due to the geography of our service territory, the Do Nothing option would result in notable deterioration of reliability indices at a system level. In addition, the Do Nothing option would be a lost opportunity for WNH customers to see the advantages of the added functionalities of remote switching working in harmony with WNH's Fault Location, Isolation, and Service Restoration (FLISR) system in creating self-healing networks. For these reasons, the Do Nothing option was not considered appropriate.

b) Install additional lines to segment feeders and/or limit their length

Reducing the length of the feeder, or the customers on each feeder also minimizes the number of faults each feeder sees, as well as the number of customers affected by each outage. However, in order to accommodate increased feeders, new lines as well as new transformer stations would need to be built. This option provides a localized solution only, requires substantially higher level of capital investments compared to installing distribution devices, and increases ongoing maintenance costs, and is therefore, not considered feasible.

c) Non-Wires Alternatives

The main intent of grid modernization investments is to create a more flexible and responsive distribution grid to disturbances on the system. Non-wires alternatives are an option that can be used to locally to augment a modern grid. To allow this type of a solution, investments would still need to be made to sectionalize feeders, but the need for automated tie points could be eliminated. The challenges of non-wires solutions are the complex technical requirements to properly site, size, source and install them to serve the current and future needs of the distribution grid. It also does not provide the same level of functionality or flexibility to WNH's distribution system as automated devices and has significantly longer deployment time compared to deploying automated switches.

d) Replace/Install new equipment, Increased Functionality

By replacing/retrofitting manual switches with remotely operable ones WNH is able to realize many benefits. One is the ability to sectionalize a feeder based on fault location. This allows WNH to only cause an outage to a portion of the customers on the feeder while the cause is determined/repared instead of the entire feeder, saving outage minutes. Also, by having remotely operable devices at tie points in WNH's distribution system, switching to restore power can be done quickly to unaffected areas of WNH system, and more switching for normal work can be done from the control room instead of needing to send a crew to operate each device in a switching order, thus using the crews time more efficiently. Finally, it allows more of WNH's distribution system to be integrated with FLISR which is able to automatically reconfigure the distribution system using remotely controlled devices to as many customers as possible under outage conditions in one minute or less, and hence, is the preferred option.

Effect on system operation efficiency and cost effectiveness (first bullet)

- a) remote system reconfiguration utilizing SCADA controlled switching devices causes fewer truck rolls
- b) information is acquired and analyzed remotely with less labour resource input
- c) additional O&M for inspection and maintenance compared to manual switches.

Net benefits accruing to customers (second bullet)

- a) reduces the length of customer outages
- b) increases the number of customers that can be restored quickly during an outage
- c) improved customer communications due to better and faster data availability on system disturbances
- d) limits the number of customers affected by an outage due to feeder segmentation
- e) shortens outage duration for customers on non-automated feeders as the crews can now get to them quicker.

Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)

To date WNH enhanced reliability through faster load transfers, allowed for feeder segmentation, and improved system performance during high impact events. Since 2015:

- a) WNH customers saved approximately 7.0 million minutes of interruption. In 2019 that represented a 30% reduction in outage minutes
- b) momentary interruptions (MAIFI) were cut in half (6.44 to 3.19 annual interruptions per customer).

Scheduling Alternatives

This project is part of an ongoing investment plan to modernize WNH's distribution system. It is budgeted at a paced amount each year to levelize the investment. If projects with a higher priority arise during the year, there is some potential to defer, however, these projects are not primary candidates for deferral as both reliability and innovation is ranked high by our customers.

Ownership and/or Funding Alternatives

These projects will consist solely of WNH's assets. There are no ownership or funding alternatives.

Safety (5.4.3.2.B.2)

Although not primarily meant to address any particular safety issues, the Grid Modernization project has the added benefit of eliminating manual switching which reduces crew exposure to energized equipment and reduces associated safety risks, especially during major weather events where access to switches might not be optimal and operating a switch may cause energization of a faulted section. It also increases safety by faster isolation of faulted conductors where feeder segmentation has been implemented.

Cyber-security, Privacy (5.4.3.2.B.3)

When connecting remote devices for Grid Modernization, WNH owned infrastructure is used (wireless or fiber communication mediums). These networks use various forms and levels of security to minimize the risk of cyber-security attacks, including, but not limited to, encryption, authentication access and firewalls.

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

WNH will meet with the area Utility Coordinating Council and municipal staff (where applicable) as well as third party stakeholders to exchange project details to coordinate construction. Since these are 2021 projects, this coordination will most likely occur in Q3-Q4 2020. WNH may also coordinate with communication asset owners for fibre connectivity to cover future risk of communication infrastructure inadequacy.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

Investments in this category (past and future) are to meet current and future operational and technological requirements. Automated switching devices provide multiple benefits as they also integrate with other grid modernization investments such as OMS and FLISR to provide better information on the location of the fault and to reroute power in the event of a fault to restore power to as many customers as possible, as quickly as possible. Currently, one-third of WNH's customers still do not realize the full benefits of this integration. This is why WNH is continuing with their grid modernization investments, which will add automated devices to areas that currently lack them and expand the benefits that these investments bring to more customers.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

Assessment of the Benefits of the Project for Customers and Customer Costs (5.4.3.2.C.c.first bullet)

Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.A.first bullet above.

Information on Regional Planning (5.4.3.2.C.c.second bullet)

Although not directly related to the Regional Planning process, this program supports the concept of addressing system service issues with distribution level solutions. It will also provide WNH the ability to quickly transfer load from a station supplied by 115kV circuits to stations supplied by 230kV circuits and vice versa. While this may be of benefit to transmission lines locally, as both the 115kV and the 230kV transmission lines belong to the same transmission subsystem, it does not have any impact at the provincial level.

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.C.c.third bullet)

Please see answers provided to Section 5.4.3.2.B.4.b and 5.4.3.2.B.3 above.

System Benefits to Reliability, Efficiency, Safety and Coordination (5.4.3.2.C.c.fourth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d above regarding Reliability and Efficiency, Section 5.4.3.2.B.2 above regarding Safety and Section 5.4.3.2.B.4 above regarding Coordination

Factors Affecting Implementation Timing/Priority (5.4.3.2.C.c.fifth bullet)

Please see answers provided in Section 5.4.3.2.B.1.c above regarding Priority as well as Section 5.4.3.2.A.fifth bullet and Section 5.4.3.2.B.1.d regarding Implementation Timing.

Summary of Options Analysis (5.4.3.2.C.c.sixth bullet)

Please see answers provided to Section 5.4.3.2.B.1.d above.

General Information on the project/program (5.4.3.2.A)

Project Name	Grid Resiliency														
OEB Investment Category	System Service														
Project Description	<p>Grid Resiliency represents targeted investments to move a number of residential services from overhead to underground in WNH's most heavily treed areas where the primary lines were recently reconstructed. Overhead services are highly vulnerable to falling tree branches during storm conditions and power restoration is slow as there is normally collateral customer equipment damage which requires a licenced electrician to repair and the Electrical Safety Authority (ESA) to inspect before power can be restored. This initiative was added in response to feedback from WNH's 2019 customer engagement activities.</p> <p>WNH reviewed the rebuild areas and added \$200,000 to the capital budget in 2021 to move some sections of overhead services in heavily treed areas to underground services. This will accomplish four things: 1) decrease the risk of damage to WNH and to customer equipment 2) decrease the risk of prolonged outages in these targeted areas 3) incrementally reduce tree trimming requirements and 4) improve aesthetics. A notable number of WNH customers are supportive of paying more for more underground.</p> <p>This program will be rolled out to a targeted customer base each year. WNH's scope of work and costs include installation of new underground service wire with proper connections of the main distribution system to the customer provided demarcation point as well as all required coordination and project management activities. The customer's scope of work and costs include supply and installation of conduits on private property, an underground style meter base, removal of customer owned overhead components and restoration of any applicable roof penetrations. Given typical overhead to underground conversion costs, WNH anticipates facilitating the conversion of up to 150 services per year. WNH plans to run this program for 5 years, assess the impact of this investment on reliability and productivity during extreme weather events and determine the appropriate level of investment to continue.</p>														
Detailed Listing of Individual Projects	The following individual projects are covered by this project category:														
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN11</td><td>2</td><td>Overhead to Underground Service Conversions</td><td>\$200,000</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 200,000</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN11	2	Overhead to Underground Service Conversions	\$200,000			Total	\$ 200,000
WNH Project	Sub Project	Project Name	Total												
06EN11	2	Overhead to Underground Service Conversions	\$200,000												
		Total	\$ 200,000												
Capital Investment (5.4.3.2.A.first bullet)	Total Capital \$200,000														
	O&M Costs (if applicable) \$0 Not Applicable														
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution \$0														
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#): Up to 150 Customer Load (peak KVA) various - depends on locations														
Project Timing (5.4.3.2.A.fourth bullet)	Start Date Mar-2021 Expected In-Service Date Nov-2021 Expenditure Timing 2021 Q1 15% \$30,000 2021 Q2 35% \$70,000 2021 Q3 35% \$70,000 2021 Q4 15% \$30,000														
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	This type of work is very routine for WNH and is covered by well established processes both from design and construction perspectives which mitigates issues around customer driven timing risks. WNH plans to reach out to customers in Q4 2020 in the targeted areas to identify interested parties and coordinate project details.														
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows: 2016: \$0 This is a new investment category based on feedback from WNH's 2019 customer engagement activities. 2017: \$0 2018: \$0 2019: \$0 2020: \$0														
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable														
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable														

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for these projects is improvement in service end point reliability for customers during extreme weather events.
Related Objectives/Performance Targets	WNH Strategic Imperative 1 (Supply & Reliability) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>In recent storm conditions WNH has seen substantial operating costs associated with: clearing fallen tree branches off secondary services to customers, disconnecting the power for repair by a licensed electrician and then returning to site to reconnect power, which can at times lead to frustration from customers due to slow restoration times. This investment is also being made in response to feedback from WNH's 2019 customer engagement activities where reducing number and duration of outages during extreme weather events are top two most important aspects of reliability to WNH customers.</p> <p>Please refer to Section 3.1 of the DSP for further details on WNH's asset management process and Customer Engagement Survey Report in Appendix L of the DSP further detail on WNH's customer engagement results.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary driver for this project is improved productivity and cost reduction under extreme weather events.
Related Objectives/Performance Targets	WNH Strategic Imperative 5 (Productivity and Cost Reduction) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>By reducing the number of overhead services in heavily treed areas in WNH's service territory, there will be an incremental reduction in annual tree trimming costs. This is also strongly supported by WNH customers where approximately 90% would like to see same or less tree trimming in their neighbourhoods.</p> <p>It will also result in avoiding the operating costs associated with truck rolls during extreme weather conditions for disconnect and reconnect requests from customers with fallen tree branches on their individual service conductors.</p> <p>Please refer to Section 3.1 of the DSP for further details on WNH's asset management process and Customer Engagement Survey Report in Appendix L of the DSP further detail on WNH's customer engagement results.</p>
Good Utility Practice (5.4.3.2.B.1.b)	<p>In recent storm conditions WNH has seen substantial operating costs and outages due to fallen branches on secondary services. By converting customers in heavily treed areas to an underground service WNH aims to address these concerns and provide a more resilient system.</p> <p>WNH ensures that the connection of new customers allows for a flexible and resilient distribution system that also supports future growth. This includes considerations such as sizing of equipment to meet both the current and projected needs of the load and any future loads, strategic placement of equipment in a location that is accessible and easy to maintain, and alignment with long term system needs including securing of easements.</p>
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the System Service category, WNH identifies project opportunities to address service level issues based on a detailed review of the WNH Distribution System Reliability Report, expected or known system constraints, post-mortem analysis of large outages, introducing functionality to address operational objectives or system performance issues and then develops a list of solutions. The solutions that can be implemented quickly and/or inexpensively are prioritized for faster execution. To prioritize the remaining projects in this category, WNH takes into account alignment with WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1), customer impact, and additional drivers or benefits from each project. These include criticality of assets, safety issues, health index of asset(s), improved condition assessments, system loss reduction (voltage conversion), alignment with WNH's long term distribution system plan, relocation requirements (WNH or municipally driven), or replacement for regulatory compliance. The greater the alignment with WNH Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a solution, the higher the priority.</p> <p>Investments in System Renewal and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 14 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	
a) Do Nothing	<p>This option results in the continuation of high operating costs in storm conditions due to fallen tree branches on customer services and the prolonged outages that accompany them. It also maintains the amount of investment required for tree trimming in these heavily treed areas, which would no longer be needed if the services were underground. Furthermore, based on customer engagement feedback, WNH knows that customers see this as an issue and have a desire to see improvements. For all of the above reasons, this option was not considered appropriate.</p>
b) Trim/Remove Trees	<p>This option would result in the removal or significant increase in trimming of trees in proximity to overhead services. While this would minimize the chances of branches in future storm conditions causing outages, the expense to complete the tree trimming/removal would be increased over other years. It would also require consent/approval from the property owners where the tree resides (municipalities and homeowners). This option is also not in alignment with customer preferences for balancing tree trimming and reliability. Please see Appendix L of the DSP for further detail. For all these reasons, this is not considered an appropriate option.</p>
c) Replace with Underground Services	<p>This option results in converting up to 150 customers a year in targeted heavily treed areas from overhead to underground. While this option has the highest upfront capital cost, the long term benefits are: 1) decrease the risk of prolonged outages in these areas 2) incrementally reduce tree trimming requirements and 3) improve aesthetics in accordance with customer preferences. For these reasons, this is the preferred option.</p>
Effect on system operation efficiency and cost effectiveness (first bullet)	<p>a) incrementally reduce tree trimming requirements/costs b) fewer truck rolls to these areas from fallen branches on overhead wires during extreme weather events.</p>
Net benefits accruing to customers (second bullet)	<p>During extreme weather events: a) decrease the risk of prolonged outages in these areas b) decreased risk of fallen tree branches causing damage to customer owned (and paid for) electrical equipment c) improved aesthetics with less overhead infrastructure.</p>

Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	This investment is expected to have an impact on service connection reliability by reducing both the frequency and length of outages to the customers in the targeted areas during extreme weather events. This investment is not expected to have a material impact on system level reliability metrics.
Scheduling Alternatives	This project is part of an investment plan to add resiliency to WNH's distribution system. It is budgeted at a paced amount each year to levelize the investment. If projects with a higher priority arise during the year, there is some potential to defer, however, these projects are not primary candidates for deferral as this would not align with customer preferences to increase grid resiliency during extreme weather events.
Ownership and/or Funding Alternatives	Under certain scenarios, according to WNH's Conditions of Service, ownership of assets is available to the Customer or WNH. When this is the case, the decision is left to the customer. Under this program, WNH will fund the supply and installation of WNH owned assets and the associated restoration within public right-of-ways while customers will fund the supply and installation of customer owned assets and the associated restoration on private property.
<u>Safety (5.4.3.2.B.2)</u>	By removing overhead infrastructure the safety hazards associated with extreme weather events are also removed. These include: shock hazards from damaged/fallen secondary conductors and damaged customer owned equipment.
<u>Cyber-security, Privacy (5.4.3.2.B.3)</u>	Not Applicable
<u>Co-ordination, Interoperability (5.4.3.2.B.4)</u>	Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)
This is a customer centric program mostly requiring coordination with the customer and their contractor(s). Where scope of work may be expanded to public right of ways, WNH will meet with the area Utility Coordinating Council and municipal staff (where applicable) as well as other utilities and third party stakeholders to exchange project details to coordinate construction.	
Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)	New residential connections are designed with capacity and capability to permit behind the meter customer generation and electric vehicle charging. Each new service to a residential building is sized for 200A to facilitate customer load growth.
<u>Environmental Benefits (5.4.3.2.B.5)</u>	Not Applicable
<u>Conservation and Demand Management (5.4.3.2.B.6)</u>	Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)
Not Applicable	
Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)	Not Applicable
How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)	Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

<u>Assessment of the Benefits of the Project for Customers and Customer Costs (5.4.3.2.C.c.first bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.A.first bullet above.
<u>Information on Regional Planning (5.4.3.2.C.c.second bullet)</u>
Not Applicable
How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.C.c.third bullet)
Not Applicable
<u>System Benefits to Reliability, Efficiency, Safety and Coordination (5.4.3.2.C.c.fourth bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d above regarding Reliability and Efficiency, Section 5.4.3.2.B.2 above regarding Safety and Section 5.4.3.2.B.4 above regarding Coordination
<u>Factors Affecting Implementation Timing/Priority (5.4.3.2.C.c.fifth bullet)</u>
Please see answers provided in Section 5.4.3.2.B.1.c above regarding Priority as well as Section 5.4.3.2.A.fifth bullet and Section 5.4.3.2.B.1.d regarding Implementation Timing.
<u>Summary of Options Analysis (5.4.3.2.C.c.sixth bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d above.

General Information on the project/program (5.4.3.2.A)

Project Name	Station Equipment Upgrades																		
OEB Investment Category	System Service																		
Project Description	<p>The Station Equipment Upgrades category represents projects that add functionality or increase capacity at WNH owned transformer stations.</p> <p>The first project in this category is for the replacement of nine (9) feeder breakers at Scheifele 'A' Transformer Station (HSA), which is a transmission connected DESN transformer station originally constructed in 1969 and supplies power within the City of Waterloo. WNH has determined that HSA has reached its maximum short-circuit rating limits for the station's feeder breakers. The fault contribution from existing connected embedded generation, Hydro One's transmission system upgrade as part of the Guelph Area Transmission Reinforcement (GATR), and transmission connected generation have incrementally contributed to the increase in short circuit levels. WNH is moving forward with the work to reduce the constant risk of catastrophic failure of the circuit breakers affecting an entire bus and causing damage to adjacent equipment during a fault clearing event, which could lead to widespread, prolonged outages. WNH has determined that the most cost effective solution will be to upgrade the feeder breakers at the station. The project will be executed over 2 years. WNH has included the cost to replace these circuit breakers, \$230,244 in 2020 and \$209,762 in 2021 in its capital investment program. Other benefits from these investments will be that generation capacity at HSA will be increased by 6,630 kW and the existing breakers, which currently do not meet the 21kA maximum 3-phase fault requirements outlined in Appendix 2 of the Transmission System Code will be replaced with ones that will allow WNH to meet or exceed this requirement.</p> <p>The second project in this category is to add online monitoring to the dissolved gases in oil at the two (2) HSA power transformers. These power transformers were originally commissioned in 1969 and are now past their typical useful life based on age. However, their latest ACA gave no indication that replacement was imminent, but did recommend increased monitoring. Given this information, WNH has decided to equip these transformers with online monitoring of the dissolved gases in the transformers. These will continuously analyze the oil to determine if there are any internal electrical transformer issues. This allows it to act as an early detection system to WNH should the internal components of the transformers begin to fail/degrade. Under a steady deterioration this will allow WNH to be proactive in their response of their critical assets and develop a replacement strategy, while under a rapid deterioration, it can potentially alert WNH to an impending equipment failure that may be avoided by removing the transformer from service. The project includes: purchasing and installation of two (2) new units, fitting units onto transformer and connecting them to oil valves and commissioning.</p>																		
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																		
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06SN04</td><td>12</td><td>HS'A' Feeder Breaker Upgrade</td><td>\$209,762</td></tr><tr><td>06SN04</td><td>20</td><td>HS'A' Transformer Upgrade to On-Line Monitoring</td><td>\$196,805</td></tr><tr><td colspan="3">Total</td><td>\$ 406,567</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06SN04	12	HS'A' Feeder Breaker Upgrade	\$209,762	06SN04	20	HS'A' Transformer Upgrade to On-Line Monitoring	\$196,805	Total			\$ 406,567
WNH Project	Sub Project	Project Name	Total																
06SN04	12	HS'A' Feeder Breaker Upgrade	\$209,762																
06SN04	20	HS'A' Transformer Upgrade to On-Line Monitoring	\$196,805																
Total			\$ 406,567																
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$406,567																	
	O&M Costs (if applicable)	\$0 Not Applicable																	
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																	
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	4,719																	
	Customer Load (peak KVA)	40,200																	
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Feb-2020 Engineering Apr-2021 Construction																	
	Expected In-Service Date	Dec-2021																	
	Expenditure Timing	<table><tr><td>2021 Q1</td><td>0%</td><td>\$0</td></tr><tr><td>2021 Q2</td><td>50%</td><td>\$203,284</td></tr><tr><td>2021 Q3</td><td>40%</td><td>\$162,627</td></tr><tr><td>2021 Q4</td><td>10%</td><td>\$40,657</td></tr></table>		2021 Q1	0%	\$0	2021 Q2	50%	\$203,284	2021 Q3	40%	\$162,627	2021 Q4	10%	\$40,657				
2021 Q1	0%	\$0																	
2021 Q2	50%	\$203,284																	
2021 Q3	40%	\$162,627																	
2021 Q4	10%	\$40,657																	
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	The main risk factor for the breaker replacement project is equipment outage scheduling windows. All station equipment outages put a strain on the components remaining in service that must supply a much higher level of load than under normal conditions as well as increase risk of prolonged outages should an unexpected failure occur during the scheduled outage. To combat this risk, extended equipment outages associated with this project are only scheduled during shoulder seasons (i.e. spring/fall) where system power flows are lower than peak. All work will also be scheduled to be completed in one outage so as to not expose the distribution system to this risk multiple times.																		
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																		
	2016:	\$46,760	Spending in this category is driven by the need to add functionality or capacity to WNH stations taking priority over renewal work needed at the stations, which causes it to fluctuate as a result. Spending in 2020 and 2021 is higher than past years as the HS'A' breaker replacement, deemed a safety issue, is a two year project beginning in 2020 with approximately the same cost each year.																
	2017:	\$138,426																	
	2018:	\$234,815																	
	2019:	\$239,219																	
	2020:	\$442,961																	
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																		
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																		

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	These upgrades are being completed to critical assets that currently have the potential to catastrophically fail, either based on age or interrupting rating, posing a constant risk of damaging adjacent equipment, creating a much larger outage.
Related Objectives/Performance Targets	WNH Strategic Imperatives 1 (Supply & Reliability) & 2 (Health, Safety and Environment) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>WNH completed internal studies and determined the fault levels at HS'A' were approaching maximum fault interrupting capabilities of the breakers. WNH contracted an independent third party to verify WNH results and to determine the most economic and feasible solution to mitigate this risk. Based on the recommendations of that report, WNH is proceeding with replacing the feeder breakers.</p> <p>WNH is investing in condition based, continuous on-line monitoring of its two oldest large grid connected power transformers. Being WNH's single largest valued assets, and considering long lead times for new power transformers, continuous online monitoring will allow for more timely and less costly intervention if asset health unexpectedly deteriorates.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	<p>Replacing breakers that are approaching or exceeding their fault interrupting capability is necessary to mitigate the risk of equipment failure and to ensure safety for personnel who could be working in the vicinity when faults happen. A benefit from this investment will be an increase in generation connection capacity at this station.</p> <p>Adding monitoring to power transformers approaching or exceeding their expected life mitigates the risk of unexpected failure of one of a stations most critical assets. It also allows for condition based replacement to optimize the assets life based on observed data.</p>
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the System Service category, WNH identifies project opportunities to address service level issues based on a detailed review of the WNH Distribution System Reliability Report, expected or known system constraints, post-mortem analysis of large outages, introducing functionality to address operational objectives or system performance issues and then develops a list of solutions. The solutions that can be implemented quickly and/or inexpensively are prioritized for faster execution. To prioritize the remaining projects in this category, WNH takes into account alignment with WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1), customer impact, and additional drivers or benefits from each project. These include criticality of assets, safety issues, health index of asset(s), improved condition assessments, system loss reduction (voltage conversion), alignment with WNH's long term distribution system plan, relocation requirements (WNH or municipally driven), or replacement for regulatory compliance. The greater the alignment with WNH Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a solution, the higher the priority.</p> <p>Investments in System Renewal and General Plant categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 5 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>The projects identified under this category are to add functionality to WNH owned Transformer Stations that reduce the safety risk of assets catastrophically failing. In light of this fact, WNH considered the following alternatives:</p> <p>a) Do Nothing The do nothing option carries significant risk of sudden complete or catastrophic failure of the feeder breakers without upgrading their fault interrupting capability and is not an option. Not adding monitoring to the power transformers would limit WNH's ability to detect asset failure or deterioration. There would be significantly less insight into the power transformers condition, which could result in them being replaced too early and not maximizing the life of the transformers, or too late resulting in significant risk of wide spread prolonged outages should another major component fail.</p> <p>b) Refurbish (Fix Components of Existing equipment) WNH explored refurbishing/retrofitting the breakers to enhance the existing breakers interrupting capacity. However, through conversations with the vendor it was determined that this was not an option and that new breakers would be necessary.</p> <p>c) Replace with new equipment, same functionality (Like-for-Like) Replacing the existing breakers like-for-like is not an option as they would have the same fault interrupting capability limitations as the existing ones. There is currently no online monitoring solution on the HSA power transformers.</p> <p>d) Replace/Install new equipment, Increased Functionality WNH is upgrading their feeder breakers to match the maximum interrupting capability of the existing switchgear. This allows WNH to maximize the benefits of the new breakers and also increases generation connection capacity. Adding monitoring to power transformers approaching or exceeding their expected life mitigates the risk of unexpected failure of one of a stations most critical assets. It also allows for condition based replacement to optimize the assets life based on observed data and provides advanced insight into any developing areas of concern allowing sufficient time to develop an appropriate remedy.</p>
Effect on system operation efficiency and cost effectiveness (first bullet)	The addition of online monitoring provides increase and more impactful information to system controllers allowing them to diagnose issues quicker. This information also provides opportunity to optimize the transformers life cycle based on historical performance and trends.
Net benefits accruing to customers (second bullet)	The replacement of the feeder breakers and the addition of the online monitors reduces the risk of catastrophic failures at the station, which can affect adjacent equipment resulting in large outages. This reduces the risk of prolonged outages and/or rotating blackouts within the city of Waterloo. Upgrading the feeder breakers has an added benefit of allowing more generation customers to connect to the HS'A' transformer station.

Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	These projects will primarily ensure that the current reliability levels are maintained and will remove a significant risk of a notable reduction in reliability indices.
Scheduling Alternatives	These investments are instrumental in reducing the risk of critical asset failures, maintaining reliability and safety performance measures and keeping expensive reactive maintenance activities to a minimum. Also, as mentioned in section 5.4.3.2.A.fifth bullet, scheduling is carefully planned during times of the year where peak demand is low. For these reasons these projects are not suitable candidates for deferral.
Ownership and/or Funding Alternatives	These projects will consist solely of WNH's assets. There are no ownership or funding alternatives.
<u>Safety (5.4.3.2.B.2)</u>	This project mitigates significant risks to safety and human life in case of catastrophic failure of the breakers or power transformers. WNH has experienced one catastrophic breaker failure in the past (in mid 1990's) which could have resulted in severe burns or death if a worker were to be present in the switchgear room at the time of the failure.
<u>Cyber-security, Privacy (5.4.3.2.B.3)</u>	Not Applicable
<u>Co-ordination, Interoperability (5.4.3.2.B.4)</u>	<p>Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a) As this is a transmission connected transformer station, close coordination with IESO and Hydro One is required, which follows an already established outage coordination and approval procedure. WNH's concerns over the increasing short circuit levels where raised during the regional planning process and forecasted short circuit increases from Hydro One were provided to WNH to incorporate into the upgrade to ensure adequate capacity.</p> <p>Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b) The new online monitors will ensure that moisture, faults or arcing within the transformer are identified quickly. This allows WNH to be proactive instead of reactive in their response. The online monitors also can be used on any power transformer, meaning that if the power transformer requires replacement prior to the monitors needing to be replaced, they can be used on the new power transformers. Upgrading feeder breakers has an added benefit of allowing more generation customers to connect to the HS'A' transformer station.</p>
<u>Environmental Benefits (5.4.3.2.B.5)</u>	Not Applicable
<u>Conservation and Demand Management (5.4.3.2.B.6)</u>	<p>Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet) Not Applicable</p> <p>Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet) Not Applicable</p> <p>How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet) Not Applicable</p>

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

<u>Assessment of the Benefits of the Project for Customers and Customer Costs (5.4.3.2.C.c.first bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.A.first bullet above.
<u>Information on Regional Planning (5.4.3.2.C.c.second bullet)</u>
The Regional Planning process discussed WNH's constraints regarding fault interrupting capabilities, however given that the constraint was localized to WNH's HSA Transformer Station, the Regional Planning process did not influence the final direction of the project.
<u>How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.C.c.third bullet)</u>
Please see answers provided to Section 5.4.3.2.B.4.b and 5.4.3.2.B.3 above.
<u>System Benefits to Reliability, Efficiency, Safety and Coordination (5.4.3.2.C.c.fourth bullet)</u>
Please see answers provided to Section 5.4.3.2.B.1.d above regarding Reliability and Efficiency, Section 5.4.3.2.B.2 above regarding Safety and Section 5.4.3.2.B.4 above regarding Coordination
<u>Factors Affecting Implementation Timing/Priority (5.4.3.2.C.c.fifth bullet)</u>
Please see answers provided in Section 5.4.3.2.B.1.c above regarding Priority as well as Section 5.4.3.2.A.fifth bullet and Section 5.4.3.2.B.1.d regarding Implementation Timing.
<u>Summary of Options Analysis (5.4.3.2.C.c.sixth bullet)</u>
As described in detail under section 5.4.3.2.B.1.d above, the Do Nothing, Refurbish existing equipment, and complete like-for-like replacement options are not appropriate for sub project 12 given the issue at hand.
For sub project 20, do nothing is an option, however WNH would then have no insight into internal issues within the transformer. This limits WNH's opportunity to be proactive on issues occurring within the transformer, increasing the likelihood of catastrophic failure of the device, or premature replacement of the power transformer. With the continuous information that online monitoring offers, including trending based on historical data, there is more of an opportunity to optimize the life of the power transformer.

General Information on the project/program (5.4.3.2.A)

Project Name	Fleet - Trucks																						
OEB Investment Category	General Plant																						
Project Description	WNNH's Fleet Asset Management plan is based on the age and condition of fleet assets. Fleet assets play a critical role in keeping WNNH working efficiently and safely. WNNH takes a levelized approach to fleet replacement spending where the strategy considers planning, acquisition, operation and disposal. The material 2021 fleet investments include the replacement of one large vehicle and the replacement of three small vehicles. These units are in a deteriorated condition and past their typical useful life (14 years for the large and medium vehicles and 10 years for the small vehicles).																						
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																						
	<table><tr><th>WNNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06FL02</td><td>2</td><td>Replacement of Large Vehicle (55' SB MHAD to Replace R55)</td><td>\$481,512</td></tr><tr><td>06FL02</td><td>4</td><td>Replacement of Small Vehicles</td><td>\$179,768</td></tr><tr><td>06FL02</td><td>3</td><td>Line Supervisor Pick Up Truck to Replace R128</td><td>\$73,907</td></tr><tr><td colspan="3">Total</td><td>\$ 735,187</td></tr></table>			WNNH Project	Sub Project	Project Name	Total	06FL02	2	Replacement of Large Vehicle (55' SB MHAD to Replace R55)	\$481,512	06FL02	4	Replacement of Small Vehicles	\$179,768	06FL02	3	Line Supervisor Pick Up Truck to Replace R128	\$73,907	Total			\$ 735,187
WNNH Project	Sub Project	Project Name	Total																				
06FL02	2	Replacement of Large Vehicle (55' SB MHAD to Replace R55)	\$481,512																				
06FL02	4	Replacement of Small Vehicles	\$179,768																				
06FL02	3	Line Supervisor Pick Up Truck to Replace R128	\$73,907																				
Total			\$ 735,187																				
Capital Investment (5.4.3.2.A.first bullet)	Total Capital \$735,187																						
	O&M Costs (if applicable) \$0 Not Applicable																						
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution \$0																						
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#): Not Applicable Customer Load (peak KVA) Not Applicable																						
Project Timing (5.4.3.2.A.fourth bullet)	Start Date Feb-2020 Expected In-Service Date Dec-2021 Expenditure Timing 2021 Q1 22% \$160,000 2021 Q2 42% \$312,000 2021 Q3 14% \$102,000 2021 Q4 22% \$161,187																						
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	The main risk for this project is the long lead time required for the delivery of a large vehicle and the suppliers adherence to the delivery schedule. This risk has been managed by initiating the specification, tender and award process early in 2020. Additionally, WNNH will persist with the vendor(s) involved on a quarterly basis to ensure the progress milestones for the major components of the large vehicle align with the delivery of the finished large vehicle in Q4 of 2021.																						
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows: 2016: \$406,938 WNNH attempts to pace fleet capital investments in coordination with 2017: \$604,043 WNNH's overall capital investment plan. This results in inconsistent 2018: \$523,603 spending patterns for this project category. 2019: \$331,409 2020: \$666,740																						
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																						
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																						

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for this project is the age and condition of the vehicles and the operational need to have reliable equipment.
Related Objectives/Performance Targets	WNH Strategic Imperatives 6 (Organizational Effectiveness) & 5 (Productivity and Cost Reduction) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>WNH Fleet Technicians perform regular maintenance and inspection on all assets. The condition of large vehicle R61 is poor in 2020 and will be very poor in 2021 due to age, engine and body condition. Reference WNH Fleet Asset Management Plan (Appendix M of the DSP), Table 4-5.</p> <p>The reliability and availability of large vehicles in the fleet impacts productivity of WNH crews working on construction projects and power restoration efforts. Vehicles not available for service when needed results in a slow down of the work program, wasted time and labour in reorganizing and rescheduling work.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	This investment does not impact reliability planning. This investment supports WNH's timely response to outages. Any delay in system repair or restoration efforts during an outage would lengthen the outage duration and have negative impact on reliability.
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the General Plant category, WNH identifies underperforming assets or processes based on feedback received from customers, vendors, staff, tracking of performance, operating and maintenance costs. WNH also identifies opportunities for improvement in its ability to meet the WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) and compiles a complete list of projects for this category. To prioritize the execution of these projects, WNH takes into account additional drivers or benefits of completing the project. This typically includes improvements in: customer experience, worker safety, security, ability to continue to provide services to customers, opportunity for cost reduction, increase in productivity, operating efficiency, ability to operate and maintain systems, ability to adapt to future needs, and regulatory compliance. The greater the alignment with WNH Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a project, the higher its priority.</p> <p>Investments in System Service and System Renewal categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 12 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>(a) Do nothing is a poor option. Large vehicle R61 has already been refurbished to extend its useful life to almost 16 years. The risk of catastrophic failure jeopardizes our ability to build and maintain a reliable distribution system.</p> <p>(b) Refurbishment was already completed on large vehicle R61 by replacing engine head gaskets to extend the useful life. A subsequent refurbishment is not a good option.</p> <p>(c) Replacement of one large vehicle and five small vehicles is the preferred and viable option because of the added reliability, availability, fuel savings and maintenance savings.</p> <p>(d) Replace and increase functionality. The large vehicle R71 (replacing R61) is a higher series heavier boom and will perform better with no increased maintenance.</p>
Effect on system operation efficiency and cost effectiveness (first bullet)	The replacement of R61 (new R71) and five small vehicles enables trades staff to design, construct and maintain WNH electrical distribution system. The replacement vehicles will avoid future increase in operating and maintenance costs.
Net benefits accruing to customers (second bullet)	The replacement of R61 (new R71) will equip an overhead construction crew with reliable equipment essential to completing planned system renewal work and to respond to unplanned power interruptions. Additionally, a higher level of public safety is realized when trucks are not at risk of breaking down in public roadways.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	Should any vehicle break down amidst a power restoration task the impact to customers would be measurable. It is a strategic imperative to ensure good customer service and system reliability.
Scheduling Alternatives	All of WNH fleet assets are inspected and maintained in house by WNH Fleet Technicians. Scheduling of vehicle refurbishment or vehicle replacement is planned to optimize the useful life. This optimizing must recognize the risk of keeping a vehicle in service too long whereby excessive maintenance and repair costs are likely or operational down time occurs.
Ownership and/or Funding Alternatives	WNH purchases and owns its fleet assets. Where vehicles are used daily for routine and emergency work, WNH owns and maintains those assets. From time to time WNH will rent specialized equipment for short term work when it would not makes sense to own and maintain that equipment. WNH does not lease long term equipment since the lifetime cost of leasing generally exceeds the cost of purchasing.

Safety (5.4.3.2.B.2)

Delaying large vehicle replacement could pose a safety risk when employees work aloft on the electrical distribution system and on roadways shared by the public.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

WNNH coordinates closely with chassis, boom and body vendors through the planning and acquisition phases for all large vehicle purchases to ensure timely delivery. Medium and small vehicles are less complex do not require as much coordination.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

WNNH was an early adopter of electric hybrid hydraulic systems in a number of large vehicles. That technology did not prove robust enough for the continuous outdoor use in a large vehicle. WNNH was an early adopter of using gasoline/propane hybrid systems in small vehicles. The unreliable valuing on these hybrid vehicles outweighed the benefits and since then gasoline costs have flattened. WNNH has one electric small vehicle in its fleet. WNNH continues to monitor and support the adoption of small electric vehicles and will consider additional small electric vehicles in its fleet.

Environmental Benefits (5.4.3.2.B.5)

An investment in new vehicles should realize better fuel efficiency and less emissions as well as reduce the risk of engine oil and hydraulic oil leaks and spill due to deteriorated equipment.

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

The Results of Quantitative and Qualitative Analyses (5.4.3.2.C.d.first bullet)

As stated in the WNNH Fleet Asset Management Plan all WNNH fleet assets (large, medium, small and rolling stock) are analyzed at least annually through their life cycle. The Asset Condition Assessment scheme establishes a score for each fleet asset. Additionally, qualified Fleet Technicians inspect and maintain each vehicle offering first hand information about each vehicle and enabling evidence-based decisions to refurbish or replace. Once a vehicle replacement is planned, WNNH continues to acquire, operate, inspect, maintain and dispose of each vehicle. Specifically, the decision to replace R61 was based on a quantifier from the Asset Condition Assessment score where in 2020 the vehicle is in poor condition with a degradation score of 47%. The qualifiers from in-house Fleet Technicians confirm the deterioration of vehicle is beyond any further refurbishment. As stated herein, the engine of R61 was refurbished with head gasket in 2018 extending the useful life of the vehicle to almost 16 years. Additional repair on the vehicles electrical system and the condition of the body make this a clear priority for replacement in 2021. The vehicle is used daily on an overhead construction crew where any downtime would be a significant obstacle in meeting our objectives.

Business Case Documentation for Project Substantially Exceeding Threshold of Materiality (5.4.3.2.C.d.second bullet)

WNNH recognizes that this project exceeds the materiality threshold however it does not exceed it to the level implied in Chapter 5 filing requirements.

General Information on the project/program (5.4.3.2.A)

Project Name Information Technology Asset Life Cycle

OEB Investment Category General Plant

Project Description This project covers all life-cycling of hardware and software assets that support daily business activities This includes but is no limited to switches, firewalls, servers, end user devices as well as core systems such as customer information, accounting, internet, geographical information and other essential systems.

Detailed Listing of Affected Line Sections The following individual projects are covered by this project category:

WNH Project	Sub Project	Project Name	Total
06SS02	50	IT - Labour	\$71,340
06SS02	9	3yr Laptop Replacement	\$43,997
06SS02	7	Server Upgrades	\$38,901
06SS02	10	5yr PC Replacement	\$31,197
06SS02	16	Corporate Wireless Upgrade and Ethernet	\$26,203
06SS02	11	Hardware Departmental Miscellaneous	\$10,000
06SS02	13	New Monitors	\$2,500
06SS03	50	IT - Capital	\$50,106
06SS03	16	Docova U/G to MS SQL	\$40,000
06SS03	15	Software Departmental Miscellaneous	\$10,000
06SS03	12	B/I - New Development / Licenses	\$3,702
Total			\$ 327,946

Capital Investment (5.4.3.2.A.first bullet)

Total Capital **\$327,946**

O&M Costs (if applicable) **\$0** Not Applicable

Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)

CCRA Contribution **\$0**

Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)

Customer Attachments (#):

Customer Load (peak KVA)

Project Timing (5.4.3.2.A.fourth bullet)

Start Date Jan-2021

Expected In-Service Date Dec-2021

Expenditure Timing

2021 Q1	40%	\$131,178
2021 Q2	25%	\$81,987
2021 Q3	25%	\$81,987
2021 Q4	10%	\$32,795

Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)

Schedule risks for this work are greatest for software systems where labour resources depend on partner and vendor availability. To mitigate this WNH works directly with each vendor to plan work far in advance.

Other potential issues can occur if there is a shortage of specific hardware items within the supply chain which can be mitigated through multiple suppliers and alternative build types.

Comparative Information (5.4.3.2.A.sixth bullet)

Comparable investments in previous years are as follows:

2016:	\$111,028	The historical years are representative of typical expenditures.
2017:	\$200,116	
2018:	\$212,975	
2019:	\$198,469	
2020:	\$323,891	

Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet) Not Applicable

Leave to Construct Approval (5.4.3.2.A.eighth bullet) Not Applicable

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for these projects is operational efficiency.
Related Objectives/Performance Targets	WNH Strategic Imperatives 5 (Productivity and Cost Reduction) & 6 (Organizational Effectiveness) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>Decisions to replace hardware assets are based on the following:</p> <ul style="list-style-type: none"> a) mean time to failure (MTTF) as published by the manufacturer b) health events on specific devices through monitoring c) ability to maintain and repair. <p>Decisions to replace/update software is based on:</p> <ul style="list-style-type: none"> a) support availability b) cost to maintain vs update c) market requirements.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	<p>Good utility practice involves a process of continual monitoring of health of our existing technology assets and systems without proactive maintenance and replacement based on a number of contributing factors critical systems such as OMS will experience performance issues and outages.</p> <p>In addition a periodic review of technology innovation and how it might apply to our systems and processes is also performed.</p>
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the General Plant category, WNH identifies underperforming assets or processes based on feedback received from customers, vendors, staff, tracking of performance, operating and maintenance costs. WNH also identifies opportunities for improvement in its ability to meet the WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) and compiles a complete list of projects for this category. To prioritize the execution of these projects, WNH takes into account additional drivers or benefits of completing the project. This typically includes improvements in: customer experience, worker safety, security, ability to continue to provide services to customers, opportunity for cost reduction, increase in productivity, operating efficiency, ability to operate and maintain systems, ability to adapt to future needs, and regulatory compliance. The greater the alignment with WNH Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a project, the higher its priority.</p> <p>Investments in System Service and System Renewal categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 10 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	
a) Do Nothing	Assets begin to fail causing outages. Outages result in failure to comply with market requirements and customer expectations.
b) Refurbish (Fix Components of Existing equipment)	Activities to refurbish technology assets is the first consideration in our technology asset life cycle. However, the rapid rate of advancement often means refurbishment is more costly both in expense and labour.
c) Replace with new equipment, same functionality (Like-for-Like)	Replacing with new equipment (like-for-like) is often not possible because of the rapid rate of change in technology. When like-for-like equipment can be found it is often more costly than new equipment due to low market supply. In addition, business requirements may outpace like-for-like technology. For example, a corporate firewall from 5-7 years ago (average life-cycle) may not support the traffic of a public facing GIS yet the business may want make this available to customers in the next 5 years.
d) Replace with new equipment, Increased Functionality	New equipment in IT technology rarely comes without increased functionality. A similar spend on storage technology in 2010 would provide 5x capacity and 1000x performance. Hence, this is the preferred option.
Effect on system operation efficiency and cost effectiveness (first bullet)	<p>Responsible asset life-cycling of both hardware, software has many cost and operational efficiency improvements.</p> <ul style="list-style-type: none"> a) newer technology typically performs much better than current for the same cost b) the labour force being trained will be familiar with modern technology. Finding labour to maintain and operate older technology can be very expensive c) older technology performs poorly from a process perspective. It is more difficult to integrate with trading partners and often introduces manual staff workarounds.
Net benefits accruing to customers (second bullet)	The "customer of the future" has already arrived. These customers would prefer to complete nearly 100% of their business transactions through digital methods such as online portals, chat, and email. WNH is committed to providing the best possible customer service which must include a seamless approach to continuous improvement regarding customer experience.

Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)

Information Technology (IT) and Operational Technology (OT) are both systems which rely on each other. Through improvements in OT WNH has been able to noticeably lower outage minutes experienced by customers. Failure to invest in IT would result in reduced outage savings going forward.

WNH's workforce has evolved as manual tasks have been automated by technology. Not too long ago every electric meter would be read manually in the field which is something that is no longer. The workforce, equipment and ability to do this work is also no longer available. Additionally the regulated environment now demands digital reads to be conducted on an hourly basis. The systems supporting this process are WNH business machines, Customer Information system and Regional network interface. If any of these systems have an outage, perform poorly or become unavailable we will fail to meet our objectives.

Scheduling Alternatives

WNH's existing practice is a staggered replacement of technology assets. Delayed implementation would disrupt workflow, customer experience and introduce inconsistent spending patterns.

Ownership and/or Funding Alternatives

While WNH is required to have some assets owned and operated on site. It is possible to shift some of capital cost towards operating through the modern "As a Service" model. This is typically not cheaper but it is being evaluated.

Safety (5.4.3.2.B.2)

Both planned and emergency work are conducted using data and communication tools that rely heavily on information technology assets. The integrity and availability of this information can affect the quality and safety of work in addition to being a platform for training and awareness.

Cyber-security, Privacy (5.4.3.2.B.3)

Every hour of every day a new vulnerability (CVE) is published. These are only the discovered ones. Improvement in the technology used will enable better cyber security processes and reduce the risk of:

- a) service unavailability due to a cyber attack
- b) lost or stolen customer information
- c) damage to the integrity of our systems in a lasting way due to a cyber attack.

In addition the cyber-security of every project that involves technology depends on the foundation of our technology assets.

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

Collaboration for research, testing and procurement of technology assets exists. This takes place through regional communication, working groups and joint projects efforts where applicable.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

WNH is on a path in regards to technology towards a high level of agility which will enable WNH to adapt to future requirements at an extremely fast rate. To accomplish a high level of technological agility WNH will heavily favour the following for all future technology purchases:

- a) standard, open and whenever possible non-proprietary technology
- b) use of APIs for scalable integration
- c) software defined storage, networks and communications
- d) distributed system architecture that scales with ease and reduces single points of failure
- e) innovation within the culture of staff that will implement WNH's life-cycle.

Environmental Benefits (5.4.3.2.B.5)

Not Applicable

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

The Results of Quantitative and Qualitative Analyses (5.4.3.2.C.d.first bullet)

Quantitative analysis is not available. Qualitative analysis is described in relevant sections of 5.4.3.2.B above.

Business Case Documentation for Project Substantially Exceeding Threshold of Materiality (5.4.3.2.C.d.second bullet)

WNH recognizes that this project exceeds the materiality threshold however it does not exceed it to the level implied in Chapter 5 filing requirements.

General Information on the project/program (5.4.3.2.A)

Project Name	Operation Technology Software																		
OEB Investment Category	General Plant																		
Project Description	<p>WNH's Graphical Information System (GIS) is the cornerstone software of this project category. The current geometric network based GIS technology was developed in the 80's. WNH's GIS provider, Environmental Systems Research Institute (ESRI), announced that due to the limitations of this 30+ year old technology, this system will have reached the end of its useful life and is ending support for this technology by January 2024. At that time support, maintenance and security updates to their existing offering, as well as their accompanying applications will no longer be available to users.</p> <p>ESRI is providing a migration path to utility network based GIS, ESRI's current technology. The utility network provides numerous enhancements to overcome the limitations of the geometric network and address the industry specific needs of Local Distribution Companies that were not envisioned when the geometric network was developed. These include: integration with more systems and devices, eliminating the need for client side software, simplified data sharing, data accessibility and editing using web connectivity, support of 3D visualization, more detailed and accurate data collection as it relates to field assets. ESRI also created templates for current users to migrate data from their Geometric Network over to the Utility Network to minimize the need to recreate or replicate data.</p> <p>WNH began preparing for this change in 2019 with Phase I of WNH's migration to the utility network, which concludes in 2020 and includes: staff training, data mapping design, and piloting WNH data in ESRI's utility network environment.</p> <p>Full deployment of the new framework is a multi-year project. It starts with Phase II in 2021 which will include: system migration, web app and service development, testing and by the end of the year, running the utility network in WNH's production GIS environment, while still maintaining the necessary links to the legacy geometric network. Subsequent phases in 2022 and through to the end of 3rd quarter in 2023 WNH plans to migrate all applications, integrations, interfaces and business process to the utility network, allowing for decommissioning of the geometric network.</p> <p>Each year WNH looks to enhance existing or develop new GIS applications used by WNH staff. In 2021, these plans include the development of an OEB repair app. This app will be integrated with WNH's existing OEB inspection app using ESRI's Workforce for ArcGIS. It will use outputs from the OEB inspection app to identify all needed repairs, track the repair status, timestamp when repairs are completed and also fulfill all regulatory requirements around safety. In subsequent years new apps will also be added. These include: a streetlight repair app where the public can report streetlight outages/issues, an interactive dashboard with a live link to WNH's outage logging software showing outage location, cause, and date, as well as data sharing with municipalities and other utilities. New apps are also contemplated as opportunities arise.</p>																		
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																		
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN13</td><td>21</td><td>GIS Migration - Geometric Network-to-Utility Network Phase II</td><td>\$209,987</td></tr><tr><td>06EN13</td><td>19</td><td>Mobile Apps & Enterprise Web Service</td><td>\$71,535</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 281,522</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN13	21	GIS Migration - Geometric Network-to-Utility Network Phase II	\$209,987	06EN13	19	Mobile Apps & Enterprise Web Service	\$71,535			Total	\$ 281,522
WNH Project	Sub Project	Project Name	Total																
06EN13	21	GIS Migration - Geometric Network-to-Utility Network Phase II	\$209,987																
06EN13	19	Mobile Apps & Enterprise Web Service	\$71,535																
		Total	\$ 281,522																
Capital Investment (5.4.3.2.A.first bullet)	Total Capital \$281,522																		
	O&M Costs (if applicable) \$0 Not Applicable																		
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution \$0																		
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#): Not Applicable Customer Load (peak KVA) Not Applicable																		
Project Timing (5.4.3.2.A.fourth bullet)	Start Date Jan-2021 Expected In-Service Date Dec-2021 Expenditure Timing 2021 Q1 10% \$28,152 2021 Q2 20% \$56,304 2021 Q3 40% \$112,609 2021 Q4 30% \$84,457																		
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	<p>With deployment of relatively new software to the industry, there are two main schedule risks that required WNH to develop risk mitigation methods: lack of employee skill set and shortage of industry skill set with respect to the new software.</p> <p>The employee skill set risks are controllable by WNH. To mitigate this risk WNH plans to start required training in 2020 through structured courses and a learning sandbox environment provided by the vendor. This approach will also help in becoming educated in selecting the right partners for the implementation stage of this project.</p> <p>The second risk of shortage of skilled industry resources is addressed by starting this project ahead of other users to minimize competition for the same resources. Starting Phase II of the project in 2021 will provide WNH enough lead time to complete the GIS system migration prior to the end of support for the existing geometric network GIS by January 2024.</p>																		

Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:	
	2016:	\$76,913
	2017:	\$176,028
	2018:	\$282,834
	2019:	\$278,783
	2020:	\$251,346
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)		Not Applicable
Leave to Construct Approval (5.4.3.2.A.eighth bullet)		Not Applicable

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver of the project is functional obsolescence as announced by the GIS vendor. The current geometric network based GIS will no longer be supported as of January 2024.
Related Objectives/Performance Targets	WNN Strategic Imperative 3 (Customer Service) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	ESRI announcement of milestone dates when existing support to the geometric network based GIS will no longer be available.
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary driver for these projects is the operational efficiency.
Related Objectives/Performance Targets	WNN Strategic Imperative 6 (Organizational Effectiveness) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Once fully deployed, Utility Network provides WNN with a GIS onto which new applications can be developed that support more functionality to engage internal and external stakeholders as GIS users, while obtaining better, faster up to date spatial asset information, allowing for more analysis and better business decisions. The Utility Network based GIS also provides a better environment to support web services and user applications, which in turn can improve the efficiency of daily business activities.
Good Utility Practice (5.4.3.2.B.1.b)	At WNN, the GIS system is a crucial component of a highly integrated ecosystem supporting day to day operation of the Control Centre and the distribution grid. It needs to be accurate and reliable in providing data to staff and to other integrated systems to support operational decisions. To ensure that standard is maintained through the migration process of the GIS, WNN plans to conduct a full needs analysis and gap analysis prior to the data migration. All systems that GIS supports and integrates with will be maintained and migrated to the new Utility Network GIS by maintaining a link to the Geometric Network GIS during the transition period. This is essential to maintain day to day operations reliably while implementing, configuring, and testing the new system and all other systems it must integrate to.
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the General Plant category, WNN identifies underperforming assets or processes based on feedback received from customers, vendors, staff, tracking of performance, operating and maintenance costs. WNN also identifies opportunities for improvement in its ability to meet the WNN Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) and compiles a complete list of projects for this category. To prioritize the execution of these projects, WNN takes into account additional drivers or benefits of completing the project. This typically includes improvements in: customer experience, worker safety, security, ability to continue to provide services to customers, opportunity for cost reduction, increase in productivity, operating efficiency, ability to operate and maintain systems, ability to adapt to future needs, and regulatory compliance. The greater the alignment with WNN Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a project, the higher its priority.</p> <p>Investments in System Service and System Renewal categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNN Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 13 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>a) Do Nothing Do nothing or deferring the projects to the following year will eventually result in the current GIS system becoming unsupported from a functionality and a cyber security point of view. Given the criticality of the GIS system to the day-to-day operation of the distribution system, this risk, and hence, this option is unacceptable.</p> <p>b) Continue to Run the Existing System and Perform Software Update Patches This option only allows for continued maintenance of the existing system until January 2024 after which there will be no new release, security patches or application development available any more. This option is not an alternative to system upgrade.</p> <p>c) Replace with new system, same functionality (Like-for-Like) Like-for-Like replacement option is common in solving hardware problems but not a proper option for solving a functionally obsolete software. Once a software is obsoleted by the vendor, it is no longer available for purchase to any user, therefore, this option is not available.</p> <p>d) Replace with system from new vendor Replacing the existing Geometric Network GIS with a different vendors GIS offering is another option. However, this option would require data migration/data mapping to a completely different, vendor specific platform, re-training of all staff on a new platform, rebuilding of all GIS applications that field staff currently use, and re-integration of all other ESRI GIS interfaces (e.g. OMS, CIS, Synergi). For these reasons this option was not deemed appropriate.</p> <p>e) Replace with new system, Increased Functionality Migrating from the existing Geometric Network GIS to the Utility Network GIS will not only address the concerns with obsolescence and lack of support, but also expand GIS functionality as not only the system of record but also as the system of engagement and system of insight. Utility Network GIS holds a web based environment that supports services and apps for users to increase productivity and operational effectiveness and therefore this option is the only viable option.</p>

Effect on system operation efficiency and cost effectiveness (first bullet)	It is not uncommon to expect increased O&M costs in the first year of implementing a relatively new system to the industry due to the learning curve of the administrators and users as well as discovery of software bugs that need to be resolved by the vendor. However, once fully implemented, the Utility Network web based GIS, makes the spatial asset information available to authorized users anywhere, anytime for their day to day work. Live data collection from the field can be validated, processed and updated to the system in real time. Users can create and share their maps with others in the organization. Organizations can share information by providing and subscribing to services through collaboration. These projects will ultimately improve efficiency of asset data collection and accuracy, support situational awareness platforms, increase efficiency and effectiveness of engineering and field staff.
Net benefits accruing to customers (second bullet)	Once the new web services based Utility Network GIS is fully in service it can provide better support for interactive map services to the public and allow customers to report outages or spot equipment failure. With the new GIS, utilities can accurately model their infrastructure in 3D which can help customers with accuracy of locates.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	There will be no immediate impact to reliability as a result of initiating this project. Over time, the new Utility Network technology and newly developed applications will facilitate better system modelling rules and data governance improving the quality of data to WNH's asset management system for performing failure and risk analysis. Ultimately, a more targeted guidance to proactive capital investments in the distribution system should lead to improvements in system reliability performance.
Scheduling Alternatives	These projects are part of a multi-year plan. It is budgeted at a paced amount each year to levelize the investment and resource availability. There could be a potential to defer, if other higher priority projects arise or an unforeseeable event happens during the year. However, since the obsolescence date is fixed, deferring this project would increase the scope of work in subsequent years, triggering resource shortages that would need to be solved by procuring additional contract resources at potentially higher overall costs.
Ownership and/or Funding Alternatives	Unlike hardware options, where leasing is an alternative, software licences must be owned and funded by the end user.
<u>Safety (5.4.3.2.B.2)</u> Safety is not a driver for this project. Safety is a key Strategic Imperative for WNH as identified in Exhibit 1.	
<u>Cyber-security, Privacy (5.4.3.2.B.3)</u> WNH will work with our IT department to ensure cyber security and privacy requirements are in place prior to and throughout the project. Contractors from third parties who will be working on WNH data will be required to sign a confidentiality agreement. The access to WNH systems whether on site or via a remote secured connection will be set up and monitored by our IT department and WNH GIS Staff.	
<u>Co-ordination, Interoperability (5.4.3.2.B.4)</u>	
Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a) Not Applicable	
Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b) The ArcGIS Utility Network uses connectivity, containment and structural attachment, three associated concepts to accurately model the wires, electrical assets and civil assets all together with inherent rules to enforce the data integrity while forming a traceable network from tier to tier. The service based web environment enables user access anytime, anywhere and makes real-time GIS field changes and map service updates possible. Users within the organization can share data, publish maps or conduct their own spatial analysis to engage people and make better business decisions more effectively. Using the web GIS portal organizations can share information through data collaboration, e.g. the municipalities can share their water, sewer and storm infrastructure as map services with hydro utilities and vice versa to allow businesses to operate more efficiently and effectively. Mobile applications also make engineering design, field inspection, asset management, outage management, emergency response and workforce management more productive and efficient.	
<u>Environmental Benefits (5.4.3.2.B.5)</u> Not Applicable	
<u>Conservation and Demand Management (5.4.3.2.B.6)</u>	
Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet) Not Applicable	
Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet) Not Applicable	
How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet) Not Applicable	

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

The Results of Quantitative and Qualitative Analyses (5.4.3.2.C.d.first bullet) Please see answers provided to Section 5.4.3.2.B.1.d and Section 5.4.3.2.B.4.b above.
Business Case Documentation for Project Substantially Exceeding Threshold of Materiality (5.4.3.2.C.d.second bullet) WNH recognizes that this project exceeds the materiality threshold however it does not exceed it to the level implied in Chapter 5 filing requirements.

General Information on the project/program (5.4.3.2.A)

Project Name	Building and Furniture Improvements																														
OEB Investment Category	General Plant																														
Project Description	<p>This program provides for the replacement of systems and equipment associated with WNH's Administration and Service Centre. Systems and equipment support day-to-day business, operating efficiency, customer service and worker productivity.</p> <p>Expenditures in are selected by the value they bring in supporting the operational and administrative function of the company. Value is based on proposed benefits, risk mitigation and alignment with WNH's Strategic Imperatives and the OEB's RRFE outcomes. Material building projects are identified through poor performance, inspection and maintenance with the assistance of third part consultants in the building technologies and construction field.</p> <p>In 2021 the program consists of a number of expenditures below the level of materiality, including furniture items, building system components, as well as power quality and Protection & Control test equipment.</p>																														
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:																														
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06EN01</td><td>1</td><td>Engineering Furniture & Equipment</td><td>\$13,500</td></tr><tr><td>06MT04</td><td>1</td><td>Metering Furniture & Equipment</td><td>\$45,000</td></tr><tr><td>06OA01</td><td>1</td><td>System Control Chairs</td><td>\$1,700</td></tr><tr><td>06SN07</td><td>1</td><td>Stations Furniture & Equipment</td><td>\$73,000</td></tr><tr><td>12SC02</td><td>1</td><td>General Facilities</td><td>\$117,500</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 250,700</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06EN01	1	Engineering Furniture & Equipment	\$13,500	06MT04	1	Metering Furniture & Equipment	\$45,000	06OA01	1	System Control Chairs	\$1,700	06SN07	1	Stations Furniture & Equipment	\$73,000	12SC02	1	General Facilities	\$117,500			Total	\$ 250,700
WNH Project	Sub Project	Project Name	Total																												
06EN01	1	Engineering Furniture & Equipment	\$13,500																												
06MT04	1	Metering Furniture & Equipment	\$45,000																												
06OA01	1	System Control Chairs	\$1,700																												
06SN07	1	Stations Furniture & Equipment	\$73,000																												
12SC02	1	General Facilities	\$117,500																												
		Total	\$ 250,700																												
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$250,700																													
	O&M Costs (if applicable)	\$0 Not Applicable																													
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0																													
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	Not Applicable																													
	Customer Load (peak KVA)	Not Applicable																													
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021																													
	Expected In-Service Date	Dec-2021																													
	Expenditure Timing																														
	2021 Q1	73%	\$183,011																												
	2021 Q2	0%	\$0																												
	2021 Q3	22%	\$55,154																												
	2021 Q4	5%	\$12,535																												
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	These projects have no significant risk factors associated with their execution.																														
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:																														
	2016:	\$175,148	The historical years are representative of typical expenditures.																												
	2017:	\$240,318																													
	2018:	\$248,038																													
	2019:	\$215,018																													
	2020:	\$299,600																													
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable																														
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable																														

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver is age and condition of systems and equipment.
Related Objectives/Performance Targets	WNH Strategic Imperatives of 3 (Customer service), 5 (Productivity and Cost Reduction) & 6 (Organizational Effectiveness) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	<p>As assets approach end of life or as condition assessments indicate need for action, WNH begins to examine replacement and refurbishment options to minimize over all life-cycle cost. Relevant technical and economic considerations that are integrated into this approach include past asset performance; condition; age; probability of failure; criticality or consequence of failure; replacement and refurbishment cost and lead time options.</p> <p>Material building projects are identified through poor performance, inspection and maintenance with the assistance of third party consultants in the building technologies and construction field.</p>
Secondary Driver(s) (5.4.3.2.B.1.a)	The secondary driver for this project is functional obsolescence.
Related Objectives/Performance Targets	WNH Strategic Imperatives of 3 (Customer service), 5 (Productivity and Cost Reduction) & 6 (Organizational Effectiveness) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	Functional obsolescence forces a number of system and equipment investments. As equipment becomes older, vendors may no longer provide: technical support; new functionality, enhanced cyber security protection, and replacement parts. Newer releases of software require more powerful hardware systems to run. Functional obsolescence is generally triggered by vendor notifications or bulletins, but sometimes also triggered by vendors going out of business.
Good Utility Practice (5.4.3.2.B.1.b)	Good utility practice involves a process of continual monitoring of health of our existing technology assets and systems with proactive maintenance and replacement based on a number of contributing factors. In addition, a periodic review of technology innovation and how it might apply to our systems and processes is also practiced.
Investment Priority (5.4.3.2.B.1.c)	<p>System Access investments are ranked as top priority, as they are mandated by regulation or code.</p> <p>Under the General Plant category, WNH identifies underperforming assets or processes based on feedback received from customers, vendors, staff, tracking of performance, operating and maintenance costs. WNH also identifies opportunities for improvement in its ability to meet the WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) and compiles a complete list of projects for this category. To prioritize the execution of these projects, WNH takes into account additional drivers or benefits of completing the project. This typically includes improvements in: customer experience, worker safety, security, ability to continue to provide services to customers, opportunity for cost reduction, increase in productivity, operating efficiency, ability to operate and maintain systems, ability to adapt to future needs, and regulatory compliance. The greater the alignment with WNH Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a project, the higher its priority.</p> <p>Investments in System Service and System Renewal categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff.</p> <p>Based on the outcome of this process, this project ranks 15 out of 16. Refer to Table 4-22 of the DSP for further details.</p>
Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)	<p>Building systems & equipment under this project have been identified as being in poor condition, end of life or functional obsolescence and in need of replacement. In light of this fact, WNH considered the following alternatives:</p> <p>a) Do Nothing The systems and equipment in this project category already began to fail, are no longer in stock or supported by the vendor, or are obsolete. The Do Nothing option would result in failure to comply with regulatory obligations and customer expectations, and hence, is not considered appropriate.</p> <p>b) Refurbish (Fix Components of Existing equipment) Activities to refurbish building systems and equipment is the first consideration. The building systems and equipment have already been refurbished and subsequent refurbishment is not a good option. The rapid rate of advancement often means refurbishment is more costly both in capital and labour. Therefore, this option is no longer considered appropriate.</p> <p>c) Replace with new equipment, same functionality (Like-for-Like) This is the preferred option for furniture (Projects 06EN01 and 06OA01) and the building automation system controllers, the heat pump compressors, the fuel filling station and the skylight replacement (components of Project 12SC02). These systems are not obsolete and the same functionality is available, safe and reliable.</p> <p>d) Replace with new equipment, Increased Functionality This is the preferred option for most video systems and test equipment. New equipment and systems rarely come without increased functionality, allowing for enhanced reliability and performance with no increased maintenance.</p>
Effect on system operation efficiency and cost effectiveness (first bullet)	Power quality analyzer and protection test sets are critical to the daily functions of the distribution system. Their replacement will ensure that this work can continue being done reliably.
Net benefits accruing to customers (second bullet)	The replacement of systems and equipment support day-to-day business and operating activities. The power quality analyzer is critical in locating and resolving customer complaints related to power quality as well as in supporting WNH's regulated requirement to conduct stray voltage investigations.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	This investment does not have a significant impact on system reliability performance. This investment supports WNH's ability to troubleshoot outage issues. Any delay in system repair or restoration efforts during an outage would lengthen the outage duration and have negative impact on reliability.
Scheduling Alternatives	System and equipment investments are important in supporting day-to-day business and operations activities. These investments need to occur; however, they tend to be more flexible in scheduling which allows WNH to utilize them to build a more levelized overall investment plan.

Ownership and/or Funding Alternatives

These projects consist solely of WNH's assets. There are no ownership or funding alternatives.

Safety (5.4.3.2.B.2)

Safety is not a driver for this project. Safety is a key Strategic Imperative for WNH as identified in Exhibit 1.

Cyber-security, Privacy (5.4.3.2.B.3)

WNH will work with our IT department to ensure cyber security and privacy requirements are in place prior and throughout any implementation of new systems. Contractors from third parties who will be working on WNH data or systems will be required to sign a confidentiality agreement. The access to WNH systems whether on site or via a remote secured connection will be set up and monitored by our IT department and WNH Facilities staff.

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

Not Applicable

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

This investment does not have a significant impact on future technological functionality or future operational requirements.

Environmental Benefits (5.4.3.2.B.5)

Reduced risk of fuel spills due to leaking fuel station pumps.

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

The Results of Quantitative and Qualitative Analyses (5.4.3.2.C.d.first bullet)

Functional obsolescence, age and condition and end of life of systems and equipment justify these expenses. Vendor quotes have been obtained and negotiated to bring costs down to a minimum.

Business Case Documentation for Project Substantially Exceeding Threshold of Materiality (5.4.3.2.C.d.second bullet)

WNH recognizes that this project exceeds the materiality threshold however it does not exceed it to the level implied in Chapter 5 filing requirements.

General Information on the project/program (5.4.3.2.A)

Project Name	MS/DS Decommissioning														
OEB Investment Category	General Plant														
Project Description	<p>System Renewal investments made between 2016 – 2019 allowed WNH to retire the last five of its 4.16 kV municipal transformer stations from service. WNH has also been able to retire all of the remaining 4.16 kV lines and distribution transformers in the City of Waterloo and the Town of Elmira. Similarly, WNH has retired two 8.32 kV stations.</p> <p>As a result of these investments, WNH determined that a number of these former station properties no longer provide benefit to the distribution system and are considered surplus. These are relatively small properties that vary in location, size, environmental condition and market value. Continuing to own such sites not only continues unnecessary maintenance costs such as taxes or property insurance, but also represents a general as well as environmental liability.</p> <p>This category of projects represents expenditures involved in the decommissioning of WNH owned substations, including, complete demolition of site structures, environmental remediation of soils and ground water, final site cleanup and restoration in preparation for their disposal. Assets removed from service are disposed of in a manner compliant with statutory and regulatory requirements. Once work is complete, O&M savings will be approximately \$19,000 annually for each station. WNH also avoids the need for further capital renewal investments for the related distribution station buildings & equipment.</p> <p>These projects typically extend over multiple years and are currently in various stages of decommissioning and environmental remediation. The project costs listed below are for 2021 only and are needed to complete phase II environmental assessments and associated work at three different sites and prepare them for sale. No properties are planned to be sold prior to the end of 2021.</p>														
Detailed Listing of Affected Line Sections	The following individual projects are covered by this project category:														
	<table><tr><th>WNH Project</th><th>Sub Project</th><th>Project Name</th><th>Total</th></tr><tr><td>06SN08</td><td>1</td><td>MS/DS De-commissioning</td><td>\$462,762</td></tr><tr><td></td><td></td><td>Total</td><td>\$ 462,762</td></tr></table>			WNH Project	Sub Project	Project Name	Total	06SN08	1	MS/DS De-commissioning	\$462,762			Total	\$ 462,762
WNH Project	Sub Project	Project Name	Total												
06SN08	1	MS/DS De-commissioning	\$462,762												
		Total	\$ 462,762												
Capital Investment (5.4.3.2.A.first bullet)	Total Capital	\$462,762													
	O&M Costs (if applicable)	\$0 Not Applicable													
Capital Contributions to a Transmitter (5.4.3.2.A.second bullet)	CCRA Contribution	\$0													
Customer Attachments/Load (kVA) (5.4.3.2.A.third bullet)	Customer Attachments (#):	Not Applicable													
	Customer Load (peak KVA)	Not Applicable													
Project Timing (5.4.3.2.A.fourth bullet)	Start Date	Jan-2021													
	Expected In-Service Date	Dec-2021													
	Expenditure Timing														
	2021 Q1	10%	\$46,276												
	2021 Q2	30%	\$138,829												
	2021 Q3	40%	\$185,105												
	2021 Q4	20%	\$92,552												
Schedule Risk and Risk Mitigation (5.4.3.2.A.fifth bullet)	The main risk factor associated with these projects occurs during the environmental assessments where unexpected issues may be discovered that increase the scope of the remediation required to the site. WNH attempts to mitigate this risk by using past projects with a similar scope of work to estimate the effort and cost required for remediation and reviewing the site history regarding spills or leaks that may have occurred. However, unknown contamination from previous land uses in the adjacent areas are difficult to predict.														
Comparative Information (5.4.3.2.A.sixth bullet)	Comparable investments in previous years are as follows:														
	2016:	\$488,315	Investment levels for this category vary depending on when stations are decommissioned, the remediation work required to sell the property and the intended end use of the property.												
	2017:	\$43,547													
	2018:	\$16,923													
	2019:	\$96,624													
	2020:	\$673,544													
Total Capital & OM&A Costs Associated with REG Investments (5.4.3.2.A.seventh bullet)	Not Applicable														
Leave to Construct Approval (5.4.3.2.A.eighth bullet)	Not Applicable														

Evaluation Criteria and information requirements for each project/program (5.4.3.2.B)

Efficiency, Customer Value, Reliability (5.4.3.2.B.1)

Main Driver (5.4.3.2.B.1.a)	The main driver for these projects is disposal of end of life surplus assets.
Related Objectives/Performance Targets	WNH Strategic Imperatives 5 (Productivity and Cost Reduction) as identified in Exhibit 1.
Source and Nature of the Information Used to Justify the Investment	O&M savings will be approximately \$19,000 annually for each station. WNH also avoids the need for further capital renewal investments for the related distribution station buildings & equipment. General, as well as environmental risks and liability are also reduced. Please refer to Section 3.1 of the DSP for further details on WNH's asset management process.
Secondary Driver(s) (5.4.3.2.B.1.a)	Not Applicable
Related Objectives/Performance Targets	Not Applicable
Source and Nature of the Information Used to Justify the Investment	Not Applicable
Good Utility Practice (5.4.3.2.B.1.b)	The investments in this category have no impact on reliability performance concerns, nor are they intended to be capable of addressing future challenges.
Investment Priority (5.4.3.2.B.1.c)	System Access investments are ranked as top priority, as they are mandated by regulation or code. Under the General Plant category, WNH identifies underperforming assets or processes based on feedback received from customers, vendors, staff, tracking of performance, operating and maintenance costs. WNH also identifies opportunities for improvement in its ability to meet the WNH Strategic Imperatives (refer to Table 4-4 of the DSP and Exhibit 1) and compiles a complete list of projects for this category. To prioritize the execution of these projects, WNH takes into account additional drivers or benefits of completing the project. This typically includes improvements in: customer experience, worker safety, security, ability to continue to provide services to customers, opportunity for cost reduction, increase in productivity, operating efficiency, ability to operate and maintain systems, ability to adapt to future needs, and regulatory compliance. The greater the alignment with WNH Strategic Imperatives, the greater the customer impact or the more drivers or benefits are attributed to a project, the higher its priority. Investments in System Service and System Renewal categories are prioritized in a similar fashion. Analysis of impact on customers and consideration of impact of project deferral are also considered. The compiled list of projects is reviewed and prioritized by Senior WNH Engineering, Operations, IT and Finance staff. Based on the outcome of this process, this project ranks 16 out of 16. Refer to Table 4-22 of the DSP for further details.

Analysis of the Project and Project Alternatives (5.4.3.2.B.1.d)

a) Do Nothing

This option is the least expensive, however carries the most risk. These sites generally have older equipment that leak oil and contaminate the soil or structures that cost more to fix or remove in the future due to rising environmental cleanup standards. This would also perpetuate ongoing maintenance costs (approximately \$19,000 per station annually).

b) Equipment Removal Only

This option minimizes site risk as the potential for oil leaks or damage from degrading structures/buildings is removed, however still carries the risk of environmental cross contamination of adjacent properties. This is the preferable option if WNH plans to re-purpose the site for their own use. Given that the properties in this project category bring no benefit to the distribution system and have been deemed surplus, continuing to own such sites not only continues unnecessary maintenance costs such as lawn care or taxes, but they also represent a general, as well as environmental liability. Delaying cleanup and disposal also carries the risk that the rising environmental cleanup standards could significantly increase future cleanup costs.

c) Remove Equipment, Remediate and Sell Property

This is the desired option when WNH does not plan to re-purpose the land for their own use. This option allows WNH to ensure that all equipment has been disposed of and the site has been cleaned up properly. It also removes any ongoing costs and risks associated with the property.

Effect on system operation efficiency and cost effectiveness (first bullet)	Decommissioning stations reduces future capital and O&M costs associated with those particular stations (approximately \$19,000 per year per station). When stations are decommissioned the areas they served are converted to a higher, more efficient voltage level.
Net benefits accruing to customers (second bullet)	By decommissioning the stations and disposing of the properties, WNH customers no longer have to pay for the costs associated with owning those properties or carry the risk of substantial future disposal cost increases.
Impact of Investment on reliability performance (including on the frequency and duration of outages) (third bullet)	The investments in this category do not have an impact on reliability.
Scheduling Alternatives	If other projects of a higher priority appear in the year, this project can be deferred if need be. However, this comes at the risk of significant increases to future disposal costs due to rising environmental cleanup standards as well as additional unplanned operating costs for property maintenance and continued general and environmental liability.
Ownership and/or Funding Alternatives	There are no ownership or funding alternatives as this is WNH owned equipment and land.

Safety (5.4.3.2.B.2)

By removing all above grade structures and contaminated soil from the properties the risk to the public is minimized.

Cyber-security, Privacy (5.4.3.2.B.3)

Not Applicable

Co-ordination, Interoperability (5.4.3.2.B.4)

Coordination with utilities, regional planning and/or links with 3rd parties (where applicable) (5.4.3.2.B.4.a)

WNH is obligated to give the first right of refusal to the municipal shareholder in whose service territory the surplus land is located. WNH works closely with the appropriate municipality to determine their interest in purchasing the property.

Enabling of future technological functionality or addressing of future operational requirements (5.4.3.2.B.4.b)

This investment does not have a significant impact on future technological functionality or future operational requirements.

Environmental Benefits (5.4.3.2.B.5)

By removing all above ground structures and contaminated soil and completing environmental assessments WNH removes any hazardous material from the site and disposes of it properly.

Conservation and Demand Management (5.4.3.2.B.6)

Assessment of benefits of project for customer in terms of cost impacts to customers (where measurable) (5.4.3.2.B.6.first bullet)

Not Applicable

Number of years proposed CDM program would be in place and number of years the required infrastructure would be deferred (5.4.3.2.B.6.second bullet)

Not Applicable

How advanced technology has been incorporated into the project, including interoperability and cyber security (if applicable) (5.4.3.2.B.6.third bullet)

Not Applicable

Category-specific requirements for each project/program - System Renewal (5.4.3.2.C.b.)

The Results of Quantitative and Qualitative Analyses (5.4.3.2.C.d.first bullet)

Please see detailed information in the Project Description above. WNH has not quantified the reduction in general liability and environmental risk.

Business Case Documentation for Project Substantially Exceeding Threshold of Materiality (5.4.3.2.C.d.second bullet)

WNH recognizes that this project exceeds the materiality threshold however it does not exceed it to the level implied in Chapter 5 filing requirements.

Appendix C:

KWCG IRRP Report (2015)

KITCHENER-WATERLOO- CAMBRIDGE-GUELPH REGION INTEGRATED REGIONAL RESOURCE PLAN

April 28, 2015



Integrated Regional Resource Plan

Kitchener-Waterloo-Cambridge-Guelph

This Integrated Regional Resource Plan (“IRRP”) was prepared by the IESO pursuant to the terms of its Ontario Energy Board licence, EI-2013-0066.

This IRRP was prepared on behalf of the KWCG Region Working Group, which included the following members:

- Independent Electricity System Operator
- Kitchener-Wilmot Hydro Inc.
- Waterloo North Hydro Inc.
- Cambridge & North Dumfries Hydro Inc.
- Guelph Hydro Electric Systems Inc.
- Hydro One Networks Inc. (Distribution) and
- Hydro One Networks Inc. (Transmission)

The KWCG Region Working Group assessed the adequacy of electricity supply to customers in the KWCG Region over a 20-year period; developed a flexible, comprehensive, integrated plan that considers opportunities for coordination in anticipation of potential demand growth scenarios and varying supply conditions in the KWCG Region; and developed an implementation plan for the recommended options, while maintaining flexibility in order to accommodate changes in key assumptions over time.

KWCG Region Working Group members agree with the IRRP’s recommendations and support implementation of the plan through the recommended actions. KWCG Region Working Group members do not commit to any capital expenditures and must still obtain all necessary regulatory and other approvals to implement recommended actions.

Table of Contents

1. Introduction.....	1
2. The Integrated Regional Resource Plan.....	3
2.1 Near- and Medium-Term Plan (2014-2023)	3
2.2 Long-Term Plan (2024-2033)	5
3. Development of the IRRP	7
3.1 The Regional Planning Process	7
3.2 The IESO's Approach to Regional Planning.....	10
3.3 KWCG Working Group and IRRP Development	11
4. Background and Scope of the KWCG IRRP.....	13
4.1 Scope of the KWCG IRRP.....	13
4.2 Existing Electricity System in the KWCG Region.....	15
5. Demand Forecast	17
5.1 Historical Electricity Demand.....	17
5.2 Demand Forecast Methodology	18
5.3 Near- and Medium-Term Planning Forecast.....	20
5.3.1 Gross Demand Forecast	20
5.3.2 Estimated Peak Demand Savings from Provincial Energy Conservation Targets	21
5.3.3 Expected Peak Demand Contribution of Contracted Distributed Generation	23
5.3.4 Planning Forecast.....	23
5.4 Long-Term Planning Forecast	24
5.4.1 High-Growth Scenario	25
5.4.2 Low-Growth Scenario	26
5.5 Summary of Demand Forecast	27
6. Near- and Medium-Term Plan.....	28
6.1 Needs Assessment Methodology	28
6.2 Summary of Near- and Medium-Term Needs.....	29
6.2.1 Supply Capacity Needs on the South-Central Guelph and Kitchener-Guelph 115 kV Systems.....	31

6.2.2	Load Restoration Needs on the Waterloo-Guelph, and Cambridge-Kitchener 230 kV Sub-system.....	31
6.3	Options to Address the Near- and Medium-Term Needs.....	32
6.3.1	Guelph Area Transmission Refurbishment (GATR) Project.....	33
6.3.2	Options to Improve Load Restoration on the Cambridge-Kitchener 230 kV Sub-system.....	35
6.4	Recommendations for the Near and Medium Term	38
7.	Long-Term Plan (2024-2033)	40
7.1	Summary of Long-Term Needs.....	40
7.1.1	High-Growth Scenario – Long-Term Needs	40
7.1.2	Low-Growth Scenario – Long-Term Needs	41
7.2	Approaches to Address Long-Term Needs	42
7.2.1	Community Self-Sufficiency	42
7.2.2	Delivering Provincial Resources (“Wires” Planning)	46
7.2.3	Large, Localized Generation Resources.....	47
7.3	Recommendations for the Long Term.....	49
8.	Community, Aboriginal and Stakeholder Engagement.....	51
9.	Conclusion	55

List of Figures

Figure 3-1: Levels of Electricity System Planning	9
Figure 3-2: Steps in the IRRP Process	11
Figure 4-1: Kitchener, Waterloo, Cambridge and Guelph Area	14
Figure 4-2: KWCG Electricity System	15
Figure 4-3: LDC Service Area	16
Figure 5-1: Historical Summer Peak Demand in the KWCG Region	18
Figure 5-2: Development of a 20-Year Planning Forecast	19
Figure 5-3: Gross Demand Forecast by LDCs	21
Figure 5-4: KWCG Near-and Medium-Term Planning Forecast 2014-2023	24
Figure 5-5: Long-Term Planning Forecast Scenarios 2024-2033	25
Figure 5-6: High-Growth Scenario – Incremental Peak Demand Growth 2024-2033 by Municipality.....	26
Figure 5-7: Historical Peak Demand, Planning Forecast and Long-Term Scenarios.....	27
Figure 6-1: Regional Sub-systems in the KWCG Region.....	30
Figure 6-2: Guelph Area Transmission Refurbishment (GATR) Project.....	34
Figure 6-3: Two Circuit Switchers at Galt Junction.....	36
Figure 7-1: Remaining Transmission Supply Capacity 2024-2033.....	41
Figure 7-2: Potential Transmission Supply into the KWCG Region.....	47
Figure 7-3: Large, Transmission-Connected Generation Option	48
Figure 8-1: Summary of the KWCG IRRP Community Engagement Process.....	52

List of Tables

Table 6-1: Near- and Medium-Term Needs in the KWCG Region	30
Table 6-2: Summary of Needs Addressed by the GATR Project	35
Table 6-3: Implementation of the Near-Term Plan for the KWCG Region.....	39
Table 7-1: Implementation of Near-Term Actions in Support of the Long-Term Plan for KWCG Region.....	50

List of Appendices

Appendix A: Demand Forecasting – Methodology and Assumptions

Appendix B: Needs Assessment

Appendix C: Transmission Options to Improve Load Restoration on Cambridge-Kitchener
230 kV Sub-system

List of Abbreviations

Abbreviation	Description
BCP	Brant County Power
C&S	Codes and Standards
CDM	Conservation Demand Management
CEP	Community Energy Plan
CHP	Combined Heat and Power
CHPSOP	Combined Heat and Power Standard Offer Program
DG	Distributed Generation
DR	Demand Response
ECO	(Region of Waterloo's) Energy Conservation Office
EV	Electric Vehicle
EE	Energy Efficiency
FIT	Feed-in Tariff
GATR	Guelph Area Transmission Refurbishment
GS	Generating Station
GHG	Greenhouse Gases
GDP	Gross Domestic Product
IESO	Independent Electricity System Operator
IPSP	(2007) Integrated Power System Plan
IRRP	Integrated Regional Resource Plan
KWCG Region or Region	Kitchener, Waterloo, Cambridge and Guelph
kV	Kilovolt
LAC	Local Advisory Committee
LRT	Light Rail Transit
LMC	Load Meeting Capability
LDC	Local Distribution Company
LED	Light Emitting Diode
LTEP	(2013) Long-Term Energy Plan
MW	Megawatt
MEP/CEP	Municipal or Community Energy Plan
MTS	Municipal Transformer Station
NERC	North American Electric Reliability Corporation
NPCC	Northeast Power Coordinating Council
OEB or Board	Ontario Energy Board
OPA	Ontario Power Authority
ORTAC	Ontario Resource and Transmission Assessment Criteria
PPWG	Planning Process Working Group

Abbreviation	Description
PV	Photovoltaic
RIP	Regional Infrastructure Plan
SCADA	Supervisory Control and Data Acquisition
SS	Switching Station
TWh	Terawatt Hour(s)
TOR	Terms of Reference
TOU	Time-of-Use
TS	Transformer Station
Working Group	Technical Working Group of the KWCG Region

1. Introduction

This report outlines the Integrated Regional Resource Plan (“IRRP”) for the Kitchener, Waterloo, Cambridge and Guelph (“KWCG”) Region (together “KWCG Region” or “Region”) over the next 20 years. This report was prepared by the IESO on behalf of a technical Working Group composed of Kitchener-Wilmot Hydro, Waterloo North Hydro, Guelph Hydro Electric Systems Inc., Hydro One Distribution, Cambridge and North Dumfries Hydro, and Hydro One Transmission (the “Working Group”).

The KWCG Region is located in southwestern Ontario and includes the Region of Waterloo, the City of Guelph, Wellington County and a portion of Oxford County. The population of the region is forecast to significantly grow during the 20-year period (2011-2031) – by roughly 40% – according to the province’s “Places to Grow” initiative.¹ This growth will be accompanied by population intensification, the development of regional transit infrastructure, redevelopment of the downtown areas, and the development of commercial and industrial parks. A reliable supply of electricity is essential to supporting community growth. There is therefore a strong need for integrated regional electricity planning to ensure that the electricity system can support the pace of development over the long term.

In Ontario, planning to meet the electrical supply and reliability needs of a large area or region is done through regional electricity planning, a process that was formalized by the Ontario Energy Board (“OEB” or “Board”) in 2013. In accordance with the OEB regional planning process, transmitters, distributors and the IESO are required to carry out regional planning activities for the 21 electricity planning regions at least once every five years.

The KWCG Region is one of the 21 electricity planning regions in Ontario as identified through the regional planning process. This IRRP fulfills the requirements for the Region as required by the IESO’s OEB licence.

This IRRP for KWCG identifies electricity supply and reliability needs in the near term (0-5 years), medium term (5-10 years) and long term (10-20 years), and sets out specific priorities and investments to meet near- and medium-term needs, respecting the lead time for development. This IRRP also identifies actions to develop long-term options and to facilitate discussions about how the communities may plan their future electricity supply. Since

¹ <http://www.placestogrow.ca/>

economic, demographic, and technological conditions will inevitably change, IRRPs will be reviewed on a five-year cycle so that plans can be updated to reflect the changing electricity outlook. The KWCG IRRP will be revisited in 2020 or sooner, if significant changes occur relative to the current forecast.

This report is organized as follows:

- A summary of the recommended plan for the Region is provided in Section 2;
- The process and methodology used to develop the plan are discussed in Section 3;
- The context for electricity planning in the Region and the study scope are discussed in Section 4;
- Demand forecast scenarios, and conservation and DG assumptions, are described in Section 5;
- The near- and medium-term plan is presented in Section 6;
- The long-term plan is presented in Section 7;
- A summary of community, aboriginal and stakeholder engagement to date and moving forward in developing this IRRP is provided in Section 8;
- A conclusion is provided in Section 9.

2. The Integrated Regional Resource Plan

The KWCG IRRP addresses the Region's electricity needs over the next 20 years, based on application of the IESO's Ontario Resource and Transmission Assessment Criteria ("ORTAC"). This IRRP identifies the needs that are forecast to arise in the near- and medium-term (0-10 years) and in the long-term (10-20 years). These two planning horizons are distinguished in the IRRP to reflect the level of commitment required to address needs over these time periods. The plans for both timeframes are coordinated to ensure consistency. The IRRP was developed based on consideration of planning criteria, including reliability, cost and feasibility; and, in the near term, it seeks to maximize the use of the existing electricity system, where it is economic to do so.

For the near- and medium-term, the IRRP identifies specific actions and investments for immediate implementation. This ensures that necessary resources are in service in time to address the KWCG Region's more urgent needs.

For the long term, the IRRP identifies potential approaches to meet needs that may arise in 10-20 years. It is not necessary to recommend specific projects at this time (nor would it be prudent given forecast uncertainty and the potential for technological change). Instead, the long-term plan focuses on developing and maintaining the viability of long-term options, engaging with the communities, and gathering information to lay the groundwork for making decisions on future options. These actions are intended to be completed before the next IRRP cycle in 2020 so that their results can inform a decision, should one be needed at that time.

The needs and recommended actions are summarized below.

2.1 Near- and Medium-Term Plan (2014-2023)

Today, the electricity system supplying the KWCG Region is approaching its maximum capacity and has limited ability to minimize potential supply interruptions to customers. The plan to meet the needs of electricity customers in the KWCG Region over the near and medium term was developed based on consideration of planning criteria, including reliability, cost, feasibility, and maximizing the use of the existing electricity system, where it is economic to do so. The near- and medium-term plan was also developed to be consistent with the long-term development of the Region's electricity system.

Recommendations

1. Implement conservation and distributed generation (LDCs/IESO)

The implementation of provincial energy conservation targets established in the 2013 Long-Term Energy Plan (“LTEP”) is a key component of the near- and medium-term plan for the KWCG Region. As part of the near- and medium-term plan, peak demand savings from provincial energy conservation targets are estimated to account for 40% of the forecast peak demand growth in the KWCG Region between 2014-2023.

To ensure that these savings materialize, it is recommended that the LDCs’ conservation efforts be focused not only on achieving their energy savings targets, but also maximizing peak demand reductions. Monitoring conservation achievements, and measuring peak demand savings, will be important elements of the near- and medium-term plan, and will also lay the foundation for the long-term plan by reviewing performance of specific conservation measures in the KWCG Region, and assessing potential in the KWCG Region for further conservation efforts.

Provincial programs that encourage the development of DG, such as the Feed-in Tariff (“FIT”), and Combined Heat and Power Standard Offer (“CHPSOP”) programs, and local interests and opportunities for distributed generation (“DG”) development can also contribute to reducing peak demand in the KWCG Region. The LDCs and the IESO will continue their activities to support these initiatives and monitor their impacts.

2. Implement the Guelph Area Transmission Refurbishment (GATR) project (Hydro One)

In 2012, the Working Group recommended proceeding with the implementation of the Guelph Area Transmission Refurbishment (“GATR”) project to address imminent supply needs in South-Central Guelph and the Kitchener area and to minimize the impact of potential supply interruptions to customers in Waterloo, Guelph and surrounding areas. This project includes the installation of two 115 kV/230 kV auto-transformers, switching facilities, and the upgrade of an existing transmission line in Guelph. The GATR project was approved by the OEB on September 26, 2013 and is expected to be in service by spring 2016. The project will substantially contribute to meeting near- and medium-term needs in the KWCG Region.

3. Install two circuit switchers at Galt Junction and explore opportunities to further improve restoration capability in the Cambridge area (Hydro One)

To substantially improve load restoration in the Cambridge and Kitchener area following a major transmission outage, the Working Group recommends proceeding with the installation of two 230 kilovolt (“kV”) circuit switchers at Galt Junction, near Highway 5. Hydro One has begun early development work on these switching facilities, which are expected to be in-service by spring 2017. Hydro One will continue to examine other potential measures to further improve the restoration capability in the Cambridge area. Please refer to Appendix C for further information regarding load restoration improvements for the Cambridge-Kitchener 230 kV sub-system.

2.2 Long-Term Plan (2024-2033)

There are no major regional supply and reliability needs identified in the KWCG Region beyond 2023, therefore early development work for major infrastructure projects in the KWCG Region is not required at this time. Localized needs, such as transformer station (“TS”) capacity needs in the KWCG Region, may arise over the long term under certain growth scenarios, but these potential needs do not require any immediate action. There may be opportunity for communities and local utilities to manage their future electricity demand through the development of community-based solutions. Communities and local utilities in the KWCG Region have become increasingly involved in the development of DG and conservation initiatives. The results of early community-based pilot projects, energy conservation initiatives, and achievable potential studies of the IESO will provide useful information to consider the potential for conservation to address identified needs in the KWCG Region in the next iteration of the plan and the ongoing regional planning process.²

Recommendations

1. Undertake community engagement (IESO/LDCs)

In between the 5-year regional planning cycle, the IESO and LDCs will continue to engage with First Nations communities and other stakeholders through community planning, environmental and sustainability initiatives, and broader community outreach such as, informational public open houses.

² The IESO’s is currently developing an achievable potential study scheduled to be completed by June 1, 2016. This study will provide an updated forecast for conservation potential in Ontario.

2. Monitor demand growth, conservation and demand management (CDM) achievement and distributed generation (IESO)

On an annual basis, the IESO will coordinate a review of conservation and demand management (“CDM” or “conservation”) achievement, provincial DG projects, and demand growth in the KWCG Region. This information will be used to track the expected timing of long-term needs to determine when a decision on the long-term plan is required. Information on CDM and DG performance will also provide useful input into the ongoing development of these options as potential long-term solutions.

3. Explore opportunities to coordinate use and development of transformation station facilities in the KWCG Region (LDCs)

Depending on the location, timing and magnitude of electricity demand growth, TS capacity needs may arise in the KWCG Region beyond 2023. LDCs will monitor the load closely to determine the timing of potential transformation needs. Where possible, these LDCs will coordinate use and development of transformation station facilities in the KWCG Region. The need, timing and location of transformer(s) will be confirmed in the next planning cycle.

3. Development of the IRRP

3.1 The Regional Planning Process

In Ontario, planning to meet the electricity needs of customers at a regional level is done through regional planning. Regional planning assesses the interrelated needs of a region - defined by common electricity supply infrastructure over the near, medium and long term, and develops a plan to ensure cost-effective, reliable, electricity supply. Regional plans consider the existing electricity infrastructure in an area, forecast growth and customer reliability, evaluate options for addressing needs, and recommend actions.

Regional planning has been conducted on an as needed basis in Ontario for many years. Most recently, the Ontario Power Authority (“OPA”) carried out regional planning activities to address regional electricity supply needs. The OPA conducted joint regional planning studies with distributors, transmitters, the IESO and other stakeholders in regions where a need for coordinated regional planning had been identified.

In 2012, the Ontario Energy Board convened the Planning Process Working Group (“PPWG”) to develop a more structured, transparent, and systematic regional planning process. This group was composed of industry stakeholders including electricity agencies, utilities, and stakeholders. In May 2013, the PPWG released its Working Group Report to the Board, setting out the new regional planning process. Twenty-one electricity planning regions in the province were identified in the Working Group Report and a phased schedule for completion was outlined. The Board endorsed the Working Group Report and formalized the process timelines through changes to the Transmission System Code and Distribution System Code in August 2013, as well as through changes to the OPA’s licence in October 2013. The OPA licence changes required it to lead a number of aspects of regional planning, including the completion of comprehensive IRRPs. Following the merger of the IESO and the OPA on January 1, 2015, the regional planning responsibilities identified in the OPA’s licence were transferred to the IESO.

The regional planning process begins with a Needs Screening process performed by the transmitter, which determines whether there are needs requiring regional coordination. If regional planning is required, the IESO then conducts a Scoping Assessment to determine whether a comprehensive IRRP is required, which considers conservation, generation, transmission, and distribution solutions, or whether a straightforward “wires” solution is the


only option. If the latter applies, then a transmission and distribution focused Regional Infrastructure Plan (“RIP”) is required. The Scoping Assessment process also identifies any sub-regions that require assessment. There may also be regions where infrastructure investments do not require regional coordination and can be planned directly by the distributor and transmitter, outside of the regional planning process. At the conclusion of the Scoping Assessment, the IESO produces a report that includes the results of the Needs Screening process – identifying whether an IRRP, RIP or no regional coordination is required - and a preliminary Terms of Reference. If an IRRP is the identified outcome, then the IESO is required to complete the IRRP within 18 months. If a RIP is required, the transmitter takes the lead and has six months to complete it. Both RIPs and IRRPs are to be updated at least every five years.

The final IRRPs and RIPs are to be posted on the IESO and relevant transmitter websites, and can be used as supporting evidence in a rate hearing or Leave to Construct application for specific infrastructure investments. These documents may also be used by municipalities for planning purposes and by other parties to better understand local electricity growth and infrastructure requirements.

Regional planning, as shown in Figure 3-1, is just one form of electricity planning that is undertaken in Ontario. There are three types of electricity planning in Ontario:

- Bulk system planning
- Regional system planning
- Distribution system planning

Figure 3-1: Levels of Electricity System Planning



Planning at the bulk system level typically considers the 230 kV and 500 kV network. Bulk system planning considers the major transmission facilities and assesses the resources needed to adequately supply the province. Bulk system planning is carried out by the IESO in accordance with government policy. Distribution planning, which is carried out by local distribution companies, looks at specific investments on the low voltage, distribution system.

Regional planning can overlap with bulk system planning. For example, overlap can occur at interface points where regional resource options may also address a bulk system issue. Similarly, regional planning can overlap with the distribution planning of LDCs. An example of this is when a distribution solution addresses the needs of the broader local area or region. Therefore, to ensure efficiency and cost-effectiveness, it is important for regional planning to be coordinated with both bulk and distribution system planning.

By recognizing the linkages with bulk and distribution system planning, and coordinating multiple needs identified within a given region over the long term, the regional planning process provides an integrated assessment of needs. Regional planning aligns near- and long-term solutions and allows specific investments recommended in the plan to be understood as part of a larger context. Furthermore, regional planning optimizes ratepayer interests by avoiding piecemeal planning and asset duplication, and allows Ontario ratepayers' interests to be represented along with the interests of LDC ratepayers. Where IRRPs are undertaken, they

allow an evaluation of the multiple options available to meet needs, including conservation, generation, and “wires” solutions. Regional plans also provide greater transparency through engagement in the planning process, and by making plans available to the public.

3.2 The IESO’s Approach to Regional Planning

IRRP’s assess electricity system needs for a region over a 20-year period. The 20-year outlook anticipates long-term trends so that near-term actions are developed within the context of a longer-term view. This enables coordination and consistency with the long-term plan, rather than simply reacting to immediate needs.


In developing an IRRP, a different approach is taken to developing the plan for the first 10 years of the plan—the near- and medium-term—than for the longer-term period of 10-20 years. The plan for the first 10 years is developed based on best available information on demand, conservation, and other local developments. Given the long lead time to develop electricity infrastructure, near-term electricity needs require prompt action to enable the specified solutions in a timely manner. By contrast, the long-term plan is characterized by greater forecast uncertainty and longer development lead time; as such solutions do not need to be committed to immediately. Given the potential for changing conditions and technological development, the IRRP for the long term is more directional, focusing on developing and maintaining the viability of options for the future, and continuing to monitor demand forecast scenarios.

In developing an IRRP, the IESO and regional working groups (see Figure 3-2 below) carry out a number of steps. These steps include electricity demand forecasts; technical studies to determine electricity needs and the timing of these needs; the development of potential options; and, a recommended plan including actions for the near and long-term. Throughout this process, engagement is carried out with communities, including local First Nations and Métis communities and stakeholders who may have an interest in the planning area. The steps of an IRRP are illustrated in Figure 3-2 below.

The IRRP report documents the inputs, findings and recommendations developed through the process described above, and provides recommended actions for the various entities responsible for plan implementation. Where “wires” solutions are included in the plan recommendations, the completion of the IRRP report is the trigger for the transmitter to initiate an RIP process to develop those options. Other actions may involve development of

conservation, local generation, or other solutions, community engagement, or information gathering to support future iterations of the regional planning process in the region.

Figure 3-2: Steps in the IRRP Process



3.3 KWCG Working Group and IRRP Development

Prior to the formation of the OEB’s Regional Planning Process in 2013, regional planning activities were undertaken by the IESO, the OPA, Hydro One and local LDCs in order to maintain a reliable supply of electricity to the KWCG Region. In the absence of a formalized process, regional planning activities in the area were triggered on an as needed basis, and solutions were examined, implemented, or deferred depending on the timing of electricity system requirements.

In 2003, as the result of a regional transmission study conducted by Hydro One and the local LDCs, a 115 kV/230 kV auto-transformer and associated remedial measures were installed at the Preston Transformer Station (“TS”) to improve the Region’s reliability. In 2007, in order to meet forecast electricity demand growth in the South-Central Guelph and Kitchener area, the Integrated Power System Plan (“IPSP”)³ recommended proceeding with the development of the GATR project. However, as a result of the global economic recession in 2008/2009, electricity

³ Integrated Power System Plan 2007 - EB-2007-0707 – Exhibit E Tab 5 Schedule 2

consumption declined across the KWCG Region and the development work for the GATR project was put on hold.

In 2010, the KWCG planning electricity supply study was initiated to re-assess electricity supply and reliability over the next 20 years. The OPA agreed that a coordinated, integrated approach was appropriate and formed the Working Group. The Working Group developed the Terms of Reference for the study⁴ and gathered data, identified near and long-term needs in the Region, and assessed a range of integrated options. In 2012/2013, the Working Group recommended proceeding with the implementation of GATR and initiating early development work on the second 115 kV/230 kV auto-transformer at Preston TS to address imminent supply and reliability needs in the KWCG Region.⁵ In March 2013, Hydro One submitted the Leave to Construct application for the GATR project and in September 2013, the application was approved by the OEB.⁶

In October 2013, the KWCG planning electricity supply study was transitioned to align with the OEB's new regional planning process. The Working Group revised the Terms of Reference to reflect the new process, and updated the study information, including demand forecasts and conservation and DG data.⁷ With this updated information, the Working Group re-confirmed the reliability and supply needs in the KWCG Region, re-examined the need for the second 115 kV/230 kV auto-transformer at Preston in the near term, and continued to revise the near-term plan and to develop recommendations for the long-term plan. This IRRP reflects this revised and updated information.

⁴ Original Terms of Reference:

<http://www.ieso.ca/Documents/Regional-Planning/KWCG/KWCG-Terms-of-References.pdf>

⁵ OPA Letter to Hydro One - March 8, 2012:

<http://www.ieso.ca/Documents/Regional-Planning/KWCG/Exhibit%20B-1-4,%20Attachments%201%20and%202.pdf>

OPA Letter to Hydro One - May 29, 2013:

<http://www.ieso.ca/Documents/Regional-Planning/KWCG/OPA-Letter-Hydro-One-KWCG.pdf>

⁶ (EB-2013-0056) Ontario Energy Board Decision and Order dated September 26, 2013

⁷ Revised July 2014 Terms of Reference (Addendum):

<http://www.ieso.ca/Documents/Regional-Planning/KWCG/Addendum-TOR-KWCG.pdf>

4. Background and Scope of the KWCG IRRP

The KWCG IRRP assesses the regional electricity supply and reliability needs for the KWCG Region, and identifies integrated solutions for the 20-year period from 2014 to 2033.

Specifically, this IRRP includes the following components:


- Examination of electricity demand requirements in the near- and medium-term (2014-2023) and under alternate long-term demand growth scenarios (2024-2033);
- Reliability and adequacy assessment of the electricity system in the KWCG Region;
- Development and evaluation of integrated alternatives including a mix of CDM, generation, transmission and distribution facilities, and other electricity system initiatives to address near- and medium-term electricity supply needs in this region (2014-2023);
- Assessment of alternate demand scenarios and development of potential approaches for the local community to address future long-term electricity supply needs (2024-2033); and
- Development of an implementation plan to address near- and medium-term electricity requirements and to ensure that options remain available to address long-term needs.

To set the context for this IRRP, the scope of this IRRP and a description of the Region are set out in Section 4.1. Section 4.2 details the existing transmission system in the KWCG Region.

4.1 Scope of the KWCG IRRP

The KWCG Region is located in southwestern Ontario and includes the Region of Waterloo, the City of Guelph, Wellington County and the Township of Blandford-Blenheim (Oxford County), as shown in Figure 4-1.

Figure 4-1: Kitchener, Waterloo, Cambridge and Guelph Area



The KWCG Region has an estimated population of 735,000.⁸ Based on growth plans, as detailed in the provincial Places to Grow Initiative,⁹ the population is forecast to increase by approximately 40% over a 20-year period (2011-2031). This is equivalent to adding 14,500 new residents and 6,500 new jobs each year. This growth will be accompanied by population intensification, the development of regional transit infrastructure, redevelopment of the downtown areas, and the development of commercial and industrial parks.

Given the mix of rural and urban development, the nature of growth and local developments may vary across the Region of Waterloo, City of Guelph, Wellington County and the Township of Blandford-Blenheim. The economic activities in the Region of Waterloo and the City of Guelph include a mix of educational institutions, manufacturing, and high-tech industries. For Wellington County and the Township of Blandford-Blenheim, the agriculture and manufacturing sectors play a key role in its economic development.


⁸ 2011 Census Data

⁹ <http://www.placestogrow.ca/>

4.2 Existing Electricity System in the KWCG Region

The KWCG Region relies primarily on the regional transmission and distribution infrastructure to deliver electricity into the local area, as there is no large, centralized generation resource in the region. The transmission system within the KWCG Region consists of an integrated 230 kV and 115 kV network. As shown in Figure 4-2, the main sources of electricity into the KWCG Region are Middleport Transformer Station, Detweiler TS, Orangeville TS, and Burlington TS.

Figure 4-2: KWCG Electricity System




Along these local 230 kV and 115 kV networks, there are three transmission-connected customers and 25 step-down transformers that enable electricity to be delivered from the high-voltage transmission system (115 kV or 230 kV) to the low-voltage distribution systems that serve the communities.

The local distribution system in the KWCG Region is operated and managed by five LDCs: Guelph Hydro Electric Systems Inc. ("Guelph Hydro"), Waterloo North Hydro Inc. ("Waterloo North Hydro"), Kitchener-Wilmot Hydro Inc. ("Kitchener-Wilmot Hydro") Hydro One

Networks Inc. (“Hydro One Distribution”), and Cambridge North Dumfries Hydro Inc. (“Cambridge North Dumfries Hydro”), as shown in Figure 4-3 below.

Figure 4-3: LDC Service Area



5. Demand Forecast


This section describes the specific details of the development of the regional demand forecast: Section 5.1 describes electricity demand trends in the region from 2004 to 2014; Section 5.2 describes the demand forecast methodology used in this study; Section 5.3 provides the near- and medium-term planning forecast; and Section 5.4 explains the long-term planning demand forecast.

5.1 Historical Electricity Demand

The KWCG Region electricity demand is a mix of residential, commercial and industrial loads, encompassing diverse economic activities ranging from educational institutions to automobile manufacturing. While the industrial and commercial sector is the largest consumer of electricity, high-energy-consuming end uses such as air conditioning also play a significant role in contributing to peak electricity demand. During the summer months, peak demand can also be influenced by extreme weather conditions, with peaks in demand typically occurring after several days of high temperatures.

As shown in Figure 5-1, the 2004-2014 historical summer peak demand has fluctuated between 1,250 MW to 1,450 MW, due to a combination of extreme summer temperatures and factors affecting commercial and industrial energy demand, such as the impact of the economic downturn, improvements in energy efficiency (“EE”), and the development of on-site generation. Specifically, the combination of the global recession and low summer temperatures resulted in a decrease in peak demand consumption during 2008 and 2009.

Figure 5-1: Historical Summer Peak Demand in the KWCG Region



In recent years, provincial policies and incentives encouraging conservation, demand response (“DR”) and on-site generation have provided opportunities for businesses and residents to better manage their electricity use. These initiatives have resulted in an increase in on-site generation, district energy systems and EE improvements for industrial, commercial, and municipal customers. This in turn has resulted in a reduced reliance on the provincial electricity grid. Local utilities in the KWCG Region have also observed more modest growth in electricity consumption in their service areas due to increased DG and conservation.

5.2 Demand Forecast Methodology


The regional electricity systems in southern Ontario are designed to meet regional coincident peak demand under extreme summer temperature conditions. Regional coincident peak demand is the 1-hour period each year when total regional demand for electricity is the highest.

For the purpose of the IRRP, a 20-year planning forecast is developed to assess supply and reliability needs at the regional level.

The 20-year planning forecast takes into consideration the gross demand forecast, estimated peak demand savings from provincial energy conservation targets, and expected peak capacity contribution of contracted DG, and adjusted to reflect extreme summer temperature conditions,

as shown in Figure 5-2. The methodology and assumptions used for the development of planning forecasts are described in detail in Appendix A.

Figure 5-2: Development of a 20-Year Planning Forecast



The 20-year planning forecast is divided into two timeframes. The first 10 years is developed under normal-year temperature conditions and is based on expected peak demand consumption growth projections from LDCs and from transmission-connected customers' in the LDC's service territory. These growth projections are modified to reflect the estimated peak demand savings from provincial energy conservation targets and contracted DG, and are also adjusted to reflect extreme temperature conditions. This modified forecast represents the near- and medium-term planning forecast, which is required to inform more immediate planning decisions.

For the 10-20-year timeframe, there is greater uncertainty with electricity demand growth, peak demand impact of conservation, DG, and emerging technologies. Longer-term demand scenarios, which consider policy drivers and emerging trends, are developed. These scenarios help communities anticipate potential future electricity demand requirements and electricity supply and reliability needs.

5.3 Near- and Medium-Term Planning Forecast


As described above, the near- and medium-term planning forecast (2014-2023) begins with the LDCs' gross demand forecast. Peak demand savings from provincial energy conservation targets and contracted DG are then deducted, and the forecast adjusted for extreme weather to produce the planning forecast. The details of this near- and medium-term forecast are described in the following sections.

5.3.1 Gross Demand Forecast

The gross demand forecast was initially developed in 2010 by the LDCs based on customer connection requests, local economic development and growth assumptions outlined in Ontario's *Places to Grow Act, 2005*, which are reflected in municipal and regional plans. LDCs periodically reviewed and updated the gross demand forecast for their service area to reflect the latest information and electricity demand trends.

Based on the most up-to-date information, LDCs indicate that the gross demand in the KWCG Region is expected to grow at an annual rate of 2.5% in the near and medium term. Consistent with the 2010 projection, Kitchener-Wilmot Hydro, Waterloo North Hydro, and Hydro One Distribution's service areas are forecast to grow at annual rates of 1.7%, 3.2%, and 1.1% respectively. Although Guelph Hydro has made a downward adjustment to the 2014 electricity peak demand level to align with current electricity consumption patterns, it expects electricity peak demand in its service area to grow at an annual rate of 3.4% over the next 10 years. In contrast, Cambridge and North Dumfries Hydro anticipate slower growth in the near term than initially forecast in 2010. A slower than expected economic recovery and a decline in energy usage from industrial customers are the primary reasons for the reduced peak demand growth in the near and medium term. Figure 5-3 shows the gross demand forecast for the LDCs in the KWCG Region.

Figure 5-3: Gross Demand Forecast by LDCs



In addition, three transmission-connected customers also contribute to the overall peak demand in the KWCG Region. For planning purposes, the IESO estimates the peak demand of these transmission-connected customers based on historical metering data and expected peak demand consumption. Prior to 2014, the peak demand of the three transmission-connected customers accounted for approximately 47 MW of the peak demand in the KWCG Region. In 2014, the total peak demand contributed by the transmission-customers was reduced to 12 MW to reflect a reduction in energy usage by a transmission-connected customer in the Cambridge area.

The specific forecasting methodology and assumptions for the gross demand forecast can be found in Appendix A.

5.3.2 Estimated Peak Demand Savings from Provincial Energy Conservation Targets

Conservation plays a key role in maximizing the useful life of existing infrastructure, and maintaining reliable supply. The 2013 LTEP committed to establishing a new 6-year

Conservation First Framework beginning in January 2015 to enable the achievement of all cost-effective conservation. In the near term, Ontario's LDCs have an aggregate energy reduction target of 7 TWh, as well as individual LDC specific targets. These targets are to be achieved between 2015 and the end of 2020 through LDC conservation programs enabled by the Conservation First Framework. Each LDC is required to prepare a CDM Plan describing how their target will be achieved and submit their CDM Plan by May 1, 2015.¹⁰ The LDC CDM Plans will link closely with regional plans, providing more detail about how a portion of the conservation targets that have been incorporated into regional planning will be realized.

As part of the Conservation First policy, the provincial government has adopted a broad definition of conservation that includes various types of customer action and behind-the-meter generation. This means that conservation includes any efforts to reduce the amount of energy consumed from the provincial electricity grid. Conservation initiatives, including behind the meter generation projects and on-site generation,¹¹ are expected to reduce customers' reliance on the provincial electricity grid and contribute to peak demand savings in the KWCG Region over the next 10 years. For the purpose of this IRRP, the allocation of the provincial energy savings target for the KWCG Region is estimated to offset approximately 144 MW or 40% of the forecast peak demand growth in the KWCG Region between 2014-2023. It is assumed that existing DR already in the base year will continue but savings from potential future DR resources are not included in the forecast. Instead, future savings are considered as possible solution to identified future needs.

Using a planning forecast that is net of provincial energy conservation targets provides consistency with the province's Conservation First policy by reducing demand requirements before assessing any growth-related needs. The planning forecast assumes that the targets will be met, and will produce the expected local peak demand impacts. Therefore, an important aspect of plan implementation will be monitoring the actual peak demand impacts of conservation programs delivered by the local LDCs.

The estimated annual peak demand savings from the provincial energy conservation targets in the KWCG Region are summarized in Appendix A.

¹⁰ At the time of this report, the CDM plans have not been submitted by the LDCs. The CDM plans will be available on the IESO and LDCs' websites once they have been submitted and reviewed.

¹¹ The government has directed the former OPA to "consider CDM to be inclusive of activities aimed at reducing electricity consumption and reducing the draw from the electricity grid, such as geothermal heating and cooling, solar heating and small scale (i.e., < 10 MW) behind-the-meter customer generation."

5.3.3 Expected Peak Demand Contribution of Contracted Distributed Generation


In recent years, a number of DG projects including, wind, solar, hydro and combined heat and power (“CHP”) projects, have been developed in the KWCG Region as a result of provincial procurement programs such as FIT and CHPSOP. Since 2010, an additional 98 MW of DG was contracted in the KWCG Region. These contracted DG resources are expected to reduce the regional peak demand by 35 MW or about 10% of forecast demand growth in the Region during the 2014-2023 timeframe. Future DG uptake was, as noted, not included in the planning forecast and is instead considered as an option for meeting identified needs.

The expected annual peak demand contribution of contracted DG in the KWCG Region can be found in Appendix A.

5.3.4 Planning Forecast

Figure 5-4 shows the near- and medium-term planning forecast for the KWCG Region (2014-2023), which takes into consideration the gross demand forecast, estimated peak demand savings from provincial energy conservation targets, and contracted DG adjusted to reflect extreme summer temperature conditions.

Figure 5-4: KWCG Near-and Medium-Term Planning Forecast 2014-2023



According to the planning forecast, the summer peak electricity demand in the KWCG Region is expected to increase at a rate of approximately 1.7% each year, with an incremental peak demand growth of approximately 250 MW between 2014-2023. Over the next 10 years, a large portion of the demand growth will be concentrated in Guelph and Waterloo. The near- and medium-term growth is driven by several concentrated areas of local developments, such as the Region of Waterloo East-Side Lands, the Rapid Transit Initiatives in Waterloo, and the Hanlon Creek Business Park in Guelph.

5.4 Long-Term Planning Forecast


As described in Section 5.2 above, for the 10-20 year timeframe, due to greater uncertainty with electricity demand growth, two longer-term demand scenarios were developed.

Two alternate policy drivers were considered in the development of long-term demand scenarios for the KWCG Region:

- Ontario's *Places to Grow Act, 2005*; and
- Ontario's 2013 LTEP.

The two long-term demand scenarios are shown in Figure 5-5 below and are described in the following sections. Additional details related to the development of these longer-term scenarios are provided in Appendix A.

Figure 5-5: Long-Term Planning Forecast Scenarios 2024-2033




5.4.1 High-Growth Scenario

This scenario reflects the Region's forecast peak electricity demand requirements associated with growth assumptions as detailed in Ontario's Places to Grow plan. It represents a future with sustained electricity demand growth across the region driven by local developments and intensification initiatives outlined in the Places to Grow plan and as reflected in municipal official plans.

Under the high-growth scenario, the summer peak electricity demand requirement in the KWCG Region is forecast to increase at a rate of 1.4% each year over the long term, with an

incremental growth of 150 MW between 2024-2033. Figure 5-6 shows the forecast incremental peak demand growth for the municipalities in the KWCG Region over the longer term.

Figure 5-6: High-Growth Scenario – Incremental Peak Demand Growth 2024-2033 by Municipality



5.4.2 Low-Growth Scenario


This scenario reflects the region's forecast peak electricity demand requirements associated with the more modest growth assumptions in the 2013 LTEP. The low-growth scenario represents a future with lower electricity demand growth due to higher electricity prices, increased electricity conservation and lower energy intensity within the broader economy. Despite an expected increase in population, energy consumption per household is assumed to decrease over time. Similarly, lower energy intensity is assumed for the commercial and industrial sectors.

Consistent with the 2013 LTEP forecast for southwest Ontario, the peak demand in the KWCG Region beyond 2023 is assumed to grow at a rate of 0.2%, far less than the high-growth scenario. This scenario assumes that electricity demand growth is managed through increased conservation and DG efforts, resulting in less incremental consumption on the provincial electricity grid in the long term.

5.5 Summary of Demand Forecast

The historical peak demand, near- and medium-term planning forecast, and long-term scenarios are shown in Figure 5-7. The annual historical demand data is influenced by variable weather and energy consumption patterns. The planning forecast was developed using assumptions based on extreme weather conditions and typical energy consumption patterns so that demand can be met under a range of conditions. Historical peak demand data was not adjusted to align with the extreme temperature and typical consumption pattern assumptions used in the planning forecast, and as such, may be lower than future projections.

Figure 5-7: Historical Peak Demand, Planning Forecast and Long-Term Scenarios



6. Near- and Medium-Term Plan

The regional planning process considers when system needs may arise by comparing the capability of the existing system with the forecast electricity demand. This section identifies the needs in the near and medium term, considers available options, and recommends actions in the near and medium term.

6.1 Needs Assessment Methodology

The IESO's Ontario Resource and Transmission Assessment Criteria ("ORTAC"),¹² the provincial standard for assessing the reliability of the transmission system, was applied to assess supply capacity and reliability needs. ORTAC includes criteria related to the assessment of the bulk transmission system, as well as the assessment of local or regional reliability requirements (see Appendix B for more details).

Through the application of these criteria, three broad categories of needs can be identified:

- **Transformer Station Capacity** describes the electricity system's ability to deliver power to the local distribution network through the regional transformer stations. This is limited by the 10-day Limited Time Rating ("LTR") of the step-down transformer stations in the local area. Transformer station capacity need is identified when the peak demand at step-down transformer stations in the local area exceeds the combined LTR ratings.
- **Supply Capacity** describes the electricity system's ability to provide continuous supply to a local area. This is limited by the load meeting capability ("LMC") of the transmission line or sub-system which is the maximum demand that can be supplied on a transmission line or sub-system under applicable transmission and generation outage scenarios as prescribed by ORTAC, and is determined through power system simulations analysis (See Appendix B for more details). Supply capacity needs are identified when peak demand on a transmission line or sub-system exceeds its LMC.
- **Load Security and Restoration** describes the electricity system's ability to minimize the impacts of potential supply interruptions to customers in the event of a major transmission outage, such as an outage on a double-circuit tower line resulting in the loss of both circuits. Load security describes the amount of load susceptible to supply interruptions in the event of a major transmission outage. Load restoration describes the

¹² http://www.ieso.ca/imoweb/pubs/marketadmin/imo_req_0041_transmissionassessmentcriteria.pdf


electricity system's ability to restore power to those affected by a major transmission outage within reasonable timeframes. The specific load security and restoration requirements prescribed by ORTAC are described in Appendix B.

In addition, the needs assessment may also identify needs related to transmission reliability performance, equipment end-of-life and planned sustainment activities. Reliability performance describes the frequency and probability of major outages on an electricity system, which can be affected by various factors such as exposure to elements, age and maintenance of equipment, and length and configuration of the transmission or distribution network. Equipment reaching the end of its life and planned sustainment activities may have an impact on the needs assessment and option development.

6.2 Summary of Near- and Medium-Term Needs

As noted earlier, the transmission system within the KWCG Region consists of an integrated 230 kV and 115 kV network. Figure 6-1, The KWCG transmission system can be further subdivided into four regional sub-systems.

Figure 6-1: Regional Sub-systems in the KWCG Region



Today, the 115 kV sub-systems supplying the KWCG Region are at or approaching maximum capacity, and the 230 kV sub-systems have limited ability to restore electricity supply to customers in the event of a major transmission outage. Table 6-1 provides a summary of the near- and medium-term needs in the KWCG Region.

Table 6-1: Near- and Medium-Term Needs in the KWCG Region

Needs	Regional Sub-systems	Need Date
Supply Capacity	South-Central Guelph 115 kV	Today
	Kitchener-Guelph 115 kV	
Load Restoration	Waterloo-Guelph 230 kV	
	Cambridge-Kitchener 230 kV	

6.2.1 Supply Capacity Needs on the South-Central Guelph and Kitchener-Guelph 115 kV Systems

South-Central Guelph 115 kV Sub-system

The South-Central Guelph 115 kV sub-system can provide up to 100 MW of continuous supply to the Kitchener and Guelph area under specific transmission and outage scenarios as defined by ORTAC (South-Central Guelph 115 kV System LMC = 100 MW). Based on the historical peak demand, the summer peak demand in the South-Central Guelph area has already exceeded the 100 MW LMC limit of the South-Central Guelph 115 kV sub-system over the last two years. The existing South-Central Guelph 115 kV sub-system therefore does not meet the ORTAC supply capacity criteria.

Kitchener-Guelph 115 kV sub-system

The Kitchener-Guelph 115 kV sub-system can provide up to 260 MW of continuous supply to the Kitchener and Guelph area under specific transmission and outage scenarios as defined by ORTAC (Kitchener-Guelph 115 kV sub-system LMC = 260 MW). Based on the planning forecast, the peak demand in the Kitchener and Guelph area exceeded the 260 MW LMC limit of Kitchener-Guelph 115 kV system in the summer of 2014. Given the forecast near- and medium-term summer peak demand growth, the existing Kitchener-Guelph 115 kV sub-system does not meet the ORTAC supply capacity criteria.

6.2.2 Load Restoration Needs on the Waterloo-Guelph, and Cambridge-Kitchener 230 kV Sub-system

Waterloo-Guelph 230 kV Sub-system

The Waterloo-Guelph 230 kV sub-system is a 77 km double-circuit 230 kV transmission line (D6V/D7V) between Detweiler TS and Orangeville TS. This system currently supplies about 465 MW of peak demand load in the Waterloo and Guelph area. Based on the planning forecast, the summer peak demand on this system is expected to increase to about 550 MW by 2023. As prescribed by ORTAC, no more than 250 MW of load can be without electricity supply within 30 minutes of a major outage involving the loss of two transmission elements.

In the event of a major outage involving the loss of both transmission circuits on the Waterloo-Guelph 230 kV system (D6/7V), all load supplied by this transmission line would be interrupted. The existing system cannot restore any load within 30 minutes, and can only

restore electricity supply in 3-4 hours using manual restoration procedures. As a result, the Waterloo-Guelph 230 kV system does not meet the ORTAC 30 minute restoration criteria.

A major outage of this type occurred on February 29, 2012, when a forced outage on one of the D6V/D7V circuits, coupled with scheduled maintenance on the companion circuit, resulted in the interruption of electricity supply for three hours to approximately 350 MW of load in Waterloo, Guelph and the surrounding area.

Cambridge-Kitchener 230 kV Sub-system

The Cambridge-Kitchener 230 kV sub-system consists of an 82 km double-circuit 230 kV transmission line (M20D/M21D) between Detweiler TS and Middleport TS. This system currently supplies about 420 MW of peak electricity demand in the Cambridge and Kitchener area. Based on the planning forecast, the summer peak demand on this system is expected to increase to about 480 MW by 2023. As prescribed by ORTAC, no more than 250 MW of load can be without electricity supply within 30 minutes of a major transmission outage.

Should a major outage involving the loss of both transmission circuits on the Cambridge-Kitchener 230 kV system (M20/21D) occur, all load supplied by M20D/M21D would be interrupted. The existing system has the ability to restore up to 65 MW of electricity supply in Cambridge within 30 minutes via the existing 115 kV/230 kV auto-transformer and the circuit switchers at Preston TS. This existing system does not meet the ORTAC criteria because more than 250 MW of load on the Cambridge-Kitchener 230 kV system would still be without service within 30 minutes of a major outage. In fact, a large portion of the customers on the Cambridge-Kitchener 230 kV sub-system would be without power for at least 3-4 hours.

Prior to the installation of the existing 115 kV/230 kV auto-transformer and disconnect switches at Preston TS, power could not be restored to any customers in the area in a timely manner. Such was the case in 2003, when supply to parts of the City of Cambridge, the Township of North Dumfries and the City of Kitchener, totaling over 250 MW, was interrupted for nearly four hours.

6.3 Options to Address the Near- and Medium-Term Needs

In developing the near- and medium-term plan, the Working Group considered a range of integrated alternatives for addressing the needs, including a mix of conservation, generation, transmission and distribution facilities, and other electricity system initiatives. Technical

feasibility, cost, and consistency with long-term needs and options were considered when evaluating alternatives. Solutions that maximized the use of existing infrastructure were given priority.


For needs arising in the near term, specific projects are recommended. Given the lead time required to develop electricity infrastructure and CDM programs, these projects must be commenced as soon as possible to ensure customer reliability. Typically, conservation solutions can be implemented within six months, or up to two years for larger projects, whereas transmission and distribution facilities can take 5-7 years. The lead time for generation development is typically 2-3 years, but it could be longer depending on the size and technology type. Recommended actions are therefore identified to initiate investments.

6.3.1 Guelph Area Transmission Refurbishment (GATR) Project

As discussed in Section 3.3, the Working Group recommended proceeding with the implementation of the GATR project, in combination with increased conservation and DG, to address imminent supply capacity and restoration needs in the KWCG Region. This project includes the installation of two 115 kV/230 kV auto-transformers, two 230 kV circuit switchers at Guelph North Junction, two 115 kV breakers at Cedar TS, and the upgrade of an existing transmission line in Guelph (as shown in Figure 6-2). The cost of the GATR project is approximately \$95 million. The project was approved by the OEB and is expected to be in-service by spring 2016.¹³

¹³ EB-2013-0056 Ontario Energy Board Decision and Order dated September 26, 2013

Figure 6-2: Guelph Area Transmission Refurbishment (GATR) Project



By interconnecting the Waterloo-Guelph 230 kV system with the South Central Guelph 115 kV system and the Kitchener-Guelph 115 kV system, the GATR project maximizes the use of the existing infrastructure and brings a strong source of supply capacity into both 115 kV systems. Following the installation of GATR, there will be sufficient supply capacity on both 115 kV systems to supply electricity demand growth in Guelph and Kitchener and to accommodate up to 100 MW of electricity demand growth in the Cambridge area over the longer term.

The GATR project also improves the ability to restore power to customers on the Waterloo-Guelph 230 kV system. By installing two 230 kV circuit switchers at Guelph North Junction,¹⁴ the sections of the Waterloo-Guelph 230 kV system affected by a possible outage can be isolated

¹⁴ The installation of two 230 kV circuit breakers at Guelph North Junction was originally identified in the GATR Section 92 filing as the preferred option to reduce the impact of supply interruptions to customers on the Waterloo-Guelph 230 kV sub-system. However, after reviewing detailed engineering studies and considering other options, the Working Group determined that it would be cost-effective to install circuit switchers at Guelph North Junction in the near-term and to defer the installation of breakers if and when they are required.

quickly. As a result, about 50% of the electricity supply to customers on the Waterloo-Guelph 230 kV system could be restored within 30 minutes.

The detailed discussion on rationale for GATR and alternatives considered can be found in the Hydro One Inc. Leave to Construct filing for GATR.¹⁵

6.3.2 Options to Improve Load Restoration on the Cambridge-Kitchener 230 kV Sub-system

As shown in Table 6-2, the GATR project provides sufficient supply capacity on the 115 kV regional sub-systems to meet the electricity demand growth in Guelph, Kitchener and Cambridge over the near and medium term, and improve the ability to restore supply to customers in Waterloo and Guelph. However, the restoration needs on the Cambridge-Kitchener 230 kV sub-system remain.

Table 6-2: Summary of Needs Addressed by the GATR Project


Needs	Regional Sub-systems	Needs addressed by the GATR project
Supply Capacity	South Central Guelph 115 kV	✓
	Kitchener-Guelph 115 kV	✓
Load Restoration	Waterloo-Guelph 230 kV	✓
	Cambridge-Kitchener 230 kV	

To substantially improve load restoration in Cambridge and Kitchener in the event of major transmission outages, the Working Group recommended proceeding with the installation of two 230 kV circuit switchers at Galt Junction, near Highway 5, as shown in Figure 6-3. The following section describes the alternatives considered and the rationale for the recommendation.

¹⁵ EB-2013-0056

http://www.rds.ontarioenergyboard.ca/webdrawer/webdrawer.dll/webdrawer/search/rec&sm_udf10=eb-2013-0053&sortd1=rs_dateregistered&rows=200

Figure 6-3: Two Circuit Switchers at Galt Junction



6.3.2.1 Conservation Options

The allocation of the provincial energy savings target is estimated to account for about 40 MW or 40% of the forecast peak demand growth on the Cambridge-Kitchener 230 kV sub-system between 2014-2023. After taking into consideration the estimated peak demand savings from the provincial energy savings conservation targets in the development of the planning forecast, more than 400 MW will still be interrupted on the Cambridge-Kitchener 230 kV sub-system in the event of major transmission outage and power will need to be restored to these customers.

While conservation can be an effective means for communities to manage electricity demand growth and reduce their reliance on the provincial electricity grid, conservation cannot aid in the restoration of power to customers in the event of a major transmission outage. As such, conservation was not considered a feasible solution to address the restoration needs on the Cambridge-Kitchener 230 kV system.

6.3.2.2 Local Generation Options

The extent to which DG can restore electricity supply following a major transmission outage depends on a number of factors, such as the size of the facility, the facility's start-up time, the ramp rate, the availability of black-start capability, storage options, safety protocols and other operating procedures. Given the uncertainties and variability associated with DG, the Working Group agreed that it cannot rely on DG to address restoration needs on the Cambridge-Kitchener 230 kV sub-system.

A large, centralized, transmission-connected generation source (100-200 MW) could improve the restoration on the 230 kV system if properly sited and integrated (e.g., Preston TS and associated switching devices). However, given the high cost associated with large, centralized generation, this option is only cost-effective when it can contribute to both regional and provincial capacity and energy needs. It is not cost-effective to implement a large, centralized generation only for improving load restoration in a local area. This option was therefore ruled out by the Working Group.

6.3.2.3 Distribution Options

One method to restore electricity supply to customers following a major outage on the transmission system is to execute temporary load transfers through the distribution network to unaffected neighboring transformer stations. The amount of load that can be transferred temporarily through the distribution network, as well as the time required to transfer, are highly variable and can depend on various factors such as load level at neighboring stations, distance between stations, voltage of the neighboring distribution system, time of day and operating procedures in place on the distribution system. As such, the Working Group determined that it is difficult to rely on distribution load transfer to restore large amounts of load on the Cambridge-Kitchener 230 kV sub-system in the event of a major transmission outage.

6.3.2.4 Transmission Options

As discussed in Section 3.3, in 2013, the installation of a second 115 kV/230 kV auto-transformer at Preston TS and associated switching and reactive facilities was previously identified by the Working Group as a potential option to address the restoration needs on the Cambridge-Kitchener 230 kV sub-system. In response to the hand-off letter to undertake a detailed study

on the development of the second 115 kV/230 kV auto-transformer at Preston TS option,¹⁶ Hydro One also identified and examined a number of alternatives to reduce the impact of supply interruptions to customers in Cambridge and Kitchener in the event of a major transmission outage on the 230 kV system. Based on Hydro One's analysis,¹⁷ the installation of two 230 kV circuit switchers at Galt junction meets the ORTAC 30-minute restoration criteria on the Cambridge-Kitchener 230 kV sub-system, provides regional benefits, and strikes a reasonable balance between cost, reliability improvement, and feasibility. As such, the Working Group recommended proceeding with the installation of two 230 kV circuit switchers at Galt junction. Hydro One has begun early development work on these switching facilities, which are expected to be in service by spring 2017. Hydro One will continue to examine other potential measures to further improve the restoration capability in the Cambridge area. Please refer to Appendix C for further information regarding load restoration improvements for the Cambridge-Kitchener 230 kV sub-system.

6.4 Recommendations for the Near and Medium Term

Based on the evaluation of alternatives discussed above, the Working Group recommends the actions described below to meet the near-term electricity needs of the KWCG Region. Successful implementation of this plan will substantially address the regional electricity supply needs in the KWCG Region over the next 20 years.

To ensure that the near-term electricity needs of the KWCG Region are addressed, it is important that the near-term plan recommendations are implemented in a timely manner. The specific actions and deliverables associated with the near-term plan are outlined in Table 6-3, along with the proposed timing and the parties that will lead the implementation.

The KWCG Working Group will continue to meet at regular intervals during the implementation phase of this IRRP to monitor developments in the KWCG Region and to track progress toward these deliverables.

¹⁶ OPA Letter to Hydro One - May 29, 2013 for the 2nd Preston Autotransformer:
<http://www.ieso.ca/Documents/Regional-Planning/KWCG/OPA-Letter-Hydro-One-KWCG.pdf>

¹⁷ Hydro One's Kitchener-Waterloo-Cambridge-Guelph area Adequacy of Transmission Facilities Report 2013/2014 report

Table 6-3: Implementation of the Near-Term Plan for the KWCG Region

Recommendations		Action(s)/Deliverable(s)	Lead Responsibility	Timeframe
1	Implement conservation and DG	Develop CDM plans	LDCs	May 2015
		LDC CDM programs implemented	LDCs	2015-2020
		Conduct Evaluation, Measurement and Verification (EM&V) of programs, including peak-demand impacts, and provide results to Working Group	IESO	annually
		Continue to support provincial DG programs	LDCs/ IESO	ongoing
2	Implement the GATR project	Design, develop and construct Seek project approval from the OEB (Leave to Construct application)	Hydro One	Submitted Leave to Construct application on March 8, 2013 Approved by the OEB on Sept 29 2013 In-service spring 2016
3	Install two 230 kV circuit switchers at Galt Junction and explore opportunities to further improve restoration capability in the Cambridge area	Design, develop and construct two 230 kV circuit switchers near Galt junction, near Highway 5 Examine cost and feasibility of potential measures to further improve restoration capability in the Cambridge area	Hydro One	In-service spring 2017

7. Long-Term Plan (2024-2033)

Given the uncertainty in forecasting demand beyond 2023, the purpose of the long-term plan is to consider alternate potential demand scenarios in order to facilitate discussions about how the KWCG Region may plan its future electricity supply, and to lay the groundwork for the next regional planning cycle. This section describes potential long-term needs, approaches to addressing these needs, and recommended actions.

7.1 Summary of Long-Term Needs


Using the needs assessment methodology outlined in Section 6.1, the KWCG Region was assessed under both of the long-term scenarios: the high-growth scenario and the low-growth scenario.

7.1.1 High-Growth Scenario – Long-Term Needs

Following the implementation of the near-term plan (Section 6.4), there will be sufficient supply capacity on the 115 kV and 230 kV systems over the long term to support the electricity demand growth projected under the high-growth scenario.

Although the 230 kV transmission system supplying customers in the Cambridge area is expected to approach its maximum capacity in the long term, as shown in Figure 7-1, future electricity demand growth in the Cambridge area can utilize the Kitchener-Guelph 115 kV sub-system as an alternative source of supply.

Figure 7-1: Remaining Transmission Supply Capacity 2024-2033



As discussed in Section 6.3.1, once the GATR project comes into service around 2016, there will be sufficient capacity on the Kitchener-Guelph 115 kV sub-system to supply up to 100 MW of peak demand growth in Cambridge over the longer-term. Therefore, no major regional supply and reliability needs are identified in the KWCG Region beyond 2023.

However, localized reliability and supply needs, such as TS capacity needs, may arise in the long term. LDCs are monitoring the load closely to determine the timing of potential transformation needs. Where possible, these LDCs are exploring opportunities to coordinate use and development of TS facilities in the KWCG Region over the long term.

7.1.2 Low-Growth Scenario – Long-Term Needs

Under the low-growth scenario, there is little incremental demand growth in the long term, and no additional needs are identified beyond 2023. Following the implementation of the near- and medium-term plan (see Section 6.4), the electricity system would have sufficient capacity to maintain reliability and manage the demand requirements under the low-growth scenario.

7.2 Approaches to Address Long-Term Needs

For localized needs developing over the long term, there is an opportunity to develop and explore a broader set of options, as specific projects do not need to be committed to immediately. Instead, the focus is on identifying possible approaches to meeting long-term needs, including alternatives that are not currently in widespread use but which show promise for the future. To facilitate these long-term options, preliminary actions should be taken to develop the identified alternatives, monitor growth, and engage with stakeholders and communities in the KWCG Region.

This approach is designed to maintain flexibility, avoid committing ratepayers to investments before they are needed, provide adequate time to gauge the success and future potential of conservation measures, test out emerging technologies, engage with communities and stakeholders, coordinate with any municipal or community energy planning (“MEP/CEP”) activities, and to lay the foundation for informed decisions in the future. While it is not necessary to commit to specific projects given forecast uncertainty and technological change, the long-term plan identifies near-term actions to develop alternatives, engage with the communities, gather information and lay the groundwork for future options.

To facilitate discussions about how the KWCG Region may plan its future electricity supply and lay the groundwork for the next planning cycle, the Working Group examined three conceptual approaches to address potential long-term electricity needs in the KWCG Region: community self-sufficiency; delivering provincial resources (“wires” planning); and, large localized generation. In practice, certain elements of electricity plans will be common to all three approaches, and some overlap between them may be necessary. It is likely that all plans will contain some combination of conservation, local generation, transmission and distribution elements. The following section describes the attributes, benefits, risks and implementation requirements associated with each of the three long-term approaches.

7.2.1 Community Self-Sufficiency

The purpose of the community self-sufficiency approach is to reduce a community’s reliance on the provincial electricity system by meeting their electricity needs with local, distributed resources and community-based solutions. This approach can include: aggressive DR and conservation programs, DG and advanced storage technologies, micro-grid and smart-grid technologies, and more efficient and integrated process systems combining heat and power and electric vehicles (“EV”).

Community self-sufficiency can supplement and/or defer transmission or generation infrastructure development and improve energy security for communities by reducing their reliance on the provincial electricity system through conservation efforts and DG. This approach can be an effective means for addressing localized supply and reliability needs and managing a community's electricity demand growth over the long term.

This approach acknowledges community interest and the desire for grassroots involvement in local electricity planning and infrastructure siting. In recent years, a number of municipalities across the province began undertaking Municipal Energy Plans¹⁸ to better understand their local energy needs, identify opportunities for EE and renewable energy, and to begin aligning their land use planning with energy infrastructure planning. With the self-sufficiency approach, commercial and industrial businesses, educational institutions, municipalities and community energy cooperatives have the ability to take greater ownership of their electricity needs and related infrastructure requirements.

Addressing the long-term needs of the KWCG Region through community self-sufficiency requires leadership from the community to identify local opportunities, to align community energy planning initiatives with the regional electricity planning process, and to develop appropriate local and provincial policy and incentives to guide the development of community-based energy solutions. This can be achieved through the development of municipal and community energy plans and increased coordination between the provincial, regional and municipal governments and local utilities.

As this approach relies on emerging technologies, recently, some communities and/or local utilities are taking action to examine the feasibility, scalability and cost-effectiveness of such technologies through the implementation of pilot projects. Going forward, regulatory guidance would be required to clarify cost recovery mechanisms for emerging technologies and to address the potential risk of stranding assets.

Communities and local utilities in the KWCG Region have become increasingly involved in the development of DG and conservation initiatives as a result of provincial procurement programs and conservation policy. The following sections provide an overview of the ongoing

¹⁸ A Municipal Energy Plan is a comprehensive long-term plan to improve energy efficiency, reduce energy consumption and greenhouse gas (GHG) emissions.

community energy initiatives, policies and solutions being developed in the City of Guelph, Region of Waterloo, Wellington County and Oxford County.

City of Guelph

The City of Guelph places an emphasis on community-based energy management and solutions. According to the Guelph Community Energy Initiative, the City of Guelph has established ambitious goals to reduce energy use per capita, to encourage and facilitate community-based renewable energy systems and to reduce greenhouse gases (“GHG”) over the next 20 years.

To facilitate the implementation of these goals under the Guelph Community Energy Initiative, the City of Guelph formed Envida Community Energy Inc. to develop and implement community-based electricity generation, thermal energy and energy management solutions. In recent years, Envida has successfully developed and implemented various district energy, combined heat and power, solar energy and bio-energy projects. Such projects include the Hanlon Creek Business Park District Energy System and Combined Heat and Power Project, the Eastview Landfill Gas Facility, and the Galt District Energy System in downtown Guelph. To facilitate the integration and optimization of these distributed resources, Guelph Hydro has been upgrading its smart grid.

In addition, Guelph Hydro and Envida have taken steps to better understand the potential and feasibility of community-based solutions and emerging technologies. Guelph Hydro conducted an Electric Vehicle Market Research Study in 2011 and was involved with an EV charging station pilot. As part of Guelph’s District Energy Strategic Plan, Envida identified 10 potential areas for district energy development and set out a 20-year roadmap for district energy development in Guelph.

To facilitate EE improvements, the City of Guelph has established building codes and efficiency requirements on building renovations and implemented voluntary energy performance labeling in buildings.

Region of Waterloo

The Region of Waterloo released a Corporate Energy Plan for 2014-2024 to effectively manage the region’s corporate energy use. Over the next 10 years, the region plans to pursue EE retrofits for buildings and renewable energy generation. The region’s Energy Conservation Office (“ECO”), established in 2007, will play a leading role in implementing the goals as

detailed in the Corporate Energy Plan. To date, the ECO has implemented more than 130 conservation and DG projects across the region, including demand shifting, energy audits, building retrofits, and geothermal, biogas, landfill gas, solar heating and solar photovoltaic (“PV”) installations. The ECO will provide information on new and emerging generation technologies to the region, by initiating new partnerships with cities and local organizations, attending relevant conferences, and reviewing research publications.

A Climate Action Plan was also developed for the region, as a collective direction for municipal and community leaders to investigate several strategies to reduce energy needs and increase local renewable energy generation. According to the plan, local building codes and standards are to be updated and improved in terms of energy efficiency, targeting building retrofits and new development. In order to help cover capital costs of building retrofits and renewable generation for homeowners, the region will consider using Local Improvement Charges as a funding mechanism. A district energy feasibility study will be conducted for the Region of Waterloo, to identify opportunities within the region for both homes and businesses. By installing public EV charging stations and raising awareness among the local residents, the region intends to have 1,000 EVs in the community. The application of geothermal energy, solar hot water systems and PV net metering solutions will be explored and developed through increased collaboration with LDCs.

The Community Environmental Fund in the Region of Waterloo has supported community-based environmental initiatives, such as supporting a solar thermal project and associated education workshops, and funding a green housing demonstration project combining passive and active solar design as well as integrated energy production.

To facilitate the integration and optimization of distributed resources, LDCs in the Region of Waterloo have invested in advanced smart grid technologies, such as automated switching, Supervisory Control and Data Acquisition (“SCADA”), and outage management systems.

Wellington and Oxford Counties

Both Wellington and Oxford Counties have recently published their Energy Management Plans that outline their goals and initiatives to monitor energy usage, reduce energy consumption and minimize carbon emission and environmental footprints in their communities. These initiatives include installing light emitting diode (“LED”) streetlights, conducting energy audits in municipal-owned and high-energy consumption buildings and exploring opportunities for the development of DG in their communities. Today, Wellington County has 15 solar PV units

operating with revenues directed to the Green Energy Reserve, a fund for future green initiatives.


7.2.2 Delivering Provincial Resources (“Wires” Planning)

Delivering provincial resources, or “wires” planning, reflects the traditional regional electricity planning approach associated with the development of centralized electric power systems. This approach involves using transmission and distribution infrastructure to supply a region’s electricity needs, taking power from the provincial electricity system. This model takes advantage of generation that is planned at the provincial level, with generation sources typically located remotely from the region. Utilities, both transmitters and distributors, play a lead role in the development of this approach.

Transmission and distribution enhancements, such as the installation of a TS, reactive support and switching facilities, can be an effective means for addressing localized supply and reliability needs in the KWCG Region in the long term.

Although it is not required at this time, a transmission line bringing supply from the west, south or east into the KWCG regional electricity system can be a potential option to address major regional supply needs (as shown in Figure 7-2), if such needs are identified in future planning cycles.

Figure 7-2: Potential Transmission Supply into the KWCG Region



Standard planning practices give preference to solutions that make use of existing corridors and brownfield sites, or that involve development of new joint-use corridors for linear infrastructure. Planning, coordination and engagement with local communities and key stakeholders are required to align land use planning and the siting of transmission and distribution infrastructure. Depending on the requirements and size of the transmission and distribution facilities, the lead time for transmission or distribution facilities is typically 5-7 years. These enhancements may be subject to regulatory approvals, such as a Class Environmental Assessment and a Leave to Construct application. The costs of “wires” solutions would depend not only on the specific infrastructure involved, but also on the cost of providing energy at the provincial system level. Cost responsibility for the transmission and distribution infrastructure would be determined as part of the regulatory application review process.


7.2.3 Large, Localized Generation Resources

Siting localized generation based on the size and location of the electricity requirements can be an effective means for addressing major regional supply and reliability needs over the long

term. While this approach is similar to community self-sufficiency in that it shares the goal of providing supply locally, the emphasis is on large, transmission-connected generation facilities rather than smaller, distributed resources.

In the context of the KWCG Region, a large, transmission-connected generation source can be sited near Cambridge (as shown in Figure 7-3) to address major regional supply needs, if such needs are identified in future planning cycles.

Figure 7-3: Large, Transmission-Connected Generation Option



There are a number of factors that need to be considered when siting localized generation, and any decisions about siting this generation would need to align with appropriate recommendations found in the August 2013 report entitled “Engaging Local Communities in Ontario’s Electricity Planning Continuum”¹⁹ that was prepared for the Minister of Energy by the OPA and the IESO.

¹⁹ <http://www.powerauthority.on.ca/stakeholder-engagement/stakeholder-consultation/ontario-regional-energy-planning-review>

As the requirements in the KWCG Region are for additional capacity during times of peak demand, a large, transmission-connected generation solution would need to be capable of being dispatched when needed, and to operate at an appropriate capacity factor. In some cases, additional transmission reinforcements may be required to accompany the generation. In addition, siting may be a challenge if the generation is to be sited in densely populated and/or urban areas.

The cost of the centralized generation option depends on the size and technology of the units chosen, as well as the degree to which they can contribute to the local and provincial capacity or energy need. The lead time for generation development is typically 2-3 years, but it could be longer depending on the size and technology type.

7.3 Recommendations for the Long Term

While specific solutions do not need to be committed to today, it is appropriate to begin work now to gather information, monitor developments, engage the community and develop alternatives to support decision-making for the next iteration of the IRRP. The long-term plan sets out the near-term actions required to ensure that options remain available to address future needs, if and when they arise.

Localized reliability and supply needs may still arise in the long term under certain growth scenarios, but these potential needs do not require any immediate action. There may be opportunity for communities and local utilities to manage their future electricity demand through the development of community-based solutions. Communities and local utilities in the KWCG Region have become increasingly involved in the development of DG and conservation initiatives. The results of early community-based pilot projects, energy conservation initiatives, and achievable potential studies will be an important input to the long-term plan for the KWCG Region and will be considered in the next iteration of the KWCG IRRP.

The recommended actions and deliverables for the long-term plan are outlined in Table 7-1, along with the proposed timing, and the parties assigned with lead responsibility for implementation. The KWCG Working Group will continue to meet regularly during the implementation phase of this IRRP to monitor developments in the KWCG Region and to track progress of these deliverables.

Table 7-1: Implementation of Near-Term Actions in Support of the Long-Term Plan for KWCG Region

Recommendations		Action(s)/Deliverable(s)	Lead Responsibility	Timeframe
1	Maintain ongoing dialogues with communities about their future electricity supply	Engage with municipalities through community planning and outreach initiatives	IESO/LDC	2015-2020
		Engage with First Nations communities through community planning and outreach initiatives		
2	Monitor load growth, CDM achievement, and DG uptake	Prepare annual update to the Working Group on demand, conservation and DG trends in the area, based on information provided by Working Group	IESO	Annually
3	Coordinate use and development of TS facilities	Monitor growth in respective service area	LDCs	2015-2020
		Explore opportunity to coordinate use and development of TS facilities among the LDCs in the KWCG Region		

8. Community, Aboriginal and Stakeholder Engagement

Community engagement is an important aspect of the regional planning process. Providing opportunities for input in the regional planning process enables the views and preferences of the community to be considered in the development of the plan, and helps lay the foundation for successful implementation. This section outlines the engagement principles as well as the activities undertaken to date for the KWCG Region IRRP and those that will take place to discuss the long-term needs identified in the plan and obtain input in the development of options.

A phased community engagement approach has been developed for the KWCG IRRP based on the core principles of creating transparency, engaging early and often, and bringing communities to the table. These principles were established as a result of the IESO's outreach with Ontarians to determine how to improve the regional planning process, and they are now guiding the IRRP outreach with communities and will ensure this dialogue continues and expands as the plan moves forward.

Figure 8-1: Summary of the KWCG IRRP Community Engagement Process



Creating Transparency

To start the dialogue on the KWCG IRRP and build transparency in the planning process, a number of information resources were created for the plan. A dedicated web page was created on the IESO (former OPA) website to provide a map of the regional planning area, information on why the plan was being developed, the Terms of Reference for the IRRP and a listing of the organizations involved was posted on the websites of the Working Group members. A dedicated email subscription service was also established for the KWCG IRRP where communities and stakeholders could subscribe to receive email updates about the IRRP.

Engaging Early and Often

The first step in the engagement of the KWCG IRRP was meeting with representatives from the municipalities and the First Nations communities in the Region. For the municipal meetings, presentations were made to the KWCG Region municipal planners at two group meetings held in Kitchener and Guelph. The IESO held a separate meeting with representatives of the Six Nations Elected Council. During these meetings, key topics of discussion included Hydro One's Guelph Area Transmission Refurbishment Project (GATR), confirmation of the growth projections, discussion of the near- and long-term needs identified in the KWCG Region, a review of the identified near-term projects including those that have already begun due to timing requirements, and a discussion of the possible approaches to address long-term needs. The discussion also focused on ways to achieve greater community self-sufficiency in the long term, a topic which was also discussed at a separate meeting with conservation, environmental and sustainability representatives from across the planning Region. Invitations to meet to discuss the KWCG IRRP were also extended to the Mississaugas of the New Credit First Nation and to the Haudenosaunee Confederacy Chiefs Council, and the IESO remains committed to responding to any questions or concerns from these communities.

Over the last couple of years, Hydro One has undertaken engagement activities for the GATR project. Going forward, additional engagement activities may be undertaken for other near-term projects. Information on these project-level engagements will be provided on Hydro One's website and will also be listed on the IESO's KWCG IRRP main webpage.

Bringing Communities to the Table

This engagement will begin with a webinar hosted by the Working Group to discuss the plan and potential approaches of possible long-term options. Presentations on the KWCG IRRP will also be made to Municipal Councils on request. To maintain ongoing dialogues with

communities, the IESO and LDCs will continue to engage with First Nations, the Métis Nation of Ontario and municipalities through community planning, environmental and sustainability initiatives and broader community outreach such as, informational public open houses, in between the 5-year regional planning cycle.

Strengthening processes for early and sustained engagement with communities and the public were introduced following an engagement held in 2013 with 1,250 Ontarians on how to enhance regional electricity planning in 2013. This feedback resulted in the development of a series of recommendations that were presented to, and subsequently adopted by the Minister of Energy. Further information can be found in the report entitled “Engaging Local Communities in Ontario’s Electricity Planning Continuum”²⁰ available on the IESO website.

Information on outreach activities for the KWCG Region IRRP can be found on the IESO website and updates will be sent to all subscribers who have requested updates on the KWCG IRRP.

²⁰ <http://www.powerauthority.on.ca/stakeholder-engagement/stakeholder-consultation/ontario-regional-energy-planning-review>

9. Conclusion

This report documents the IRRP that has been carried out for the KWCG Region and fulfills the OEB's regional planning requirement for the KWCG Region. The IRRP identifies electricity needs in the KWCG Region over the 20-year period from 2014 to 2033, and recommends a plan to address near-term needs and actions to facilitate discussions about how the KWCG Region may plan its future electricity supply over the longer-term.

Implementation of the near-term plan is already underway. Consistent with the Conservation First policy, LDCs are currently preparing CDM plans, which will be submitted to the IESO by May 2015. Concurrently, the GATR project has been approved and is expected to come into service in 2016. The early development work for the two circuit switchers on the Cambridge-Kitchener 230 kV sub-system is underway. The implementation of these near-term actions would substantially address electricity supply and reliability needs in the KWCG Region and there are no major regional needs identified beyond 2023. Early development work for major electricity infrastructure projects in the KWCG Region is not required at this time. Localized reliability and supply needs may still arise in the long term under certain growth scenarios, but these potential needs do not require any immediate action. There may be opportunity for communities and local utilities to manage their future electricity demand through the development of community-based solutions.

The KWCG Working Group will continue to meet regularly throughout the implementation of the plan to monitor progress and developments in the area, and will produce annual update reports that will be posted on the IESO website. To support development of the long-term plan, a number of actions have been identified to develop alternatives, engage with the community, and monitor growth in the area, and responsibility has been assigned to appropriate members of the Working Group for these actions. Information gathered and lessons learned from these activities will inform development of the next iteration of the IRRP for the KWCG Region. The plan will be revisited according to the OEB-mandated 5-year schedule.

<Blank Page>

Appendix D:

KWCG RIP Report (2015)



Kitchener-Waterloo-Cambridge-Guelph

REGIONAL INFRASTRUCTURE PLAN

December 15, 2015



[This page is intentionally left blank]

Prepared and supported by:

Company
Hydro One Networks Inc. (Lead Transmitter)
Cambridge and North Dumfries Hydro Inc.
Centre Wellington Hydro
Guelph Hydro Electric System Inc.
Halton Hills Hydro
Hydro One Distribution
Independent Electricity System Operator
Kitchener Wilmot Hydro Inc.
Milton Hydro
Waterloo North Hydro Inc.
Wellington North Power Inc.

[This page is intentionally left blank]

DISCLAIMER

This Regional Infrastructure Plan (“RIP”) report was prepared for the purpose of developing an electricity infrastructure plan to address needs identified in previous planning phases and also any additional needs identified based on new and/or updated information provided by the RIP Working Group.

The preferred solution(s) that have been identified in this report may be reevaluated based on the findings of further analysis. The load forecast and results reported in this RIP report are based on the information provided and assumptions made by the participants of the RIP Working Group.

Working Group participants, their respective affiliated organizations, and Hydro One Networks Inc. (collectively, “the Authors”) make no representations or warranties (express, implied, statutory or otherwise) as to the RIP report or its contents, including, without limitation, the accuracy or completeness of the information therein and shall not, under any circumstances whatsoever, be liable to each other, or to any third party for whom the RIP report was prepared (“the Intended Third Parties”), or to any other third party reading or receiving the RIP report (“the Other Third Parties”), for any direct, indirect or consequential loss or damages or for any punitive, incidental or special damages or any loss of profit, loss of contract, loss of opportunity or loss of goodwill resulting from or in any way related to the reliance on, acceptance or use of the RIP report or its contents by any person or entity, including, but not limited to, the aforementioned persons and entities.

[This page is intentionally left blank]

EXECUTIVE SUMMARY

THIS REGIONAL INFRASTRUCTURE PLAN (“RIP”) WAS PREPARED BY HYDRO ONE AND THE WORKING GROUP IN ACCORDANCE WITH THE ONTARIO TRANSMISSION SYSTEM CODE REQUIREMENTS. IT IDENTIFIES INVESTMENTS IN TRANSMISSION FACILITIES, DISTRIBUTION FACILITIES, OR BOTH, THAT SHOULD BE DEVELOPED AND IMPLEMENTED TO MEET THE ELECTRICITY INFRASTRUCTURE NEEDS WITHIN THE KITCHENER-WATERLOO-CAMBRIDGE-GUELPH (“KWCG”) REGION.

The participants of the RIP Working Group included members from the following organizations:

- Cambridge and North Dumfries Hydro Inc.
- Centre Wellington Hydro
- Guelph Hydro Electric System Inc.
- Halton Hills Hydro One
- Hydro One Distribution
- Hydro One Transmission
- Independent Electricity System Operator
- Kitchener Wilmot Hydro Inc.
- Milton Hydro
- Waterloo North Hydro Inc.
- Wellington North Power Inc.

This RIP provides a consolidated summary of needs and recommended plans for the KWCG Region for the near-term (up to 5 years) and mid-term (5 to 10 years). No long term needs (10 to 20 years) have been identified at this time.

This RIP is the final phase of the regional planning process and it follows the completion of the KWCG Integrated Regional Resource Plan (“IRRP”) by the IESO in April 2015.

The major infrastructure investments planned for the KWCG Region over the near and mid-term, identified in the various phases of the regional planning process, are given in the table below.

No.	Project	In-Service Date	Cost
1	Guelph Area Transmission Reinforcement	May 2016	\$95 M
2	Arlen MTS: Install Series reactors	May 2016	\$0.95 M
3	M20D/M21D – Install 230 kV In-line Switches	May 2017	\$6 M
4	Waterloo North Hydro: MTS #4	2024	TBD

In accordance with the Regional Planning process, the Regional Plan should be reviewed and/or updated at least every five years. The Region will continue to be monitored and should there be a need that emerges due to a change in load forecast or any other reason, the next regional planning cycle may be started earlier to address the need.

TABLE OF CONTENTS

Disclaimer	5
Executive Summary	7
Table of Contents	9
List of Figures	11
List of Tables	11
1. Introduction	13
1.1 Scope and Objectives.....	14
1.2 Structure.....	14
2. Regional Planning Process	15
2.1 Overview	15
2.3 RIP Methodology	18
3. Regional Characteristics	19
5. Forecast And Other Study Assumptions	24
6. Adequacy of Facilities and Regional Needs over the 2015-2025 Period	26
6.1 230 kV Transmission Facilities	28
6.2 500/230 kV and 230/115 kV Transformation Facilities	28
6.3 Supply Capacity of the 115 kV Network.....	28
6.4 Step-down Transformer Stations	29
6.5 Other Items Identified During Regional Planning.....	29
6.5.1 Customer Impact Assessment for the GATR project.....	29
6.5.2 System Impact Assessment for the GATR Project	29
6.5.3 Load Restoration to the Cambridge area	30
6.6 Long-Term Regional Needs	30
7. Regional Plans	31
7.1 Transmission Circuit Capacity and Load Restoration	31
7.1.1 South-Central Guelph 115 kV Sub-system.....	31
7.1.2 Kitchener-Guelph 115 kV Sub-system	31
7.1.3 Waterloo-Guelph 230 kV Sub-system	31
7.1.4 Recommended Plan and Current Status	31
7.2 Load Restoration.....	32
7.2.1 Cambridge-Kitchener 230 kV Sub-system	32
7.2.2 Recommended Plan and Current Status.....	32
7.3 Step-down Transformation Capacity	33
7.3.1 Waterloo North Hydro	33
7.3.2 Recommended Plan and Current Status	33
7.4 Station Short Circuit Capability.....	33
7.4.1 Arlen MTS	33
7.4.2 Recommended Plan and Current Status	33
8. Conclusions	34
9. References	35
Appendix A. Step-Down Transformer Stations in the KWCG Region.....	36
Appendix B. Transmission Lines in the KWCG Region	37

Appendix C.	Distributors in the KWCG Region.....	38
Appendix D.	KWCG Regional Load Forecast (2015-2025)	39
Appendix E.	List of Acronyms	41
Appendix F.	KWCG Adequacy of Transmission Facilities and Transmission Plan 2016-2025	42

LIST OF FIGURES

Figure 1-1 KWCG Region	13
Figure 2-1 Regional Planning Process Flowchart.....	17
Figure 2-2 RIP Methodology	18
Figure 3-1 Geographical Area of the KWCG Region with Electrical Layout.....	20
Figure 3-2 KWCG Single Line Diagram	21
Figure 5-1 KWCG Region’s Planning Forecast	24

LIST OF TABLES

Table 6-1 Near and Medium Term Regional Needs	27
Table 8-1 Regional Plans – Next Steps, Lead Responsibility and Plan In-Service Dates	34

[This page is intentionally left blank]

1. INTRODUCTION

THIS REPORT PRESENTS THE REGIONAL INFRASTRUCTURE PLAN (“RIP”) TO ADDRESS THE ELECTRICITY NEEDS OF THE KWCG REGION.

The report was prepared by Hydro One Networks Inc. (“Hydro One”) and documents the results of the joint study carried out by Hydro One, Kitchener-Wilmot Hydro Inc. (“Kitchener-Wilmot Hydro”), Waterloo North Hydro Inc. (“WNH”), Cambridge & North Dumfries Hydro Inc. (“CND”), Guelph Hydro Electric Systems Inc. (“Guelph Hydro”), Hydro One Distribution and the Independent Electricity System Operator (“IESO”) in accordance with the Regional Planning process established by the Ontario Energy Board (“OEB”) in 2013.




Figure 1-1 KWCG Region

The KWCG Region covers the cities of Kitchener, Waterloo, Cambridge and Guelph, portions of Oxford and Wellington counties and the townships of North Dumfries, Puslinch, Woolwich, Wellesley and Wilmot. Electrical supply to the Region is provided from eleven 230 kV and thirteen 115 kV step-down transformer stations. The summer 2015 coincident regional load was about 1240 MW. The boundaries of the Region are shown in Figure 1-1 above.

1.1 Scope and Objectives

This RIP report examines the needs in the KWCG Region. Its objectives are:

- To identify new supply needs that may have emerged since previous planning phases (e.g. Needs Assessment, Scoping Assessment, Local Plan, and/or Integrated Regional Resource Plan)
- To assess and develop a wires plan to address these needs
- To provide the status of wires planning currently underway or completed for specific needs
- To identify investments in transmission and distribution facilities or both that should be developed and implemented on a coordinated basis to meet the electricity infrastructure needs within the region.

The RIP reviews factors such as load forecast, transmission and distribution system capabilities along with any updates with respect to local plans, conservation and demand management (“CDM”), renewable and non-renewable generation development, and other electricity system and local drivers that may impact the need and alternatives under consideration.

The scope of this RIP is as follows:

- A consolidated report of all the needs and relevant plans to address near and mid-term needs (2015-2025) identified in previous planning phases (Needs Assessment, Scoping Assessment, Local Plan or Integrated Regional Resource Plan)
- Identification of any new needs over the 2015-2025 period and a wires plan to address these needs based on new and/or updated RIP phase information
- Develop a plan to address any longer term needs identified by the Working Group

The IRRP or RIP Working Group did not identify any long term needs at this time. If required, further assessment will be undertaken in the next planning cycle because adequate time is available to plan for required facilities.

1.2 Structure

The rest of the report is organized as the follows:

- Section 2 provides an overview of the regional planning process
- Section 3 describes the region
- Section 4 describes the transmission work completed over the last ten years
- Section 5 describes the load forecast and study assumptions used in this assessment
- Section 6 describes the results of the adequacy assessment of the transmission facilities and identifies the needs
- Section 7 summarizes the Regional Plan to address the needs
- Section 8 provides the conclusions and next steps

2. REGIONAL PLANNING PROCESS

2.1 Overview

Planning for the electricity system in Ontario is done at essentially three levels: bulk system planning, regional system planning, and distribution system planning. These levels differ in the facilities that are considered and the scope of impact on the electricity system. Planning at the bulk system level typically looks at issues that impact the system on a provincial level, while planning at the regional and distribution levels looks at issues on a more regional or localized level.

Regional planning looks at supply and reliability issues at a regional or local area level. Therefore, it largely considers the 115 kV and 230 kV portions of the power system that supply various parts of the province.

2.2 Regional Planning Process

A structured regional planning process was established by the Ontario Energy Board in 2013, through amendments to the Transmission System Code (“TSC”) and the Distribution System Code (“DSC”). The process consists of four phases: the Needs Assessment¹ (“NA”), the Scoping Assessment (“SA”), the Integrated Regional Resource Plan (“IRRP”), and the Regional Infrastructure Plan (“RIP”).

The regional planning process begins with the NA phase which is led by the transmitter to determine if there are regional needs. The NA phase identifies the needs and the Working Group determines whether further regional coordination is necessary to address them. If no further regional coordination is required, further planning is undertaken by the transmitter and the impacted local distribution company (“LDC”) or customer and develops a Local Plan (“LP”) to address them. These needs are local in nature and can be best addressed by a straight forward wires solution.

In situations where identified needs require coordination at the regional or sub-regional levels, the IESO initiates the SA phase. During this phase, the IESO, in collaboration with the transmitter and impacted LDCs, reviews the information collected as part of the NA phase, along with additional information on potential non-wires alternatives, and makes a decision on the most appropriate regional planning approach. The approach is either a RIP, which is led by the transmitter, or an IRRP, which is led by the IESO. If more than one sub-region was identified in the NA phase, it is possible that a different approach could be taken for different sub-regions.

The IRRP phase will generally assess infrastructure (wires) versus resource (CDM and Distributed Generation (“DG”)) options at a higher or more macro level but sufficient to permit a comparison of options. If the IRRP process identifies that infrastructure options may be most appropriate to meet a need, the RIP phase will conduct detailed planning to identify and assess the specific wires alternatives and recommend the preferred wires solution. Similarly, resource options which the IRRP identifies as best

¹ Also referred to a Needs Screening

suited to meet a need are then further planned in greater detail by the IESO. The IRRP phase also includes IESO led stakeholder engagement with municipalities and establishes a Local Advisory Committee in the region or sub-region.

The RIP phase is the final stage of the regional planning process and involves: confirmation of previously identified needs; identification of any new needs that may have emerged since the start of the planning cycle; and development of a wires plan to address the needs where a wires solution would be the best overall approach. This phase is led and coordinated by the transmitter and the deliverable of this stage is a comprehensive report of a wires plan for the region. Once completed, this report can be referenced in rate filing submissions or as part of LDC rate applications with a planning status letter provided by the transmitter. Reflecting the timeliness provisions of the RIP, plan level stakeholder engagement is not undertaken at this stage. However, stakeholder engagement at a project specific level will be conducted as part of the project approval requirement.

To efficiently manage the regional planning process, Hydro One has been undertaking wires planning activities in collaboration with the IESO and LDCs for the region as part of and/or in parallel with:

- Planning activities that were already underway in the region prior to the new regional planning process taking effect
- The NA, SA, and LP phases of regional planning
- Participating in and conducting wires planning as part of the IRRP for the region or sub-region

Figure 2-1 illustrates the various steps of the regional planning process (NA, SA, IRRP and RIP) and their respective phase trigger, lead, and outcome.

Note that as the KWCG Region was identified as a “transitional” region at the onset of the OEB defined Regional Planning process in 2013, the Needs Assessment and Scoping Assessment phases were deemed complete and the region was placed into the IRRP phase of the process.




Figure 2-1 Regional Planning Process Flowchart

2.3 RIP Methodology

The RIP phase consists of four steps (see Figure 2-2) as follows:

- 1) **Data Gathering:** The first step of the RIP phase is the review of planning assessment data collected in the previous stages of the regional planning process. Hydro One collects this information and reviews it with the Working Group to reconfirm or update the information as required. The data collected includes:
 - Net peak demand forecast at the transformer station level. This includes the effect of any distributed generation or conservation and demand management programs.
 - Existing area network and capabilities including any bulk system power flow assumptions.
 - Other data and assumptions as applicable such as asset conditions; load transfer capabilities, and previously committed transmission and distribution system plans.
- 2) **Technical Assessment:** The second step is a technical assessment to review the adequacy of the regional system including any previously identified needs. Additional near and mid-term needs may be identified at this stage.
- 3) **Alternative Development:** The third step is the development of wires options to address the needs and to come up with a preferred alternative based on an assessment of technical considerations, feasibility, environmental impact and costs.
- 4) **Implementation Plan:** The fourth and last step is the development of the implementation plan for the preferred alternative.




Figure 2-2 RIP Methodology

3. REGIONAL CHARACTERISTICS

THE KWCG REGION COMPRISES OF THE CITIES OF KITCHENER, WATERLOO, CAMBRIDGE AND GUELPH, PORTIONS OF OXFORD AND WELLINGTON COUNTIES AND THE TOWNSHIPS OF NORTH DUMFRIES, PUSLINCH, WOOLWICH, WELLESLEY AND WILMOT AS SHOWN IN FIGURE 3-1.

The main sources of electricity into the KWCG Region are from four Hydro One stations: Middleport TS, Detweiler TS, Orangeville TS and Burlington TS. At these stations electricity is transformed from 500 kV and 230 kV to 230 kV and 115 kV, respectively. Electricity is then delivered to the end users of LDCs and directly-connected industrial customers by 24 step-down transformer stations. Figure 3-2 illustrates these stations as well as the four major regional sub-systems: Waterloo-Guelph 230 kV sub-system, Cambridge-Kitchener 230 kV sub-system, Kitchener-Guelph 115 kV sub-system and South-Central Guelph 115 kV sub-system. Appendix A lists all step-down transformer stations in the KWCG Region, Appendix B lists all transmission circuits in the KWCG Region and Appendix C lists LDCs in the KWCG Region.




Figure 3-1 Geographical Area of the KWCG Region with Electrical Layout

*CTS relocated to the distribution system as part of the GATR project




Figure 3-2 KWCG Single Line Diagram

*CTS relocated to the distribution system as part of the GATR project

4. TRANSMISSION FACILITIES COMPLETED OVER LAST TEN YEARS OR CURRENTLY UNDERWAY

OVER THE LAST 10 YEARS A NUMBER OF TRANSMISSION PROJECTS HAVE BEEN COMPLETED BY HYDRO ONE, OR ARE UNDERWAY, AIMED AT IMPROVING THE SUPPLY TO THE KWCG REGION.

These projects were identified as a result of joint planning studies undertaken by Hydro One, IESO and the LDCs; or initiated to meet the needs of the LDCs; and/or to meet Provincial Government policies. A brief listing of the completed projects is given below.

For transmission voltage level transformation capacity needs:

- 250 MVA 230/115 kV autotransformer T4 at Burlington TS replaced in 2006
- 250 MVA 230/115 kV autotransformer T6 at Burlington TS replaced in 2009

For distribution voltage level transformation capacity needs:

- Kitchener MTS#9 connected to replace the Detweiler TS DESN in 2010
- Arlen MTS connected in 2011

For reactive and voltage support needs:

- a 13.8 kV shunt capacitor bank installed at Cedar TS in 2006
- a 230 kV shunt capacitor bank installed at Detweiler TS in 2007
- a 230 kV shunt capacitor bank installed at Orangeville TS in 2008
- a 230 kV shunt capacitor bank installed at Burlington TS in 2010
- a 115 kV shunt capacitor bank installed at Detweiler TS in 2012

For transmission circuit capacity needs:

- M20D/M21D circuit sections capacity increased by sag limit mitigation in 2014

For transmission load security needs:

- Freeport SS installed to sectionalize circuits D7G/D9G (Detweiler TS by Cedar TS) in 2008

For transmission load restoration needs:

- 250 MVA 230/115 kV autotransformer T2 installed at Preston TS in 2007

The following projects are underway:

- Guelph Area Transmission Reinforcement (GATR) project that entails the extension the 230kV circuits D6V/D7V to Cedar TS; the installation of two new 250MVA, 230/115kV

autotransformers at Cedar TS; and the installation of two 230 kV in-line switches onto circuits D6V/D7V at Guelph North Junction. This project reinforces the Kitchener-Guelph and South-Central Guelph 115kV sub-systems as well as improves restoration capability to the Waterloo-Guelph 230 kV sub-system. This project is identified in the IESO KWCG IRRP, reference [1].

- The installation of a 13.8 kV series reactor to mitigate short circuit levels at Arlen MTS. This project was identified in the RIP phase.
- The installation two new 230kV in-line switches onto circuits M20D/M21D near Galt Junction to improve restoration capability in the Cambridge-Kitchener 230 kV sub-system. This project is identified in Hydro One's KWCG Adequacy of Transmission Facilities & Transmission Plan 2016-2025 report, reference [2]/Appendix F as well as reference [1].

5. FORECAST AND OTHER STUDY ASSUMPTIONS

5.1 Load Forecast

The load in the KWCG Region is forecast to increase at an average rate of approximately 1.7% annually between 2015 and 2025. The growth rate varies across the Region with most of the growth concentrated in the cities of Waterloo and Guelph, each at an average rate of 2.5% over the next ten years.

Figure 5-1 shows the KWCG Region's planning load forecast (summer net, regional-coincident extreme weather peak). The regional-coincident (at the same time) forecast represents the total peak load of the 24 step-down transformer stations in the KWCG Region. By 2025 the forecasted coincident regional peak load is approximately 1765 MW.




Figure 5-1 KWCG Region's Planning Forecast

The KWCG 2015 RIP planning load forecast is provided in Appendix D and is based upon the KWCG IRRP planning load forecast prepared by the IESO and was reaffirmed by the Working Group upon initiation of the RIP phase. In the IRRP phase, the LDC's provided the IESO with a 10 year gross, normal weather, regional-coincident, peak load forecast in MW. The IESO adjusted the forecast by subtracting the effective CDM capacity, applying an extreme weather factor and then subtracting the effective DG capacity. Further details regarding the CDM and connected DG are provided in reference [1]. The RIP forecast is identical to the IRRP forecast except as otherwise noted in Appendix D.

5.2 Other Study Assumptions

The following other assumptions are made in this report.

- 1) The Study period for the RIP assessment is 2015-2025.
- 2) All planned facilities for which work has been initiated and are listed in Section 4 are assumed to be in-service.
- 3) Summer is the critical period with respect to line and transformer loadings. The assessment is based therefore based on summer peak loads.
- 4) Station capacity adequacy is assessed by comparing the non-coincident peak load with the station's normal planning supply capacity, assuming a 90% lagging power factor for stations having no low-voltage capacitor banks and 95% lagging power factor for stations having low-voltage capacitor banks.
- 5) Normal planning supply capacity for Hydro One transformer stations in this Region is determined by the summer 10-Day Limited Time Rating (LTR), while some LDCs use different methodologies for determining transformer station LTR.
- 6) Adequacy assessment is done as per the Ontario Resource and Transmission Adequacy Criteria ("ORTAC").

6. ADEQUACY OF FACILITIES AND REGIONAL NEEDS OVER THE 2015-2025 PERIOD

THIS SECTION REVIEWS THE ADEQUACY OF THE EXISTING TRANSMISSION SYSTEM AND DELIVERY STATION FACILITIES SUPPLYING THE KWCG REGION AND LISTS THE FACILITIES REQUIRING REINFORCEMENT OVER THE NEAR AND MID-TERM.

Within the current regional planning cycle two regional assessments have been conducted for the KWCG Region. The findings of these studies are input to the RIP. The studies are:

- 1) IESO's KWCG Integrated Regional Resource Plan – dated April 28, 2015^[1]
- 2) Hydro One's Adequacy of Transmission Facilities and Transmission Plan 2016-2025 – dated April 1, 2015 with revision 1 – dated October 30, 2015^[2] (please see Appendix F)

The IRRP identified a number of regional needs to meet the forecast load demand over the near to mid-term. Due to the immediate nature of the needs the Guelph Area Transmission Reinforcement (GATR) project was initiated to provide adequate load supply capability to the KWCG area while the IRRP study was still underway. A detailed description and status of the GATR project and other work initiated or planned to meet these needs is given in Section 7.

This RIP reviewed the loading on transmission lines and stations in the KWCG Region assuming the GATR project is in-service. Sections 6.1-6.4 present the results of this review and Table 6-1 lists the Region's needs identified in both the IRRP and RIP phases.

Table 6-1 Near and Medium Term Regional Needs

Type	Section	Needs	Timing
Needs Identified in the IRRP ^[1] and the Adequacy Report ^[2]			
Transmission Circuit Capacity	7.1.1	South-Central Guelph 115 kV sub-system- Capacity of 115kV circuits B5G/B6G	Immediate
	7.1.2	Kitchener–Guelph 115 kV sub-system – Capacity of 115kV circuits D7F/D9F and F11C/F12C	Immediate
Load Restoration	7.1.3	Waterloo-Guelph 230 kV sub-system	Immediate
	7.2.1	Cambridge-Kitchener 230 kV sub-system	Immediate
Step-down Transformation Capacity	7.3.1	Waterloo North Hydro Inc.	2018
Additional Needs identified in RIP Phase			
Station Short Circuit Capability	7.4.1	Arlen MTS: Short Circuit capability	2016

6.1 230 kV Transmission Facilities

All 230 kV transmission circuits in the KWCG Region are classified as part of the Bulk Electricity System (“BES”). They connect the Region to the rest of the Ontario’s transmission system and are also part of the transmission path from generation in Southwestern Ontario to the load centers in the Hamilton, Niagara and GTA areas. These circuits also serve local area stations within the Region and the power flow on them depends on the bulk system transfer as well as local area loads. These circuits are as follows (refer to Figure 3-2):

- 1) Detweiler TS to Orangeville TS 230 kV transmission circuits D6V/D7V – supplies Fergus TS, Campbell TS, Waterloo North MTS#3 and Scheifele MTS
- 2) Detweiler TS to Middleport TS 230 kV transmission circuits M20D/M21D – supplies Kitchener MTS #6, Kitchener MTS # 8, Cambridge MTS #1, Galt TS, Preston TS and Customer #1 CTS
- 3) Detweiler TS to Buchanan TS 230 kV transmission circuits D4W/D5W – supplies Kitchener MTS#9.

The RIP review shows that based on current forecast station loadings and bulk transfers, all 230 kV circuits are expected to be adequate over the study period. Refer to section 3.4.2 of Appendix F for the detailed analysis.

6.2 500/230 kV and 230/115 kV Transformation Facilities

Bulk power supply to the KWCG Region is provided by Hydro One’s 500 kV to 230 kV and 230 kV to 115 kV autotransformers. The number and location of these autotransformers are as follows:

- 1) Two 500/230 kV autotransformers at Middleport TS
- 2) Four 230/115 kV autotransformers at Burlington TS
- 3) Three 230/115 kV autotransformers at Detweiler TS
- 4) Two 230/115 kV autotransformers at Cedar TS
- 5) One 230/115 kV autotransformer at Preston TS

The RIP review shows that based on current forecast station loadings and bulk transfers, the auto-transformation supply capacity is adequate over the study period. Refer to section 3.4.1 of Appendix F for the detailed analysis.

6.3 Supply Capacity of the 115 kV Network

The KWCG Region contains five pairs of double circuit 115 kV lines. This 115 kV network serves local area load. These circuits are as follows (see Figure 3-2):

- 1) Detweiler TS to Freeport SS 115 kV transmission circuits D7F/D9F – supplies Wolverton DS, Kitchener MTS #3, Kitchener MTS#7
- 2) Freeport SS to Cedar TS 115 kV transmission circuits F11C/F12C – supplies Kitchener MTS#5 and Cedar T1/T2 transformers
- 3) Burlington TS to Cedar TS 115 kV transmission circuits B5G/B6G – supplies Puslinch DS, Arlen MTS, Hanlon TS, Customer #2 CTS and Cedar T7/T8 transformers
- 4) Detweiler TS 115 kV radial transmission circuit D11K/D12K – supplies Kitchener MTS#1 and Kitchener MTS#4
- 5) Detweiler TS to Seaforth TS/Hanover TS 115 kV transmission circuit D8S/D10H with Normally Open (N/O) points – supplies Rush MTS and Elmira TS

The RIP review shows that based on current forecast station loadings and bulk transfers, the supply capacity of the 115 kV network is adequate over the study period. Refer to section 3.4.3 of Appendix F for the detailed analysis.

6.4 Step-down Transformer Stations

There are 24 step-down transformer stations within the KWCG Region. Twenty-two supply electricity to LDCs and two are transmission-connected industrial customer stations. These stations are listed within the load forecast in Appendix D. Of those 24 stations, 15 of them are owned and operated by the LDCs.

As part of the IRRP, step-down transformation station capacity was reviewed and resulted in the IRRP forecast which was reaffirmed by the Working Group for use in the RIP phase. According to the load forecast, Waterloo North Hydro anticipates requiring additional step-down transformation capacity in 2018.

6.5 Other Items Identified During Regional Planning

6.5.1 Customer Impact Assessment for the GATR project

Based on the Customer Impact Assessment^[3] for the GATR project, Guelph Hydro identified the need to mitigate short circuit levels at Arlen MTS in order to ensure the short circuit levels remain within the TSC limits and equipment ratings. The project need date is May 2016 so as to correlate with the completion of the GATR project.

6.5.2 System Impact Assessment for the GATR Project

A System Impact Assessment (“SIA”)^[4] was performed for Hydro One’s application to the IESO for the Guelph Area Transmission Reinforcement (GATR) project.

Several findings emanated from the SIA report due to conservative assumptions made for the Bulk Power System. The Working Group has reviewed these findings and recommends that the assumptions be

looked at in greater detail within a Bulk Power System study. If the Bulk Power System study results in regional needs then an early trigger of the next Regional Planning cycle may occur.

6.5.3 Load Restoration to the Cambridge area

The IRRP recommended Hydro One to continue to explore options with Cambridge and North Dumfries Hydro (“CND”) to further improve the load restoration capability to the Cambridge area. During the RIP phase Hydro One presented to CND a detailed explanation of its capability to restore power to transformer stations that service the Cambridge area. Based on this discussion, CND and Hydro One have agreed that, at this time, no additional infrastructure is required and the restoration capability afforded by the GATR project and the 230 kV in-line switches at Galt Junction is acceptable for the study period.

6.6 Long-Term Regional Needs

The IRRP examined high-growth and low-growth scenarios to identify long-term needs. Under the high-growth scenario, there is sufficient transmission capacity afforded by the GATR project to meet demand in the long-term; however the need for additional step-down transformation capacity may arise. LDC’s to closely monitor their load to determine the timing of potential step-down transformation needs. Under the low-growth scenario, no needs were identified in the long-term.

Consistent with the IRRP, the Working Group did not identify any additional long-term needs during the RIP phase. If new long-term needs were to arise, there is sufficient time to assess them in the next planning cycle which can also be started earlier to make timely investment decisions..

7. REGIONAL PLANS

THIS SECTION DISCUSSES THE ELECTRICAL SUPPLY NEEDS FOR THE KWCG REGION AND SUMMARIZES THE REGIONAL PLANS FOR ADDRESSING THE NEEDS. THESE NEEDS ARE LISTED IN TABLE 6-1 AND INCLUDE NEEDS PREVIOUSLY IDENTIFIED IN THE IRRP AS WELL AS THE NEEDS IDENTIFIED DURING THE RIP PHASE.

7.1 Transmission Circuit Capacity and Load Restoration

7.1.1 South-Central Guelph 115 kV Sub-system

The South-Central Guelph area is supplied by the 115 kV double circuit line B5G/B6G. As per section 6.2.1 of the IRRP, historical peak demand on the B5G/B6G line has already exceeded the 100 MW line Load Meeting Capability (“LMC”).

7.1.2 Kitchener-Guelph 115 kV Sub-system

The Kitchener-Guelph area is supplied by two 115 kV double-circuit lines D7F/D9F and F11C/F12C supported by 230/115 kV autotransformers at Detweiler TS and Preston TS. As per section 6.2.1 of the IRRP, the planning forecast peak demand in the Kitchener-Guelph 115 kV sub-system will exceed the 260 MW line LMC by summer 2014.

7.1.3 Waterloo-Guelph 230 kV Sub-system

As per section 6.2.2 of the IRRP, the transmission infrastructure supplying load in the Waterloo-Guelph 230 kV sub-system does not meet reliability requirements to quickly restore supply in the event of a major outage involving the loss of both transmission circuits, D6V and D7V.

7.1.4 Recommended Plan and Current Status

To address the transmission circuit capacity needs for the South-Central Guelph 115 kV sub-system and the Kitchener-Guelph 115 kV sub-system, the IRRP Working Group recommended reinforcement of the 115 kV transmission system by introducing a new 230 kV – 115 kV injection point. The new injection point is to be located at Cedar TS using two new 230 kV/115 kV autotransformers in conjunction with a 5 km extension of the existing 230 kV double-circuit transmission line, D6V/D7V from Campbell TS to Cedar TS. This reinforcement is covered under the GATR project.

To address the load restoration need of the Waterloo-Guelph 230 kV sub-system, the IRRP Working Group’s preferred alternative is to install two new 230 kV in-line switches near Guelph North Junction. The switches will enable Hydro One to quickly isolate a problem and allow the resupply of load to occur expeditiously. This work is also covered under the GATR project.

Current Status of the GATR Project

Hydro One initiated construction on the GATR project in fall 2013 following the OEB approval in September 2013. The project has three components:

- Campbell TS x Cedar TS: Extend the 230 kV D6V/D7V tap from Campbell TS to Cedar TS. This requires replacing approximately a 5 km section of the existing 115 kV double circuit transmission section between CGE Junction and Campbell TS with a new 230 kV double circuit transmission line,
- Cedar TS: Install two new 230/115 kV autotransformers and associated 115 kV switching facilities at Cedar TS. Connect 115 kV switching facilities to the existing B5G/B6G line and the F11C/F12C at Cedar TS.
- Guelph North Junction: Install two in-line 230 kV switches at Guelph North Jct.

This investment will provide for sufficient 230/115 kV autotransformation capacity beyond the study period. The current in-service date of the project is May 2016.

The cost of this project is approximately \$95 million. The project is a transmission pool investment as the autotransformers provide supply to all customers in the Region.

7.2 Load Restoration

7.2.1 Cambridge-Kitchener 230 kV Sub-system

As per section 6.2.2 of the IRRP and the section 3.4.8 of the Adequacy of Transmission Facilities report, transmission infrastructure supplying load in the Cambridge-Kitchener 230 kV sub-system does not meet reliability requirements to quickly restore supply in the event of a major outage involving the loss of both transmission circuits, M20D and M21D.

7.2.2 Recommended Plan and Current Status

To address the load restoration need of the Cambridge-Kitchener 230 kV sub-system, the IRRP Working Group's preferred alternative is to install two new 230 kV in-line switches on the M20D/M21D line near Galt Junction. The switches will enable Hydro One to quickly isolate a problem and allow the resupply of load to occur expeditiously. This work is covered under the M20D/M21D Install 230 kV In-line Switches project.

Current Status of the 230 kV In-Line Switches near Galt Junction

Hydro One has established a project to install the two 230 kV in-line switches onto the M20D/M21D double circuit line. One set of switches to be installed onto each circuit. One set of switches to be installed north of the Junction while the other to be installed south of Galt Junction. The switches will enable

Hydro One to quickly isolate a problem on either side of the junction and initiate the restoration of load to the Cambridge-Kitchener 230 kV sub-system.

The project is currently in the detailed design and estimation phase which also includes real estate negotiations. The cost of this project is approximately \$6 million and it will be a transmission pool investment. The planned in-service date is May 2017.

7.3 Step-down Transformation Capacity

7.3.1 Waterloo North Hydro

The RIP/IRRP planning load forecast indicates that additional step-down transformation capacity is required by 2018, specifically Waterloo North Hydro's MTS #4.

7.3.2 Recommended Plan and Current Status

To address step-down transformation capacity needs of Waterloo North Hydro, Waterloo North Hydro will, wherever possible, manage load growth by maximizing the utilization of existing stations by increasing distribution load transfer capability between those stations and will continue to explore opportunities for CDM and DG. In addition Waterloo North Hydro will also explore, with other LDCs, opportunities to coordinate possible joint use and development of step-down transformer stations in the Region over the long term. With this in mind, additional step-down transformation capacity is not anticipated prior to 2024. This need will be reviewed in the next cycle of regional planning.

7.4 Station Short Circuit Capability

7.4.1 Arlen MTS

Arlen MTS is a 115/13.8 kV step-down transformer station owned by Guelph Hydro. As a result of the new 230/115 kV injection point afforded by the GATR project, the short circuit levels at Arlen MTS's 13.8 kV bus will exceed the TSC limit and equipment capability.

7.4.2 Recommended Plan and Current Status

To address the station short circuit capability need at Arlen MTS, Guelph Hydro will install series reactors to bring station short circuit levels within TSC limits and within equipment ratings.

Current Status of Short Circuit Mitigation

Guelph Hydro has initiated a project to install series reactors to bring station short circuit levels within TSC limits and equipment ratings. The cost of this project is \$0.95 million and the expected completion date is May 2016 so as to correlate with the completion of the GATR project.

8. CONCLUSIONS

THIS REGIONAL INFRASTRUCTURE PLAN REPORT CONCLUDES THE REGIONAL PLANNING PROCESS FOR THE KWCG REGION. THIS REPORT MEETS THE INTENT OF THE PROCESS DESCRIBED IN SECTION 2 WHICH IS ENDORSED BY THE OEB AND MANDATED IN THE TSC AND DSC.

Six near and mid-term needs were identified for the KWCG Region. They are:

- I. Transmission capacity in the South-Central Guelph 115 kV sub-system
- II. Transmission capacity in the Kitchener-Guelph 115 kV sub-system
- III. Load restoration capability in the Waterloo-Guelph 230 kV sub-system
- IV. Load restoration capability in the Cambridge-Kitchener 230 kV sub-system
- V. Step-down transformation capacity for Waterloo North Hydro
- VI. Station Short Circuit Capacity at Arlen MTS

This RIP report addresses all six of these needs. Next Steps, Lead Responsibility, and Timeframes for implementing the wires solutions for the near and mid-term needs are summarized in the Table 8-1 below.

Table 8-1 Regional Plans – Next Steps, Lead Responsibility and Plan In-Service Dates

No.	Project	Next Steps	Lead Responsibility	I/S Date	Cost	Needs Mitigated
1	Guelph Area Transmission Reinforcement	Construction in the final stages	Hydro One	May 2016	\$95M	I, II, III
2	Mitigate Short Circuit Levels at Arlen MTS	Construction underway	Guelph Hydro	May 2016	\$0.95M	VI
3	M20D/M21D – Install 230 kV In-line Switches	Transmitter to carry out this work	Hydro One	May 2017	\$6M	IV
4	Waterloo North Hydro: MTS #4	LDC to monitor growth	Waterloo North Hydro	2024	TBD	V

In accordance with the Regional Planning process, the Regional Plan should be reviewed and/or updated at least every five years. The region will continue to be monitored and should there be a need that emerges due to a change in load forecast or any other reason, the next regional planning cycle will be started earlier to address the need.

9. REFERENCES

- [1] Independent Electricity System Operator, Kitchener-Waterloo-Cambridge-Guelph Region Integrated Region Resource Plan, 28 April 2015.
<http://www.ieso.ca/Documents/Regional-Planning/KWCG/2015-KWCG-IRRP-Report.pdf>
- [2] Hydro One Networks Inc., Kitchener-Waterloo-Cambridge-Guelph Area – Adequacy of Transmission Facilities and Transmission Plan 2016-2025, 1 April 2015, revised 30 October 2015.
- [3] Hydro One Networks Inc., Customer Impact Assessment Guelph Area Transmission Refurbishment Project, 28 May 2013,
- [4] Independent Electricity System Operator, System Impact Assessment, CAA ID: 2012-478, Project: Guelph Area Transmission Refurbishment, 17 May 2013.
http://www.ieso.ca/Documents/caa/CAA_2012-478_GATR_Final_Report.pdf

Appendix A. Step-Down Transformer Stations in the KWCG Region

Station	Voltage (kV)	Supply Circuits
Waterloo-Guelph 230 kV sub-system		
Fergus TS	230 kV	D6V/D7V
Scheifele MTS	230 kV	D6V/D7V
Waterloo North MTS #3	230 kV	D6V/D7V
Campbell TS	230 kV	D6V/D7V
Cambridge-Kitchener 230 kV sub-system		
Kitchener MTS #6	230 kV	M20D/M21D
Kitchener MTS #8	230 kV	M20D/M21D
Cambridge MTS #1	230 kV	M20D/M21D
Preston TS	230 kV	M20D/M21D
Galt TS	230 kV	M20D/M21D
Customer #1 CTS	230 kV	M21D
Kitchener–Guelph 115 kV sub-system		
Wolverton DS	115 kV	D7F/D9F
Kitchener MTS #3	115 kV	D7F/D9F
Kitchener MTS #7	115 kV	D7F/D9F
Kitchener MTS #5	115 kV	F11C/F12C
Cedar TS (T1/T2)	115 kV	F11C/F12C
South-Central Guelph 115 kV sub-system		
Puslinch DS	115 kV	B5G/B6G
Arlen MTS	115 kV	B5G/B6G
Hanlon TS	115 kV	B5G/B6G
Cedar TS (T8/T7)	115 kV	B5G/B6G
Customer #2 CTS	115 kV	B5G
Other Stations in the KWCG Region		
Kitchener MTS #9	230 kV	D4W/D5W
Rush MTS	115 kV	D8S/D10H
Elmira TS	115 kV	D10H
Kitchener MTS #1	115 kV	D11K/D12K
Kitchener MTS #4	115 kV	D11K/D12K

Appendix B. Transmission Lines in the KWCG Region

Location	Circuit Designations	Voltage (kV)
Detweiler TS – Orangeville TS	D6V/D7V	230 kV
Detweiler TS - Middleport TS	M20D/M21D	230 kV
Detweiler TS - Buchanan TS	D4W/D5W	230 kV
Detweiler TS - Freeport SS	D7F/D9F	115 kV
Freeport SS - Cedar TS	F11C/F12C	115 kV
Burlington TS - Cedar TS	B5G/B6G	115 kV
Detweiler TS – Kitchener MTS #4	D11K/D12K	115 kV
Detweiler TS – Palmerston TS	D10H	115 kV
Detweiler TS – Seaforth TS	D8S	115 kV

Appendix C. Distributors in the KWCG Region

Distributor Name	Station Name	Connection Type
Cambridge and North Dumfries Hydro Inc.	Cambridge NDum MTS#1	Tx
	Galt TS	Tx
	Preston TS	Tx
	Wolverton DS	Dx
Centre Wellington Hydro Ltd.	Fergus TS	Dx
Guelph Hydro Electric System - Rockwood Division	Fergus TS	Dx
Guelph Hydro Electric Systems Inc.	Arlen MTS	Tx
	Campbell TS	Tx
	Cedar TS	Tx
	Hanlon TS	Tx
Halton Hills Hydro Inc.	Fergus TS	Dx
Hydro One Networks Inc.	Fergus TS	Tx
	Elmira TS	Tx
	Puslinch DS	Tx
	Wolverton DS	Tx
	Galt TS	Dx
Kitchener-Wilmot Hydro Inc.	Kitchener MTS#1	Tx
	Kitchener MTS#3	Tx
	Kitchener MTS#4	Tx
	Kitchener MTS#5	Tx
	Kitchener MTS#6	Tx
	Kitchener MTS#7	Tx
	Kitchener MTS#8	Tx
	Kitchener MTS#9	Tx
Milton Hydro Distribution Inc.	Fergus TS	Dx
Waterloo North Hydro Inc.	Elmira TS	Dx
		Tx
	Fergus TS	Dx
	Rush MTS	Tx
	Scheifele MTS	Tx
	Waterloo North MTS #3	Tx
	Preston TS	Dx
	Kitchener MTS#9	Dx
Wellington North Power Inc.	Fergus TS	Dx

Appendix D. KWCG Regional Load Forecast (2015-2025)

Table D-1 RIP Planning Demand Forecast (MW)

Station	LDC	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
Cambridge MTS #1	Cambridge & North Dumfries Hydro	92.3	93.8	95.6	98.1	99.7	102.7	101.8	102.1	102.4	102.2	101.6
Galt TS	Cambridge & North Dumfries Hydro	108.1	109.5	112.3	113.7	116.1	119.0	122.8	127.9	134.8	141.9	148.8
Preston TS ⁽¹⁾	Cambridge & North Dumfries Hydro	108.0	100.3	102.0	104.4	105.9	108.7	109.6	111.8	111.9	111.5	111.8
Kitchener MTS #6	Kitchener-Wilmot Hydro	72.8	72.8	73.0	73.0	72.4	72.1	71.7	71.6	71.5	71.1	71.1
Kitchener MTS #8	Kitchener-Wilmot Hydro	44.2	37.6	40.3	43.1	45.3	38.6	41.1	43.5	46.0	48.2	50.6
Kitchener MTS #3	Kitchener-Wilmot Hydro	54.3	64.4	66.5	67.3	67.5	77.0	77.5	78.1	78.7	79.0	79.6
Kitchener MTS #7	Kitchener-Wilmot Hydro	44.9	45.1	45.9	46.0	45.6	45.6	45.6	45.7	39.9	39.8	39.9
Wolverton DS	Hydro One Distribution	21.2	21.4	21.6	21.6	21.6	21.6	21.6	21.7	21.8	21.7	21.9
Cedar TS T1/T2	Guelph Hydro	72.3	74.9	75.8	77.4	78.3	79.5	79.8	82.2	84.6	85.5	87.9
Cambridge MTS # 2 ⁽²⁾	Cambridge & North Dumfries Hydro	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Kitchener MTS #5	Kitchener-Wilmot Hydro	73.9	73.8	74.6	74.5	73.8	73.5	73.2	73.1	78.8	78.3	78.2
Cedar TS T7/T8	Guelph Hydro	30.2	32.0	32.0	32.8	32.3	33.0	33.7	33.4	34.2	34.8	35.5
Hanlon TS	Guelph Hydro	29.8	30.7	31.6	32.5	33.0	33.7	34.4	35.1	34.9	35.5	35.3
Puslinch DS	Hydro One Distribution	35.6	36.2	36.8	37.3	37.5	37.9	38.3	38.7	39.2	39.5	39.9
Arlen MTS	Guelph Hydro	30.0	33.0	37.0	40.9	33.3	37.9	41.4	43.0	44.6	45.9	47.5
Campbell TS	Guelph Hydro	131.9	136.3	139.0	140.2	141.2	142.8	144.4	148.4	152.2	156.2	160.1
Scheifele MTS	Waterloo North Hydro	169.0	166.0	170.7	150.3	151.2	152.7	154.3	156.2	158.1	153.4	155.4
Waterloo North MTS #3	Waterloo North Hydro	61.9	70.8	72.7	75.3	79.3	64.6	58.0	75.3	76.8	76.9	78.4
MTS #4 ⁽²⁾	Waterloo North Hydro	0.0	0.0	0.0	30.6	35.2	50.9	60.3	61.9	64.4	65.6	68.1
Fergus TS	Hydro One Distribution	108.9	108.8	109.5	109.7	108.5	108.3	108.2	108.5	108.7	108.3	108.7
Kitchener MTS #1	Kitchener-Wilmot Hydro	29.1	29.6	31.1	31.6	31.8	32.1	32.4	32.9	33.3	33.5	33.9
Kitchener MTS #4	Kitchener-Wilmot Hydro	67.8	68.2	69.1	69.3	69.0	69.0	68.9	69.2	69.3	69.1	69.3
Kitchener MTS #9	Kitchener-Wilmot Hydro	33.7	33.9	34.3	34.6	34.5	34.7	34.9	35.0	35.3	35.4	35.5
Elmira TS ⁽³⁾	Waterloo North Hydro/ Hydro One Distribution	38.0	32.6	33.5	33.3	34.8	35.4	36.0	36.8	38.4	39.0	40.6
Rush MTS	Waterloo North Hydro	54.9	63.8	65.7	67.4	67.4	67.8	69.1	53.0	53.6	60.7	61.3
Customer #1 CTS ⁽⁴⁾	Customer Station	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5
Customer #2 CTS	Customer Station (Assumed Values)	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0

Table D1 -is based upon KWCG 2015 IRRP Planning Load Forecast except as noted.

- (1) Cambridge and North Dumfries Hydro (“CND”) has confirmed 9.2 MW of cogeneration at a large customer to be accounted for in the Preston TS forecast starting year 2016. The generation plant is expected to run most of the time and would offset the customer's load. This cogeneration was not factored into the KWCG 2015 IRRP Planning Load Forecast.
- (2) Both CND and Waterloo North Hydro (“WNH”) are monitoring the load closely to determine the timing of potential transformation needs. For planning purposes, WNH has moved back the in service date of MTS #4 from 2018 to 2024. WNH is closely monitoring the need for additional transformation capacity to determine if the load growth indicated at MTS #4 in the forecast can be managed through a combination of improving transformer station interties, CDM and DG in the Waterloo Region. Where possible, these LDCs are exploring opportunities to coordinate possible joint use and development of step-down transformer station facilities in the KWCG Region over the long term.
- (3) Updated to include Hydro One Distribution load
- (4) Based on information provided by the transmission-connected customer

Appendix E. List of Acronyms

Acronym	Description
A	Ampere
BES	Bulk Electric System
BPS	Bulk Power System
CDM	Conservation and Demand Management
CIA	Customer Impact Assessment
CGS	Customer Generating Station
CTS	Customer Transformer Station
DESN	Dual Element Spot Network
DG	Distributed Generation
DSC	Distribution System Code
GS	Generating Station
GTA	Greater Toronto Area
HV	High Voltage
IESO	Independent Electricity System Operator
IRRP	Integrated Regional Resource Plan
kV	Kilovolt
LDC	Local Distribution Company
LP	Local Plan
LTE	Long Term Emergency
LTR	Limited Time Rating
LV	Low Voltage
MTS	Municipal Transformer Station
MW	Megawatt
MVA	Mega Volt-Ampere
MVAR	Mega Volt-Ampere Reactive
NA	Needs Assessment
NERC	North American Electric Reliability Corporation
NGS	Nuclear Generating Station
NPCC	Northeast Power Coordinating Council Inc.
NUG	Non-Utility Generator
OEB	Ontario Energy Board
OPA	Ontario Power Authority
ORTAC	Ontario Resource and Transmission Assessment Criteria
PF	Power Factor
PPWG	Planning Process Working Group
RIP	Regional Infrastructure Plan
ROW	Right-of-Way
SA	Scoping Assessment
SIA	System Impact Assessment
SPS	Special Protection Scheme
SS	Switching Station
TS	Transformer Station
TSC	Transmission System Code
UFLS	Under Frequency Load Shedding
ULTC	Under Load Tap Changer
UVLS	Under Voltage Load Rejection Scheme

Appendix F. KWCG Adequacy of Transmission Facilities and Transmission Plan 2016-2025

Revision 1

KITCHENER/WATERLOO/CAMBRIDGE/GUELPH AREA

ADEQUACY OF TRANSMISSION FACILITIES

AND

TRANSMISSION PLAN 2016 – 2025

October 30, 2015

Prepared by Hydro One Networks Inc. in Consultation with the KWCG Working Group

Foreword

This report is the result of a joint study by KWCG Working Group. It has been prepared by Hydro One Networks in consultation with the Working Group.

The working group members were:

Entity	Member
Kitchener-Wilmot Hydro	Shaun Wang L. Frank G. Cameron
Waterloo North Hydro Inc.	Herbert Haller David Wilkinson Dorothy Moryc
Cambridge & North Dumfries Hydro	Ron Sinclair Shawn Jackson
Guelph Hydro Electric System Inc.	Michael Wittemund K. Marouf Eric Veneman
Hydro One Distribution	Charlie Lee
Ontario Power Authority	Bob Chow Bernice Chan
Independent Electricity Operator	Peter Drury
Hydro One Networks Inc.	Alessia Dawes Farooq Qureshy Emeka Okongwu Qasim Raza

The preferred plan has been selected based on technical and economic considerations. The issue of cost allocation between utilities was not addressed.

Prepared by: Qasim Raza – Transmission Planning Officer

Reviewed by: Alessia Dawes – Senior Transmission Planning Engineer

Approved by: Farooq Qureshy – Manager, Transmission System Development, Central & East

October 30, 2015

Revision History

Revision	Date	Author	Description of change
1	October 30, 2015	Qasim Raza	Refreshed based on 2015 IRRP/RIP load forecast (April/August2015)
0	April 1, 2015	Alessia Dawes	Original- based on May 2013 forecast

TABLE OF CONTENTS

Executive Summary	5
1.0 Introduction	6
2.0 Existing Transmission Infrastructure	7
2.1 Transmission in KWCG.....	7
2.2 Transmission-Connected Generation	8
3.0 Adequacy of Existing Transmission Infrastructure in KWCG area	8
3.1 Study Assumptions	8
3.2 Study Criteria	8
3.3 Load Forecast.....	9
3.4 Supply Capacity Needs	9
3.4.1 Auto-transformation Supply Capacity	9
3.4.2 Supply Capacity of the 230 kV Network	10
3.4.3 Supply Capacity of the 115 kV Network	10
3.4.4 Voltage Performance	10
3.4.5 Load Security Analysis	10
3.4.6 Load Restoration Capability Analysis	11
3.4.7 Impact of Contingencies on the BPS to the KWCG Area.....	11
3.4.8 Summary of Needs	12
4.0 Options to Address the Need.....	12
5.0 Discussion of Preferred Options	14
5.1 Preferred Option to Improve Restoration to M20/21D Load	14
6.0 Development Plan.....	14
7.0 Conclusions.....	14
8.0 Recommendations	15
Appendix A: KWCG Maps	16
Appendix B: Transmission-Connected Generation in the KWCG area.....	18
Appendix C: KWCG Customer & LDC Load Forecasts	19
Appendix D: Technical Results – Local Area Analysis	20
Appendix E: Technical Results – Bulk Power System Considerations.....	21
Appendix F: Load Security Analysis.....	23
Appendix G: Load Restoration Analysis	25

Appendix H: Supply To Elmira TS and Rush MTS.....	29
----------------------------------------------------------	-----------

EXECUTIVE SUMMARY

In 2010 an integrated regional planning study was initiated to assess the electricity supply and reliability over a twenty year period for the Kitchener-Waterloo-Cambridge-Guelph (KWCG) areas and continues to be conducted by a Working Group led by the Ontario Power Authority (OPA) and includes staff from the Independent Electricity System Operator (IESO), Hydro One Networks Inc., Kitchener-Wilmot Hydro, Waterloo North Hydro, Cambridge & North Dumfries Hydro, Guelph Hydro Electric Systems Inc. and Hydro One Distribution.

The early results of the integrated regional planning study identified the need to reinforce supply capacity for the South-Central Guelph and the City of Cambridge over the near and medium term. It also identified the need to minimize the impact of double circuit interruptions in the area¹. As a result, the Working Group recommended two transmission projects in conjunction with conservation and distributed generation:

1. The Guelph Area Transmission Reinforcement (GATR) project – comprising a new 230/115kV autotransformer station at Guelph Cedar TS, upgrading the circuit section between Campbell TS and CGE Junction to 230 kV and in-line switching on the Orangeville TS x Detweiler TS 230kV circuits D6V/D7V – to reinforce supply to South Central Guelph,
2. The Preston TS Autotransformer Project – comprising the installation of a second 230/115kV autotransformer at Preston TS - to reinforce supply to the City of Cambridge.

Work on the GATR project was started in 2014 following approval from the Ontario Energy Board and the Ministry of Environment. The project's planned in-service date is June 2016.

For the Preston project, the OPA issued Hydro One a hand off letter to develop a “Wires” solution to improve the supply to the Cambridge area and to facilitate the connection of a future Cambridge and North Dumfries Hydro transformer station by 2018.

This report presents the results of Hydro One led “Wires” study of the adequacy of supply to the City of Cambridge and the wider KWCG area based on the planned in-service of the GATR project in summer 2016. The main conclusions of the report are as follows:

- The supply capability to the KWCG 115kV area has been significantly increased to meet all 2025 forecast loads by the addition of the GATR project. The need for the Preston autotransformer can be deferred to beyond 2025.
- There is inadequate load restoration capability for load connected to Middleport TS x Detweiler TS 230kV double circuit line M20D and M21D

This report recommends that the most cost effective plan to improve load restoration capability for load connected to circuits M20/21D is to install 230 kV in-line switches onto circuits M20/21D.

¹ OPA Submission to the OEB for the GATR Project – Document EB-2013-0053 dated March 8, 2013 entitled, “Kitchener-Waterloo-Cambridge-Guelph Area

1.0 INTRODUCTION

This transmission adequacy assessment focused on the electrical supply to the municipalities of Kitchener, Waterloo, Cambridge and Guelph and their surrounding areas of Ontario, collectively referred to as the KWCG area in this report. Its primary focus was to confirm the near and mid-term transmission needs for the area and to provide a 10-year transmission plan in order satisfy those Needs.

Geographically, the KWCG area consists of 4 municipalities – Kitchener, Waterloo, Cambridge, Guelph and portions of two counties - Perth and Wellington. Hydro One Networks Inc. is the sole high voltage transmitter in the KWCG area; however the low voltage distribution of electricity in the KWCG area is carried out by Cambridge and North Dumfries Hydro Inc., Guelph Hydro Electric System Inc., Hydro One Distribution, Kitchener-Wilmot Hydro Inc., and Waterloo North Hydro. A geographic map of the area is shown in Appendix A, Map 1 while an electrical map of the area is shown in Appendix A, Map 2.

The KWCG area is a major regional load centre in Ontario. The area has a well-established history in manufacturing and technology. The area peak load is approximately 1400 MW.

This report presents the results of the Hydro One led “Wires” study of the adequacy of supply to the City of Cambridge and the wider KWCG area based on the planned in-service of the GATR project in summer 2016.

2.0 EXISTING TRANSMISSION INFRASTRUCTURE

2.1 TRANSMISSION IN KWCG

Electrical Supply in this area is provided through 230 kV and 115 kV transmission lines and step down transformation facilities (transmission stations, TS) as show in Appendix A, Map 2.

The main sources of electricity into the KWCG Region are Middleport TS, Detweiler TS, Orangeville TS, Cedar TS and Burlington TS. At these stations electricity is transformed from 500 kV and 230 kV to 230 kV and 115 kV, respectively. The KWCG Region transmission system is connected as follows:

- Two 230 kV circuits (D6V/D7V) that run North-East from Detweiler TS to Orangeville TS that supply five load serving stations;
- Two 230 kV circuits (M20/21D) that run South-East from Detweiler TS to Middleport TS that supply five load serving stations and one transmission-connected customer;
- Two 230 kV circuits (D4W/D5W) that run South-West from Detweiler TS to Buchanan TS (in the “London area”) that supply one load serving station;
- Four 115 kV circuits (D7F/D9F, F11C/F12C) that run East-West: D7/9F from Detweiler TS to Freeport SS that supply three load serving stations and F11/12C from Freeport SS to Cedar TS that supply one load serving station;
- Two 115 kV circuits (B5G/B6G) that run North-West from Burlington TS to Cedar TS that supply three load serving stations and one transmission-connect customer;
- Two 115 kV radial circuits (D11K/D12K) emanating East from Detweiler TS that supply two load serving stations; and,
- Two 115 kV circuit (D8S and D10H) emanating North from Detweiler TS that supply two load serving stations in the KWCG area.

Voltage support is provided in the area by:

- Four high voltage shunt capacitor banks and one SVC at Detweiler TS
- Four high voltage shunt capacitor banks at Middleport TS
- Three high voltage shunt capacitor banks at Burlington TS
- One high voltage shunt capacitor bank at Orangeville TS
- 43.2 MVar low voltage station shunt capacitor at Galt TS
- 21.6 MVar low voltage station shunt capacitors at Campbell TS
- 59.81 MVar low voltage station shunt capacitors at Cedar TS
- 9.92 MVar low voltage station shunt capacitors at Elmira TS
- Low voltage feeder shunt capacitors were lumped at: C&ND MTS#1, Waterloo North Hydro MTS #3, Scheifele MTS

All stations in the KWCG Region were considered in the analysis to determine the adequacy of the existing transmission system. Transformation capacity at individual load serving stations was previously analyzed by the OPA as part of the Integrated Regional Resource Plan (IRRP). The result of that analysis was a load forecast that included proposed new stations, as shown in Appendix C. Therefore, transformation capacity at individual load serving stations was not considered in this study.

2.2 TRANSMISSION-CONNECTED GENERATION

There are no existing large-scale transmission-connected generation plants in the KWCG area; however two contracted renewable transmission-connected wind farms were included in the study area and are listed in Appendix B.

3.0 ADEQUACY OF EXISTING TRANSMISSION INFRASTRUCTURE IN KWCG AREA

3.1 STUDY ASSUMPTIONS

Assumptions were made in order to assess the effects of contingencies to verify the adequacy of the transmission system. The assumptions used in the study were:

1. A 10 year load forecast: years 2016 to 2025; shown in Appendix C
2. Forecasted loads were provided by the LDC's in MW. The MVAR portion of the load was set to 40% of the MW load which is a reasonable assumption to achieve a power factor of 0.9 at the defined meter point of load serving transformer stations (TS, CTS, MTS)
3. A summer assessment was performed as the KWCG area is summer load peaking while the equipment is at its lowest rating during summer ambient conditions. This was deemed to be the most conservative approach;
4. Equipment continuous and Limited Time Ratings (LTR) were based on an ambient temperature of 35°C for summer and a wind speed of 4 km/hour;
5. The Guelph Area Transmission Reinforcement (GATR) project would be in-service in June 2016;
6. Circuits M20D and M21D are assigned their updated long-term emergency rating (LTE) based on a maximum temperature of 127°C;
7. Simulation of year 2025 load forecast was performed as it was the maximum loading of the area for the duration of the study period; year 2016 was simulated as necessary;
8. Waterloo North Hydro's Snider MTS #4 (MTS #4) will connect to 230 kV circuit D6/7V between Scheifele MTS and Guelph North Jct., projected in-service date 2024 (refer to Note 2 in Appendix C, Table C1)
9. The flows on Ontario's major internal transmission interfaces were assumed as follows:
 - FETT ~ 4500 MW
 - FS ~1250 MW
 - FABCW ~ 5800MW
 - NBLIP ~ 1650 MW (the slightly high NBLIP was offset by the lower FABCW)
 - QFW ~ 1550 MW

3.2 STUDY CRITERIA

The adequacy of the transmission system is assessed as per the IESO Ontario Resource and Transmission Assessment Criteria, Issue 5.0.

3.3 LOAD FORECAST

The load forecast used in this assessment is the KWCG 2015 RIP forecast as shown in Appendix C. This summer forecast is an extreme weather, area coincident, net, peak load forecast.

The KWCG 2015 RIP forecast is based upon the KWCG 2015 IRRP forecast. The LDC's provided the IESO with a 20 year gross, normal weather, area coincident, peak load forecast in MW. The IESO adjusted the forecast by subtracting the effective conservation and demand management (CDM) capacity, applying an extreme weather factor and then subtracting the effective Distribution Generation (DG) capacity.

3.4 SUPPLY CAPACITY NEEDS

Single element contingencies were considered in assessing the adequacy and reliability of the local transmission system that serves the KWCG area. Figure 1 summarizes the local KWCG area Needs for the 10-year period under study. Appendices D, F and G detail the technical study and results.

At stations, within the KWCG area, classified as NPCC Bulk Power System (BPS) additional contingencies were considered to establish their impact to the local KWCG area. Appendix E details the technical study and results.

3.4.1 AUTO-TRANSFORMATION SUPPLY CAPACITY

There is no major generation station in the KWCG area. Hence, the majority of supply to the load is provided by Hydro One's 500 kV to 230 kV and 230 kV to 115 kV auto-transformers. The number and location of these auto-transformers are as follows:

- Two 500/230 kV autotransformers at Middleport TS
- Four 230/115 kV autotransformers at Burlington TS²
- Three 230/115 kV autotransformers at Detweiler TS
- Two 230/115 kV autotransformers at Cedar TS
- One 230/115 kV autotransformer at Preston TS

Single autotransformer contingencies were performed to assess the adequacy of the transmission system to supply bulk power into the KWCG area via the autotransformers for year 2025 loading.

The results indicate that there are no thermal overloads and no voltage violations for the loss of a single autotransformer.

² The loading of the autotransformers at Burlington TS is mainly driven by the load connected in the Burlington to Nanticoke area. Only a small percentage of the autotransformer load is due to local Guelph load and as such, analysis of the Burlington TS autotransformers was undertaken in the 'Burlington to Nanticoke' Regional Infrastructure Plan.

3.4.2 SUPPLY CAPACITY OF THE 230 kV NETWORK

The KWCG area contains three pairs of double circuit 230 kV lines: M20D/M21D, D6V/D7V and D4W/D5W.

Single circuit contingencies were performed to assess the adequacy of the local 230 kV transmission system for year 2025 loading³.

As indicated in Appendix D there are no thermal overloads and no voltage violations for the loss of a single 230 kV circuit.

3.4.3 SUPPLY CAPACITY OF THE 115 kV NETWORK

The KWCG area contains five pairs of double circuit 115 kV lines: D7F/D9F, F11C/F12C, B5G/B6G, D11K/D12K and D8S/D10H.

Single circuit contingencies were performed to assess the adequacy of the local 115 kV transmission system for year 2025 loading.

As indicated in Appendix D there are no thermal overloads and no voltage violations for the loss of a single 115 kV circuit. Appendix H details supply capacity on circuit D8S and D10H as request by the LDC.

3.4.4 VOLTAGE PERFORMANCE

Single circuit contingencies as well as single element HV shunt capacitor bank contingencies were performed to determine the overall voltage performance of the KWCG area for year 2025 loading.

As indicated in Appendix D there are no thermal overloads and no voltage violations for these contingencies. Appendix H details voltage performance at Elmira TS and Rush MTS as request by the LDC.

3.4.5 LOAD SECURITY ANALYSIS

The most stringent load security criterion that applies to the KWCG area states that with any two elements out of service:

- Voltage must be within applicable emergency ratings and equipment loading must be within applicable short-term emergency ratings;
- Load transfers to meet the applicable long-term emergency ratings must be able to be made in the time afforded by short-time ratings;
- Planned load curtailment or load rejection in excess of 150 MW is not permissible (except for local generation outages) and;

³ Note, if another element such as an autotransformer, circuit or capacitor bank shared the same “switching position” and/or zone of protection with the circuit under contingency, both were removed from service.

- Not more than 600 MW of load may be interrupted by configuration and by planned load curtailment or load rejection excluding voluntary demand management with any two transmission elements out of service.

There are three pairs of 230 kV double circuit lines and five pairs of 115 kV double circuit lines in the KWCG area. While one circuit of a double circuit line is out of service, the loss of the companion circuit in the pair would result in the loss of all load stations connected to the pair by configuration. Tables F1 and F2 in Appendix F illustrate the load lost due to configuration in both years 2016 and 2025.

There are five stations in the KWCG area that have autotransformers. Overlapping autotransformer contingencies were taken and Table F3 in Appendix F illustrates any load transfer requirements due to two overlapping autotransformer outages.

As seen in Appendix F, the load forecasted on all circuit pairs is less than 600 MW within the 10-year study period and the loss of two autotransformers within this local area does not result in equipment loading beyond their applicable emergency ratings; therefore there is no concern with Load Security in the KWCG area for the study period.

3.4.6 LOAD RESTORATION CAPABILITY ANALYSIS

The load restoration criteria requires that the transmission system be planned such that following local area design criteria contingencies, the affected loads can be restored within the restoration times indicated below⁴:

- All load lost must be restored within 8 hours;
- Load lost in excess of 250 MW must be restored within 30 min; and
- Load lost between the amount of 150 MW and 250 MW must be restored within 4 hours.

Each pair of double circuit 230 kV and 115 kV lines were assessed to verify their load restoration capability. This assessment is detailed in Appendix G.

The results indicated the existing transmission system can adequately restore load to each circuit pair with the exception of M20/21D. Therefore, improvement to the restoration capability of load connected to circuits M20D and M21D is required.

3.4.7 IMPACT OF CONTINGENCIES ON THE BPS TO THE KWCG AREA

Northeast Power Coordinating Council (NPCC) Bulk Power System stations in the KWCG area are:

- Middleport TS 500 kV bus
- Middleport TS 230 kV bus
- Detweiler TS 230 kV bus

⁴ As per ORTAC: "These approximate restoration times are intended for locations that are near staffed centres. In more remote locations, restoration times should be commensurate with travel times and accessibility."

All elements connected to BPS buses are considered BPS facilities. Elements refer to circuit breakers, transmission lines, generators, transformers and reactive devices (e.g. SVC or capacitor bank).

Appendix E: Technical Results-Bulk Power System Considerations provides a list of BPS contingencies and the results. A *limited* number of BPS contingencies were performed in order to establish the impact of contingencies on the BPS to the local KWCG area.

Three NPCC Directory 1 contingency events were utilized in this study:

1. Simultaneous loss of two adjacent transmission circuits on a multiple circuit tower
2. Loss of any element with delayed fault clearing (a.k.a. Breaker Failure)
3. Loss of a critical element, followed by system adjustment, then loss of a critical element.

These BPS contingency events were applied to BPS buses only. The results can be summarized as follows:

- As per Table E3 and E5 when two of the three auto-transformers at Detweiler TS are not available the remaining auto-transformer may become overloaded. Since the loading of the remaining auto-transformer is within its 15-minute Short-Term Emergency Rating (STE) operational control actions can be taken to reduce the loading to within acceptable limits. Control actions could entail isolation of the faulted element e.g. circuit breaker, bus or transformer, and placing back in-service a healthy auto-transformer (at Detweiler TS and/or Preston TS). Another control action could entail opening of 115kV breakers at Freeport SS to redirect flows through the Cedar TS autotransformers.

3.4.8 SUMMARY OF NEEDS

Figure 1 illustrates the Needs timeline for the KWCG region.



Figure 1: Transmission Needs in the KWCG Area

4.0 OPTIONS TO ADDRESS THE NEED

Options were considered to address the insufficient load restoration capability for loads connected to circuits M20D and M21D. These options are shown in Table 1. Although there are several metrics that can be utilized to measure and compare options, the simple metric “initial capital cost/MW of load restored” was selected because it compares the unit costs of remedial measures. This was deemed sufficient in order to select the preferred option

Table 1: Options to Improve M20/21D Load Restoration

Option	Options to Improve Restoration	Fault on the Main Line – Restorable Load (Note 1)	Fault on the Tap – Restorable Load (Note 1)	Initial Capital Cost (Note 3)	Initial Capital Cost/ MW Load Restored
--	Existing (Benchmark)	100 MW (Preston TS only)	100 MW (Preston TS only)	0	\$0/MW
1	230 kV in-line switches on M20/21D at Preston Junction	100 MW (C&ND load only-Note 2)	100 MW (C&ND load only-Note 2)	\$6M	\$60k/MW
2	230 kV in-line switches on M20/21D at Galt Junction (main line)	368 MW - 484 MW	234 MW (100 MW via existing Preston Auto)	\$6M	\$12k/MW to \$26k/MW
3	One 230 kV cap bank at Preston TS plus 230 kV in-line switches on MxD at Preston Junction	140 MW (Note 4) (C&ND load only-Note 2)	140 MW (Note 4) (C&ND load only-Note 2)	\$11M	\$79k/MW
4	2nd autotransformer at Preston TS plus 230 kV in-line switches on MxD at Preston Junction	200 MW (Note 4) (C&ND load only-Note 2)	200 MW (Note 4) (C&ND load only-Note 2)	\$21M	\$105k/MW
5	2nd autotransformer at Preston TS plus 230 kV in-line switches on MxD at Preston Junction plus two 230 kV cap banks at Preston TS	280 MW (Note 4) (C&ND load only-Note 2)	280 MW (Note 4) (C&ND load only-Note 2)	\$31M	\$111k/MW

NOTE 1 Restorable load values are approximate values only as the actual amount of restorable load will depend on the prevailing system conditions and Operating/Control Centre protocols and priorities

NOTE 2 “C&ND load only” means that only those customers connected to Galt TS, C&ND MTS#1 and Preston TS will benefit. Cambridge and North Dumfries Hydro customers are the sole customers of these three stations.

NOTE 3 All prices are based on historical data: taxes extra, overhead extra, no escalation considered, no assumptions are made to feasibility or constructability, no assumptions made as to space requirements, real estate and environmental cost extra

NOTE 4 Restoration of 230 kV load (Cambridge and North Dumfries load) via the Preston TS auto-transformer may require operational measures on the 115 kV system to secure the transmission system to handle a subsequent contingency e.g. open the low voltage bus-tie breakers/switches at 115kV connected stations

5.0 DISCUSSION OF PREFERRED OPTIONS

5.1 PREFERRED OPTION TO IMPROVE RESTORATION TO M20/21D LOAD

Currently, loads connected to circuits M20/21D do not meet the restoration criteria.

Of the five options, option #2: 230 kV in-line switches on M20/21D at/near Galt Junction is the preferred option to satisfy the Need as it will provide the capability to restore the most load supplied from M20/21D.

Not only does Option #2 allow for more load to be restored, it provides for better operational flexibility; and is the most economical solution. As option 2 substantially meets the need by significantly improving the existing restoration capability, it is therefore the preferred option.

6.0 DEVELOPMENT PLAN

The transmission infrastructure development plan for the KWCG area is as followings:

1) Immediate Action: Install 230 kV In-Line Switches

Install 230 kV Load Interrupter type in-line switches on circuits M20D and M21D on the main line near Galt Junction. Note that load interrupter type switches cannot be used to interrupt fault current.

7.0 CONCLUSIONS

The following conclusions can be reached from the analysis performed by this study.

Local Area Performance

1. Improvement to the load restoration capability of transmission-connected customers on circuits M20D and M21D is required. The preferred option can be implemented by summer 2017.

BPS Performance

2. Autotransformer T2 at Detweiler TS is expected to be at 104.4% of LTE loading for year 2016 for the following contingency:
 - i. Detweiler T4 outage plus Detweiler T3 with M20D (includes Preston T2 via Preston SPS). Since the post-contingency flow is below the auto-transformer STE, operational control actions can be taken to reduce loading to within the LTE rating.

8.0 RECOMMENDATIONS

The following recommendations are to address the transmission infrastructure deficiencies within the study period for the KWCG area. These recommendations are:


1. Hydro One Networks to install a set of 230 kV in-line switches onto the main line of circuits M20D and M21D near Galt Junction as soon as possible.
2. Hydro One Networks, the LDCs and the IESO to review the KWCG local area in 2019 with updated KWCG load forecasts to decide on appropriate actions to meet longer-term needs as they emerge.

The map displays the Regional Municipality of Waterloo, including the cities of Waterloo, Kitchener, and Cambridge. Major transit routes are highlighted in red and green, with stations marked by red and green squares. Key locations include:

- Waterloo:** Waterloo North MTS #3, Rush MTS, Kitchener MTS #1 & #4, Kitchener MTS #5, Kitchener MTS #7, Freeport SS, Kitchener MTS #6, Kitchener MTS #3, Kitchener MTS #8, Kitchener MTS #9.
- Kitchener:** Detweiler TS, Scheifele MTS, Conestoga Pkwy, Kitchener MTS #1 & #4.
- Cambridge:** Preston TS, Cambridge NDUM MTS #1, Galt TS, CTS.
- Other Areas:** Elmira TS, Campbell TS, Cedar TS, Hanlon TS, Arlen MTS, Fergus TS, Orangeville TS, Seaforth TS, Middleport TS, Burlington TS, Buchanan TS.

Highways shown include Highway 86, Highway 6, Highway 7, Highway 124, Highway 401, Highway 8, and Highway 7 & 8. Transit routes are labeled with codes such as D10H, D8S, D11K, D7F, D9F, D4W, D3W, D1C, F1C, F1G, B6G, and M300 M310.

Map 1: Geographical Area of KWCG with Electrical Layout



Map 2: KWCG Electrical Single-Line

APPENDIX B: TRANSMISSION-CONNECTED GENERATION IN THE KWCG AREA

Name	Installed Capacity	Peak Capacity Contribution⁵	Location	Existing or Contracted
Dufferin Wind Farm	97	13.6	Orangeville TS	Existing
Conestoga Wind Farm	67	10.8	D10H	Contracted (future i/s date unknown)

⁵ Percentage of installed capacity is 14 % for wind generation

APPENDIX C: KWCG CUSTOMER & LDC LOAD FORECASTS

Table C1: KWCG 2015 RIP Load Forecast*

TS	LDC	Load Forecast	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
Cambridge MTS #1	Cambridge & North Dumfries Hydro	Planning Demand	92.3	93.8	95.6	98.1	99.7	102.7	101.8	102.1	102.4	102.2	101.6
Galt TS	Cambridge & North Dumfries Hydro	Planning Demand	108.1	109.5	112.3	113.7	116.1	119.0	122.8	127.9	134.8	141.9	148.8
Preston TS-Note 1	Cambridge & North Dumfries Hydro	Planning Demand	108.0	100.3	102.0	104.4	105.9	108.7	109.6	111.8	111.9	111.5	111.8
Cambridge MTS # 2-Note	Cambridge & North Dumfries Hydro	Planning Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Kitchener MTS #6	Kitchener-Wilmot Hydro	Planning Demand	72.8	72.8	73.0	73.0	72.4	72.1	71.7	71.6	71.5	71.1	71.1
Kitchener MTS #8	Kitchener-Wilmot Hydro	Planning Demand	44.2	37.6	40.3	43.1	45.3	38.6	41.1	43.5	46.0	48.2	50.6
Kitchener MTS #3	Kitchener-Wilmot Hydro	Planning Demand	54.3	64.4	66.5	67.3	67.5	77.0	77.5	78.1	78.7	79.0	79.6
Kitchener MTS #7	Kitchener-Wilmot Hydro	Planning Demand	44.9	45.1	45.9	46.0	45.6	45.6	45.6	45.7	39.9	39.8	39.9
Kitchener MTS #5	Kitchener-Wilmot Hydro	Planning Demand	73.9	73.8	74.6	74.5	73.8	73.5	73.2	73.1	78.8	78.3	78.2
Detweiler TS	Kitchener-Wilmot Hydro	Planning Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Kitchener MTS #4	Kitchener-Wilmot Hydro	Planning Demand	67.8	68.2	69.1	69.3	69.0	69.0	68.9	69.2	69.3	69.1	69.3
Kitchener MTS #9	Kitchener-Wilmot Hydro	Planning Demand	33.7	33.9	34.3	34.6	34.5	34.7	34.9	35.0	35.3	35.4	35.5
Kitchener MTS #1	Kitchener-Wilmot Hydro	Planning Demand	29.1	29.6	31.1	31.6	31.8	32.1	32.4	32.9	33.3	33.5	33.9
Wolverton DS	Hydro One Distribution	Planning Demand	21.2	21.4	21.6	21.6	21.6	21.6	21.6	21.7	21.8	21.7	21.9
Fergus TS	Hydro One Distribution	Planning Demand	108.9	108.8	109.5	109.7	108.5	108.3	108.2	108.5	108.7	108.3	108.7
Puslinch DS	Hydro One Distribution	Planning Demand	35.6	36.2	36.8	37.3	37.5	37.9	38.3	38.7	39.2	39.5	39.9
Cedar TS T1/T2	Guelph Hydro	Planning Demand	72.3	74.9	75.8	77.4	78.3	79.5	79.8	82.2	84.6	85.5	87.9
Cedar TS T7/T8	Guelph Hydro	Planning Demand	30.2	32.0	32.0	32.8	32.3	33.0	33.7	33.4	34.2	34.8	35.5
Hanlon TS	Guelph Hydro	Planning Demand	29.8	30.7	31.6	32.5	33.0	33.7	34.4	35.1	34.9	35.5	35.3
Arlen MTS	Guelph Hydro	Planning Demand	30.0	33.0	37.0	40.9	33.3	37.9	41.4	43.0	44.6	45.9	47.5
Campbell TS	Guelph Hydro	Planning Demand	131.9	136.3	139.0	140.2	141.2	142.8	144.4	148.4	152.2	156.2	160.1
Scheifele MTS	Waterloo North Hydro	Planning Demand	169.0	166.0	170.7	150.3	151.2	152.7	154.3	156.2	158.1	153.4	155.4
Waterloo MTS #3	Waterloo North Hydro	Planning Demand	61.9	70.8	72.7	75.3	79.3	64.6	58.0	75.3	76.8	76.9	78.4
Snider MTS-Note 2	Waterloo North Hydro	Planning Demand	0.0	0.0	0.0	30.6	35.2	50.9	60.3	61.9	64.4	65.6	68.1
Bradley MTS-Note 2	Waterloo North Hydro	Planning Demand	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Elmira TS	Waterloo North Hydro	Planning Demand	30.4	25.1	26.0	25.8	27.4	28.1	28.8	29.6	31.3	31.9	33.6
Rush MTS	Waterloo North Hydro	Planning Demand	54.9	63.8	65.7	67.4	67.4	67.8	69.1	53.0	53.6	60.7	61.3
Customer #1 CTS-Note 3	Customer Tx Stations	Planning Demand	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5	5.5
Customer #2 CTS	Customer Tx Stations (Assumed values)	Planning Demand	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0

Planning demand (MW) = ((Gross-CDM) x Extreme Weather Factor) – DG

*Based upon KWCG 2015 IRRP Planning Load Forecast except where otherwise noted.

Note 1: The LDC has confirmed 9.2 MW of cogeneration at a large customer to be accounted for in the Preston TS forecast starting year 2016. The generation plant is expect to run most of the time and would offset the customer's load. This cogeneration was not factored into the KWCG 2015 IRRP Planning Load Forecast.

Note 2: The LDC has confirmed that additional transformation capacity (Snider/Bradley TS) would not be required until after 2024. The exact location and timing of these TS's have not been determined at this time. The load growth indicated at Snider and Bradley in the forecast can be managed by existing TS's/impact of CDM/DG in the Waterloo Region. LDCs are monitoring the load closely to determine the timing of potential transformation needs.

Where possible, these LDCs are exploring opportunities to coordinate use and development of TS facilities in the KWCG Region over the long term. Cambridge #2 is assumed to be supplied off the KWCG 115kV system

Note 3: Slight modification from KWCG 2015 IRRP Planning forecast based on information provided by the transmission-connected customer

Note: Guelph CTS 1 forecast was removed as the LDC confirmed the load was already accounted for within their forecast

APPENDIX D: TECHNICAL RESULTS – LOCAL AREA ANALYSIS

Single element contingencies were considered in order to determine the presence of thermal overload and/or voltage violations.

Table D1: Single Element Contingencies (single zone of protection)

Loss of a Single Circuit (N-1)					
D11K	D12K	D8S	D10H	D7F	D9F
F11C	F12C	B5G	B6G	D4W	D5W
M20D*	M21D**	D6V***	D7V****		
Loss of a Single Autotransformer (N-1)					
Detw. T2	Detw. T3♦	Detw. T4♦♦	Cedar T3♦♦♦	Cedar T4♦♦♦♦	Preston T2**
Middleport T3♦♦♦♦♦		Middleport T6♦♦♦♦♦			
Loss of a Single HV Reactive Element (N-1)					
Detweiler 230 kV cap. bank	Middleport 230 kV cap. bank(K1D1)	Orangeville 230 kV cap. bank		Burlington 230 kV cap. bank	
Detweiler 230 kV SVC	Middleport 230 kV cap. bank(K2D2)	Detweiler 115 kV cap bank		Burlington 115 kV cap bank	

*M20D (includes Detweiler T3 and Preston T2 via Preston Special Protection Scheme)

**M21D (includes Preston T2)

***D6V (includes Detweiler T4 and Cedar T3)

****D7V (includes Cedar T4)

♦Detweiler T3 (includes circuit M20D and Preston T2 via Preston SPS)

♦♦Detweiler T4 (includes circuit D6V and Cedar T3)

♦♦♦Cedar T3 (includes circuit D6V and Detweiler T4)

♦♦♦♦Cedar T4 (includes circuit D7V)

♦♦♦♦♦Middleport T3 (includes circuit N580M and V586M due to Line End Open)

♦♦♦♦♦Middleport T6 (includes circuit N581M and M585M due to Line End Open)

Results: Thermal Overload and Voltage Violations

Table D3: Thermal Analysis (>100% LTE), year 2025

Element	Contingency	%LTE
All circuits and auto-transfers are within ratings		

Table D4: Voltage Analysis, year 2025

Element	Contingency	%Voltage Decline	Voltage kV
All voltages are within criteria			

APPENDIX E: TECHNICAL RESULTS – BULK POWER SYSTEM CONSIDERATIONS

Applicable contingencies were considered on BPS elements to establish their impact on the local area.

Table E1: N-2 Contingencies

Loss of a Double Circuit Line (N-2) emanating from a BPS station		
B22D and B23D	D4W and D5W	M20D and M21D
D6V and D7V	--	--
Breaker Failure (B/F) Contingencies at BPS station (N-2)		
Detweiler TS 230 kV bus	B/F of AL6	Loss of: D6V, Cedar T3, Detw T4, M21D, Preston T2
	B/F of AL7	Loss of: D7V, Cedar T4, M21D, Preston T2
	B/F of L7L20	Loss of: D7V, Cedar T4, M20D, Detw T3, Preston T2
	B/F of HT1A	Loss of: M21D, Preston T2, SVC1
	B/F of ACS21	Loss of : M21D, Preston T2, SC21
	B/F of HL20	Loss of: M20D, Detw T3, D5W, SC22
	B/F of T2SC21	Loss of: Detw T2, SC21
	B/F of HT2	Loss of: Detw T2, SC21, D5W
	B/F of DL22	Loss of: B22D, D6V, Cedar T3, Detw T4
Middleport TS 500 kV bus	Covered under Loss of Middleport T3 and T6 autotransformers for the local area analysis (Appendix D)	
Middleport TS 230 kV bus	There are no B/F conditions that would be critical to the supply to the KWCG area.	

Table E2: N-1-1 Contingencies

Loss of a Critical Element, System Adjustment, Loss of a Critical Element (N-1-1)
Loss of: Detw T4 plus Detw T3 (plus M20D by configuration which also includes the loss of Preston T2 via Preston SPS)
Loss of: Preston T2 plus D7V (plus Cedar T4 by configuration)

Note that during the simulations no System Adjustment was afforded; this is considered a conservative approach.

Results: Thermal Overloads and Voltage Violations

As per Table E3 and E5: Detweiler TS 230/115 kV autotransformer T2 will become overloads when Detweiler TS autotransformer T4 is out-of-service followed by the loss of Detweiler TS autotransformer T3 in conjunction with circuit M20D by configuration. Preston TS autotransformer T2 is also removed from service via the Preston SPS.

Table E3: Thermal Analysis (>95% LTE), year 2016

Element	Contingency	%LTE
Detweiler TS T2 autotransformer	Detweiler T4 plus Detweiler T3 with M20D (includes Preston T2 via Preston SPS)	104.4 (74.2% STE*) %

*STE rating of Detweiler T2 auto-transformer is 396 MVA.

Table E4: Voltage Analysis, year 2016

Element	Contingency	%Voltage Decline	Voltage kV
All voltages are within criteria			

Table E5: Thermal Analysis (>95% LTE), year 2025

Element	Contingency	%LTE
Detweiler TS T2 autotransformer	Detweiler T4 plus Detweiler T3 with M20D (includes Preston T2 via Preston SPS)	114.2 (81.4%STE*)

*STE rating of Detweiler T2 auto-transformer is 396 MVA.

Table E6 Voltage Analysis, year 2025

Element	Contingency	%Voltage Decline	Voltage kV
All voltages are within criteria			

APPENDIX F: LOAD SECURITY ANALYSIS

Load connected to each circuit pair that is lost by configuration following an [N-2] double circuit contingency is:

Table F1: Load Lost Due to Configuration, year 2016

Circuit Pair	MW
M20/21D	420
D6/7V	482
D4/5W	34
D7/9F	131
F11/12C	74
B5/6G	105
D11/12K	98
D8S/D10H	89

Table F2: Load Lost Due to Configuration, year 2025

Circuit Pair	MW
M20/21D	489
D6/7V	571
D4/5W	36
D7/9F	141
F11/12C	78
B5/6G	128
D11/12K	103
D8S/D10H	95 ⁶

Table F1 illustrates that none of the double circuit contingencies result in more than 482 MW of load lost in year 2016.

Table F2 illustrates that none of the double circuit contingencies result in more than 571 MW of load lost in year 2025.

⁶ D8S and D10H emanate out of Detweiler TS as a double circuit line however after ~ 5 km they each become a single circuit 115 kV line. Based on their N/O open points, the loss of the double circuit line within the 5 km span out of Detweiler TS, will results in approximately 95 MW of load lost.

Table F3: Two Elements Out of Service

Loss of a Double Circuit Line				
D7F and D9F		F11C and F12C		B5G and B6G
D4W and D5W		M20D and M21D		D11K and D12K
D6V and D6V				
Loss of Two Autotransformers ⁷				
Station	Detweiler Auto	Preston Auto	Cedar Auto	Burlington Auto
Detweiler Auto	N/A	Detweiler T3 + Preston T2	Cedar T3 + Detweiler T4	Burlington T6 + Detweiler T3
Preston Auto	Detweiler T3 + Preston T2	N/A	Cedar T4 + Preston T2	Burlington T6 + Preston T2
Cedar Auto	Cedar T3 + Detweiler T4	Cedar T4 + Preston T2	Cedar T3 + Cedar T4	Burlington T6 + Cedar T3
Burlington Auto	Burlington T6 + Detweiler T3	Burlington T6 + Preston T2	Burlington T6 + Cedar T3	N/A

Results: Thermal Overload and Voltage Violations

Table F5: Thermal Analysis (>100% STE), year 2025

Element	Contingency	%STE
All circuits and auto-transfers are within ratings		
Element	Contingency	%LTE
All circuits and auto-transfers are within ratings		

Table F6: Voltage Analysis (> emergency ratings), year 2025

Element	Contingency	%Voltage Decline	Voltage kV
All voltages are within criteria			

⁷ For stations that have three or more autotransformers connected in parallel typical operating practice after the loss of one autotransformer is to make load transfers to other interconnected autotransformer station(s) such that the remaining load at the affected station would be at or below the station's reduced Limited Time Rating (LTR). It is assumed in this case that sufficient time between single autotransformer contingencies is available for such load transfers to be carried out by operator response.

APPENDIX G: LOAD RESTORATION ANALYSIS

Restoration of Load Connected to M20/21D

By year 2025 the total forecasted load connected to circuits M20/21D is 489 MW. Loss of this double circuit line would result in the loss of all 489 MW. In order to restore load to these stations at least one circuit would have to be placed back in service, noting that to restore Customer #1 CTS circuit M21D must specifically be placed back in service due to the customer's single-circuit transmission-connection

Based on criteria:

Load Required to be Restored	Duration
239MW	30 min.
100 MW	Within 4 hrs.
150 MW	Within 8 hrs.

Existing infrastructure allows for only the restoration of 100 MW of load in approximately 30 min. This can be accomplished by opening the M20/211D line disconnect switches at Preston TS and back-feed Preston TS T2 230-115 kV autotransformer to supply load at Preston TS only.

Therefore, the existing restoration capability to loads connected to M20/21D does not meet criteria for the duration of the study period.

Restoration of Load Connected to D6/7V

By year 2025 the total forecasted load connected to D6/7V is 571 MW. Loss of this double circuit line would result in the loss of all 571 MW. As part of the Guelph Area Transmission Reinforcement project, two 230 kV in-line switches will be installed in year 2016 on the main line between Detweiler TS and Orangeville TS at Guelph North Junction. To restore load to these stations, the operator will utilize these switches to isolate the problem and return to service the remaining healthy circuit sections. These switches allow for more flexibility to restore load to the affected stations in a timely fashion.

Based on criteria:

Load Required to be Restored	Duration
321MW	30 min.
100 MW	Within 4 hrs.
150 MW	Within 8 hrs.

Depending on:

1. the severity of the double circuit contingency;
2. the prevailing system conditions and

3. the relative distance from the nearest field maintenance centre⁸

the load restoration criterion is substantially met. Therefore, no additional transmission restoration capability is warranted at this time.

Restoration of Load Connected to D4/5W

By year 2025 the total forecasted load connected to D4/5W is 36 MW. Loss of this double circuit line would result in the loss of all 36 MW. To restore load to this station at least one circuit would have to be placed back in service.

Based on criteria:

Load Required to be Restored	Duration
36 MW	Within 8 hrs.

Depending on:

1. the severity of the double circuit contingency;
2. the prevailing system conditions and
3. the relative distance from the nearest field maintenance centre

the load restoration criteria can be met. Therefore, no additional transmission restoration capability is warranted at this time.

Restoration of Load Connected to D7/9F

By year 2025 the total forecasted load connected to D7/9F is 141 MW. Loss of this double circuit line would result in the loss of all 141 MW. To restore load to these stations at least one circuit would have to be placed back in service.

Based on criteria:

Load Required to be Restored	Duration
141 MW	Within 8 hrs.

Depending on:

1. the severity of the double circuit contingency;
2. the prevailing system conditions and
3. the relative distance from the nearest field maintenance centre

the load restoration criteria can be met. Therefore, no additional transmission restoration capability is warranted at this time.

⁸ The KWCG area is considered an urban area and as such, access to transmission facilities, repair materials and personnel in order to make a repair within 8 hours is realistic. A Hydro One field maintenance centre is located in Guelph.

Restoration of Load Connected to F11/12C

By year 2025 the total forecasted load connected to F11/12C is 78 MW. Loss of this double circuit line would result in the loss of all 78 MW. To restore load to these stations at least one circuit would have to be placed back in service.

Based on criteria:

Load Required to be Restored	Duration
78 MW	Within 8 hrs.

Depending on:

1. the severity of the double circuit contingency;
2. the prevailing system conditions and
3. the relative distance from the nearest field maintenance centre

the load restoration criteria can be met. Therefore, no additional transmission restoration capability is warranted at this time.

Restoration of Load Connected to B5/6G

By year 2025 the total forecasted load connected to B5/6G is 128 MW. Loss of this double circuit line would result in the loss of all 128 MW. To restore load to Enbridge Westover CTS's circuit B5G must be placed back in service due to the CTS's single-circuit transmission connection. To restore load at the other stations at least one circuit would to be placed back in service.

Based on criteria:

Load Required to be Restored	Duration
128 MW	Within 8 hrs.

Depending on:

1. the severity of the double circuit contingency;
2. the prevailing system conditions and
3. the relative distance from the nearest field maintenance centre

the load restoration criteria can be met. Therefore, no additional transmission restoration capability is warranted at this time.

Restoration of Load Connected to D11/12K

The total forecasted load serviced by radial circuits D11/12K will not exceed 103 MW by 2025. Loss of this double circuit line would result in the loss of all 103 MW. To restore load to these stations at least one circuit would have to be placed back in service.

Based on criteria:

Load Required to be Restored	Duration
103 MW	Within 8 hrs.

Depending on:

1. the severity of the double circuit contingency;
2. the prevailing system conditions and
3. the relative distance from the nearest field maintenance centre

the load restoration criteria can be met. Therefore, no additional transmission restoration capability is warranted at this time.

Restoration of Load Connected to D8S/D10H

The total forecasted load serviced by these radially operated 115 kV circuits will not exceed approximately 95 MW by year 2025. Loss of this double circuit line would result in loss of all 95MW. To restore Rush MTS either circuit can be placed back into service or the station could possibly be fed via circuit L7S out of Seaforth TS; however to restore Elmira TS circuit D10H must be placed back in service due to Elmira TS's single-circuit transmission-connection.

Based on criteria:

Load Required to be Restored	Duration
95 MW	Within 8 hrs.

Depending on:

1. the severity of the double circuit contingency;
2. the prevailing system conditions and
3. the relative distance from the nearest field maintenance centre

the load restoration criteria can be met. Therefore, no additional transmission restoration capability is warranted at this time.

APPENDIX H: SUPPLY TO ELMIRA TS AND RUSH MTS**Study Results:**

Table H1: Station Capacity: Summer Ratings and Summer Load Forecast

Station	Transformer Capacity (10-day LTR)	Year 2025 Load Forecast
Rush MTS	69 MVA*	61.3 MW / 69.9 MVA (0.88 pf** at defined meter point, 115 kV side)
Elmira TS	58.5 MVA	33.6 MW / 37.1 MVA*** (0.91 pf at defined meter point, 115 kV side)

*The limiting component is a low voltage cable; when required the limiting component will be modified and the rating to be 75 MVA

** Power factor at the defined meter point improves to 0.92 when 5.4 MVar of installed feeder capacitor banks assumed lumped at the LV bus and results in 66.8 MVA loading

*** A 9.2 MVar @ 27.6 kV shunt capacitor bank is installed at Elmira TS not in-service; when in-service power factor improves and loading through the transformers decrease.

Table H2: Transmission Capacity of circuits D8S and D10H

Year	Contingency	D10H – Detweiler TS x Waterloo Jct.	D8S – Detweiler TS x Leong Jct.
		590 A Continuous 640 A Long-Term Emergency (LTE) 660 A Short-Term Emergency (15-min.)	590 A Continuous 640 A Long-Term Emergency (LTE) 660 A Short-Term Emergency (15-min.)
2016	Pre	287 A	285 A
	Loss of D8S	454 A	--
	Loss of D10H	--	459 A
2025	Pre	319 A /	302 A
	Loss of D8S	511	--
	Loss of D10H	--	500 A

-assume all St. Mary's TS load is supplied by D8S (as this is more conservative for the study), assume Conestogo Wind Farm not-service (as it would displace load on D10H) and the normally-open point on D10H is between Elmira TS and Palmerston TS

Table H3: Voltage Profile at Rush MTS and Elmira TS

Year	Contingency	Rush MTS 115 kV D8S	Rush MTS 115 kV D10H	Rush MTS 13.8 kV	Elmira TS 115 kV	Elmira TS 27.6 kV
2016	Pre	122.2	122.2	14.4	120.8	27.2
	Loss of D8S	--	121.8	13.7	120.6	27.1
	Loss of D10H	121.5	--	13.7	--	--
2025	Pre	123.2	123.1	14.2	121.6	27.3
	Loss of D8S	--	122.6	13.6	121.1	27.2
	Loss of D10H	122.4	--	13.6	--	--

-assume all St. Mary's TS load is supplied by D8S (as this is more conservative for the study), assume Conestogo Wind Farm not-service (as it would displace load on D10H) and the normally-open point on D10H is between Elmira TS and Palmerston TS

Analysis:

D8S

Circuit D8S has a normally open point at St. Mary's TS separating the circuit from circuit L7S. D8S normally supplies half the load at Rush MTS and half the load at St. Mary's TS. The other half of the load at Rush MTS is normally supplied by circuit D10H and the other half of the load at St. Mary's TS is normally supplied by L7S. Referring to Table H2, for the loss of circuit D10H, circuit D8S has sufficient capacity to supply all load at Rush MTS and St. Mary's TS for year 2025 and beyond.

D10H

Circuit D10H runs between Detweiler TS and Hanover TS and has a normally open point between Elmira TS and Palmerston TS. Elmira TS is normally supplied from Detweiler TS while Palmerston TS is normally supplied from Hanover TS. Referring to Table H2, D10H has sufficient capacity to supply all load at Elmira TS for year 2025 and beyond. When circuit D8S is out of service, D10H has sufficient capacity to supply all load at Elmira TS and Rush MTS (while St. Mary's TS is supplied by circuit L7S).

Rush MTS

Since this station is a Municipal owned station, Waterloo North Hydro is to ensure there is sufficient transformation capacity to accommodate load growth. According to load forecasts and referring to Table H1, over the next 10-years load will fluctuate above and below the year 2025 forecast but will remain within the station's Limited Time Rating (LTR). Waterloo North Hydro is to inform Hydro One if the connection requires

modification and/or if a new station connection is required in order to accommodate load growth. Waterloo North Hydro has already incorporated their future Snider MTS and Bradley MTS into the KWCG regional plan to cater for load growth.

Rush MTS is supplied by two 115 kV circuits, D8S and D10H. Referring to Tables H2 and H3, when one of these circuits is out of service, the voltage profile at Rush MTS is healthy and the other circuit has sufficient capacity to supply all load to Rush MTS.

Elmira TS

According to the forecast and referring to Table H1, transformers at Elmira TS have sufficient capacity for year 2025 loading and beyond.

Elmira TS is supplied by one 115 kV circuit, D10H. Referring to Tables H2 and H3, the voltage profile at Elmira TS is healthy and the circuit has sufficient capacity to supply load to Elmira TS for year 2025 loading and beyond.

When circuit D10H out of Detweiler TS is unavailable, Elmira TS may also be supplied by D10H out of Hanover TS (by closing the normally open point between Palmerston TS and Elmira TS). Assuming Palmerston TS is at its forecasted year 2025 normal weather peak load, approximately 25 MW of load at Elmira TS may be supplied out of Hanover TS. The limiting factor being the 115 kV voltage profile on D10H as Elmira TS is nearly 80 circuit km from Hanover TS.

<Blank Page>

Appendix E:

KWCG Needs Assessment Report (2018)



Hydro One Networks Inc.
483 Bay Street
Toronto, Ontario
M5G 2P5

NEEDS ASSESSMENT REPORT

Kitchener - Waterloo - Cambridge - Guelph (KWCG) Region

Date: December 19, 2018

Prepared by: KWCG Region Study Team



Disclaimer

This Needs Assessment Report was prepared for the purpose of identifying potential needs in the KWCG Region and to recommend which need may require further assessment and/or regional coordination to develop a preferred plan. The results reported in this Needs Assessment are based on the input and information provided by the Study Team.

The Study Team participants, their respective affiliated organizations, and Hydro One Networks Inc. (collectively, “the Authors”) shall not, under any circumstances whatsoever, be liable to each other, to any third party for whom the Needs Assessment Report was prepared (“the Intended Third Parties”) or to any other third party reading or receiving the Needs Assessment Report (“the Other Third Parties”). The Authors, Intended Third Parties and Other Third Parties acknowledge and agree that: (a) the Authors make no representations or warranties (express, implied, statutory or otherwise) as to this document or its contents, including, without limitation, the accuracy or completeness of the information therein; (b) the Authors, Intended Third Parties and Other Third Parties and their respective employees, directors and agents (the “Representatives”) shall be responsible for their respective use of the document and any conclusions derived from its contents; (c) and the Authors will not be liable for any damages resulting from or in any way related to the reliance on, acceptance or use of the document or its contents by the Authors, Intended Third Parties or Other Third Parties or their respective Representatives.

Executive Summary

REGION	Kitchener - Waterloo - Cambridge - Guelph (KWCG) Region		
LEAD	Hydro One Networks Inc. (“HONI”)		
START DATE	September 17, 2018	END DATE	December 19, 2018

1. INTRODUCTION

The first cycle of the Regional Planning process for the KWCG Region an Integrated Regional Resource Plan (“IRRP”) was published in April 2015 which identified a number of near- and mid-term needs in the KWCG region. The planning process was completed in December 2015 with the publication of the Regional Infrastructure Plan (“RIP”) which provided a description of needs and recommendations of preferred wires plans to address near-term needs. The RIP also identified some near- and mid-term needs that will be reviewed during this Regional Planning cycle.

The purpose of this Needs Assessment (“NA”) is to identify any new needs and to reaffirm needs identified in the previous KWCG Regional Planning cycle.

2. REGIONAL ISSUE/TRIGGER

In accordance with the Regional Planning process, the regional planning cycle should be triggered at least every five years. In light of the timing of the needs identified in the previous Integrated Regional Resource Plan (“IRRP”) and RIP reports as well as new replacement/ refurbishment needs in the KWCG Region, the 2nd Regional Planning cycle was triggered for this Region.

3. SCOPE OF NEEDS ASSESSMENT

The scope of this NA includes:

- Review and reaffirm needs/plans identified in the previous RIP; and
- Identification and assessment of system capacity, reliability, operation, and aging infrastructure needs.

The Study Team may also identify additional needs during the next phases of the planning process, namely Scoping Assessment (“SA”), IRRP and RIP, based on updated information available at that time.

4. INPUTS/DATA

The Study Team representatives from Local Distribution Companies (“LDC”), the Independent Electricity System Operator (“IESO”), and Hydro One provided input and relevant information for the KWCG Region regarding capacity needs, reliability needs, operational issues, and major assets/facilities approaching end-of-life (“EOL”). In addition, community energy plans in the region have also been scanned and reviewed.

5. ASSESSMENT METHODOLOGY

The assessment’s primary objective is to identify the electrical infrastructure needs, recommend further mitigation or action plan(s) to address these needs, and determine whether further regional coordination or broader study would be beneficial.

The assessment reviewed available information including load forecasts, conservation and demand management (“CDM”) and distributed generation (“DG”) forecasts, reliability needs, operational issues, and major high

voltage equipment identified to be at or near the end of their useful life and requiring replacement/refurbishment.

A technical assessment of needs was undertaken based on:

- Current and future station capacity and transmission adequacy;
- Reliability needs and operational concerns; and
- Any major high voltage equipment reaching the end of its useful life.

6. NEEDS

I. Station & Transmission Supply Capacity

- Campbell TS (T3/T4) DESN Overloading is forecasted in the 2021-2022.
- Future need for Waterloo North Hydro MTS #4
- Future need for Energy+ MTS #2

A contingency analysis was performed and due to reduced forecasts no issues were found.

II. System Reliability & Operation

- D10H 115 kV line reliability and restoration of Elmira TS loads.

III. Aging Infrastructure – Transformer Replacements and line Section Refurbishment

- Projects in execution:
 - i. Campbell TS – T1 (2018)
 - ii. Detweiler TS -Auto T2 & T4 (2021-2022)
 - iii. 115 kV B5C/ B6C Circuits (2019-2020)¹
- New projects:
 - i. 115 kV D7F/ D9F Circuits (2019-2020)²
 - ii. 230 kV D6V/ D7V Circuits (2019- 2020)³
 - iii. Hanlon TS - T1 & T2 (2023-2024)
 - iv. Kitchener MTS #5 - T9 & T10 (2023-2024)
 - v. Cedar TS - T7 & T8 (2024-2025)
 - vi. Scheifele MTS - T1 & T2 (2024-2026)
 - vii. Preston TS - T3 & T4 (2025-2026)

IV. Other Planning Considerations

The local municipalities in the region are extremely engaged and actively pursuing innovative ways to manage and/or reduce their energy needs over the next 10-20 Years. For example, several community energy plans have been developed in the region.

¹ Burlington TS to a CTS Line Section

² Tower 157 to Freeport Switching Station Line Section

³ Guelph North Junction to Fergus TS Line Section

7. RECOMMENDATIONS

The Study Team's recommendations for the above identified needs are as follows:

- a) The replacement of EOL station supply transformers at Campbell TS, Hanlon TS, Cedar TS, Kitchener MTS #5 and Preston TS along with the EOL auto transformers at Detweiler to proceed. Hydro One and the concerned LDCs will coordinate replacement of above equipment and develop replacement plans.
- b) The refurbishment of EOL line sections 115 kV B5C/ B6C, D7F/ D9F and 230 kV D6V/ D7V to proceed. Hydro One will coordinate refurbishment of these line sections with affected LDCs/ Customer.
- c) Hydro One will continue to work with Waterloo North Hydro Inc. to address the supply reliability issue at Elmira TS.
- d) The Study Team has recommended that Hydro One Transmission and the Guelph Hydro Electric System Inc. to closely monitor the loading at the T3/T4 Campbell TS DESN and to balance the loads between these DESNs when required.
- e) The Study Team recommends that the supply capacity needs with regards to Energy + MTS #2 and WNH MTS #4 be further assessed for optimization in the SA phase of regional planning. Once the optimization options are complete, Waterloo North Hydro and Energy+ shall conduct a technical and economic assessment in consultation with Hydro One.
- f) The Study Team has recommended that community energy plans will be further considered in the SA phase of the regional planning process.

TABLE OF CONTENTS

1	Introduction	7
2	Regional Issue/Trigger	8
3	Scope of Needs Assessment.....	8
4	Regional Description and Connection Configuration	8
5	Inputs and Data	11
6	Assessment Methodology	11
7	Needs.....	12
8	Conclusion and Recommendations	24
9	References	25
	Appendix A: KWCG Region Non-Coincident Summer Load Forecast.....	26
	Appendix B: Lists of Step-Down Transformer Stations.....	28
	Appendix C: Lists of Transmission Circuits.....	29
	Appendix D: Lists of LDCs in the KWCG Region	30
	Appendix E: Acronyms.....	31

List of Tables and Figures

Table 1: KWCG Region Study Team Participants	7
Table 2: Needs Identified in the Previous Regional Planning Cycle.....	12
Table 3: End-of-Life Equipment – KWCG Region	13
Figure 1: Geographical Area of the KWCG Region with Electrical Layout.....	9
Figure 2: KWCG Region (Single Line Diagram).....	10
Figure 3: Burlington TS to Harper’s Jct. to CTS B5C/ B6C Line Sections	16
Figure 5: Tower #157 Jct. to Freeport SS F11C/ F12C Line Section.....	17
Figure 4: Guelph North Jct. to Fergus TS D6V/ D7V Line Section.....	18
Figure 6: D10H 115 kV Line (Burlington TS to Elmira TS).....	22

1 INTRODUCTION

The first cycle of the Regional Planning process for the KWCG Region was completed in December 2015 with the publication of the Regional Infrastructure Plan (“RIP”). The RIP provided a description of needs and recommendations of preferred wires plans to address near- and medium-term needs. Waterloo North Hydro MTS #4 was the only need to be reviewed in this planning cycle.

The purpose of this Needs Assessment (“NA”) is to identify new needs and to reconfirm needs identified in the previous KWCG regional planning cycle. Since the previous regional planning cycle, some new needs in the region have been identified.

This report was prepared by the KWCG Region Study Team (“Study Team”), led by Hydro One Networks Inc. Participants of the Study Team are listed below in Table 1. The report presents the results of the assessment based on information provided by the Hydro One, the Local Distribution Companies (“LDC”) and the Independent Electricity System Operator (“IESO”).

Table 1: KWCG Region Study Team Participants

Company
Centre Wellington Hydro
Energy+
Guelph Hydro Electric System Inc.
Halton Hills Hydro
Hydro One Networks Inc. (Lead Transmitter)
Hydro One Networks Inc. (Distribution)
Independent Electricity System Operator (“IESO”)
Kitchener Wilmot Hydro Inc.
Milton Hydro
Waterloo North Hydro Inc.
Wellington North Power Inc.

2 REGIONAL ISSUE/TRIGGER

In accordance with the Regional Planning process, the Regional Planning cycle should be triggered at least every five years. In light of the timing of the needs identified in the previous IRRP and RIP reports as well as new replacement/ refurbishment identified needs in the KWCG Region, the 2nd Regional Planning cycle was triggered for the KWCG region.

3 SCOPE OF NEEDS ASSESSMENT

The scope of this NA covers the KWCG Region and includes:

- Identification of new needs based on latest information provided by the Study Team; and,
- Confirmation/updates of existing needs and/or plans identified in the previous planning cycle.

The Study Team may identify additional needs during the next phases of the regional planning process, namely Scoping Assessment (“SA”), Local Planning (“LP”), IRRP, and/or RIP.

4 REGIONAL DESCRIPTION AND CONNECTION CONFIGURATION

The KWCG Region covers the cities of Kitchener, Waterloo, Cambridge and Guelph, portions of Oxford and Wellington counties and the townships of North Dumfries, Puslinch, Woolwich, Wellesley and Wilmot. Electrical supply to the Region is provided from eleven 230 kV and thirteen 115 kV step-down transformer stations. The summer 2018 non-coincident regional loads were about 1390 MW. The approximate boundaries of the KWCG Region are shown below in Figure 1.

The main sources of electricity into the KWCG Region are from five Hydro One stations: Middleport TS, Buchanan TS, Detweiler TS, Orangeville TS and Burlington TS. At these stations electricity is transformed from 500 kV and 230 kV to 230 kV and 115 kV levels, respectively. Electricity is then delivered to the end users of LDCs and directly-connected industrial customers through 26 (TS/ MTS/ CTS) step-down transformer stations. Figure 2 illustrates these stations as well as the four major regional sub-systems: Waterloo-Guelph 230 kV sub-system, Cambridge-Kitchener 230 kV sub-system, Kitchener-Guelph 115 kV sub-system and South-Central Guelph 115 kV sub-system.

The summer non-coincident regional load forecast is provided as Appendix A. Appendix B lists all step-down transformer stations, Appendix C transmission circuits and Appendix D LDCs in the KWCG Region.




Figure 1: Geographical Area of the KWCG Region with Electrical Layout

An electrical single line diagram for the KWCG Region facilities is shown below in Figure 2.




Figure 2: KWCG Region (Single Line Diagram)

5 INPUTS AND DATA

Study Team participants, including representatives from LDCs, IESO, and Hydro One provided information and input for the KWCG Region NA. The information provided includes the following:

- KWCG Load Forecast for all supply stations;
- Known capacity and reliability needs, operating issues, and/or major assets approaching the end of their useful life (“EOL”); and
- Planned/foreseen transmission and distribution investments that are relevant to regional planning for the KWCG Region.

6 ASSESSMENT METHODOLOGY

The following methodology and assumptions are made in this Needs Assessment:

Information gathering included:

- i. Load forecast: The relevant LDCs provided load forecasts for all the stations supplying their loads in the KWCG region for the 10 year study period. The IESO provided a Conservation and Demand Management (“CDM”) and Distributed Generation (“DG”) forecast for the KWCG region. The region’s extreme summer non-coincident peak gross load forecast for each station were prepared by applying the LDC load forecast load growth rates to the actual 2018 summer peak extreme weather corrected loads. The extreme summer weather correction factors were provided by Hydro One. The net extreme weather summer load forecasts were produced by reducing the gross load forecasts for each station by the % age CDM and then by the amount of effective DG capacity provided by the IESO for that station. These extreme weather summer load forecast for the individual stations in the KWCG region is given in Appendix A;
- ii. Relevant information regarding system reliability and operational issues in the region; and
- iii. List of major HV transmission equipment planned and/or identified to be refurbished and/or replaced due to the end of their useful life which is relevant for regional planning purposes. This includes HV transformers, autotransformers, HV Breakers, HV underground cables and overhead lines.

A technical assessment of needs was undertaken based on:

- Current and future station capacity and transmission adequacy;
- System reliability and operational concerns; and
- Any major high voltage equipment reaching the end of its useful life.

In addition, Hydro One has reviewed the Community Energy Plans in the region. It is worth noting that there are several community energy plans in the region and some of them are meant to sustain at the

current level or reduce the community's reliance on the provincial electric system by meeting future electricity needs with local, distributed resources and/or community-based solutions. These plans may have potential to supplement and/or defer future transmission infrastructure development needs.

7 NEEDS

This section describes emerging needs identified in the KWCG Region, and also reaffirms the near, mid, and long-term needs already identified in the previous regional planning cycle.

The recent load forecast prepared for this report is lower than that of the previous cycle of regional planning. A contingency analysis was performed for the region and due to reduced load forecasts, as expected; no new system needs were identified.

The newly identified/emerging needs pertaining to this NA will be discussed further in the following sub-sections, while the status of the previously identified needs is summarized in Table 2 below.

Table 2: Needs Identified in the Previous Regional Planning Cycle

Type of Needs identified in the previous RP cycle	Needs Details	Current Status
115kV System Supply Capacity	GATR Project Two new additional 230/115kV autotransformers at Cedar TS to reinforce supply to both 115kV sub-systems in the region.	Completed
230kV Load Restoration Needs	GATR Project Two new additional 230 kV in-line switches on D6V/D7V circuits to improve restoration capability of Waterloo-Guelph 230 kV sub-system.	Completed
	Galt Junction Two new additional 230kV in-line switches on M20D/M21D circuits to improve restoration capability of the Cambridge-Kitchener 230 kV sub-system.	Completed
Station Short Circuit Capacity	Arlen MTS Install 13.8 kV series reactors to mitigate LV bus short circuit levels.	Completed
Station Transformation Capacity	New Waterloo North Hydro: MTS #4 (2024).	Need is now expected beyond 2029.

7.1 End-Of-Life (EOL) Equipment Needs

Hydro One and LDCs have provided high voltage asset information under the following categories that have been identified at this time and are likely to be replaced over the next 10 years:

- Autotransformers
- Power transformers
- HV breakers
- Transmission line requiring refurbishment where an uprating is being considered for planning needs and require Leave to Construct (i.e., Section 92) application and approval
- HV underground cables where an uprating is being considered for planning needs and require EA and Leave to Construct (i.e., Section 92) application and approval

Accordingly, following major high voltage equipment has been identified as approaching its end of useful life over the next 10 years.

Table 3: End-of-Life Equipment – KWCG Region

EOL Asset Replacement/ Refurbishment	Replacement/ Refurbishment Timing	Details
Projects in Execution		
Campbell TS (T1/T2 DESN): T1 Supply Transformer	2018	These Project are discussed further in Section 7.1.1
Detweiler TS: 230/ 115 kV T2/ T4 Auto-transformers	2021-2022	
115 kV B5C/ B6C: Burlington TS to Westover CTS Line Sections	2019-2020	
New Identified Projects		
115 kV D7F/ D9F : Tower #157 to Freeport SS Line Section	2019-2020	These Project are discussed further in Section 7.1.2
230 kV D6V/ D7V: Guelph North Jct. to Fergus Jct. Line Section	2019-2020	
Kitchener MTS #5 ^[1] : T9/T10 Supply Transformers	2023-2024	
Hanlon TS: T1/T2 Supply Transformers	2023-2024	
Cedar TS: T7/T8 Supply Transformers	2024-2025	
Scheifele MTS ^[1] - T1/T2 Supply Transformers	2024-2026	
Preston TS: T3/T4 Supply Transformers	2025-2026	

[¹] LDC owned assets

The end-of-life assessment for the above high voltage equipment typically included consideration of the following options:

1. Maintaining the status quo;
2. Replacing equipment with similar equipment of lower ratings and built to current standards;
3. Replacing equipment with lower ratings and built to current standards by transferring some load to other existing facilities;
4. Eliminating equipment by transferring all of the load to other existing facilities;
5. Replacing equipment with similar equipment and built to current standards (i.e., “like-for-like” replacement);
6. Replacing equipment with higher ratings and built to current standards; and
7. Station reconfiguration

Maintaining status quo is not an option for any of the above EOL autotransformer, station transformer or line sections due to risk of equipment failure, would result in increased maintenance cost and customer outages. Replacing “Like-for-Like” with nonstandard transformers would result in complexity with failures and difficulty in getting similar spare equipment along with their installation. Nonstandard equipment also poses serious safety risk for employees under normal and emergency situations.

No other lines or HV station equipment in the KWCG region have been identified for major replacement/refurbishment at this time. If and when new and/or additional information is available, it will be provided during the next planning phase underway at the time.

7.1.1 Projects in Execution

The following end-of-life refurbishment needs are under execution. This region was deemed to be in transition and NA for this region was deemed complete. Hence, following projects were not listed or discussed in the first cycle of regional planning and are currently in execution:

Campbell TS – T1 Transformer

Campbell TS is located in the city of Guelph supplying Guelph Hydro Electric System Inc. loads. Campbell TS has two 230/ 13.8 kV DESNs T1/T2 and T3/T4 of 75 MVA transformers with an LTR of 105 MVA (94 MW @ 0.9 PF) and 63 MVA (56 MW @ 0.9 PF) respectively. The loads on these two DESNs are currently forecasted to be about 87 MW and 66 MW respectively by the end of study period.

The 75 MVA T1/T2 DESN transformer T2 failed in 2017 and was replaced with a new standard 100 MVA unit and transformer T1 is also being replaced with a similar unit. In 2021-2022, Hydro One in addition plans to replace the secondary equipment limiting the station LTR. This will result in sufficient LTR of about 130 MVA for T1/T2 DESN, over the study period.

The replacement of T1 transformer is currently in execution and expected to be completed by the end of year 2018.

Detweiler TS - T2 & T4 Autotransformers

Detweiler TS is a Bulk System, major switching and autotransformer station located in the city of Kitchener. Detweiler TS facilities include a 230 kV switchyard, three 230/115 kV autotransformers (T2/T3/T4) and a 115 kV switchyard.

The Detweiler TS autotransformers T2/T3/ T4 were built in 1959, 2004 and 1963 respectively. The condition assessment has identified T2 and T4 autotransformers as EOL requiring replacement. At this time none of other HV equipment at this station has been identified as approaching EOL over the next 5-10 years.

Not replacing these auto transformers would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers. The replacement of both the EOL Detweiler TS T2 and T4 autotransformers with similar units is in execution expected to be completed in 2021-22. This will address the 230/ 115 kV transformation needs at Detweiler TS and maintain station's operability and reliability of supply.

Any Detweiler TS 230 kV system reconfiguration needs will be studied under bulk system planning expected to commence in early 2019.

115 kV B5C/ B6C Line Sections

The 115 kV B5C/B6C circuits consist of about 45 km of double circuit line and 15 km of single circuit line supplying South-Central Guelph 115 kV loads. About 12 km of double circuit line section from Burlington TS to Harper's Jct. and about 15 km B5C 115 kV line tap from Harper's Jct. to a Westover Jct. requires refurbishment.

Not refurbishing these line sections would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers.

The refurbishment of this 27 km long 115 kV B5C/B6C line sections from Burlington TS to a CTS is currently under execution and the work is planned to be completed by the end of year 2019.




Figure 3: Burlington TS to Harper's Jct. to CTS B5C/ B6C Line Sections

7.1.2 New Needs

The following end-of-life refurbishment needs have been identified in this regional planning cycle:

115 kV D7F/D9F Line Section

The 115 kV D7F/ D9F double circuit line is about 12 km long supplying Kitchener- Guelph 115 kV loads. The 115 kV D7F/ D9F double circuit 450 meter line section from Tower 157 to Freeport Switching Station was built in 1951. It is approaching end of life and requires refurbishment.

Not refurbishing this line section would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers.

Therefore the Study Team recommends Hydro One to continue with refurbishment of the 450 meter long 115 kV D7F/ D9F end of life line section from Tower 157 to Freeport Switching Station. This project is currently under estimating and is planned to be completed by the end of year 2019.




Figure 4: Tower #157 Jct. to Freeport SS F11C/ F12C Line Section

230 kV D6V/D7V Line Section

The 230 kV D6V/D7V double circuit line is about 84 km long and is part of bulk power system supplying loads in the Waterloo Guelph 230kV and South Central Guelph 115 kV loads. A 230 kV D6V/ D7V 9.5 km double circuit line section from Guelph North junction to Fergus TS was built in 1950's and its conductor is approaching end of life. It requires refurbishment.

Not refurbishing this line section would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers.

Therefore the Study Team recommends to refurbish this the 9.5 km long 230 kV D6V/D7V end of life line section from Guelph North Junction to Fergus TS. This project is currently under estimating and is planned to be completed by the end of year 2019.




Figure 5: Guelph North Jct. to Fergus TS D6V/ D7V Line Section

Kitchener MTS #5 T9/T10 Transformers

Kitchener MTS #5 is located in the city of Kitchener supplying Kitchener-Wilmot Hydro Inc. loads. Kitchener MTS #5 is a 115/ 13.8 kV single T9/T10 DESN station of 83 MVA nonstandard transformers having a LTR of 89 MVA (80 MW @ 0.9 PF), currently supplying 67 MW of peak load. The loads at Kitchener MTS #5 are currently forecasted to remain flat over the entire study period. The supply capacity of this station is therefore expected to be sufficient over and beyond the study period.

Both the T9/T10 transformers at this station have been identified as approaching end of life requiring replacement. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Kitchener MTS #5 having surplus capacity where this station's loads can be transferred. The Study Team recommends replacing the T9/T10 nonstandard transformers with standard units of similar size is the preferred option. Kitchener-Wilmot Hydro Inc. and Hydro One will coordinate the replacement plan of these transformers. The replacement of the EOL equipment is expected to be completed by 2023-2024.

Hanlon TS T1/T2 Transformer

Hanlon TS is located south of the city of Guelph supplying Guelph Hydro Electric System Inc. loads. Hanlon TS is a single T1/T2 DESN station of 33 MVA nonstandard transformers having a LTR of 48

MVA (43 MW @ 0.9 PF). This station is currently supplying about 27 MW of peak load. The loads at Hanlon TS are currently forecasted to remain flat over the entire study period. The supply capacity of this station is therefore expected to be sufficient over and beyond the study period.

The T1/T2 transformers are of 1955/ 56 built and have been identified as EOL requiring replacement. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

There is no nearby supply station/s to Hanlon TS having surplus capacity where this station's loads can be transferred therefore Hydro One plans to replace these EOL transformers with standard size units of 42 MVA in 2023-2024.

Cedar TS – T7/ T8 Transformers

Cedar TS is located in the city of Guelph supplying Guelph Hydro Electric System Inc. loads. Cedar TS has two 115/ 13.8 kV DESN units T1/T2 and T7/T8 of 75 MVA with a LTR of 115 MVA (103 MW @ 0.9 PF) and 37 MVA with a LTR of 44 MVA (40 MW @ 0.9 PF), currently supplying 67 MW and 36 MW of peak loads respectively. The loads at both Cedar TS DESNs are currently forecasted to remain almost flat over the entire study period. The supply capacity of this station is therefore expected to be sufficient over and beyond the study period.

The T7/T8 DESN 38 MVA nonstandard transformers are of 1958 built have been identified for replacement. The T1/T2 transformers are relatively newer and were built in early 1990s. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Cedar TS having surplus capacity where this station's loads can be transferred therefore Hydro One plans to replace these EOL transformers with standard size units of 42 MVA in 2024-2025 timeframe.

Cedar TS and Hanlon TS Optimization with Neighbouring Stations

After performing an analysis of the current distribution situation, it was determined that there are not enough spare feeder positions at HONI and GHESI stations to reallocate DESN loads in the sub-system without significant distribution system and neighboring station upgrades.

Over loading of Campbell DESN T3/T4 will be effectively managed by load transfer to DESN T1/T2 after 2021/22. Following that there will be no additional capacity at these two DESNs.

Secondly, Hanlon TS DESN has eight (8) feeders with three (3) being dedicated underground infrastructure to existing customers, two (2) feeders supplying the industrial load in the Hanlon Industrial Park, two (2) feeder circuits supplying residential load north of Hanlon TS and one (1) feeder to be utilized for planned future load growth at Gordon/ Clair. In addition, due to technical limitations at 13.8 kV distribution voltage and density of load on certain feeders sections, it is not possible to supply existing

loads from any other station without significant transmission and distribution investments. Therefore there are little or no significant optimization opportunity is present at this point in time. Option considered for load transfer will require significant new investment; for example:

- The two residential distribution feeders supplying loads north of Hanlon TS could be transferred to existing feeders out of Cedar TS. These load transfers will result in increased line losses and reduced capacity (due to voltage drop)
- Another option could be transferring remaining Hanlon TS load to Arlen MTS. This load transfer will require an additional DESN and underground infrastructure at Arlen MTS.

Hence, the Study Team recommends that Hydro One undertakes replacement of Cedar TS T7/T8 and Hanlon TS T1/T2 transformers with 42 MVA standard size units, being technically and economical most suitable solution. The replacement of EOL equipment is expected to be completed by 2023-2025 timeframe for both stations.

Scheifele MTS – T1/ T2 Transformers

Scheifele MTS is located in the city of Waterloo supplying Waterloo North Hydro Inc. loads. Scheifele MTS has four 230/ 13.8 kV transformers T1 and T2 of 67 MVA, and T3 and T4 of 83 MVA currently supplying 145 MW of peak loads. The load at this station is forecasted to remain almost flat over the entire study period. The total supply capacity of Scheifele MTS is 161 MW expected to be sufficient over the study period.

The T1/T2 transformers based on their age have been identified by Waterloo North Hydro Inc. as approaching end of life potentially requiring replacement in the 2024- 2026 timeframe. Waterloo North Hydro will be monitoring the condition of these transformers to assess their replacement need. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Scheifele MTS having surplus capacity where this station's loads can be transferred. The Study Team recommends that Waterloo North Hydro continue monitoring the condition of these T1/T2 transformers at Scheifele MTS and this need to be reassessed in the next regional planning cycle.

Preston TS T3/T4 Transformers

Preston TS (DESN) is located in the city of Cambridge supplying Energy+ loads. Preston TS is a single T3/T4 DESN station of 125 MVA transformers with no additional LTR capability available i.e. 125 MVA (113 MW @ 0.9 PF). This station is currently supplying about 92 MW of peak load. The loads at Preston TS are currently forecasted to peak at about 102 MW during the study period.

The T3/T4 transformers are almost 50 years old, having been built in 1968. Condition assessment has identified that both T3/T4 transformers are at their EOL requiring replacement. At this time none of other HV/LV equipment at this station has been identified as EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Preston TS having spare supply capacity where this station's loads can be transferred. The Study Team recommends replacing the existing 125 MVA 230/ 27.6 kV T3/T4 transformers at Preston TS with 125 MVA standard units. This will also result in an increased supplying capacity at Preston TS required to meet the future Energy+ needs in the Cambridge distribution area. The replacement plan for the equipment will be developed by Hydro One and coordinated with the affected LDC and/or customers and it is expected to be completed by 2025-2026.

7.2 Supply Reliability Needs

Supply reliability of Elmira TS –D10H 115 kV Line

The 115 kV D10H circuit between Detweiler TS and Hanover TS supplies loads at Rush MTS, Elmira TS and Palmerston TS. The D10H circuit has a normally open point just south of Palmerston TS through a motorized disconnect switch. The northern section of D10H is supplied from Hanover TS radially supplying Palmerston TS loads. The southern section of D10H supplied from Detweiler TS radially supplies Waterloo North Hydro's 34 MW Elmira TS peak loads. D10H also supplies Rush MTS which is also supplied by 115 kV D8S circuit from Detweiler TS.

The normally open motorized switch near Palmerston TS helps restore the loads at Elmira TS from Hanover TS in-case supply from Detweiler TS is interrupted and similarly helps restoring Palmerston TS loads from Detweiler if supply from Hanover is interrupted.

In last three years, supply to Elmira TS from Detweiler TS resulted in 3 outages due to faults on the D10H line section between Elmira TS tap and Detweiler TS. The Elmira TS load restoration from Hanover TS is slower due to manually operated disconnect switches at Elmira TS tap location.

Hydro One is currently assessing the condition of line and will continue to work with Waterloo North Hydro to address the supply reliability at Elmira TS. The developed mitigation plan to improve supply reliability of Elmira TS loads will be included in the final RIP report.




Figure 6: D10H 115 kV Line (Burlington TS to Elmira TS)

7.3 Station and Transmission Capacity Needs in the KWCG Region

The following Station and Transmission supply capacities needs have been identified in the KWCG region during the study period of 2019 to 2028.

7.3.1 Campbell TS (T3/T4) DESN Overloading

There are two DESN stations inside Campbell TS boundary. Both the T1/T2 and T3/T4 DESNs are 230 kV/ 13.8 kV having supply capacities of 94 MW and 56 MW, currently supplying 84 MW and 52 MW of loads respectively. The 75 MVA transformer T2 recently failed and was replaced with a Hydro One standard 100 MVA unit. The transformer T1 is also being replaced with a similar 100 MVA unit by the end of 2018. The load at T3/T4 DESN is forecasted to exceed its supply capacity of 56 MW in the 2021-2022 timeframe.

At Campbell TS, after replacement of T1 transformer and secondary equipment there will be sufficient spare supply capacity on T1/T2 DESN where excess T3/T4 DESN loads can be transferred. Hydro One Transmission and the Guelph Hydro Electric System Inc. will monitor the loading at the T3/T4 Campbell TS DESN and will balance the loads between the two DESNs, when required. The Study Team therefore recommends that no further action is required at this time.

7.3.2 Waterloo North Hydro MTS #4

During the last regional planning cycle a need for a new MTS #4 DESN was identified in the 2024 timeframe. The current load forecast defers this need beyond the needs assessment study period.

7.3.3 Energy+ MTS #2

Energy+ has initially identified a future need for a new DESN station (MTS #2) in the city of Cambridge near Preston TS. This station need is due to a potential new load center growth in their service territory. The additional supply capacity due to EOL transformer replacement and available new feeder positions at Preston TS, will defer this new MTS need beyond the study period of current regional planning cycle.

WNH MTS #4 and Energy+ MTS #2 Optimization

The Preston TS like-for-like transformer replacement is critical for local supply needs and will proceed according to the current plan. However, study team recommends that the supply capacity needs with regards to Energy + MTS #2 and WNH MTS #4 be further assessed for optimization in the next phases of regional planning. Once the optimization options are complete, Waterloo North Hydro and Energy+ shall conduct a technical and economic assessment in consultation with Hydro One.

7.4 Other Planning Considerations in the KWCG Region

Municipalities in KWCG region have developed their community energy plans with a primary focus to reduce their energy consumption by local initiatives over next 25 to 30 years. With respect to electricity, these communities are planning for an increased reliance on community energy sources such as distributed generation, generation behind the meters like rooftop solar systems and local battery storage systems to reduce cost and for improved reliability of electricity supply.

There are situations where behind the meter battery storage cannot be connected due to technical constraints. The LDCs in this region and Hydro One, outside the regional planning forum, can undertake the task of exploring the issue to assess technical constraints and /or other solutions that can facilitate connection of additional battery storage.

Communities are also working towards self-sufficiency by improving efficiencies of existing local energy systems i.e. reducing energy consumption and losses by means of utilizing smarter buildings, houses, efficient heating, cooling, appliances, equipment, and processes for all community needs. Ultimately, the objective of these energy plans in the region is to be a net zero carbon community.

Community energy plans may have potential to supplement and/or defer future transmission infrastructure development needs. The Study Team therefore recommends reviewing the community energy plans in the SA phase.

8 CONCLUSION AND RECOMMENDATIONS

Hydro One and Waterloo North Hydro Inc. will develop a supply reliability improvement plan for Elmira TS loads. The developed local plan to improve supply reliability of Elmira TS loads will be included in the final RIP report.

At Campbell TS, after replacement of T1 transformer and addressing the secondary equipment limitations there will be sufficient spare supply capacity on T1/T2 DESN to accommodate T3/T4 DESN overloading. Hydro One and the LDC will work together to balance loads between the two Campbell TS DESNs, when required.

The distribution system in the Cedar TS, Hanlon TS and Arlen MTS supply area is already optimized and there are not enough spare feeder positions at any of the stations to reallocate DESN loads without significant distribution system investments and upgrades at neighboring stations.

The Study Team's recommendations for the above identified needs are as follows:

- a) The replacement of EOL station supply transformers at Campbell TS, Hanlon TS, Cedar TS, Kitchener MTS #5 and Preston TS along with the EOL auto transformers at Detweiler to proceed. Hydro One and the concerned LDCs will coordinate replacement of above equipment and develop replacement plans.
- b) The refurbishment of EOL line sections 115 kV B5C/ B6C, D7F/ D9F and 230 kV D6V/ D7V to proceed. Hydro One will coordinate refurbishment of these line sections with affected LDCs/ Customer.
- c) Hydro One will continue to work with Waterloo North Hydro Inc. to address the supply reliability issue at Elmira TS.
- d) The Study Team has recommended that Hydro One Transmission and the Guelph Hydro Electric System Inc. to closely monitor the loading at the T3/T4 Campbell TS DESN and to balance the loads between these DESNs when required.
- e) The Study Team recommends that the supply capacity needs with regards to Energy + MTS #2 and WNH MTS #4 be further assessed for optimization in the SA phase of regional planning. Once the optimization options are complete, Waterloo North Hydro and Energy+ shall conduct a technical and economic assessment in consultation with Hydro One.
- f) The Study Team has recommended that community energy plans will be further considered in the SA phase of the regional planning process.

9 REFERENCES

- [1] [KWCG Regional Infrastructure Plan - December 2015](#)
- [2] [Planning Process Working Group Report to the Ontario Energy Board - May 2013](#)
- [3] [Ontario Resource and Transmission Assessment Criteria \(ORTAC\) – Issue 5.0 -August 2007](#)

Appendix A: KWCG Region Non-Coincident Summer Load Forecast

* LTR based on 0.9 power factor

Transformer Station		Summer 10 Day LTR*	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
Arlen MTS	Gross	45	24.44	25.17	25.92	26.70	27.50	28.33	29.18	30.05	30.95	31.88	32.84	33.82
	CDM		0.00	0.22	0.28	0.44	0.57	0.79	1.12	1.50	2.05	2.71	3.40	3.99
	DG		0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
	Net		24.42	24.94	25.64	26.25	26.92	27.53	28.04	28.54	28.89	29.16	29.43	29.83
Campbell TS (T1/T2)	Gross	94	83.46	84.71	85.98	87.27	88.58	89.91	91.26	92.63	94.02	95.43	96.86	98.31
	CDM		0.00	0.72	0.91	1.44	1.83	2.50	3.51	4.63	6.22	8.11	10.03	11.59
	DG		0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
	Net		83.45	83.98	85.06	85.82	86.75	87.40	87.74	87.99	87.78	87.30	86.82	86.72
Campbell TS (T3/T4)	Gross	56	51.62	53.42	55.29	57.23	59.23	61.30	63.45	65.67	67.97	70.35	72.81	75.36
	CDM		0.00	0.46	0.59	0.94	1.22	1.70	2.44	3.28	4.50	5.98	7.54	8.88
	DG		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Net		51.62	52.97	54.71	56.28	58.01	59.60	61.01	62.39	63.47	64.37	65.27	66.48
Cedar TS (T1/T2)	Gross	103	67.35	67.69	68.03	68.37	68.71	69.05	69.40	69.75	70.09	70.44	70.80	71.15
	CDM		0.00	0.58	0.72	1.13	1.42	1.92	2.67	3.49	4.64	5.99	7.33	8.38
	DG		0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
	Net		67.30	67.06	67.26	67.19	67.24	67.09	66.68	66.21	65.40	64.41	63.42	62.72
Cedar TS (T7/T8)	Gross	40	35.63	35.80	35.98	36.16	36.34	36.53	36.71	36.89	37.08	37.26	37.45	37.63
	CDM		0.00	0.31	0.38	0.60	0.75	1.01	1.41	1.85	2.45	3.17	3.88	4.44
	DG		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Net		35.63	35.50	35.60	35.57	35.59	35.51	35.29	35.05	34.62	34.09	33.57	33.20
Elmira TS	Gross	55	34.19	34.62	35.04	35.38	35.73	36.06	36.39	36.71	37.05	37.40	37.75	38.10
	CDM		0.00	0.30	0.37	0.58	0.74	1.00	1.40	1.84	2.45	3.18	3.91	4.49
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		34.17	34.31	34.65	34.78	34.98	35.04	34.97	34.86	34.58	34.20	33.83	33.60
Energy+ MTS #1	Gross	102	84.03	84.87	85.72	86.58	87.44	88.53	89.64	90.76	91.90	93.05	94.21	95.39
	CDM		0.00	0.73	0.91	1.43	1.80	2.46	3.45	4.54	6.08	7.91	9.75	11.24
	DG		0.32	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49
	Net		83.71	83.65	84.31	84.65	85.15	85.58	85.70	85.73	85.32	84.64	83.96	83.65
Fergus TS	Gross	154	87.52	88.57	89.62	90.27	90.96	91.52	92.07	92.62	93.20	93.83	94.45	95.05
	CDM		0.00	0.76	0.95	1.49	1.87	2.54	3.54	4.63	6.17	7.98	9.78	11.20
	DG		0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
	Net		87.47	87.77	88.62	88.73	89.03	88.92	88.48	87.94	86.98	85.80	84.62	83.80
Galt TS	Gross	169	113.56	114.69	115.84	117.00	118.17	119.64	121.14	122.65	124.19	125.74	127.31	128.90
	CDM		0.00	0.98	1.23	1.93	2.44	3.32	4.66	6.14	8.22	10.69	13.18	15.19
	DG		0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
	Net		113.35	113.51	114.40	114.86	115.53	116.11	116.27	116.31	115.76	114.84	113.93	113.51
Hanlon TS	Gross	43	26.85	27.25	27.66	28.08	28.50	28.93	29.36	29.80	30.25	30.70	31.16	31.63
	CDM		0.00	0.23	0.29	0.46	0.59	0.80	1.13	1.49	2.00	2.61	3.23	3.73
	DG		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Net		26.85	27.02	27.37	27.62	27.91	28.12	28.23	28.31	28.25	28.09	27.94	27.90
Kitchener MTS # 1	Gross	54	31.31	33.64	34.72	35.81	36.90	37.76	38.60	39.46	40.31	41.16	42.02	42.87
	CDM		0.00	0.29	0.37	0.59	0.76	1.05	1.49	1.97	2.67	3.50	4.35	5.05
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		31.28	33.33	34.33	35.19	36.11	36.68	37.09	37.47	37.62	37.64	37.65	37.79
Kitchener MTS # 3	Gross	108	46.73	45.03	45.34	46.05	46.78	47.49	48.22	48.93	49.64	50.37	51.08	51.81
	CDM		0.00	0.38	0.48	0.76	0.96	1.32	1.86	2.45	3.29	4.28	5.29	6.11
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		46.71	44.63	44.83	45.27	45.79	46.15	46.34	46.46	46.34	46.06	45.77	45.68

Transformer Station		Summer 10 Day LTR*	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
Kitchener MTS # 4	Gross	90	58.39	59.76	60.63	61.49	62.36	63.05	63.73	64.41	65.09	65.77	66.46	67.13
	CDM		0.00	0.51	0.64	1.01	1.29	1.75	2.45	3.22	4.31	5.59	6.88	7.91
	DG		0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
	Net		58.34	59.19	59.93	60.43	61.02	61.24	61.22	61.14	60.73	60.12	59.52	59.17
Kitchener MTS #5	Gross	80	66.56	67.94	68.82	69.70	70.58	71.28	71.96	72.66	73.35	74.03	74.73	75.42
	CDM		0.00	0.58	0.73	1.15	1.45	1.98	2.77	3.63	4.86	6.29	7.74	8.89
	DG		0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
	Net		66.50	67.31	68.03	68.49	69.07	69.24	69.14	68.97	68.43	67.68	66.94	66.47
Kitchener MTS #6	Gross	90	64.17	62.22	62.97	63.71	64.47	65.21	65.96	66.70	67.44	68.19	68.93	69.68
	CDM		0.00	0.53	0.67	1.05	1.33	1.81	2.54	3.34	4.46	5.80	7.14	8.21
	DG		0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09
	Net		64.08	61.60	62.21	62.57	63.04	63.30	63.33	63.27	62.88	62.30	61.70	61.38
Kitchener MTS #7	Gross	54	42.79	43.98	44.69	45.38	46.08	46.77	47.47	48.16	48.85	49.55	50.24	50.95
	CDM		0.00	0.38	0.48	0.75	0.95	1.30	1.83	2.41	3.23	4.21	5.20	6.00
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		42.77	43.59	44.19	44.61	45.11	45.45	45.63	45.73	45.60	45.32	45.03	44.92
Kitchener MTS #8	Gross	54	38.68	39.94	41.18	42.44	43.70	45.62	47.53	49.45	51.38	53.30	55.21	57.13
	CDM		0.00	0.34	0.44	0.70	0.90	1.27	1.83	2.47	3.40	4.53	5.71	6.73
	DG		0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
	Net		38.62	39.54	40.69	41.68	42.74	44.30	45.65	46.92	47.92	48.71	49.44	50.34
Kitchener MTS #9	Gross	90	30.16	30.72	31.28	31.83	32.39	32.94	33.50	34.05	34.61	35.17	35.73	36.27
	CDM		0.00	0.26	0.33	0.52	0.67	0.92	1.29	1.70	2.29	2.99	3.70	4.27
	DG		0.23	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
	Net		29.94	29.96	30.45	30.80	31.22	31.53	31.71	31.85	31.82	31.68	31.53	31.50
Preston TS	Gross	113	92.38	95.15	98.00	100.94	103.97	105.27	106.59	107.92	109.27	110.63	112.02	113.42
	CDM		0.00	0.81	1.04	1.67	2.14	2.92	4.10	5.40	7.23	9.41	11.60	13.37
	DG		0.00	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19
	Net		92.38	94.14	96.76	99.08	101.63	102.15	102.29	102.33	101.84	101.03	100.23	99.86
Puslinch DS	Gross	56	28.49	29.24	30.01	30.45	30.92	31.30	31.68	32.05	32.45	32.88	33.31	33.72
	CDM		0.00	0.25	0.32	0.50	0.64	0.87	1.22	1.60	2.15	2.80	3.45	3.97
	DG		0.02	0.02	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
	Net		28.47	28.98	29.54	29.80	30.14	30.29	30.31	30.30	30.16	29.94	29.71	29.60
Rush MTS	Gross	68	45.33	46.24	47.16	48.11	49.07	50.05	51.05	52.07	53.11	54.17	55.26	56.36
	CDM		0.00	0.40	0.50	0.79	1.01	1.39	1.97	2.60	3.52	4.61	5.72	6.64
	DG		0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
	Net		45.30	45.81	46.63	47.28	48.03	48.63	49.06	49.44	49.57	49.54	49.51	49.69
Scheifele MTS	Gross	161	144.78	146.96	149.16	151.39	153.67	155.98	158.32	160.69	163.11	165.55	168.04	170.56
	CDM		0.00	1.26	1.59	2.50	3.17	4.33	6.10	8.04	10.80	14.08	17.39	20.10
	DG		0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08
	Net		144.70	145.62	147.49	148.81	150.42	151.56	152.14	152.57	152.23	151.40	150.56	150.38
WNH MTS #3	Gross	77	56.29	57.42	58.57	59.74	60.93	62.15	63.39	64.66	65.95	67.27	68.62	69.99
	CDM		0.00	0.49	0.62	0.99	1.26	1.73	2.44	3.23	4.37	5.72	7.10	8.25
	DG		0.06	0.06	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
	Net		56.23	56.87	57.80	58.61	59.53	60.28	60.81	61.28	61.44	61.41	61.37	61.60
Wolverton DS	Gross	54	18.42	18.73	19.05	19.19	19.35	19.47	19.59	19.71	19.83	19.98	20.12	20.25
	CDM		0.00	0.16	0.20	0.32	0.40	0.54	0.75	0.99	1.31	1.70	2.08	2.39
	DG		0.00	0.00	0.00	0.00	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19
	Net		18.41	18.57	18.84	18.87	18.76	18.74	18.64	18.53	18.33	18.08	17.84	17.67
CTS	Net		9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80

Appendix B: Lists of Step-Down Transformer Stations

Sr. No.	Transformer Stations
1.	Arlen MTS
2.	Campbell TS (T1/T2)
3.	Campbell TS (T3/T4)
4.	Cedar TS (T1/T2)
5.	Cedar TS (T7/T8)
6.	Elmira TS
7.	Energy+ MTS #1
8.	Fergus TS
9.	Galt TS
10.	Hanlon TS
11.	Kitchener MTS # 1
12.	Kitchener MTS # 3
13.	Kitchener MTS # 4
14.	Kitchener MTS #5
15.	Kitchener MTS #6
16.	Kitchener MTS #7
17.	Kitchener MTS #8
18.	Kitchener MTS #9
19.	Preston TS
20.	Puslinch DS
21.	Rush MTS
22.	Scheifele MTS
23.	Waterloo North MTS 3
24.	Wolverton DS
25.	CTS - 1
26.	CTS - 2

Appendix C: Lists of Transmission Circuits

Sr. No.	Circuit ID	From Station	To Station	Voltage (kV)
1.	D6V/ D7V	Detweiler TS	Orangeville TS	220
2.	M20D/ M21D	Detweiler TS	Middleport TS	220
3.	D4W/ D5W	Detweiler TS	Buchanan TS	220
4.	B22D/ B23D	Detweiler TS	Bruce TS	220
5.	D7F/ D9F	Detweiler TS	Free Port SS	115
6.	F11C/ F12C	Free Port SS	Cedar TS	115
7.	B5C/ B6C	Cedar TS	Burlington TS	115
8.	D11K/ D12K	Detweiler TS	Kitchener MTS #4	115
9.	D8S	Detweiler TS	St. Mary TS	115
10.	D10H	Detweiler TS	Hanover TS	115

Appendix D: Lists of LDCs in the KWCG Region

Sr. No.	Company	Connection Type (TX/DX)
1.	Centre Wellington Hydro	Dx
2.	Energy+	Tx/ Dx
3.	Guelph Hydro Electric System Inc.	Tx/ Dx
4.	Halton Hills Hydro	Dx
5.	Hydro One Networks Inc. (Distribution)	Tx/ Dx
6.	Kitchener Wilmot Hydro Inc.	Tx
7.	Milton Hydro	Dx
8.	Waterloo North Hydro Inc.	Tx/ Dx
9.	Wellington North Power Inc.	Dx

Appendix E: Acronyms

Acronym	Description
A	Ampere
BES	Bulk Electric System
BPS	Bulk Power System
CDM	Conservation and Demand Management
CIA	Customer Impact Assessment
CGS	Customer Generating Station
CSS	Customer Switching Station
CTS	Customer Transformer Station
DESN	Dual Element Spot Network
DG	Distributed Generation
DS	Distribution Station
GS	Generating Station
HV	High Voltage
IESO	Independent Electricity System Operator
IRRP	Integrated Regional Resource Plan
kV	Kilovolt
LDC	Local Distribution Company
LP	Local Plan
LTE	Long Term Emergency
LTR	Limited Time Rating
LV	Low Voltage
MTS	Municipal Transformer Station
MW	Megawatt
MVA	Mega Volt-Ampere
MVAR	Mega Volt-Ampere Reactive
NA	Needs Assessment
NERC	North American Electric Reliability Corporation
NGS	Nuclear Generating Station
NPCC	Northeast Power Coordinating Council Inc.
NUG	Non-Utility Generator
OEB	Ontario Energy Board
OPA	Ontario Power Authority
ORTAC	Ontario Resource and Transmission Assessment Criteria
PF	Power Factor
PPWG	Planning Process Working Group
RIP	Regional Infrastructure Plan
SA	Scoping Assessment
SIA	System Impact Assessment
SPS	Special Protection Scheme
SS	Switching Station
STG	Steam Turbine Generator
TS	Transformer Station

Appendix F:

KWCG IRRP Scoping Assessment Outcome
Report (2019)

KITCHENER-WATERLOO- CAMBRIDGE-GUELPH REGION SCOPING ASSESSMENT OUTCOME REPORT

MAY 9, 2019



Table of Contents

KWCG Scoping Study Team	3
1. Introduction	4
2. Team.....	5
3. Categories of Needs, Analysis and Results	5
4. Conclusion	12
List of Acronyms	14
Appendix A: The Kitchener-Waterloo-Cambridge-Guelph IRRP Terms of Reference	15

KWCG Scoping Study Team

Company
Independent Electricity System Operator
Hydro One Networks Inc. (Transmission)
Hydro One Networks Inc. (Distribution)
Guelph Hydro Electric Systems Inc. (Alectra)
Centre Wellington Hydro
Waterloo North Hydro Inc.
Energy + Inc.
Kitchener-Wilmot Hydro
Wellington North Power Inc.
Halton Hills Hydro
Milton Hydro

Scoping Assessment Outcome Report Summary			
Region:	KWCG		
Start Date	February 8, 2019	End Date	May 8, 2019
1. Introduction			
<p>This Scoping Assessment Outcome Report is part of the Ontario Energy Board (OEB)’s regional planning process. The Board endorsed the Planning Process Working Group’s Report to the Board in May 2013 and formalized the process and timelines through changes to the Transmission System Code and Distribution System Code in August 2013.</p> <p>The first cycle of the regional planning process for the KWCG region was completed in April 2015. Needs were identified in the near- to medium-term timeframes, and solutions were recommended to address them, including the Guelph Area Transmission Reinforcement Project that is now in service.</p> <p>The second cycle of the regional planning process for the KWCG region was initiated in September 2018 with the Needs Assessment (NA) – the first step in the regional planning process – carried out by the study team led by Hydro One Networks Inc. (Hydro One). This report was issued on December 19, 2018 and concluded that a number of needs did not require regional coordination, while others required regional coordination. The need information from the Needs Assessment has been input into the scoping process to determine the nature of the planning process to address the identified needs.</p> <p>During the scoping assessment, participants reviewed the nature and timing of all known needs in the region to determine both the most appropriate planning approach and the best geographic grouping of needs to facilitate an efficient study. Planning approaches discussed include an Integrated Regional Resource Plan (IRRP), where non-wires options have potential to address needs; a Regional Infrastructure Plan (“RIP”), which considers wires-only options; or a local plan undertaken by the transmitter and affected Local distribution company (LDC) where no further regional coordination is needed.</p> <p>Additional information on selecting a planning approach can be found in Appendix B.</p> <p>This Scoping Assessment Report:</p> <ul style="list-style-type: none"> • Lists the needs requiring more comprehensive planning, as identified in the Needs Assessment Report; • Reassesses the areas that need to be studied and the geographic grouping of the needs; 			

- Determines the appropriate regional planning approach and scope for each sub-region where a need for regional coordination or more comprehensive planning is identified;
- Establishes terms of reference for an IRRP if one is required;
- Establishes the composition of the Working Group for the IRRP.

2. Team

The scoping assessment was carried out with members of the study team:

- Independent Electricity System Operator (IESO)
- Hydro One Networks Inc. (“Hydro One Transmission”)
- Hydro One Networks Inc. (“Hydro One Distribution”)
- Guelph Hydro Electric Systems Inc. (Alectra)
- Centre Wellington Hydro
- Waterloo North Hydro Inc.
- Energy + Inc.
- Kitchener- Wilmot Hydro Inc.
- Wellington North Power
- Halton Hills Hydro
- Milton Hydro

3. Categories of Needs, Analysis and Results

I. Overview of the region

The Kitchener-Waterloo-Cambridge-Guelph (KWCG) region in southwestern Ontario includes the Region of Waterloo,¹ the City of Guelph, Wellington County and the Township of Blandford-Blenheim (Oxford County).

Located in this region are the Grand River Métis Council, and two First Nation communities: Six Nations of the Grand River and Mississaugas of the New Credit.

A summer-peaking region, KWCG is supplied by a network of 230 kV and 115 kV regional transmission and distribution infrastructure. Electricity to the region is primarily supplied by five major bulk transmission stations: Middleport TS, Buchanan TS, Detweiler TS, Orangeville TS and Burlington TS. Customers in the area are supplied via a number of LDCs: Guelph Hydro Electric Systems Inc., Hydro One Distribution, Centre Wellington Hydro, Waterloo North Hydro Inc., Energy + Inc., Kitchener Wilmot Hydro Inc., Halton Hills Hydro and Milton


¹ The Region of Waterloo includes the cities of Kitchener, Cambridge, Waterloo and the townships of North Dumfries, Wellesley, Wilmot and Woolwich.

Hydro.

The summer 2018 non-coincident regional demand was approximately 1390 MW. Economic activities contributing to electrical demand in the Region of Waterloo and the City of Guelph include a mix of educational institutions, manufacturing, and high-tech industries. For Wellington County and the Township of Blandford-Blenheim, the agriculture and manufacturing sectors play a key role in economic development.

The electricity infrastructure supplying the KWCG Region is shown in Figure 1.

Figure 0 Electricity Infrastructure in the KWCG Region



II. Background: previous planning process

In 2013, to prioritize and manage the regional planning process, Ontario was organized into 21 regions, each of which was assigned to one of three groups. KWCG became one of the Group 1 planning regions; however, at that time regional planning activities in this region led by the former Ontario Power Authority (now the IESO) were already underway, involving Hydro One, the IESO and LDCs.

In October 2013, the KWCG planning electricity supply study was transitioned to align with the OEB's new regional planning process. The Working Group revised the terms of reference to reflect the new process, and updated the study information, including demand forecasts and conservation and distributed generation (DG) data, to confirm the region's reliability and supply needs.

To meet these needs, the Working Group recommended implementation of:

- The Guelph Area Transmission Reinforcement (GATR) project
 - Installation of two new 230/115kV autotransformers at Cedar TS to reinforce supply to the 115 kV sub-systems in the region; and upgrading of the 5km idle 115 kV line B5G/B6G between Campbell TS and Cedar TS to 230 kV
 - Installation of two new 230 kV in-line switches on D6V/D7V circuits to improve restoration capability of the Waterloo-Guelph 230 kV sub-system
- In-line switches at Galt Junction
 - Installation of two new 230kV in-line switches on M20D/M21D circuits to improve restoration capability of the Cambridge-Kitchener 230 kV sub-system

These projects are complete and in service.

Following the IRRP, a regional infrastructure plan (RIP) was published in December 2015 to address transmission needs identified in the needs assessment and the IRRP. Plans to address some of these needs were further developed in the RIP, with some in the medium- to longer-term timeframe to be confirmed in the next regional planning cycle.

This second regional planning cycle started with the Needs Assessment Report published by Hydro One in December 2018. The needs identified in this report form the basis of the analysis for this scoping assessment and are discussed in further detail in section III.

III. Identified needs

Hydro One's NA identified a number of needs in the KWCG region based on the most up-to-date sustainment plans and a 10-year demand forecast. These needs are outlined in Table 1-1, which summarizes both the projects underway to address near-term needs, and the needs to be addressed in this regional planning cycle.

Projects and Plans Underway

The NA completed recently by Hydro One listed projects currently underway to meet near-term needs. Table 1-1 below lists these needs and the plans to address them.

Table 1-1 Projects Underway

Need	Facilities	Status	In-service date
End of Life	Campbell TS (T1/T2 DESN): T1 supply transformer 230/13.8 kV	T1 is being replaced with a 100 MVA unit similar to T2 replacement in 2017. There are plans to replace secondary equipment limiting station LTR to achieve LTR of 130 MVA at the DESN.	I/S 2021-2022
	Detweiler TS: 230/115 kV T2/T4 auto-transformers	Autotransformers T2 and T4, built in 1959 and 1963 respectively, were declared at end of life and are being replaced with similar units.	I/S 2021-2022
	115 kV circuits B5/6C: Burlington TS to Westover CTS (27 km)	Line section of B5/6C from Burlington TS to CTS is currently under refurbishment.	I/S 2019-2020

Needs to be Addressed in the new Planning Cycle

Table 1-2 below includes needs that must be met in the next five years and are designated as near term and those in the five-to-10-year timeframe, which are classified as medium term.

Table 1-2 Projects Underway

Need	Facilities	Need Date
Near-term needs identified through needs assessment		
Equipment end of life	230 kV circuits D6V/D7V: Guelph North Jct. to Fergus Jct. (9.5 km)	2019-2020
	115 kV circuits D7F/D9F: Tower # 157 to Freeport SS (0.5 km)	2019-2020
	Kitchener MTS #5: T9/T10 supply transformers	2023-2024
	Hanlon TS: T1/T2 supply transformers	2023-2024
	Cedar TS: T7/T8 supply transformers	2024-2025
	Scheifele MTS:T1/T2 supply transformers	2024-2026

Capacity	Campbell TS (T3/T4) DESN overloading	2021-2022
Supply performance	Elmira TS and 115 kV circuit D10H	Existing
Need	Facilities	Need Date
Medium-term needs identified through the needs assessment		
Equipment end of life	Preston TS: T3/T4 supply transformers	2025-2026
Capacity	Waterloo North Hydro MTS #4	2026
	Energy + MTS #2	2026

IV. Analysis of needs and identification of sub-regions

A number of factors were considered in recommending a planning approach for the needs identified in the needs assessment, and the overall approach for further study in this area. Broadly speaking, where there is the potential for a wide range of solutions to meet the needs of an area, including conservation, generation, new technologies, and wires infrastructure, an integrated planning approach is optimal.

In the case of the KWCG region, the Working Group recommended an integrated approach to address the medium-term capacity needs of Waterloo North Hydro and Energy+, and to complete a comprehensive load restoration review of the region in the context of recent infrastructure investments and a new 20-year demand forecast. Additionally, planning for replacement of end-of-life facilities and documentation of rationale will also benefit from the integrated view afforded by an IRRP.

The section below provides additional details on needs recommended to move to the IRRP process.

Integrated capacity planning for medium-term need for capacity for Energy + and Waterloo North Hydro

Both Waterloo North Hydro (WNH) and Energy + have identified the need for new capacity in the next five to 10 years, tied, in part, to demand from development of the “East Side Development Lands.” The two new potential stations for each LDC, as well as Preston TS (if

expansion is possible) are all theoretically positioned to service future load growth. New capacity in the area could be optimized to address the growth needs of both LDCs. The integration exercise will also consider Preston TS end-of-life replacement plans and potential optimization with incremental capacity needs. This capacity study will consider whether the Preston TS can be expanded to supply future load growth rather than deferring the end-of-life transformer replacement plans slated to be in service for 2025-2026. The study group recommends that need for new capacity for WNH and Energy + be addressed in the IRRP in consideration of capacity at Preston TS.

Opportunities to optimize end-of-life investments

Re-examining the current use and configuration of facilities reaching end of life in the context of the latest load forecast and generation data can help ensure that any new assets installed in their place will continue to appropriately service both the impacted LDCs and their customers, over the new assets' lifetime. In this instance, there are three stations in series on circuits B5C/B6C, two of which have supply transformers identified at end of life over the next five years. Cedar TS is connected to the region's 230 kV system via 230 kV/ 115 kV auto-transformers, and also supplies load via the 115 kV supply transformers. Just downstream of Cedar TS is Hanlon TS, followed by Arlen MTS. Supply transformers at both Cedar and Hanlon have been identified for end-of-life replacement in the next five years. End-of-life investments regarding these three stations could be optimized via consolidation of load to be supplied by two stations of a larger size. The Needs Assessment Report identified, at a high level, why further optimization of load between Hanlon and Arlen stations was not feasible. The study team recommends documenting in the IRRP why no further optimization is feasible at this point for these stations.

Load restoration review

Broadly speaking, a load restoration review studies the ability of the electricity system in the area to minimize the impacts of potential supply interruptions to customers in the event of major transmission outages within specific timeframes and defined magnitude of load lost. In the past planning cycle, a partial solution was developed to improve the restoration ability for load supplied off the Preston tap and M20/21D supply. The study group recommends that a load restoration review be completed for the entire region as part of an IRRP. This review will also recommend the responsible parties to undertake application to the IESO for ORTAC restoration criteria exemptions as necessary.

Two other issues raised during the needs assessment and scoping assessment meetings are also recommended for study in the IRRP.

Area short circuit levels forecast

A study team member expressed concern regarding rising short circuit levels on circuits D6V/D7V and D10H/D8S and existing short circuit levels approaching maximum capacity of LDC-owned equipment at a number of stations in Waterloo North Hydro territory. Waterloo North Hydro has requested that the scope of this study be expanded to include analysis of cost-effective ways of managing the rise in short circuit levels on this line to avoid replacement of

equipment that is in good condition and only approximately halfway through its expected service life. This is also an optimal time for a short circuit study as equipment replacement is underway for the D6V/D7V conductors and T2/T4 autotransformers at Detweiler TS.

Connection challenges for behind-the-meter projects

Wellington North Power raised concerns with challenges in connecting behind-the-meter (BTM) projects in its service territory. These projects are treated as any front of the meter resources and subject to the same connection criteria. The ability to connect these (BTM) projects is limited in areas with existing generation that is connected to the system that reduces the capacity to connect additional generation.

The study team recommends that these issues be studied further through an integrated process. This is due to the fact that s both issues concern short circuit levels due to resources in the broader area, and associated limitations of electrical equipment in the area.

The study team recommends that the assessment of needs outlined above will benefit from an integrated view. There are potential opportunities to assess wires and non-wires solutions and to address multiple needs in an optimal manner. Some interactions with bulk system planning of the Middleport system in this area are also expected and will be captured in an IRRP. The study team recommends that these needs be grouped and studied together as one IRRP for the KWCG region.

As described in Table 1-3 below, remaining needs are singular in nature and local planning is recommended to address them, as there is limited opportunity to reconfigure and resize the facilities to align with other regional needs. The team recommends that these needs be studied and addressed as part of local planning between the transmitter and impacted LDCs.

Table 1-3 Needs to be Addressed by Local Planning

Need	Facilities	Need Date	Status
Equipment End of Life	230 kV circuits D6V/D7V: Guelph North Jct. to Fergus Jct. (9.5 km)	2019-2020	Hydro One to undertake replacement
	115 kV circuits D7F/D9F: Tower # 157 to Freeport SS (0.5 km)	2019-2020	Hydro One to undertake replacement
	Preston TS: T3/T4 supply transformers	2025-2026	Hydro One to undertake replacement
	Kitchener MTS #5: T9/T10 supply transformers	2023-2024	Kitchener -Wilmot Hydro and Hydro One to coordinate replacement of transformers with standard units of similar size

	Hanlon TS: T1/T2 supply transformers	2023-2024	Hydro One to undertake replacement of the transformers with standard 42 MVA units*
	Cedar TS: T7/T8 supply transformers	2024-2025	Hydro One to undertake replacement of transformers with standard 42 MVA units*
	Scheifele MTS:T1/T2 supply transformers	2024-2026	Waterloo North Hydro to continue to monitor the condition of these transformers (to be addressed in the next regional planning cycle if necessary)
Capacity	Campbell TS (T3/T4) DESN overloading	2021-2022	Hydro One and Guelph Hydro to monitor the loads and I balance them between the two DESNs when required
Supply performance	Elmira TS and 115 kV circuit D10H	Existing	Hydro One to continue to work with Waterloo North Hydro to address the supply performance issue

*End-of-life replacement plans to continue as planned; IESO to document rationale for not further optimizing these stations in the IRRP.

Additional considerations for further studies in the KWCG region

Changes to provincial energy-efficiency programs may impact the demand forecast. An integrated planning exercise will capture the impact of these changes on the timing and magnitude of needs, and on the consideration of non-wires solutions.

4. Conclusion

The Scoping Assessment concludes that:

- An IRRP be undertaken for the KWCG region to address the following needs:
 - Document optimization of end-of-life replacement plans for transformers at Hanlon TS and Cedar TS
 - Plan for the medium-term capacity needs of Waterloo North Hydro and Energy +
 - Conduct a load restoration review of the area and document exemptions
 - Assess impacts of area short circuit levels and resource connection challenges

- Additional needs identified in the needs assessment (outlined below) will be addressed through local planning between the transmitter and relevant LDC:
 - End-of-life replacements
 - Section of 230 kV circuits D6V/D7V
 - Section of 115 kV circuits D7F/D9F
 - T9/T10 transformers at Kitchener MTS #9
 - T1/T2 transformers at Scheifele MTS
 - T3/T4 transformers at Preston TS
 - T7/T8 transformers at Cedar TS
 - T1/T2 transformers at Hanlon TS
 - Supply performance issue at Elmira TS and supply from D10H
 - Campbell TS DESN overloading

The draft terms of reference for the KWCG IRRP is attached in Appendix A.

List of Acronyms

CDM	Conservation and Demand Management
DG	Distributed Generation
IESO	Independent Electricity System Operator
IRRP	Integrated Regional Resource Plan
kV	Kilovolt
LDC	Local Distribution Company
MW	Megawatt
NA	Needs Assessment
OEB	Ontario Energy Board
ORTAC	Ontario Resource and Transmission Assessment Criteria
RIP	Regional Infrastructure Plan
TS	Transformer Station

Appendix A: The Kitchener-Waterloo-Cambridge-Guelph IRRP Terms of Reference

1. Introduction and Background

These Terms of Reference establish the objectives, scope, key assumptions, roles and responsibilities, activities, deliverables and timelines for an Integrated Regional Resource Plan (IRRP) for the Kitchener-Waterloo-Cambridge-Guelph (KWCG) region.

Based on the needs identified within the region, including opportunities for coordinating demand and supply options with capacity needs in the Waterloo North Hydro and Energy + territories, load restoration capability review, short circuit capability needs, and challenges in connecting behind-the-meter energy storage, an integrated regional resource planning approach for the KWCG region is recommended.


The KWCG Region

The KWCG region in southwestern Ontario includes the Region of Waterloo,² the City of Guelph, Wellington County and the Township of Blandford-Blenheim (Oxford County). Under the "Places to Grow" policy, the KWCG area is expected to meet the mandated population growth target set by the province in the coming decades.

The approximate geographical boundaries of the region are shown in Figure A-1.

² The Region of Waterloo includes the cities of Kitchener, Cambridge, Waterloo and the townships of North Dumfries, Wellesley, Wilmot and Woolwich.

Figure A-1: Electricity Infrastructure in the KWCG Region³



KWCG Region Electricity System

The KWCG region's electricity demand is a mix of residential, commercial and industrial loads, and includes diverse economic activities, such as post-secondary education and automobile manufacturing. It is a summer-peaking region supplied by the bulk system from the 230 kV Orangeville TS, Detweiler TS, Burlington TS, Middleport TS, and Buchanan TS, through local 115 kV and 230 kV step-down transformer stations. The electricity system supplying the KWCG region is shown in Figure A-2.

³ The region is defined by electricity infrastructure; geographical boundaries are approximate.




Figure A-1: Single-Line diagram of electricity system supplying the KWCG region⁴

Background

In May 2013, the OEB endorsed the Planning Process Working Group's report, formalizing the regional planning process. As regional planning in KWCG was already underway at that time, the KWCG region became one of the first to undergo the new regional planning process. As planning for the region had progressed significantly before the OEB process was implemented, no formal needs assessment or scoping assessment was published in the region's first planning cycle. The Working Group revised the terms of reference to reflect the new process, updated the study information, and re-confirmed reliability and supply needs in the KWCG region.

⁴ Burlington TS is not included in the KWCG study area.

In April 2015, the IESO published an IRRP for the KWCG region recommending conservation and distributed generation to help meet peak demand growth. The plan also recommended the implementation of Guelph Area Transmission Refurbishment (GATR) that focused on addressing supply needs in the south-central Guelph and Kitchener area, and minimizing the impact of potential supply interruptions to customers in Waterloo, Guelph and surrounding areas. The plan also called for the installation of two circuit switches at Galt Junction to further improve restoration capability in the Cambridge and Kitchener area. Both the GATR project and Galt Junction in-line switches have been completed and are in service.

Subsequently, and in accordance with the OEB's process, in December 2015 Hydro One Transmission published a regional infrastructure plan (RIP) to address transmission needs identified in the IRRP.

The second cycle of KWCG regional planning launched in late 2018, and Hydro One published the Needs Assessment Report in December of the same year. Because a number of needs identified in the report require integrated regional consideration, the scoping assessment led by the IESO with Hydro One and LDCs recommended an integrated regional resource plan (IRRP) be undertaken to address these needs.

2. Objectives

The KWCG IRRP will assess the adequacy of electricity supply to customers in the region and will develop a set of recommended actions to maintain reliability of supply to the region over the next 20 years.

- Assess the adequacy of electricity supply to customers in the KWCG area over the next 20 years
- Determine whether there is a need to initiate development work or to fully commit infrastructure investments in this planning cycle
- Identify and coordinate major asset renewal needs with customer needs, and develop a flexible, comprehensive, integrated electricity plan for KWCG
- Develop an implementation plan, while maintaining the flexibility to accommodate changes in key assumptions over time

3. Scope

This IRRP will develop and recommend an integrated plan to meet the needs of the KWCG region. The plan was developed by members of the KWCG IRRP Working Group comprising Centre Wellington Hydro, Energy + Inc., Guelph Hydro Electric Systems Inc. (Alectra), Hydro

One Distribution, Kitchener-Wilmot Hydro, Waterloo North Hydro Inc., Wellington North Power Inc., Hydro One Transmission, and the IESO.

The plan will focus on these items in order of priority:

- Documentation of end-of-life needs optimization at Hanlon/Cedar/Campbell stations
- Medium-term integrated planning for capacity needs of Waterloo North Hydro and Energy+
- Review of restoration capability in the area, including undertaking restoration criteria exemptions as necessary
- Long-term planning for the 115 kV system in this region
- Review of short circuit capability needs associated with rising short circuit levels, including recommendation of integrated solutions
- Review of connection challenges of behind-the-meter energy storage projects, including recommendation of solutions as relevant or recommendation to address in other forums

In its identification or confirmation of any capacity or restoration needs, and analysis of options for addressing end-of-life needs, this plan – like all IRRPs – will integrate forecast electricity demand growth, conservation and demand management (CDM) with transmission and distribution system capability, relevant community plans, other bulk system developments, and the uptake of distributed energy resources (DER).

The IESO will assess the adequacy of the bulk system supplying the area in the Middleport bulk system planning study through a separate process. Results of that study will be shared with the Working Group and incorporated into applicable regional studies as they become available.

Based on the identified needs, the KWCG IRRP process will involve the:

- 1) Development of an updated 20-year demand forecast for the region.
- 2) Confirmation of the adequacy of transformer station ratings and the area's load-meeting capability and reliability.
 - a. Identify or confirm the transformer station capacity needs and sufficiency of the area's load-meeting capability for the study period using the updated load forecast.
 - b. Confirm identified restoration needs using the updated load forecast.
 - c. Collect information on known reliability issues and load transfer capabilities from the LDCs.
- 3) Assessment of options for confirmed needs, using decision-making criteria that includes, but is not limited to, technical feasibility, economics, reliability performance, and environmental and social factors.

The options analysis has been divided into groupings based on the priority/timing of the needs, known lead time information, and the depth of analysis required.

- a. Phase 1:
 - i. Confirm and document the reasons and conclusion(s) of the optimization of end-of-life Hanlon/Cedar/Campbell stations.
 - ii. Identify options for meeting medium-term capacity needs in Waterloo North Hydro and Energy+ territories, with consideration of supply from Preston TS per recommendations from the Working Group.
 - b. Phase 2:
 - i. Review restoration capabilities in the area, and recommend responsible parties to undertake restoration criteria exemption application as necessary.
 - ii. Long-term planning for the 115 kV system between Detweiler TS and Cedar TS.
 - iii. Review options for managing rising short circuit capability need.
 - iv. Review options to address challenges of connecting behind-the-meter energy storage projects, and recommend solutions.
 - v. Engage with representatives from the Region of Waterloo, municipalities and Indigenous communities, to review and consider municipal energy plans.
- 4) Development of the long-term recommendations and the implementation plan.
 - 5) Completion of the IRRP report documenting near-, mid-, and long-term needs and recommendations.

In order to carry out this scope of work, the Working Group will consider the data and assumptions outlined in section 4 below.

4. Data and Assumptions

The plan will consider the following data and assumptions:

- Demand data
 - Historical coincident and non-coincident peak demand information Historical weather correction, for median and extreme conditions
 - Gross peak demand forecast scenarios by region, TS
 - Coincident peak demand data, including transmission-connected customers
 - Identified potential future load customers
- Conservation and demand management (CDM)

- LDC CDM plans
- Verified results and CDM programs/opportunities in the area
- Long-term conservation forecast for LDC customers based on planned provincial CDM activities
- Conservation potential studies, if available
- Potential for CDM at transmission-connected customer facilities
- Load segmentation data for each TS based on customer type (e.g., residential, commercial, industrial, agricultural) and proportion of LDC service territory within the study area
- Local resources
 - Existing local generation, including distributed generation (DG), district energy, customer-based generation, non-utility generators and hydroelectric facilities as applicable
 - Existing or committed renewable generation from feed-in-tariff (FIT) and non-FIT procurements
 - Future resource proposals as relevant
- Relevant local plans, as applicable
 - LDC distribution system plans
 - Community energy plans and municipal energy plans (e.g., Community Energy Investment Strategy for Waterloo Region)
 - Municipal growth plans
 - Any transit plans impacting electricity use or tied to community developments
- Criteria, codes and other requirements
 - Ontario Resource and Transmission Assessment Criteria (ORTAC)
 - Supply capability
 - Load security
 - Load restoration requirements
 - NERC and NPCC reliability criteria, as applicable
 - OEB Transmission System Code
 - OEB Distribution System Code
 - Reliability considerations, e.g., frequency and duration of interruptions to customers
 - Other applicable requirements
- Existing system capability
 - Transmission line ratings as per transmitter records
 - System capability as per current IESO PSS/E base cases
 - Transformer station ratings (10-day LTR) as per asset owner
 - Load transfer capability
 - Technical and operating characteristics of local generation

- End-of-life asset considerations and sustainment plans
 - Transmission assets
 - Distribution assets
 - Impact of ongoing plans and projects on applicable facility ratings
- Other considerations, as applicable

5. Working Group

The core Working Group will consist of planning representatives from the following organizations, including embedded LDCs that have identified needs in this region:

- Independent Electricity System Operator (*Team Lead for IRRP*)
- Hydro One Transmission
- Guelph Hydro Electric Systems Inc. (Alectra)
- Centre Wellington Hydro
- Waterloo North Hydro Inc.
- Energy + Inc.
- Kitchener-Wilmot Hydro
- Wellington North Power Inc.
- Hydro One Distribution

Other LDCs in the region are welcome to participate as observers and the study outcome will be shared with all participants.

Authority and Funding

Each entity involved in the study will be responsible for complying with regulatory requirements as applicable to the actions/tasks assigned under the implementation plan resulting from this IRRP. For the duration of the study process, each participant is responsible for their own funding.

5. Engagement

Integrating early and sustained engagement with communities and stakeholders was recommended by the IESO, and adopted by the provincial government to enhance the regional planning and siting processes in 2013. The Working Group is committed to conducting plan-level engagement throughout the development of the KWCG IRRP.

The first step in engagement will consist of meetings with representatives from the region, including municipalities and Indigenous communities within the planning area, Indigenous

communities that may have an interest in the planning area, and the Métis Nation of Ontario to discuss regional planning, the development of the KWCG plan, and integrated solutions.

Municipal and regional level engagement will continue throughout the development and completion of the plan. The Working Group will develop a comprehensive stakeholder engagement plan, in accordance with the Activities Timeline shown in Table A-1.

6. Activities, Timeline and Primary Accountability

Table A-1 Summary of IRRP Timelines and Activities

Activity		Lead Responsibility	Deliverable(s)	Timeframe
1	Prepare terms of reference considering stakeholder input	<i>IESO</i>	- Finalized Terms of Reference	Feb - Apr 2019
2	Develop planning forecast for the sub-region			
	Establish historical coincident and non-coincident peak demand information	<i>IESO</i>	- Long-term planning forecast scenarios	Apr - Jul 2019
	Establish historical weather correction, median and extreme conditions	<i>IESO</i>		
	Establish gross peak demand forecast and high-/low-growth scenarios	<i>LDCs</i>		
	Establish existing, committed and potential distributed generation (DG)	<i>LDCs</i>		
	Establish near- and long-term conservation forecasts based on planned CDM activities	<i>IESO</i>		
	Develop planning forecast scenarios, including the impacts of CDM, DG and extreme weather conditions	<i>IESO</i>		
3	Provide information on load transfer capabilities under normal and emergency conditions	<i>LDCs</i>	- Load transfer capabilities under normal and emergency conditions	Apr - Jul 2019
4	Provide and review relevant community plans, if applicable	<i>LDCs and IESO</i>	- Relevant community plans	Apr - Jul 2019

Activity		Lead Responsibility	Deliverable(s)	Timeframe
5	Prioritize planning considering timing of need and coordination with end-of-life replacement plans (will proceed in parallel with information-gathering phase)			
	Confirm and document the recommended option regarding end-of-life optimization of Hanlon /Cedar/Campbell stations	All	- Documentation of optimization rationale of end-of-life facilities at the Hanlon/Cedar/Campbell stations	Q2 - Q3 2019
	Identify potential options to meet the integrated capacity needs in the Waterloo North Hydro and Energy+ territories, with consideration of capacity at Preston TS		- Documentation of cost, feasibility, and reliability performance of potential wires options - Detailed option development	Q3 2019 – Q1 2020
6	Complete system studies to identify needs over a 20-year period <ul style="list-style-type: none"> - Obtain PSS/E base case, and include bulk system assumptions as identified in the key assumptions - Apply reliability criteria as defined in ORTAC to demand forecast scenarios - Confirm and refine the need(s) and timing/load levels 	<i>IESO, Hydro One Transmission</i>	- Summary of needs based on demand forecast scenarios for the 20-year planning horizon	Q3 2019 – Q1 2020
7	Develop options and alternatives			
	Develop conservation options	<i>IESO and LDCs</i>	- Flexible planning options for forecast scenarios	Q4 2019 - Q1 2020
	Develop local generation options	<i>IESO and LDCs</i>		
	Develop transmission (see Action 7 below) and distribution options	<i>Hydro One, and LDCs</i>		
	Develop options involving other electricity initiatives (e.g., smart grid, storage)	<i>IESO/ LDCs with support as needed</i>		
	Integrate with bulk needs	<i>IESO</i>		
	Develop portfolios of integrated alternatives	<i>All</i>		
	Complete technical comparison and evaluation	<i>All</i>		

Activity		Lead Responsibility	Deliverable(s)	Timeframe
8	Plan and undertake community & stakeholder engagement			
	Engage with local municipalities and Indigenous communities within study area, First Nation communities who may have an interest in the study area, and the Métis Nation of Ontario	<i>All</i>	<ul style="list-style-type: none"> - Community and stakeholder engagement plan - Input from local communities 	Q3 2019
	Develop communication materials	<i>All</i>		Q4 2019 - Q1 2020
	Undertake community and stakeholder engagement	<i>All</i>		
	Summarize input and incorporate feedback	<i>All</i>		
9	Develop long-term recommendations and implementation plan based on community and stakeholder input	<i>IESO</i>	<ul style="list-style-type: none"> - Implementation plan - Monitoring activities and identification of decision triggers - Hand-off letters - Procedures for annual review 	Q1-Q2 2020
10	Prepare the IRRP report detailing the recommended near-, medium- and long-term plan for approval by all parties	<i>IESO</i>	<ul style="list-style-type: none"> - IRRP report 	Q2 2020

Appendix G:

KWCG Regional Planning Status Letter

Hydro One Networks Inc.

483 Bay Street
13th Floor, North Tower
Toronto, ON M5G 2P5
www.HydroOne.com

Tel: (416) 345-5420
Fax: (416) 345-4141
Ajay.Garg@HydroOne.com



March 2, 2020

Ms. Dorothy Moryc
Waterloo North Hydro Inc.
526 Country Squire Road
Waterloo, ON N2J 4G8
Dear Ms. Moryc,

Subject: Regional Planning Status

As per your request, this Planning Status letter is provided to meet one of the requirements of your upcoming Rate Application to the Ontario Energy Board (OEB).

As you are aware, the province of Ontario is divided into 21 Regions for the purpose of Regional Planning (RP), a map of Ontario showing the 21 Regions and the list of Local Distribution Companies (LDCs) in each of the Region are attached as Appendix A and B respectively.

Waterloo North Hydro Inc. is an LDC within the Kitchener-Waterloo-Cambridge-Guelph (KWCG) region and Hydro One Networks Inc. (Hydro One) is the lead transmitter.

This letter confirms that the first cycle of RP for KWCG region was completed in 2015. Since then, the second cycle for the region is in progress and Needs Assessment report was completed and published in December 2018. The findings and the recommendations stemming out of the 2nd cycle Needs Assessment are provided in details in the KWCG Needs Assessment report (attached as Appendix C). The report can be accessed from Hydro One's Regional Planning website for the KWCG region.

Kitchener-Waterloo-Cambridge-Guelph Region

The KWCG region includes the municipalities of Kitchener, Waterloo, Cambridge and Guelph, as well as portions of Perth and Wellington Counties and the Townships of Wellesley, Woolwich, Wilmot and North Dumfries.

The following transmission projects were completed by Hydro One to address near-term supply needs that were recommended in the first cycle RIP:

- The Guelph Area Transmission Refurbishment Project (GATR), placed into service since Q4 2016.
- The switching facilities work at Galt Junction to improve supply reliability for the Cambridge-Kitchener 230 kV Sub-system, placed into service in Oct 2017.

As mentioned above, the second cycle is in progress and the Needs Assessment (Appendix D) report was completed and published in December 2018. The Needs Assessment has identified new needs in the region. It is

expected that there will be little or no cost implications for Waterloo North Hydro Inc. from the following transmission projects being undertaken by Hydro One:

- Project addressing the near term aging Infrastructure needs
 - Campbell TS – T1 (2018)
 - 115 kV B5C/ B6C Circuits (2019)
 - 115 kV D7F/ D9F Circuits (2019)
 - 230 kV D6V/ D7V Circuits (2020- 2021)
 - Detweiler TS -Auto T2 &T4 (2021-2022)
- Project to address the mid-term aging Infrastructure needs
 - Hanlon TS - T1 & T2 (2022-2023)
 - Cedar TS - T7 & T8 (2024-2025)
 - Preston TS - T3 & T4 (2025-2026)

Two LDC projects addressing mid-term aging infrastructure needs, as outlined in the 2nd cycle Needs Assessment Report, are being planned and managed by the LDCs:

- Project to address the mid-term aging Infrastructure needs by LDCs
 - Scheifele MTS - T1 & T2 (2024-2026) for Waterloo North Hydro
 - Kitchener MTS #5 - T9 & T10 (2023-2024) for Kitchener Wilmot Hydro Inc.

Based on their age, Waterloo North Hydro has identified Scheifele T1 & T2 transformers as approaching end-of-life. Based on their current condition, replacement is not expected before 2025. Waterloo North Hydro is closely monitoring the condition of these transformers and will reassess their need for replacement on an annual basis.

The above projects are expected to improve the overall reliability performance in the region. The future system capacity need for Waterloo North Hydro MTS #4 and the new future system capacity need for Energy+ MTS #2 will be studied during the next phases of second cycle regional planning.

In summary, little or no capital contribution is expected from Waterloo North Hydro Inc. for the projects developed by Hydro One in the KWCG Region.

Waterloo North Hydro Inc. is an active participating member on the regional Study Teams and Hydro One is looking forward to continue working with Waterloo North Hydro Inc. in executing the regional planning process. Please feel free to contact me if you have any questions.

Sincerely,



Ajay Garg, Manager – Regional Planning Coordination
Hydro One Networks Inc.

Appendix A. Map of Ontario's Planning Regions

Northern Ontario



Southern Ontario



Greater Toronto Area (GTA)



Burlington to Nanticoke	East Lake Superior	Chatham/Lambton/Sarnia
Greater Ottawa	London area	Greater Bruce/Huron
GTA East	Peterborough to Kingston	Niagara
GTA North	South Georgian Bay/Muskoka	North of Moosonee*
GTA West	Sudbury/Algoma	North/East of Sudbury
Kitchener- Waterloo- Cambridge- Guelph ("KWCG")	Northwest Ontario	Renfrew
Toronto	Windsor-Essex	St. Lawrence

*This region is not within Hydro One's territory.

Appendix B. List of LDCs for Each Region

(Hydro One as Upstream Transmitter)

Region	LDCs
1. Burlington to Nanticoke	<ul style="list-style-type: none"> • Energy+ Inc. • Brantford Power Inc. • Burlington Hydro Inc. • Haldimand County Hydro Inc.** • Alectra Utilities Corporation • Hydro One Networks Inc. • Norfolk Power Distribution Inc.** • Oakville Hydro Electricity Distribution Inc.
2. Greater Ottawa	<ul style="list-style-type: none"> • Hydro 2000 Inc. • Hydro Hawkesbury Inc. • Hydro One Networks Inc. • Hydro Ottawa Limited • Ottawa River Power Corporation • Renfrew Hydro Inc.
3. GTA North	<ul style="list-style-type: none"> • Alectra Utilities Corporation • Hydro One Networks Inc. • Newmarket-Tay Power Distribution Ltd. • Toronto Hydro Electric System Limited • Elexicon Energy Inc.
4. GTA West	<ul style="list-style-type: none"> • Burlington Hydro Inc. • Alectra Utilities Corporation • Halton Hills Hydro Inc. • Hydro One Networks Inc. • Milton Hydro Distribution Inc. • Oakville Hydro Electricity Distribution Inc.
5. Kitchener- Waterloo-Cambridge-Guelph (“KWCG”)	<ul style="list-style-type: none"> • Energy+ Inc. • Centre Wellington Hydro Ltd. • Alectra Utilities Corporation • Halton Hills Hydro Inc. • Hydro One Networks Inc. • Kitchener-Wilmot Hydro Inc. • Milton Hydro Distribution Inc. • Waterloo North Hydro Inc. • Wellington North Power Inc.

6. Toronto	<ul style="list-style-type: none"> • Alectra Utilities Corporation • Hydro One Networks Inc. • Toronto Hydro Electric System Limited • Elexicon Energy Inc.
7. Northwest Ontario	<ul style="list-style-type: none"> • Atikokan Hydro Inc. • Chapleau Public Utilities Corporation • Fort Frances Power Corporation • Hydro One Networks Inc. • Kenora Hydro Electric Corporation Ltd. • Sioux Lookout Hydro Inc. • Thunder Bay Hydro Electricity • Distribution Inc.
8. Windsor-Essex	<ul style="list-style-type: none"> • E.L.K. Energy Inc. • Entegrus Power Lines Inc. [Chatham- Kent] • EnWin Utilities Ltd. • Essex Powerlines Corporation • Hydro One Networks Inc.
9. East Lake Superior* *Hydro One Sault Ste. Marie L.P. is the Lead Transmitter for the region.	<ul style="list-style-type: none"> • Algoma Power Inc. • Chapleau PUC • Sault Ste. Marie PUC • Hydro One Networks Inc.
10. GTA East	<ul style="list-style-type: none"> • Hydro One Networks Inc. • Oshawa PUC Networks Inc. • Elexicon Energy Inc.
11. London Area	<ul style="list-style-type: none"> • Entegrus Power Lines Inc. [Middlesex] • Erie Thames Power Lines Corporation • Hydro One Networks Inc. • London Hydro Inc. • Norfolk Power Distribution Inc.** • St. Thomas Energy Inc. • Tillsonburg Hydro Inc. • Woodstock Hydro Services Inc.**
12. Peterborough to Kingston	<ul style="list-style-type: none"> • Eastern Ontario Power Inc. • Hydro One Networks Inc. • Kingston Hydro Corporation • Lakefront Utilities Inc. • Peterborough Distribution Inc. • Elexicon Energy Inc.

13. South Georgian Bay/Muskoka	<ul style="list-style-type: none"> • EPCOR • Hydro One Networks Inc. • InnPower Corporation • Lakeland Power Distribution Ltd. • Midland Power Utility Corporation • Orangeville Hydro Limited • Orillia Power Distribution Corporation • Alectra Utilities Corporation • Elexicon Energy Inc. • Elexicon Energy Inc. • Wasaga Distribution Inc.
14. Sudbury/Algoma	<ul style="list-style-type: none"> • Espanola Regional Hydro Distribution Corp. • Greater Sudbury Hydro Inc. • Hydro One Networks Inc.
15. Chatham/Lambton/Sarnia	<ul style="list-style-type: none"> • Bluewater Power Distribution Corporation • Entegrus Power Lines Inc. [Chatham- Kent] • Hydro One Networks Inc.
16. Greater Bruce/Huron	<ul style="list-style-type: none"> • Entegrus Power Lines Inc. [Middlesex] • Erie Thames Power Lines Corporation • Festival Hydro Inc. • Hydro One Networks Inc. • Wellington North Power Inc. • West Coast Huron Energy Inc. • Westario Power Inc.
17. Niagara	<ul style="list-style-type: none"> • Canadian Niagara Power Inc. [Port Colborne] • Grimsby Power Inc. • Haldimand County Hydro Inc.** • Alectra Utilities Corporation • Hydro One Networks Inc. • Niagara Peninsula Energy Inc. • Niagara-On-The-Lake Hydro Inc. • Welland Hydro-Electric System Corp. • Niagara West Transformation Corporation* <p>* Changes to the May 17, 2013 OEB Planning Process Working Group Report</p>

19. North/East of Sudbury	<ul style="list-style-type: none"> • Greater Sudbury Hydro Inc. • Hearst Power Distribution Company Limited • Hydro One Networks Inc. • North Bay Hydro Distribution Ltd. • Northern Ontario Wires Inc.
20. Renfrew	<ul style="list-style-type: none"> • Hydro One Networks Inc. • Ottawa River Power Corporation • Renfrew Hydro Inc.
21. St. Lawrence	<ul style="list-style-type: none"> • Cooperative Hydro Embrun Inc. • Hydro One Networks Inc. • Rideau St. Lawrence Distribution Inc.

****This Local Distribution Company (LDC) has been acquired by Hydro One Networks Inc.**

Appendix C

2nd cycle Needs Assessment (NA) Report – December 2018



Hydro One Networks Inc.
483 Bay Street
Toronto, Ontario
M5G 2P5

NEEDS ASSESSMENT REPORT

Kitchener - Waterloo - Cambridge - Guelph (KWCG) Region

Date: December 19, 2018

Prepared by: KWCG Region Study Team



Disclaimer

This Needs Assessment Report was prepared for the purpose of identifying potential needs in the KWCG Region and to recommend which need may require further assessment and/or regional coordination to develop a preferred plan. The results reported in this Needs Assessment are based on the input and information provided by the Study Team.

The Study Team participants, their respective affiliated organizations, and Hydro One Networks Inc. (collectively, “the Authors”) shall not, under any circumstances whatsoever, be liable to each other, to any third party for whom the Needs Assessment Report was prepared (“the Intended Third Parties”) or to any other third party reading or receiving the Needs Assessment Report (“the Other Third Parties”). The Authors, Intended Third Parties and Other Third Parties acknowledge and agree that: (a) the Authors make no representations or warranties (express, implied, statutory or otherwise) as to this document or its contents, including, without limitation, the accuracy or completeness of the information therein; (b) the Authors, Intended Third Parties and Other Third Parties and their respective employees, directors and agents (the “Representatives”) shall be responsible for their respective use of the document and any conclusions derived from its contents; (c) and the Authors will not be liable for any damages resulting from or in any way related to the reliance on, acceptance or use of the document or its contents by the Authors, Intended Third Parties or Other Third Parties or their respective Representatives.

Executive Summary

REGION	Kitchener - Waterloo - Cambridge - Guelph (KWCG) Region		
LEAD	Hydro One Networks Inc. (“HONI”)		
START DATE	September 17, 2018	END DATE	December 19, 2018

1. INTRODUCTION

The first cycle of the Regional Planning process for the KWCG Region an Integrated Regional Resource Plan (“IRRP”) was published in April 2015 which identified a number of near- and mid-term needs in the KWCG region. The planning process was completed in December 2015 with the publication of the Regional Infrastructure Plan (“RIP”) which provided a description of needs and recommendations of preferred wires plans to address near-term needs. The RIP also identified some near- and mid-term needs that will be reviewed during this Regional Planning cycle.

The purpose of this Needs Assessment (“NA”) is to identify any new needs and to reaffirm needs identified in the previous KWCG Regional Planning cycle.

2. REGIONAL ISSUE/TRIGGER

In accordance with the Regional Planning process, the regional planning cycle should be triggered at least every five years. In light of the timing of the needs identified in the previous Integrated Regional Resource Plan (“IRRP”) and RIP reports as well as new replacement/ refurbishment needs in the KWCG Region, the 2nd Regional Planning cycle was triggered for this Region.

3. SCOPE OF NEEDS ASSESSMENT

The scope of this NA includes:

- Review and reaffirm needs/plans identified in the previous RIP; and
- Identification and assessment of system capacity, reliability, operation, and aging infrastructure needs.

The Study Team may also identify additional needs during the next phases of the planning process, namely Scoping Assessment (“SA”), IRRP and RIP, based on updated information available at that time.

4. INPUTS/DATA

The Study Team representatives from Local Distribution Companies (“LDC”), the Independent Electricity System Operator (“IESO”), and Hydro One provided input and relevant information for the KWCG Region regarding capacity needs, reliability needs, operational issues, and major assets/facilities approaching end-of-life (“EOL”). In addition, community energy plans in the region have also been scanned and reviewed.

5. ASSESSMENT METHODOLOGY

The assessment’s primary objective is to identify the electrical infrastructure needs, recommend further mitigation or action plan(s) to address these needs, and determine whether further regional coordination or broader study would be beneficial.

The assessment reviewed available information including load forecasts, conservation and demand management (“CDM”) and distributed generation (“DG”) forecasts, reliability needs, operational issues, and major high

voltage equipment identified to be at or near the end of their useful life and requiring replacement/refurbishment.

A technical assessment of needs was undertaken based on:

- Current and future station capacity and transmission adequacy;
- Reliability needs and operational concerns; and
- Any major high voltage equipment reaching the end of its useful life.

6. NEEDS

I. Station & Transmission Supply Capacity

- Campbell TS (T3/T4) DESN Overloading is forecasted in the 2021-2022.
- Future need for Waterloo North Hydro MTS #4
- Future need for Energy+ MTS #2

A contingency analysis was performed and due to reduced forecasts no issues were found.

II. System Reliability & Operation

- D10H 115 kV line reliability and restoration of Elmira TS loads.

III. Aging Infrastructure – Transformer Replacements and line Section Refurbishment

- Projects in execution:
 - i. Campbell TS – T1 (2018)
 - ii. Detweiler TS -Auto T2 & T4 (2021-2022)
 - iii. 115 kV B5C/ B6C Circuits (2019-2020)¹
- New projects:
 - i. 115 kV D7F/ D9F Circuits (2019-2020)²
 - ii. 230 kV D6V/ D7V Circuits (2019- 2020)³
 - iii. Hanlon TS - T1 & T2 (2023-2024)
 - iv. Kitchener MTS #5 - T9 & T10 (2023-2024)
 - v. Cedar TS - T7 & T8 (2024-2025)
 - vi. Scheifele MTS - T1 & T2 (2024-2026)
 - vii. Preston TS - T3 & T4 (2025-2026)

IV. Other Planning Considerations

The local municipalities in the region are extremely engaged and actively pursuing innovative ways to manage and/or reduce their energy needs over the next 10-20 Years. For example, several community energy plans have been developed in the region.

¹ Burlington TS to a CTS Line Section

² Tower 157 to Freeport Switching Station Line Section

³ Guelph North Junction to Fergus TS Line Section

7. RECOMMENDATIONS

The Study Team's recommendations for the above identified needs are as follows:

- a) The replacement of EOL station supply transformers at Campbell TS, Hanlon TS, Cedar TS, Kitchener MTS #5 and Preston TS along with the EOL auto transformers at Detweiler to proceed. Hydro One and the concerned LDCs will coordinate replacement of above equipment and develop replacement plans.
- b) The refurbishment of EOL line sections 115 kV B5C/ B6C, D7F/ D9F and 230 kV D6V/ D7V to proceed. Hydro One will coordinate refurbishment of these line sections with affected LDCs/ Customer.
- c) Hydro One will continue to work with Waterloo North Hydro Inc. to address the supply reliability issue at Elmira TS.
- d) The Study Team has recommended that Hydro One Transmission and the Guelph Hydro Electric System Inc. to closely monitor the loading at the T3/T4 Campbell TS DESN and to balance the loads between these DESNs when required.
- e) The Study Team recommends that the supply capacity needs with regards to Energy + MTS #2 and WNH MTS #4 be further assessed for optimization in the SA phase of regional planning. Once the optimization options are complete, Waterloo North Hydro and Energy+ shall conduct a technical and economic assessment in consultation with Hydro One.
- f) The Study Team has recommended that community energy plans will be further considered in the SA phase of the regional planning process.

TABLE OF CONTENTS

1	Introduction	7
2	Regional Issue/Trigger	8
3	Scope of Needs Assessment	8
4	Regional Description and Connection Configuration	8
5	Inputs and Data	11
6	Assessment Methodology	11
7	Needs.....	12
8	Conclusion and Recommendations	24
9	References	25
	Appendix A: KWCG Region Non-Coincident Summer Load Forecast	26
	Appendix B: Lists of Step-Down Transformer Stations	28
	Appendix C: Lists of Transmission Circuits	29
	Appendix D: Lists of LDCs in the KWCG Region	30
	Appendix E: Acronyms.....	31

List of Tables and Figures

Table 1: KWCG Region Study Team Participants	7
Table 2: Needs Identified in the Previous Regional Planning Cycle	12
Table 3: End-of-Life Equipment – KWCG Region	13
Figure 1: Geographical Area of the KWCG Region with Electrical Layout	9
Figure 2: KWCG Region (Single Line Diagram)	10
Figure 3: Burlington TS to Harper’s Jct. to CTS B5C/ B6C Line Sections.....	16
Figure 5: Tower #157 Jct. to Freeport SS F11C/ F12C Line Section	17
Figure 4: Guelph North Jct. to Fergus TS D6V/ D7V Line Section	18
Figure 6: D10H 115 kV Line (Burlington TS to Elmira TS).....	22

1 INTRODUCTION

The first cycle of the Regional Planning process for the KWCG Region was completed in December 2015 with the publication of the Regional Infrastructure Plan (“RIP”). The RIP provided a description of needs and recommendations of preferred wires plans to address near- and medium-term needs. Waterloo North Hydro MTS #4 was the only need to be reviewed in this planning cycle.

The purpose of this Needs Assessment (“NA”) is to identify new needs and to reconfirm needs identified in the previous KWCG regional planning cycle. Since the previous regional planning cycle, some new needs in the region have been identified.

This report was prepared by the KWCG Region Study Team (“Study Team”), led by Hydro One Networks Inc. Participants of the Study Team are listed below in Table 1. The report presents the results of the assessment based on information provided by the Hydro One, the Local Distribution Companies (“LDC”) and the Independent Electricity System Operator (“IESO”).

Table 1: KWCG Region Study Team Participants

Company
Centre Wellington Hydro
Energy+
Guelph Hydro Electric System Inc.
Halton Hills Hydro
Hydro One Networks Inc. (Lead Transmitter)
Hydro One Networks Inc. (Distribution)
Independent Electricity System Operator (“IESO”)
Kitchener Wilmot Hydro Inc.
Milton Hydro
Waterloo North Hydro Inc.
Wellington North Power Inc.

2 REGIONAL ISSUE/TRIGGER

In accordance with the Regional Planning process, the Regional Planning cycle should be triggered at least every five years. In light of the timing of the needs identified in the previous IRRP and RIP reports as well as new replacement/ refurbishment identified needs in the KWCG Region, the 2nd Regional Planning cycle was triggered for the KWCG region.

3 SCOPE OF NEEDS ASSESSMENT

The scope of this NA covers the KWCG Region and includes:

- Identification of new needs based on latest information provided by the Study Team; and,
- Confirmation/updates of existing needs and/or plans identified in the previous planning cycle.

The Study Team may identify additional needs during the next phases of the regional planning process, namely Scoping Assessment (“SA”), Local Planning (“LP”), IRRP, and/or RIP.

4 REGIONAL DESCRIPTION AND CONNECTION CONFIGURATION

The KWCG Region covers the cities of Kitchener, Waterloo, Cambridge and Guelph, portions of Oxford and Wellington counties and the townships of North Dumfries, Puslinch, Woolwich, Wellesley and Wilmot. Electrical supply to the Region is provided from eleven 230 kV and thirteen 115 kV step-down transformer stations. The summer 2018 non-coincident regional loads were about 1390 MW. The approximate boundaries of the KWCG Region are shown below in Figure 1.

The main sources of electricity into the KWCG Region are from five Hydro One stations: Middleport TS, Buchanan TS, Detweiler TS, Orangeville TS and Burlington TS. At these stations electricity is transformed from 500 kV and 230 kV to 230 kV and 115 kV levels, respectively. Electricity is then delivered to the end users of LDCs and directly-connected industrial customers through 26 (TS/ MTS/ CTS) step-down transformer stations. Figure 2 illustrates these stations as well as the four major regional sub-systems: Waterloo-Guelph 230 kV sub-system, Cambridge-Kitchener 230 kV sub-system, Kitchener-Guelph 115 kV sub-system and South-Central Guelph 115 kV sub-system.

The summer non-coincident regional load forecast is provided as Appendix A. Appendix B lists all step-down transformer stations, Appendix C transmission circuits and Appendix D LDCs in the KWCG Region.




Figure 1: Geographical Area of the KWCG Region with Electrical Layout

An electrical single line diagram for the KWCG Region facilities is shown below in Figure 2.




Figure 2: KWCG Region (Single Line Diagram)

5 INPUTS AND DATA

Study Team participants, including representatives from LDCs, IESO, and Hydro One provided information and input for the KWCG Region NA. The information provided includes the following:

- KWCG Load Forecast for all supply stations;
- Known capacity and reliability needs, operating issues, and/or major assets approaching the end of their useful life (“EOL”); and
- Planned/foreseen transmission and distribution investments that are relevant to regional planning for the KWCG Region.

6 ASSESSMENT METHODOLOGY

The following methodology and assumptions are made in this Needs Assessment:

Information gathering included:

- i. Load forecast: The relevant LDCs provided load forecasts for all the stations supplying their loads in the KWCG region for the 10 year study period. The IESO provided a Conservation and Demand Management (“CDM”) and Distributed Generation (“DG”) forecast for the KWCG region. The region’s extreme summer non-coincident peak gross load forecast for each station were prepared by applying the LDC load forecast load growth rates to the actual 2018 summer peak extreme weather corrected loads. The extreme summer weather correction factors were provided by Hydro One. The net extreme weather summer load forecasts were produced by reducing the gross load forecasts for each station by the % age CDM and then by the amount of effective DG capacity provided by the IESO for that station. These extreme weather summer load forecast for the individual stations in the KWCG region is given in Appendix A;
- ii. Relevant information regarding system reliability and operational issues in the region; and
- iii. List of major HV transmission equipment planned and/or identified to be refurbished and/or replaced due to the end of their useful life which is relevant for regional planning purposes. This includes HV transformers, autotransformers, HV Breakers, HV underground cables and overhead lines.

A technical assessment of needs was undertaken based on:

- Current and future station capacity and transmission adequacy;
- System reliability and operational concerns; and
- Any major high voltage equipment reaching the end of its useful life.

In addition, Hydro One has reviewed the Community Energy Plans in the region. It is worth noting that there are several community energy plans in the region and some of them are meant to sustain at the

current level or reduce the community's reliance on the provincial electric system by meeting future electricity needs with local, distributed resources and/or community-based solutions. These plans may have potential to supplement and/or defer future transmission infrastructure development needs.

7 NEEDS

This section describes emerging needs identified in the KWCG Region, and also reaffirms the near, mid, and long-term needs already identified in the previous regional planning cycle.

The recent load forecast prepared for this report is lower than that of the previous cycle of regional planning. A contingency analysis was performed for the region and due to reduced load forecasts, as expected; no new system needs were identified.

The newly identified/emerging needs pertaining to this NA will be discussed further in the following sub-sections, while the status of the previously identified needs is summarized in Table 2 below.

Table 2: Needs Identified in the Previous Regional Planning Cycle

Type of Needs identified in the previous RP cycle	Needs Details	Current Status
115kV System Supply Capacity	GATR Project Two new additional 230/115kV autotransformers at Cedar TS to reinforce supply to both 115kV sub-systems in the region.	Completed
230kV Load Restoration Needs	GATR Project Two new additional 230 kV in-line switches on D6V/D7V circuits to improve restoration capability of Waterloo-Guelph 230 kV sub-system.	Completed
	Galt Junction Two new additional 230kV in-line switches on M20D/M21D circuits to improve restoration capability of the Cambridge-Kitchener 230 kV sub-system.	Completed
Station Short Circuit Capacity	Arlen MTS Install 13.8 kV series reactors to mitigate LV bus short circuit levels.	Completed
Station Transformation Capacity	New Waterloo North Hydro: MTS #4 (2024).	Need is now expected beyond 2029.

7.1 End-Of-Life (EOL) Equipment Needs

Hydro One and LDCs have provided high voltage asset information under the following categories that have been identified at this time and are likely to be replaced over the next 10 years:

- Autotransformers
- Power transformers
- HV breakers
- Transmission line requiring refurbishment where an uprating is being considered for planning needs and require Leave to Construct (i.e., Section 92) application and approval
- HV underground cables where an uprating is being considered for planning needs and require EA and Leave to Construct (i.e., Section 92) application and approval

Accordingly, following major high voltage equipment has been identified as approaching its end of useful life over the next 10 years.

Table 3: End-of-Life Equipment – KWCG Region

EOL Asset Replacement/ Refurbishment	Replacement/ Refurbishment Timing	Details
Projects in Execution		
Campbell TS (T1/T2 DESN): T1 Supply Transformer	2018	These Project are discussed further in Section 7.1.1
Detweiler TS: 230/ 115 kV T2/ T4 Auto-transformers	2021-2022	
115 kV B5C/ B6C: Burlington TS to Westover CTS Line Sections	2019-2020	
New Identified Projects		
115 kV D7F/ D9F : Tower #157 to Freeport SS Line Section	2019-2020	These Project are discussed further in Section 7.1.2
230 kV D6V/ D7V: Guelph North Jct. to Fergus Jct. Line Section	2019-2020	
Kitchener MTS #5 ^[1] : T9/T10 Supply Transformers	2023-2024	
Hanlon TS: T1/T2 Supply Transformers	2023-2024	
Cedar TS: T7/T8 Supply Transformers	2024-2025	
Scheifele MTS ^[1] - T1/T2 Supply Transformers	2024-2026	
Preston TS: T3/T4 Supply Transformers	2025-2026	

^[1] LDC owned assets

The end-of-life assessment for the above high voltage equipment typically included consideration of the following options:

1. Maintaining the status quo;
2. Replacing equipment with similar equipment of lower ratings and built to current standards;
3. Replacing equipment with lower ratings and built to current standards by transferring some load to other existing facilities;
4. Eliminating equipment by transferring all of the load to other existing facilities;
5. Replacing equipment with similar equipment and built to current standards (i.e., “like-for-like” replacement);
6. Replacing equipment with higher ratings and built to current standards; and
7. Station reconfiguration

Maintaining status quo is not an option for any of the above EOL autotransformer, station transformer or line sections due to risk of equipment failure, would result in increased maintenance cost and customer outages. Replacing “Like-for-Like” with nonstandard transformers would result in complexity with failures and difficulty in getting similar spare equipment along with their installation. Nonstandard equipment also poses serious safety risk for employees under normal and emergency situations.

No other lines or HV station equipment in the KWCG region have been identified for major replacement/refurbishment at this time. If and when new and/or additional information is available, it will be provided during the next planning phase underway at the time.

7.1.1 Projects in Execution

The following end-of-life refurbishment needs are under execution. This region was deemed to be in transition and NA for this region was deemed complete. Hence, following projects were not listed or discussed in the first cycle of regional planning and are currently in execution:

Campbell TS – T1 Transformer

Campbell TS is located in the city of Guelph supplying Guelph Hydro Electric System Inc. loads. Campbell TS has two 230/ 13.8 kV DESNs T1/T2 and T3/T4 of 75 MVA transformers with an LTR of 105 MVA (94 MW @ 0.9 PF) and 63 MVA (56 MW @ 0.9 PF) respectively. The loads on these two DESNs are currently forecasted to be about 87 MW and 66 MW respectively by the end of study period.

The 75 MVA T1/T2 DESN transformer T2 failed in 2017 and was replaced with a new standard 100 MVA unit and transformer T1 is also being replaced with a similar unit. In 2021-2022, Hydro One in addition plans to replace the secondary equipment limiting the station LTR. This will result in sufficient LTR of about 130 MVA for T1/T2 DESN, over the study period.

The replacement of T1 transformer is currently in execution and expected to be completed by the end of year 2018.

Detweiler TS - T2 & T4 Autotransformers

Detweiler TS is a Bulk System, major switching and autotransformer station located in the city of Kitchener. Detweiler TS facilities include a 230 kV switchyard, three 230/115 kV autotransformers (T2/T3/T4) and a 115 kV switchyard.

The Detweiler TS autotransformers T2/T3/ T4 were built in 1959, 2004 and 1963 respectively. The condition assessment has identified T2 and T4 autotransformers as EOL requiring replacement. At this time none of other HV equipment at this station has been identified as approaching EOL over the next 5-10 years.

Not replacing these auto transformers would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers. The replacement of both the EOL Detweiler TS T2 and T4 autotransformers with similar units is in execution expected to be completed in 2021-22. This will address the 230/ 115 kV transformation needs at Detweiler TS and maintain station's operability and reliability of supply.

Any Detweiler TS 230 kV system reconfiguration needs will be studied under bulk system planning expected to commence in early 2019.

115 kV B5C/ B6C Line Sections

The 115 kV B5C/B6C circuits consist of about 45 km of double circuit line and 15 km of single circuit line supplying South-Central Guelph 115 kV loads. About 12 km of double circuit line section from Burlington TS to Harper's Jct. and about 15 km B5C 115 kV line tap from Harper's Jct. to a Westover Jct. requires refurbishment.

Not refurbishing these line sections would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers.

The refurbishment of this 27 km long 115 kV B5C/B6C line sections from Burlington TS to a CTS is currently under execution and the work is planned to be completed by the end of year 2019.



Figure 3: Burlington TS to Harper's Jct. to CTS B5C/ B6C Line Sections

7.1.2 New Needs

The following end-of-life refurbishment needs have been identified in this regional planning cycle:

115 kV D7F/D9F Line Section

The 115 kV D7F/ D9F double circuit line is about 12 km long supplying Kitchener- Guelph 115 kV loads. The 115 kV D7F/ D9F double circuit 450 meter line section from Tower 157 to Freeport Switching Station was built in 1951. It is approaching end of life and requires refurbishment.

Not refurbishing this line section would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers.

Therefore the Study Team recommends Hydro One to continue with refurbishment of the 450 meter long 115 kV D7F/ D9F end of life line section from Tower 157 to Freeport Switching Station. This project is currently under estimating and is planned to be completed by the end of year 2019.




Figure 4: Tower #157 Jct. to Freeport SS F11C/ F12C Line Section

230 kV D6V/D7V Line Section

The 230 kV D6V/D7V double circuit line is about 84 km long and is part of bulk power system supplying loads in the Waterloo Guelph 230kV and South Central Guelph 115 kV loads. A 230 kV D6V/ D7V 9.5 km double circuit line section from Guelph North junction to Fergus TS was built in 1950's and its conductor is approaching end of life. It requires refurbishment.

Not refurbishing this line section would increase risk of failure due to asset condition, maintenance expenses and reduce supply reliability to the customers.

Therefore the Study Team recommends to refurbish this the 9.5 km long 230 kV D6V/D7V end of life line section from Guelph North Junction to Fergus TS. This project is currently under estimating and is planned to be completed by the end of year 2019.




Figure 5: Guelph North Jct. to Fergus TS D6V/ D7V Line Section

Kitchener MTS #5 T9/T10 Transformers

Kitchener MTS #5 is located in the city of Kitchener supplying Kitchener-Wilmot Hydro Inc. loads. Kitchener MTS #5 is a 115/ 13.8 kV single T9/T10 DESN station of 83 MVA nonstandard transformers having a LTR of 89 MVA (80 MW @ 0.9 PF), currently supplying 67 MW of peak load. The loads at Kitchener MTS #5 are currently forecasted to remain flat over the entire study period. The supply capacity of this station is therefore expected to be sufficient over and beyond the study period.

Both the T9/T10 transformers at this station have been identified as approaching end of life requiring replacement. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Kitchener MTS #5 having surplus capacity where this station's loads can be transferred. The Study Team recommends replacing the T9/T10 nonstandard transformers with standard units of similar size is the preferred option. Kitchener-Wilmot Hydro Inc. and Hydro One will coordinate the replacement plan of these transformers. The replacement of the EOL equipment is expected to be completed by 2023-2024.

Hanlon TS T1/T2 Transformer

Hanlon TS is located south of the city of Guelph supplying Guelph Hydro Electric System Inc. loads. Hanlon TS is a single T1/T2 DESN station of 33 MVA nonstandard transformers having a LTR of 48

MVA (43 MW @ 0.9 PF). This station is currently supplying about 27 MW of peak load. The loads at Hanlon TS are currently forecasted to remain flat over the entire study period. The supply capacity of this station is therefore expected to be sufficient over and beyond the study period.

The T1/T2 transformers are of 1955/ 56 built and have been identified as EOL requiring replacement. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

There is no nearby supply station/s to Hanlon TS having surplus capacity where this station's loads can be transferred therefore Hydro One plans to replace these EOL transformers with standard size units of 42 MVA in 2023-2024.

Cedar TS – T7/ T8 Transformers

Cedar TS is located in the city of Guelph supplying Guelph Hydro Electric System Inc. loads. Cedar TS has two 115/ 13.8 kV DESN units T1/T2 and T7/T8 of 75 MVA with a LTR of 115 MVA (103 MW @ 0.9 PF) and 37 MVA with a LTR of 44 MVA (40 MW @ 0.9 PF), currently supplying 67 MW and 36 MW of peak loads respectively. The loads at both Cedar TS DESNs are currently forecasted to remain almost flat over the entire study period. The supply capacity of this station is therefore expected to be sufficient over and beyond the study period.

The T7/T8 DESN 38 MVA nonstandard transformers are of 1958 built have been identified for replacement. The T1/T2 transformers are relatively newer and were built in early 1990s. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Cedar TS having surplus capacity where this station's loads can be transferred therefore Hydro One plans to replace these EOL transformers with standard size units of 42 MVA in 2024-2025 timeframe.

Cedar TS and Hanlon TS Optimization with Neighbouring Stations

After performing an analysis of the current distribution situation, it was determined that there are not enough spare feeder positions at HONI and GHESI stations to reallocate DESN loads in the sub-system without significant distribution system and neighboring station upgrades.

Over loading of Campbell DESN T3/T4 will be effectively managed by load transfer to DESN T1/T2 after 2021/22. Following that there will be no additional capacity at these two DESNs.

Secondly, Hanlon TS DESN has eight (8) feeders with three (3) being dedicated underground infrastructure to existing customers, two (2) feeders supplying the industrial load in the Hanlon Industrial Park, two (2) feeder circuits supplying residential load north of Hanlon TS and one (1) feeder to be utilized for planned future load growth at Gordon/ Clair. In addition, due to technical limitations at 13.8 kV distribution voltage and density of load on certain feeders sections, it is not possible to supply existing

loads from any other station without significant transmission and distribution investments. Therefore there are little or no significant optimization opportunity is present at this point in time. Option considered for load transfer will require significant new investment; for example:

- The two residential distribution feeders supplying loads north of Hanlon TS could be transferred to existing feeders out of Cedar TS. These load transfers will result in increased line losses and reduced capacity (due to voltage drop)
- Another option could be transferring remaining Hanlon TS load to Arlen MTS. This load transfer will require an additional DESN and underground infrastructure at Arlen MTS.

Hence, the Study Team recommends that Hydro One undertakes replacement of Cedar TS T7/T8 and Hanlon TS T1/T2 transformers with 42 MVA standard size units, being technically and economical most suitable solution. The replacement of EOL equipment is expected to be completed by 2023-2025 timeframe for both stations.

Scheifele MTS – T1/ T2 Transformers

Scheifele MTS is located in the city of Waterloo supplying Waterloo North Hydro Inc. loads. Scheifele MTS has four 230/ 13.8 kV transformers T1 and T2 of 67 MVA, and T3 and T4 of 83 MVA currently supplying 145 MW of peak loads. The load at this station is forecasted to remain almost flat over the entire study period. The total supply capacity of Scheifele MTS is 161 MW expected to be sufficient over the study period.

The T1/T2 transformers based on their age have been identified by Waterloo North Hydro Inc. as approaching end of life potentially requiring replacement in the 2024- 2026 timeframe. Waterloo North Hydro will be monitoring the condition of these transformers to assess their replacement need. At this time none of other HV/LV equipment at this station has been identified as approaching EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Scheifele MTS having surplus capacity where this station's loads can be transferred. The Study Team recommends that Waterloo North Hydro continue monitoring the condition of these T1/T2 transformers at Scheifele MTS and this need to be reassessed in the next regional planning cycle.

Preston TS T3/T4 Transformers

Preston TS (DESN) is located in the city of Cambridge supplying Energy+ loads. Preston TS is a single T3/T4 DESN station of 125 MVA transformers with no additional LTR capability available i.e. 125 MVA (113 MW @ 0.9 PF). This station is currently supplying about 92 MW of peak load. The loads at Preston TS are currently forecasted to peak at about 102 MW during the study period.

The T3/T4 transformers are almost 50 years old, having been built in 1968. Condition assessment has identified that both T3/T4 transformers are at their EOL requiring replacement. At this time none of other HV/LV equipment at this station has been identified as EOL over the next 5-10 years.

The station cannot be downsized or eliminated because there is no nearby supply station/s to Preston TS having spare supply capacity where this station's loads can be transferred. The Study Team recommends replacing the existing 125 MVA 230/ 27.6 kV T3/T4 transformers at Preston TS with 125 MVA standard units. This will also result in an increased supplying capacity at Preston TS required to meet the future Energy+ needs in the Cambridge distribution area. The replacement plan for the equipment will be developed by Hydro One and coordinated with the affected LDC and/or customers and it is expected to be completed by 2025-2026.

7.2 Supply Reliability Needs

Supply reliability of Elmira TS –D10H 115 kV Line

The 115 kV D10H circuit between Detweiler TS and Hanover TS supplies loads at Rush MTS, Elmira TS and Palmerston TS. The D10H circuit has a normally open point just south of Palmerston TS through a motorized disconnect switch. The northern section of D10H is supplied from Hanover TS radially supplying Palmerston TS loads. The southern section of D10H supplied from Detweiler TS radially supplies Waterloo North Hydro's 34 MW Elmira TS peak loads. D10H also supplies Rush MTS which is also supplied by 115 kV D8S circuit from Detweiler TS.

The normally open motorized switch near Palmerston TS helps restore the loads at Elmira TS from Hanover TS in-case supply from Detweiler TS is interrupted and similarly helps restoring Palmerston TS loads from Detweiler if supply from Hanover is interrupted.

In last three years, supply to Elmira TS from Detweiler TS resulted in 3 outages due to faults on the D10H line section between Elmira TS tap and Detweiler TS. The Elmira TS load restoration from Hanover TS is slower due to manually operated disconnect switches at Elmira TS tap location.

Hydro One is currently assessing the condition of line and will continue to work with Waterloo North Hydro to address the supply reliability at Elmira TS. The developed mitigation plan to improve supply reliability of Elmira TS loads will be included in the final RIP report.




Figure 6: D10H 115 kV Line (Burlington TS to Elmira TS)

7.3 Station and Transmission Capacity Needs in the KWCG Region

The following Station and Transmission supply capacities needs have been identified in the KWCG region during the study period of 2019 to 2028.

7.3.1 Campbell TS (T3/T4) DESN Overloading

There are two DESN stations inside Campbell TS boundary. Both the T1/T2 and T3/T4 DESNs are 230 kV/ 13.8 kV having supply capacities of 94 MW and 56 MW, currently supplying 84 MW and 52 MW of loads respectively. The 75 MVA transformer T2 recently failed and was replaced with a Hydro One standard 100 MVA unit. The transformer T1 is also being replaced with a similar 100 MVA unit by the end of 2018. The load at T3/T4 DESN is forecasted to exceed its supply capacity of 56 MW in the 2021-2022 timeframe.

At Campbell TS, after replacement of T1 transformer and secondary equipment there will be sufficient spare supply capacity on T1/T2 DESN where excess T3/T4 DESN loads can be transferred. Hydro One Transmission and the Guelph Hydro Electric System Inc. will monitor the loading at the T3/T4 Campbell TS DESN and will balance the loads between the two DESNs, when required. The Study Team therefore recommends that no further action is required at this time.

7.3.2 Waterloo North Hydro MTS #4

During the last regional planning cycle a need for a new MTS #4 DESN was identified in the 2024 timeframe. The current load forecast defers this need beyond the needs assessment study period.

7.3.3 Energy+ MTS #2

Energy+ has initially identified a future need for a new DESN station (MTS #2) in the city of Cambridge near Preston TS. This station need is due to a potential new load center growth in their service territory. The additional supply capacity due to EOL transformer replacement and available new feeder positions at Preston TS, will defer this new MTS need beyond the study period of current regional planning cycle.

WNH MTS #4 and Energy+ MTS #2 Optimization

The Preston TS like-for-like transformer replacement is critical for local supply needs and will proceed according to the current plan. However, study team recommends that the supply capacity needs with regards to Energy + MTS #2 and WNH MTS #4 be further assessed for optimization in the next phases of regional planning. Once the optimization options are complete, Waterloo North Hydro and Energy+ shall conduct a technical and economic assessment in consultation with Hydro One.

7.4 Other Planning Considerations in the KWCG Region

Municipalities in KWCG region have developed their community energy plans with a primary focus to reduce their energy consumption by local initiatives over next 25 to 30 years. With respect to electricity, these communities are planning for an increased reliance on community energy sources such as distributed generation, generation behind the meters like rooftop solar systems and local battery storage systems to reduce cost and for improved reliability of electricity supply.

There are situations where behind the meter battery storage cannot be connected due to technical constraints. The LDCs in this region and Hydro One, outside the regional planning forum, can undertake the task of exploring the issue to assess technical constraints and /or other solutions that can facilitate connection of additional battery storage.

Communities are also working towards self-sufficiency by improving efficiencies of existing local energy systems i.e. reducing energy consumption and losses by means of utilizing smarter buildings, houses, efficient heating, cooling, appliances, equipment, and processes for all community needs. Ultimately, the objective of these energy plans in the region is to be a net zero carbon community.

Community energy plans may have potential to supplement and/or defer future transmission infrastructure development needs. The Study Team therefore recommends reviewing the community energy plans in the SA phase.

8 CONCLUSION AND RECOMMENDATIONS

Hydro One and Waterloo North Hydro Inc. will develop a supply reliability improvement plan for Elmira TS loads. The developed local plan to improve supply reliability of Elmira TS loads will be included in the final RIP report.

At Campbell TS, after replacement of T1 transformer and addressing the secondary equipment limitations there will be sufficient spare supply capacity on T1/T2 DESN to accommodate T3/T4 DESN overloading. Hydro One and the LDC will work together to balance loads between the two Campbell TS DESNs, when required.

The distribution system in the Cedar TS, Hanlon TS and Arlen MTS supply area is already optimized and there are not enough spare feeder positions at any of the stations to reallocate DESN loads without significant distribution system investments and upgrades at neighboring stations.

The Study Team's recommendations for the above identified needs are as follows:

- a) The replacement of EOL station supply transformers at Campbell TS, Hanlon TS, Cedar TS, Kitchener MTS #5 and Preston TS along with the EOL auto transformers at Detweiler to proceed. Hydro One and the concerned LDCs will coordinate replacement of above equipment and develop replacement plans.
- b) The refurbishment of EOL line sections 115 kV B5C/ B6C, D7F/ D9F and 230 kV D6V/ D7V to proceed. Hydro One will coordinate refurbishment of these line sections with affected LDCs/ Customer.
- c) Hydro One will continue to work with Waterloo North Hydro Inc. to address the supply reliability issue at Elmira TS.
- d) The Study Team has recommended that Hydro One Transmission and the Guelph Hydro Electric System Inc. to closely monitor the loading at the T3/T4 Campbell TS DESN and to balance the loads between these DESNs when required.
- e) The Study Team recommends that the supply capacity needs with regards to Energy + MTS #2 and WNH MTS #4 be further assessed for optimization in the SA phase of regional planning. Once the optimization options are complete, Waterloo North Hydro and Energy+ shall conduct a technical and economic assessment in consultation with Hydro One.
- f) The Study Team has recommended that community energy plans will be further considered in the SA phase of the regional planning process.

9 REFERENCES

- [1] [KWCG Regional Infrastructure Plan - December 2015](#)
- [2] [Planning Process Working Group Report to the Ontario Energy Board - May 2013](#)
- [3] [Ontario Resource and Transmission Assessment Criteria \(ORTAC\) – Issue 5.0 -August 2007](#)

Appendix A: KWCG Region Non-Coincident Summer Load Forecast

* LTR based on 0.9 power factor

Transformer Station		Summer 10 Day LTR*	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
Arlen MTS	Gross	45	24.44	25.17	25.92	26.70	27.50	28.33	29.18	30.05	30.95	31.88	32.84	33.82
	CDM		0.00	0.22	0.28	0.44	0.57	0.79	1.12	1.50	2.05	2.71	3.40	3.99
	DG		0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
	Net		24.42	24.94	25.64	26.25	26.92	27.53	28.04	28.54	28.89	29.16	29.43	29.83
Campbell TS (T1/T2)	Gross	94	83.46	84.71	85.98	87.27	88.58	89.91	91.26	92.63	94.02	95.43	96.86	98.31
	CDM		0.00	0.72	0.91	1.44	1.83	2.50	3.51	4.63	6.22	8.11	10.03	11.59
	DG		0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01
	Net		83.45	83.98	85.06	85.82	86.75	87.40	87.74	87.99	87.78	87.30	86.82	86.72
Campbell TS (T3/T4)	Gross	56	51.62	53.42	55.29	57.23	59.23	61.30	63.45	65.67	67.97	70.35	72.81	75.36
	CDM		0.00	0.46	0.59	0.94	1.22	1.70	2.44	3.28	4.50	5.98	7.54	8.88
	DG		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Net		51.62	52.97	54.71	56.28	58.01	59.60	61.01	62.39	63.47	64.37	65.27	66.48
Cedar TS (T1/T2)	Gross	103	67.35	67.69	68.03	68.37	68.71	69.05	69.40	69.75	70.09	70.44	70.80	71.15
	CDM		0.00	0.58	0.72	1.13	1.42	1.92	2.67	3.49	4.64	5.99	7.33	8.38
	DG		0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
	Net		67.30	67.06	67.26	67.19	67.24	67.09	66.68	66.21	65.40	64.41	63.42	62.72
Cedar TS (T7/T8)	Gross	40	35.63	35.80	35.98	36.16	36.34	36.53	36.71	36.89	37.08	37.26	37.45	37.63
	CDM		0.00	0.31	0.38	0.60	0.75	1.01	1.41	1.85	2.45	3.17	3.88	4.44
	DG		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Net		35.63	35.50	35.60	35.57	35.59	35.51	35.29	35.05	34.62	34.09	33.57	33.20
Elmira TS	Gross	55	34.19	34.62	35.04	35.38	35.73	36.06	36.39	36.71	37.05	37.40	37.75	38.10
	CDM		0.00	0.30	0.37	0.58	0.74	1.00	1.40	1.84	2.45	3.18	3.91	4.49
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		34.17	34.31	34.65	34.78	34.98	35.04	34.97	34.86	34.58	34.20	33.83	33.60
Energy+ MTS #1	Gross	102	84.03	84.87	85.72	86.58	87.44	88.53	89.64	90.76	91.90	93.05	94.21	95.39
	CDM		0.00	0.73	0.91	1.43	1.80	2.46	3.45	4.54	6.08	7.91	9.75	11.24
	DG		0.32	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49	0.49
	Net		83.71	83.65	84.31	84.65	85.15	85.58	85.70	85.73	85.32	84.64	83.96	83.65
Fergus TS	Gross	154	87.52	88.57	89.62	90.27	90.96	91.52	92.07	92.62	93.20	93.83	94.45	95.05
	CDM		0.00	0.76	0.95	1.49	1.87	2.54	3.54	4.63	6.17	7.98	9.78	11.20
	DG		0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
	Net		87.47	87.77	88.62	88.73	89.03	88.92	88.48	87.94	86.98	85.80	84.62	83.80
Galt TS	Gross	169	113.56	114.69	115.84	117.00	118.17	119.64	121.14	122.65	124.19	125.74	127.31	128.90
	CDM		0.00	0.98	1.23	1.93	2.44	3.32	4.66	6.14	8.22	10.69	13.18	15.19
	DG		0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21	0.21
	Net		113.35	113.51	114.40	114.86	115.53	116.11	116.27	116.31	115.76	114.84	113.93	113.51
Hanlon TS	Gross	43	26.85	27.25	27.66	28.08	28.50	28.93	29.36	29.80	30.25	30.70	31.16	31.63
	CDM		0.00	0.23	0.29	0.46	0.59	0.80	1.13	1.49	2.00	2.61	3.23	3.73
	DG		0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	Net		26.85	27.02	27.37	27.62	27.91	28.12	28.23	28.31	28.25	28.09	27.94	27.90
Kitchener MTS # 1	Gross	54	31.31	33.64	34.72	35.81	36.90	37.76	38.60	39.46	40.31	41.16	42.02	42.87
	CDM		0.00	0.29	0.37	0.59	0.76	1.05	1.49	1.97	2.67	3.50	4.35	5.05
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		31.28	33.33	34.33	35.19	36.11	36.68	37.09	37.47	37.62	37.64	37.65	37.79
Kitchener MTS # 3	Gross	108	46.73	45.03	45.34	46.05	46.78	47.49	48.22	48.93	49.64	50.37	51.08	51.81
	CDM		0.00	0.38	0.48	0.76	0.96	1.32	1.86	2.45	3.29	4.28	5.29	6.11
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		46.71	44.63	44.83	45.27	45.79	46.15	46.34	46.46	46.34	46.06	45.77	45.68

Transformer Station		Summer 10 Day LTR*	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
Kitchener MTS # 4	Gross	90	58.39	59.76	60.63	61.49	62.36	63.05	63.73	64.41	65.09	65.77	66.46	67.13
	CDM		0.00	0.51	0.64	1.01	1.29	1.75	2.45	3.22	4.31	5.59	6.88	7.91
	DG		0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
	Net		58.34	59.19	59.93	60.43	61.02	61.24	61.22	61.14	60.73	60.12	59.52	59.17
Kitchener MTS #5	Gross	80	66.56	67.94	68.82	69.70	70.58	71.28	71.96	72.66	73.35	74.03	74.73	75.42
	CDM		0.00	0.58	0.73	1.15	1.45	1.98	2.77	3.63	4.86	6.29	7.74	8.89
	DG		0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
	Net		66.50	67.31	68.03	68.49	69.07	69.24	69.14	68.97	68.43	67.68	66.94	66.47
Kitchener MTS #6	Gross	90	64.17	62.22	62.97	63.71	64.47	65.21	65.96	66.70	67.44	68.19	68.93	69.68
	CDM		0.00	0.53	0.67	1.05	1.33	1.81	2.54	3.34	4.46	5.80	7.14	8.21
	DG		0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09	0.09
	Net		64.08	61.60	62.21	62.57	63.04	63.30	63.33	63.27	62.88	62.30	61.70	61.38
Kitchener MTS #7	Gross	54	42.79	43.98	44.69	45.38	46.08	46.77	47.47	48.16	48.85	49.55	50.24	50.95
	CDM		0.00	0.38	0.48	0.75	0.95	1.30	1.83	2.41	3.23	4.21	5.20	6.00
	DG		0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02
	Net		42.77	43.59	44.19	44.61	45.11	45.45	45.63	45.73	45.60	45.32	45.03	44.92
Kitchener MTS #8	Gross	54	38.68	39.94	41.18	42.44	43.70	45.62	47.53	49.45	51.38	53.30	55.21	57.13
	CDM		0.00	0.34	0.44	0.70	0.90	1.27	1.83	2.47	3.40	4.53	5.71	6.73
	DG		0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
	Net		38.62	39.54	40.69	41.68	42.74	44.30	45.65	46.92	47.92	48.71	49.44	50.34
Kitchener MTS #9	Gross	90	30.16	30.72	31.28	31.83	32.39	32.94	33.50	34.05	34.61	35.17	35.73	36.27
	CDM		0.00	0.26	0.33	0.52	0.67	0.92	1.29	1.70	2.29	2.99	3.70	4.27
	DG		0.23	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
	Net		29.94	29.96	30.45	30.80	31.22	31.53	31.71	31.85	31.82	31.68	31.53	31.50
Preston TS	Gross	113	92.38	95.15	98.00	100.94	103.97	105.27	106.59	107.92	109.27	110.63	112.02	113.42
	CDM		0.00	0.81	1.04	1.67	2.14	2.92	4.10	5.40	7.23	9.41	11.60	13.37
	DG		0.00	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19
	Net		92.38	94.14	96.76	99.08	101.63	102.15	102.29	102.33	101.84	101.03	100.23	99.86
Puslinch DS	Gross	56	28.49	29.24	30.01	30.45	30.92	31.30	31.68	32.05	32.45	32.88	33.31	33.72
	CDM		0.00	0.25	0.32	0.50	0.64	0.87	1.22	1.60	2.15	2.80	3.45	3.97
	DG		0.02	0.02	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
	Net		28.47	28.98	29.54	29.80	30.14	30.29	30.31	30.30	30.16	29.94	29.71	29.60
Rush MTS	Gross	68	45.33	46.24	47.16	48.11	49.07	50.05	51.05	52.07	53.11	54.17	55.26	56.36
	CDM		0.00	0.40	0.50	0.79	1.01	1.39	1.97	2.60	3.52	4.61	5.72	6.64
	DG		0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03	0.03
	Net		45.30	45.81	46.63	47.28	48.03	48.63	49.06	49.44	49.57	49.54	49.51	49.69
Scheifele MTS	Gross	161	144.78	146.96	149.16	151.39	153.67	155.98	158.32	160.69	163.11	165.55	168.04	170.56
	CDM		0.00	1.26	1.59	2.50	3.17	4.33	6.10	8.04	10.80	14.08	17.39	20.10
	DG		0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.08
	Net		144.70	145.62	147.49	148.81	150.42	151.56	152.14	152.57	152.23	151.40	150.56	150.38
WNH MTS #3	Gross	77	56.29	57.42	58.57	59.74	60.93	62.15	63.39	64.66	65.95	67.27	68.62	69.99
	CDM		0.00	0.49	0.62	0.99	1.26	1.73	2.44	3.23	4.37	5.72	7.10	8.25
	DG		0.06	0.06	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
	Net		56.23	56.87	57.80	58.61	59.53	60.28	60.81	61.28	61.44	61.41	61.37	61.60
Wolverton DS	Gross	54	18.42	18.73	19.05	19.19	19.35	19.47	19.59	19.71	19.83	19.98	20.12	20.25
	CDM		0.00	0.16	0.20	0.32	0.40	0.54	0.75	0.99	1.31	1.70	2.08	2.39
	DG		0.00	0.00	0.00	0.00	0.19	0.19	0.19	0.19	0.19	0.19	0.19	0.19
	Net		18.41	18.57	18.84	18.87	18.76	18.74	18.64	18.53	18.33	18.08	17.84	17.67
CTS	Net		9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80	9.80

Appendix B: Lists of Step-Down Transformer Stations

Sr. No.	Transformer Stations
1.	Arlen MTS
2.	Campbell TS (T1/T2)
3.	Campbell TS (T3/T4)
4.	Cedar TS (T1/T2)
5.	Cedar TS (T7/T8)
6.	Elmira TS
7.	Energy+ MTS #1
8.	Fergus TS
9.	Galt TS
10.	Hanlon TS
11.	Kitchener MTS # 1
12.	Kitchener MTS # 3
13.	Kitchener MTS # 4
14.	Kitchener MTS #5
15.	Kitchener MTS #6
16.	Kitchener MTS #7
17.	Kitchener MTS #8
18.	Kitchener MTS #9
19.	Preston TS
20.	Puslinch DS
21.	Rush MTS
22.	Scheifele MTS
23.	Waterloo North MTS 3
24.	Wolverton DS
25.	CTS - 1
26.	CTS - 2

Appendix C: Lists of Transmission Circuits

Sr. No.	Circuit ID	From Station	To Station	Voltage (kV)
1.	D6V/ D7V	Detweiler TS	Orangeville TS	220
2.	M20D/ M21D	Detweiler TS	Middleport TS	220
3.	D4W/ D5W	Detweiler TS	Buchanan TS	220
4.	B22D/ B23D	Detweiler TS	Bruce TS	220
5.	D7F/ D9F	Detweiler TS	Free Port SS	115
6.	F11C/ F12C	Free Port SS	Cedar TS	115
7.	B5C/ B6C	Cedar TS	Burlington TS	115
8.	D11K/ D12K	Detweiler TS	Kitchener MTS #4	115
9.	D8S	Detweiler TS	St. Mary TS	115
10.	D10H	Detweiler TS	Hanover TS	115

Appendix D: Lists of LDCs in the KWCG Region

Sr. No.	Company	Connection Type (TX/DX)
1.	Centre Wellington Hydro	Dx
2.	Energy+	Tx/ Dx
3.	Guelph Hydro Electric System Inc.	Tx/ Dx
4.	Halton Hills Hydro	Dx
5.	Hydro One Networks Inc. (Distribution)	Tx/ Dx
6.	Kitchener Wilmot Hydro Inc.	Tx
7.	Milton Hydro	Dx
8.	Waterloo North Hydro Inc.	Tx/ Dx
9.	Wellington North Power Inc.	Dx

Appendix E: Acronyms

Acronym	Description
A	Ampere
BES	Bulk Electric System
BPS	Bulk Power System
CDM	Conservation and Demand Management
CIA	Customer Impact Assessment
CGS	Customer Generating Station
CSS	Customer Switching Station
CTS	Customer Transformer Station
DESN	Dual Element Spot Network
DG	Distributed Generation
DS	Distribution Station
GS	Generating Station
HV	High Voltage
IESO	Independent Electricity System Operator
IRRP	Integrated Regional Resource Plan
kV	Kilovolt
LDC	Local Distribution Company
LP	Local Plan
LTE	Long Term Emergency
LTR	Limited Time Rating
LV	Low Voltage
MTS	Municipal Transformer Station
MW	Megawatt
MVA	Mega Volt-Ampere
MVAR	Mega Volt-Ampere Reactive
NA	Needs Assessment
NERC	North American Electric Reliability Corporation
NGS	Nuclear Generating Station
NPCC	Northeast Power Coordinating Council Inc.
NUG	Non-Utility Generator
OEB	Ontario Energy Board
OPA	Ontario Power Authority
ORTAC	Ontario Resource and Transmission Assessment Criteria
PF	Power Factor
PPWG	Planning Process Working Group
RIP	Regional Infrastructure Plan
SA	Scoping Assessment
SIA	System Impact Assessment
SPS	Special Protection Scheme
SS	Switching Station
STG	Steam Turbine Generator
TS	Transformer Station

Appendix H:

WNH Renewable Energy Generation (REG)

Investment Plan



Waterloo North Hydro Inc.

Renewable Energy Generation Investments Plan 2019

June 21, 2020

Filed with
Waterloo North Hydro's
2021 COS Application

TABLE OF CONTENTS

TABLE OF CONTENTS	2
LIST OF TABLES	2
LIST OF FIGURES	3
EXECUTIVE SUMMARY	4
1. Introduction.....	7
2. Waterloo North Hydro's Distribution System	9
3. Current and Forecast Generation Connections	11
4. Generation Contribution to System Peak Demand.....	14
5. Current and Forecast Generation Capacity	15
6. System Assessment to Identify Constraints	17
7. Distribution Automation and Smart Grid Development	19
8. Proposed Investments to Facilitate Renewable Energy Generation Connections...	20
APPENDIX A – WNH 20 Largest Embedded Generators	21
APPENDIX B - WNH REG Feeder Capacities.....	22
APPENDIX B – Continued.....	23

LIST OF TABLES

Table 1-1: WNH Transmission Points of Supply.....	9
Table 1-2: WNH Points of Supply < 50 kV	10
Table 1-3: WNH Generator Connections by Type	11
Table 1-4: WNH Generation, Connected, Allocated, Pending & Forecast.....	12
Table 1-5: WNH Total Generator Connections by Year.....	12
Table 1-6: WNH REG Connections by Year.....	13
Table 1-7: WNH Total Generation at time of System Peak (2019)	14
Table 1-8: WNH REG at time of System Peak (2019)	14
Table 1-9: WNH Transformer Station Capacity	16
Table A-1: WNH 20 Largest Embedded Generators	21
Table B-1A: WNH REG Feeder Capacities	22
Table B-1B: WNH REG Feeder Capacities	23

LIST OF FIGURES

Figure 1-1: WNH Service Area	8
Figure 1-2: Historical and Forecast Growth in Connected Generation	13

EXECUTIVE SUMMARY

This Renewable Energy Generation Investments (REGI) Plan provides the Ontario Energy Board (OEB) and interested stakeholders a consolidated view of the Renewable Energy Generation (REG) connected to Waterloo North Hydro Inc.'s (WNH) distribution system and WNH's ability to connect additional REG over the 2020 – 2025 timeframe. Included are current and forecast REG connections, available capacity to accommodate REG, constraints and investment requirements for any expansion or reinforcement necessary to remove distribution and grid constraints to accommodate generator connections. The report also provides brief analysis of the contribution of embedded generation to the 2019 WNH system peak demand.

This plan has been prepared in accordance with the Ontario Energy Board's (OEB) Chapter 5 "Filing Requirements for Electricity Distribution Rate Applications, May 14, 2020" (Chapter 5). The information in this plan is current as of December 31, 2019. This REGI Plan will be filed with WNH's Distribution System Plan (DSP) and 2021 Cost of Service Rate Application.

As of December 31, 2019, WNH had connected 655 generators to its distribution system for a total of 19,968 kW. Of these, 652 were REG connections totalling 15,448 kW. From 2015 to 2019 WNH connected 287 generators for a total of 11,492 kW. Of these, 284 for a total of 6,972 kW were REGs. At the time of WNH's 2019 summer system peak, total generation contributed an estimated 9,120 kW of which REG contributed 7,865 kW. Overall, generation was operating at approximately 45% of capacity.

The Independent Electricity System Operator (IESO) ceased to accept applications under the microFIT and FIT Programs as of December 31, 2016. The last connections made under these programs were made in 2018 and no more microFIT or FIT applications are allocated or pending. Total REGs connected under these programs comes to 568 MicoFIT (4,740 kW) and 41 FIT (9,223 kW).

The amount of Net Metering generation (948 kW) connected to date has been relatively small and is not forecast to be a major factor over the forecast period. Currently, WNH

has only 2 projects allocated for a total of 230 kW.

For the past two years, Load Displacement Generation (LDG), incented by higher Global Adjustment charges and electricity commodity pricing, has been the fastest growing segment of connected generation. Currently WNH has 7 LDG projects allocated for a total of 10,348 kW and one LDG project pending for a total of 1,890 kW, the majority being non-renewable gas fired generation.

Solar represents the largest segment of REG at 12,330 kW or 80% of REG. Biomass is the second largest segment at 18% for REG but also has the single largest generator (2,850 kW) in WNH's service area.

There is significant remaining generation capacity at WNH's transformer stations and feeders, however currently there are constraints related to the connection of generation at two WNH stations.

- 1) Scheifele 'A' station has reached its short-circuit rating limits at the station's feeder breakers. The fault contribution from existing connected embedded generation and Hydro One's transmission system upgrade as part of the Guelph Area Transmission Reinforcement (GATR) have contributed to the increase in short circuit levels. Taking into consideration the amount of generation that is allocated and pending, these short circuit rating limits will be exceeded within the next 12 – 36 months.

WNH has investigated the problem and has determined that the most cost effective solution will be to upgrade the feeder breakers at the station. WNH is moving forward with the work to reduce the risk of catastrophic failure of the circuit breakers during a fault clearing event. The project will be executed over 2 years. WNH has included the cost to replace these circuit breakers, \$230,244 in 2020 and \$209,762 in 2021, in their capital investment program. A secondary benefit will be the increase of 6,630 kW of generation capacity at this station.

- 2) Scheifele 'B' station has dual secondary winding transformers used in a Bermondsey configuration. Generation capacity is limited to the minimum load on

a single transformer due to concerns with reverse power through this type of transformer configuration. There is considerable generation capacity at this station with the limitation in effect, therefore there is no action required at this time. WNH will reevaluate this situation in the future if additional generation capacity is required.

WNH is not proposing any other capital investments to accommodate the connection of generation for the period 2021 to 2025.

WNH does not believe that the aforementioned constraints will have any material impact on the connection of REGs from 2020 to 2025.

No constraints have been identified on WNH feeders and there are no expansion or reinforcement investments necessary to remove grid constraints to accommodate the connections of REG relating to WNH.

1. Introduction

Waterloo North Hydro Inc. (WNH) is an Electricity Distribution Company (LDC) licensed by the OEB in accordance with its Distribution License ED-2002-0575. With a service area of approximately 683 sq. km., WNH provides all regulated electricity distribution services to approximately 58,000 customers mostly within the City of Waterloo, the Township of Woolwich and the Township of Wellesley. Due to service area boundary amendments, since 2017, WNH also provides distribution services to approximately 127 customers in the Township of Perth East, Township of Mapleton, Township of Centre Wellington, Township of Guelph/Eramosa, and the City of Cambridge. **Figure 1-1** illustrates a map of WNH's service area.

WNH is incorporated under the Ontario Business Corporations Act and is a subsidiary of Waterloo North Hydro Holding Company (WNHHC) whose shareholders are the City of Waterloo (73.2%), the Township of Woolwich (20.2%) and the Township of Wellesley (6.6%).

WNH is preparing a Cost of Service Rate Application as set out in the report of the Board: Renewed Regulatory Framework for Electricity (RRFE), for rates to be in effect January 01, 2021. WNH has prepared this Renewable Energy Generation Investments (REGI) Plan in accordance with the Ontario Energy Board's (OEB) Chapter 5 "Filing Requirements for Electricity Distribution Rate Applications, July 12, 2018" (Chapter 5).

This REGI Plan provides information to the OEB and interested stakeholders, regarding the readiness of WNH's distribution system to connect Renewable Energy Generation (REG), including details on existing generation connections, available capacity and a forecast of proposed connections. The Plan also identifies if any investments are required to accommodate REG connections including any expansion or reinforcement necessary to remove grid constraints to accommodate these connections for the period 2021 to 2025.

WNH's previous REGI Plan was prepared in 2015. The information contained in this report is current as of December 31, 2019.

2. Waterloo North Hydro's Distribution System

WNH is connected to the Hydro One Networks Inc. (HONI) Transmission System (HONI Tx) through five grid connected Transformer Stations as illustrated in Table 1-1. Four of these stations are owned and operated by WNH and are Dual Element Spot Network (DESN) stations. One station, Elmira Transformer Station (ELTS), is owned and operated by HONI and is embedded inside of WNH's service territory. ELTS is fed from a radial, single circuit, 115 kV transmission line. WNH owns 2 feeders and portions of the third feeder emanating from the ELTS. Approximately 80% of the ELTS load is supplied to WNH customers with the remaining load supplied to HONI customers in nearby Wellington County.

WNH's grid connected transformer stations have all been constructed new or extensively refurbished over the last 20 years and provide a high degree of reliability, not only to load customers but also to existing and future REG connections.

Table 1-1: WNH Transmission Points of Supply

#	Transformer Stations	Owned & Operated by	Supplied By	HO TX Line	HV (kV)	Station Location	LV (kV)	Tx ID	Tx ONAF Rating (MVA)	10 day LTR (MVA)
1	HMSTS 'A'	WNH	HONI Tx	D6V	230	Waterloo	13.8	T1	50	69
				D7V	230			T2	50	
2	HMSTS 'B'	WNH	HONI Tx	D7V	230	Waterloo	13.8	T3	83	110
				D6V	230			T4	83	
3	MTS #3	WNH	HONI Tx	D6V	230	Waterloo	27.6	T1	67	85
				D7V	230			T2	67	
4	ERTS (Note1)	WNH	HONI Tx	D10H	115	Waterloo	13.8	T1	50	75
				D8S	115			T2	50	
5	ELTS	HONI	HONI Tx	D10H	115	Woolwich	27.6	T1	42	62
								T2	42	

(Note1) – ERTS is currently limited by the thermal rating of the station transformers' secondary cables to a summer LTR of 69 MVA. The LTR of the power transformers is 75 MVA.

From the transmission connected transformer stations, WNH distributes electricity to its customers over 44 feeders at distribution voltages of 27.6 kV, 13.8 kV, and 17 feeders at 8.32 kV. WNH's end-of-life Asset Renewal program has produced secondary benefits such as eliminating the 4.16 kV distribution and steadily reducing the 8.32 kV distribution. Replacing these lower and less efficient voltages with higher capacity 13.8 kV and 27.6 kV distribution has also provided a secondary benefit of creating additional REG capacity.

WNH also receives electrical supply at < 50 kV (Dx) through feeders from 3 neighbouring LDCs; Hydro One Distribution (HONI Dx), Kitchener-Wilmot Hydro Inc. (KWHI) and Energy+. **Table 1-2** provides a listing of these points of supply. The capacities listed in **Table 1-2** for HONI, KWHI and Energy+ supply points are estimates only. Capacity to connect generation to feeders owned by other LDC's is subject to activities outside of WNH's service territory and need to be determined on a case by case basis at the time of application.

Table 1-2: WNH Points of Supply < 50 kV

	Feeder ID	Supplied From	Supply Point Location	LV (kV)	Load Capacity at WNH Boundary (MVA)	Generation Capacity at WNH Boundary (MVA)
1	73M7	HONI	Woolwich	44.0	8.0	4.8
2	9M4	KWHI	Wellesley	27.6	6.0	3.6
3	21M25	Energy+	Woolwich	27.6	14.3	8.6

3. Current and Forecast Generation Connections

As of December 31, 2019, 655 generators for a total of 19,968 kW were connected to WNH's distribution system. Of these, 652 were REG connections totalling 15,448 kW.

Table 1-3 provides a breakdown of the connections by generation type.

Table 1-3: WNH Generator Connections by Type

Generation Type	microFIT		FIT		Net Metered		Load Displacement		Total Connected	
	Num	(kW)	Num	(kW)	Num	(kW)	Num	(kW)	Num	(kW)
Solar	568	4,740	38	6,273	39	905	1	412	646	12,330
CHP							1	50	1	50
Wind			2	100	2	43			4	143
Biomass			1	2,850					1	2,850
Battery							2	4,470	2	4,470
Organic Rankine Cycle							1	125	1	125
Total	568	4,740	41	9,223	41	948	5	5,057	655	19,968
% of Total	87%	24%	6%	46%	6%	5%	1%	25%	100%	100%
REG	568	4,740	41	9,223	41	948	2	537	652	15,448
% REG	87%	31%	6%	60%	6%	6%	0.3%	3%	100%	100%

The Independent Electricity System Operator (IESO) ceased to accept applications under the microFIT and FIT Programs as of December 31, 2016. The last connections under these programs were made in 2018. WNH has no microFIT or FIT applications allocated or pending. REGs connected under these programs total 568 MicoFIT (4,740 kW) and 41 FIT (9,223 kW).

The amount of Net Metered generation connected to date has been relatively small and is not forecast to be a major factor over the forecast period. Currently, WNH has only 2 projects pending for a total of 230 kW.

Incented by high Global Adjustment charges and electricity commodity pricing, Load Displacement Generation (LDG) has been the fastest growing segment of connected generation over the last 2 years. Currently WNH has 7 LDG projects allocated for a total of 10,348 kW and one LDG project pending for a total of 1,890 kW. **Table 1-4** provides a

comparison of the amount of connected generation to that of allocated and pending.

Table 1-4: WNH Generation, Connected, Allocated, Pending & Forecast

Status	Total Generator Connections	Total Gen (kW)	REG Connections	REG (kW)	NON REG Connections	NON REG (kW)
Connected	655	19,968	652	15,448	3	4,520
Allocated	10	10,613	3	265	7	10,348
Pending	1	1,890	0	0	1	1,890
Forecast to 2025	68	19,293	57	4,400	11	14,893
Total	734	51,764	712	20,113	22	31,651

Table 1-5 illustrates the growth in all generation since 2015 and forecast generation to 2025.

Table 1-5: WNH Total Generator Connections by Year

Year	microFIT		FIT		Net Metered		Load Displacement		Total		Accumulated Total (kw)
	Num	(kW)	Num	(kW)	Num	(kW)	Num	(kW)	Num	(kW)	
2015	38	347	11	1,647	3	33	0	0	52	2,027	10,503
2016	35	335	3	650	4	90	0	0	42	1,075	11,577
2017	83	725	5	960	6	47	1	2,000	95	3,732	15,309
2018	70	511	2	370	8	511	3	587	83	1,979	17,288
2019					14	210	1	2,470	15	2,680	19,968
2020			1	35	2	230	7	10,348	10	10,613	30,581
2021					9	400	5	4,353	14	4,753	35,334
2022					9	400	4	4,330	13	4,730	40,064
2023					9	400	5	3,500	14	3,900	43,964
2024					9	400	5	3,500	14	3,900	47,864
2025					9	400	5	3,500	14	3,900	51,764
Total 2015 - 2019	226	1,917	21	3,627	35	891	5	5,057	287	11,492	
Total 2020 - 2025	0	0	1	35	47	2,230	31	29,531	79	31,796	


Table 1-6 illustrates the growth of REG in WNH's service area from 2015 - 2019 and WNH's forecast in REG from 2020 – 2025.

Table 1-6: WNH REG Connections by Year

Year	microFIT		FIT		Net Metered		Load Displacement		Total		Accumulated Total (kW)
	Num	(kW)	Num	(kW)	Num	(kW)	Num	(kW)	Num	(kW)	
2015	38	347	11	1,647	3	33	0	0	52	2,027	10,503
2016	35	335	3	650	4	90	0	0	42	1,075	11,577
2017	83	725	5	960	6	47	0	0	94	1,732	13,309
2018	70	511	2	370	8	511	2	537	82	1,929	15,238
2019					14	210	0	0	14	210	15,448
2020			1	35	2	230	2	400	5	665	16,113
2021					12	400	2	400	14	800	16,913
2022					12	400	2	400	14	800	17,713
2023					12	400	2	400	14	800	18,513
2024					12	400	2	400	14	800	19,313
2025					12	400	2	400	14	800	20,113
Total 2015 - 2019	226	1,917	21	3,627	35	891	2	537	284	6,972	
Total 2020 - 2025	0	0	1	35	62	2,230	12	2,400	75	4,665	

Figure 1-2 illustrates the growth of REG and NON REG in WNH's service area from 2006 - 2019 and WNH's forecast for each from 2020 – 2025. WNH has budgeted to support this level of activity and these connection costs will be recovered from the REG applicants.

Figure 1-2: Historical and Forecast Growth in Connected Generation



4. Generation Contribution to System Peak Demand

On July 5th, 2019 @ 17:15 hours EST, WNH experienced a gross summer system peak demand of 275.6 MW. Of the total, 266.5 MW were supplied through IESO wholesale transmission and < 50 kV metering points. The remaining 9.1 MW were supplied by embedded generation connected to WNH's distribution system.

The 654 embedded generators connected at the time had a total capacity of 19,943 kW. Generation contributed 3.3% toward the system peak or 45.7% of the total available generating capacity. REG represented 86.2% of the total generation at the time.

Break downs of total connected generation and REG at time of system peak are provided in **Table 1-7** and **Table 1-8**.

Table 1-7: WNH Total Generation at time of System Peak (2019)

Generation Type	Connections	Total Capacity (kW)	Total Output at System PK (kW)
microFIT	567	4,676	2,376
FIT	40	11,245	4,701
Net Metering	44	1,015	516
Load Displacement	3	3,007	1,528
Total	654	19,943	9,120

Table 1-8: WNH REG at time of System Peak (2019)

Generation Type	Connections	Total Capacity (kW)	Total Output at System PK (kW)
microFIT	567	4,676	2,376
FIT	40	11,245	4,701
Net Metering	44	1,015	516
Load Displacement	2	537	273
Total	653	17,473	7,865

5. Current and Forecast Generation Capacity

Table 1-9 illustrates the estimated generation capacity that is available at WNH points of supply. Overall there is a significant amount of generation capacity available, however currently there are two constraints related to the connection of generation at the WNH stations.

While most of WNH's transformer stations have sufficient short-circuit capacity and thermal rating to accommodate the existing and forecast generation connections, there are two exceptions:

- 1) Scheifele 'A' station has reached its short-circuit rating limits at the station's feeder breakers. The fault contribution from existing connected embedded generation and Hydro One's transmission system upgrade as part of the Guelph Area Transmission Reinforcement (GATR) project have contributed to the increase in short circuit levels. Taking into consideration the amount of generation that is allocated and pending, these short circuit rating limits will be exceeded within the next 12 – 36 months.
- 2) Scheifele 'B' station has dual secondary winding transformers used in a Bermondsey configuration. Generation capacity is limited to the minimum load on a single transformer due to concerns with reverse power through this type of transformer configuration. There is considerable generation capacity at this station with the limitation in effect, therefore there is no action required at this time. WNH will reevaluate this situation in the future if additional generation capacity is required.

No constraints pertaining to WNH's 13.8 kV and 27.6 kV station feeders have been identified. The capacities listed in **Table 1-9** for HONI and Energy+ supply points are estimates only. Capacity to connect generation to feeders owned by other LDCs is subject to activities outside of WNH's service territory and need to be determined on a case by case basis at the time of application.

WNH's 8.32 kV distribution lines have limited capacity and can only accept small to mid-sized generation (< 500 kW). There is capacity to connect larger scale generation at the

higher voltages, up to 5.0 MW (13.8 kV) and 10.0 MW (27.6 kV). Capacity to connect generation of this size would need to be determined on a case by case basis at the time of application.

Table 1-9: WNH Transformer Station Capacity

TRANSFORMER STATION / FEEDER						
Station	Feeder(s)	Owner	Total Generation Capacity (kW)	Connected Generation (kW)	Remaining Generation Capacity (kW)	Remaining Generation Capacity (%)
Rush		WNH	12,900	743	8,200	94%
Scheifele A (1)		WNH	11,000	4,370	-	0%
Scheifele B (2)		WNH	27,500	3,497	24,003	87%
WNH MTS #3		WNH	18,300	2,666	15,634	85%
Elmira TS		HONI Tx	25,020	7,025	17,995	72%
Preston TS	21M25	Energy+	8,580	365	8,215	96%
Fergus TS	73M7	HONI Dx	4,800	414	4,386	91%
KWH #9	9M4	KWHI	3,600	887	2,713	75%
Total			111,700	19,968	85,103	76%

As WNH's 8.32 kV distribution lines and stations reach end-of-life or where their capabilities have been surpassed by load growth, the stations are retired and the lines are replaced with new assets that are more efficient and operate at the higher 27.6 kV voltages. This allows WNH greater flexibility to connect larger scale generation.

WNH is supplied by one 44 kV feeder from Hydro One Dx. WNH's connection is at the end of a long radial feeder, out of phase with the rest of WNH's distribution system and has limited capacity. It is not a significant contributor to WNH's Renewable Generation Capacity but is noted only for completeness.

Appendix B, Table B-1A and B-1B provides a summary of WNH's capacity by individual feeder and voltage level. Ultimately, generation connections to any feeder is limited by the available station capacity at the time of request.

WNH does not believe that the aforementioned constraints and limitations will have any material impact on the ability to connect REG over the forecast period.

6. System Assessment to Identify Constraints

On an annual basis, WNH internally reviews its station capacities and constraints. Two constraints have been identified at WNH Transformer Stations and are described in Section 4.

WNH also assesses its distribution network for capacity constraints. WNH's three phase 13.8 kV and 27.6 kV feeders have sufficient capacity to permit the forecast amount of REG connections. WNH's 8.32 kV distribution has limited capacity and can only accept small to mid-sized generation (<500 kW).

WNH also works with the organizations listed below to develop the Kitchener-Waterloo-Cambridge-Guelph (KWCG) Regional Infrastructure Plans (RIP) and the Integrated Regional Resources Plans (IRRP).

- i. Kitchener-Wilmot Hydro Inc. (KWHI),
- ii. Cambridge and North Dumfries Hydro (CNDH now Energy+),
- iii. Guelph Hydro Electric System Inc. (GHESI now Alectra),
- iv. Hydro One Distribution (HONI Dx),
- v. Hydro One Transmission, (HONI Tx)
- vi. Independent Electricity System Operator (IESO)
- vii. Ontario Power Authority (now IESO)

The RIP and IRRP review factors such as load forecast, transmission and distribution system capabilities along with any updates with respect to local plans, conservation and demand management ("CDM"), renewable and non-renewable generation development.

The first cycle of regional planning for the region began in 2010 and was completed in April 2015 with the release of an Integrated Regional Resource Plan (IRRP). Currently a new regional planning cycle is underway for the Kitchener-Waterloo-Cambridge-Guelph (KWCG) Region. The next IRRP for the region is anticipated to be completed in Q2 2020.

WNH has participated in the planning meetings and consulted with all of the aforementioned stakeholders and determined that there are no expansion or reinforcement investments necessary to remove grid constraints to accommodate the connections of REG relating to WNH.

WNH notes an increasing trend in the connection of Load Displacement Generation (behind the meter natural gas generation) since 2018. Allocated and pending projects signal a significant increase in LDG between 2020 and 2025. Problematic for REG in the future is the fact that natural gas generation can reduce available generation capacity at a much faster rate than renewable inverter-based generation.

However, based on WNH's evaluation of current connections and forecast applications, WNH believes that there is adequate capacity to connect the anticipated generation over the forecast period.

7. Distribution Automation and Smart Grid Development

All WNH grid connected Transformer Stations, Municipal Stations, and Distribution Stations have SCADA monitoring and control, programmable electronic protection systems and communication systems. The same is true of all < 50 kV points of supply from HONI Dx, KWHI and Energy+. All are interfaced with WNH's Survalent Outage Management System.

WNH also has 84 electronic reclosers with SCADA monitoring and control, programmable electronic protection and communications installed at various locations on its distribution system.

Although REG has not been the primary driver for these Renewal and System Service investments, they have had the added benefit of facilitating these connections.

8. Proposed Investments to Facilitate Renewable Energy Generation Connections

As mentioned in Section 4, there is one constraint at Scheifele 'A' station caused by the maximum available short circuit level being reached at the station.

- 1) Scheifele 'A' station has reached its short-circuit rating limits at the station's feeder breakers. The fault contribution from existing connected embedded generation and Hydro One's transmission system upgrade as part of the Guelph Area Transmission Reinforcement (GATR) have contributed to the increase in short circuit levels. Taking into consideration the amount of generation that is allocated and pending, these short circuit rating limits will be exceeded within the next 12 – 36 months.

WNH has investigated the problem and has determined that the most cost effective solution will be to upgrade the feeder breakers at the station. WNH is moving forward with the work to reduce the risk of catastrophic failure of the circuit breakers during a fault clearing event. The project will be executed over 2 years. WNH has included the cost to replace these circuit breakers, \$230,244 in 2020 and \$209,762 in 2021, in their capital investment program. A secondary benefit will be the increase of 6,630 kW of generation capacity at this station.

WNH is not proposing and other capital investments to accommodate the connection of generation for the period 2021 to 2025.

APPENDIX A – WNH 20 Largest Embedded Generators

Table A-1: WNH 20 Largest Embedded Generators

Rank	Fuel Type	Feeder #	Year Installed	Generator Size (kW)	Category
1	Biomass	33M1	2013	2,850	FIT
2	Battery	HS-10	2019	2,470	LOAD DISPLACEMENT
3	Battery	33M1	2017	2,000	LOAD DISPLACEMENT
4	Solar	33M3	2014	500	FIT
5	Solar	33M1	2017	450	FIT
6	Solar	HS-12	2018	412	LOAD DISPLACEMENT
7	Solar	3F-65	2018	399	NET METERED
8	Solar	9M4	2016	300	FIT
9	Solar	HS-10	2012	250	FIT
10	Solar	HS-23	2013	250	FIT
11	Solar	HS-24	2013	250	FIT
12	Solar	HS-28	2014	250	FIT
13	Solar	HS-20	2015	250	FIT
14	Solar	9M4	2016	250	FIT
15	Solar	HS-8	2017	250	FIT
16	Solar	3F-66	2013	225	FIT
17	Solar	3F-65	2018	219	FIT
18	Solar	HS-10	2010	200	FIT
19	Solar	HS-21	2014	200	FIT
20	Solar	HS-28	2015	200	FIT

APPENDIX B - WNH REG Feeder Capacities

Table B-1A: WNH REG Feeder Capacities

Transformer Station	Bus	Feeder	Voltage (kV)	Total Generation Capacity (kW)	Remaining Generation Capacity (kW)	% Remaining Capacity
Rush	B1	ER-41	13.8	6,812	6,781	99.5%
		ER-42	13.8	6,812	6,766	99.3%
		ER-43	13.8	6,812	6,758	99.2%
		ER-44	13.8	6,812	6,584	96.6%
Rush	B2	ER-45	13.8	6,812	6,745	99.0%
		ER-46	13.8	6,812	6,687	98.2%
		ER-47	13.8	6,812	6,744	99.0%
		ER-48	13.8	6,812	6,665	97.8%
Scheifele A	B	HS-7	13.8	6,812	6,652	97.7%
		HS-8	13.8	6,812	6,562	96.3%
		HS-9	13.8	6,812	6,812	100.0%
		HS-10	13.8	6,812	3,840	56.4%
Scheifele A	Y	HS-11	13.8	6,812	4,654	68.3%
		HS-12	13.8	6,812	2,112	31.0%
		HS-13	13.8	6,812	6,654	97.7%
		HS-14	13.8	6,812	6,212	91.2%
Scheifele B	H	HS-15	13.8	6,812	6,567	96.4%
		HS-16	13.8	6,812	6,812	100.0%
		HS-17	13.8	6,812	6,684	98.1%
		HS-18	13.8	6,812	6,812	100.0%
Scheifele B	J	HS-19	27.6	13,624	13,300	97.6%
		HS-20	13.8	6,812	6,495	95.3%
		HS-21	13.8	6,812	6,502	95.4%
		HS-22	13.8	6,812	5,930	87.0%
		HS-32	13.8	6,812	6,812	100.0%

APPENDIX B – Continued

Table B-1B: WNH REG Feeder Capacities

Transformer Station	Bus	Feeder	Voltage (kV)	Total Generation Capacity (kW)	Remaining Generation Capacity (kW)	% Remaining Capacity
Scheifele B	Q	HS-23	13.8	6,812	6,392	93.8%
		HS-24	13.8	6,812	6,370	93.5%
		HS-25	13.8	6,812	6,812	100.0%
		HS-26	27.6	13,624	12,807	94.0%
		HS-31	13.8	6,812	6,812	100.0%
Scheifele B	T	HS-27	13.8	6,812	6,725	98.7%
		HS-28	13.8	6,812	6,174	90.6%
		HS-29	13.8	6,812	6,667	97.9%
		HS-30	13.8	6,812	2,787	40.9%
WNH MTS#3	B1	3F-60	27.6	13,624	13,624	100.0%
		3F-61	27.6	13,624	13,344	97.9%
		3F-50	13.8	6,812	6,723	98.7%
		3F-63	27.6	13,624	13,068	95.9%
		3F-64	27.6	Future	N/A	
WNH MTS#3	B2	3F-65	27.6	13,624	13,005	95.5%
		3F-66	27.6	13,624	13,336	97.9%
		3F-51	13.8	6,812	6,803	99.9%
		3F-68	27.6	13,624	11,647	85.5%
		3F-69	27.6	Future	N/A	

Appendix I:

IESO REG Letter of Comment

IESO response to Waterloo North Hydro Inc.'s REG Investments Plan 2020 - 2025

In accordance with the Ontario Energy Board's (OEB) **Filing Requirements For Electricity Distribution Rate Applications** to submit a Distribution System Plan with its Cost of Service application, on February 25, 2020 Waterloo North Hydro Inc. (WNH) sent its Renewable Energy Generation (REG) Investments Plan 2019 (Plan) to the IESO. WNH's Plan covers the period 2020-2025.

Filing Requirements, Chapter 5, section 5.2.2 *Coordinated planning with third parties* requires the following:

- d) For REG investments a distributor is expected to provide the comment letter provided by the IESO in relation to REG investments included in the distributor's DSP, along with any written response to the letter from the distributor, if applicable. The OEB expects that the IESO comment letter will include:
- Whether the distributor has consulted with the IESO, or participated in planning meetings with the IESO
 - The potential need for co-ordination with other distributors and/or transmitters or others on implementing elements of the REG investments
 - Whether the REG investments proposed in the DSP are consistent with any Regional Infrastructure Plan

Consultation

The IESO has reviewed WNH's Plan and confirms that WNH is a participating member of the working group in the Kitchener-Waterloo-Cambridge-Guelph (KWCG) Region. The working group consists of the IESO, Hydro One Networks Inc. (Transmission and Distribution), Centre Wellington Hydro Ltd., Energy+ Inc., Guelph Hydro Electric Systems Inc. (Alectra Utilities Corporation), Halton Hills Hydro Inc., Kitchener-Wilmot Hydro Inc., Milton Hydro Distribution Inc., and Waterloo North Hydro Inc.

The first regional planning cycle for KWCG Region was concluded with the publishing of a Regional Infrastructure Plan (RIP) in December 2015¹. In the current planning cycle, to date Hydro One's Needs Assessment² (NA) has been published in December 2018, and the IESO's Scoping Assessment (SA) Outcome Report and Draft Terms of Reference for the KWCG Region Integrated Regional Resource Plan (IRRP)³ have been published in May 2019. An IRRP for the KWCG Region is now underway and is planned for publication in October 2020. Following the completion of the IRRP, Hydro One is expected

¹ <https://www.hydroone.com/abouthydroone/CorporateInformation/regionalplans/kitchenerwaterloocambridgeguelph/Documents/KWCG%20RIP%20Report.pdf>

² <https://www.hydroone.com/abouthydroone/CorporateInformation/regionalplans/kitchenerwaterloocambridgeguelph/Documents/KWCG%20Needs%20Assessment%202018.pdf>

³ <http://www.ieso.ca/en/Get-Involved/Regional-Planning/Southwest-Ontario/Kitchener-Waterloo-Cambridge-Guelph>

to conduct a RIP to complete this cycle of the regional planning process. As part of a planning process requirement WNH provided the IESO with load forecasts and other supporting information in its service territory.

Coordination

Based on a review of the investments proposed in WNH's Plan, the IESO only sees potential need for co-ordination with the transmitter Hydro One on implementing elements of the REG investments.

Consistency

Regarding REG investments, WNH Plan indicates that while most of its transformer stations are capable of accommodating existing and forecast generation connections, Scheifele "A" station has reached its short-circuit rating limits at the station's feeder breakers. Considering its allocated and pending generation, WNH estimates that these short circuit rating limits will be exceeded within the next 12 – 36 months. WNH's Plan includes capital investments for 2020 and 2021 to replace Scheifele "A" feeder breakers which WNH indicates will also allow for an increase in generation connection capacity of 6,630 kW.

The IESO notes that WNH has no other capital investments to accommodate the connection of generation for the Plan period.

Although the specific investments described in WNH's Plan are not included within the most recent RIP, addressing barriers to connect additional distributed generation (DG) including REG within WNH's service area is consistent with regional planning principles. Removing technical barriers to new DG connections can provide lasting benefits to the upstream transmission system by reducing the need, over time, for additional load meeting demands on the high voltage transmission serving the area.

The IESO looks forward to working with WNH on regional planning through the current cycle and appreciates this opportunity to comment on the REG investment information provided as part of its Distribution System Plan.

Appendix J:

WNH System Supply and Capacity Study



Waterloo North Hydro Inc.

System Supply and Capacity Study

June 21, 2020

Filed with

Waterloo North Hydro's

2021 COS Application

TABLE OF CONTENTS

TABLE OF CONTENTS	1
LIST OF TABLES	2
LIST OF FIGURES	2
GLOSSARY	3
EXECUTIVE SUMMARY	5
1. OVERVIEW OF WNH's DISTRIBUTION SYSTEM	8
2. WNH SYSTEM DEMAND	10
2.1. Overview	10
2.2. Impact of Embedded Generation	10
3. WNH ELECTRICAL SUPPLY	13
4. WNH CAPACITY UTILIZATION	15
4.1. HONI Transmission Lines (230 kV & 115 kV)	15
4.2. WNH Transmission Connected Stations (230 kV & 115 kV)	16
4.3. Transformer Station Feeders (27.6 kV and 13.8 kV)	19
4.4. Municipal and Distribution Station (DS) Capacity Utilization	23
4.5. Distribution Feeder (8 kV) Capacity Utilization	24
4.6. Distribution Transformers	25

LIST OF TABLES

Table 1-1: WNH Customer & Service Area Demographics.....	8
Table 3-1: WNH Gross Summer Peak Load MW (2019).....	13
Table 3-2: WNH Peak Load by Delivery Point (2019).....	13
Table 3-3: WNH Average Peak Load by Delivery Point (2016 - 2019).....	14
Table 3-4: WNH Embedded Generation (2019).....	14
Table 4-1: WNH Transmission Supply	15
Table 4-2: WNH Transmission Connected Stations.....	16
Table 4-3: Capacity Utilization - Station Transformers.....	17
Table 4-4: Station Feeder Utilization HMSTS"A" (2016 – 2019)	20
Table 4-5: Station Feeder Utilization HMSTS"B" (2016 – 2019)	20
Table 4-6: Station Feeder Utilization MTS#3 (2016 – 2019)	20
Table 4-7: Station Feeder Utilization ERTS (2016 – 2019)	21
Table 4-8: Station Feeder Utilization ELTS (2016 – 2019).....	22
Table 4-9: Delivery Point Feeder Utilization (< 50 kV) (2016 – 2019)	22
Table 4-10: WNH DS Station Capacity Utilization.....	23
Table 4-11: WNH DS Station Feeder Capacity Utilization.....	24

LIST OF FIGURES

Figure 1-1: WNH Service Area.....	9
Figure 2-1: WNH Historical and Forecast Peak Demand.....	11
Figure 2-2: Historical and Forecast Growth in Generation	12
Figure 4-1: WNH Distribution Transformer Utilization (%).....	25

GLOSSARY

- 1) AM – Asset Management
- 2) AMP – Asset Management Plan
- 3) CEA – Canadian Electrical Association
- 4) CSA – Canadian Standard Association
- 5) DS – Distribution Station
- 6) DSC – Distribution System Code
- 7) DSP – Distribution System Plan
- 8) EOL – End-of-Life
- 9) GM – Grid Modernization
- 10) HONI – Hydro One Networks Inc.
- 11) IESO – Independent Electricity System Operator
- 12) KWCG – Kitchener – Waterloo – Cambridge – Guelph
- 13) KWHI – Kitchener-Wilmot Hydro Inc.
- 14) LDC – Local Distribution Company
- 15) LOS – Loss of Supply
- 16) MS – Municipal Station
- 17) MVA - Motor Vehicle Accident
- 18) O/H or OH - Overhead
- 19) O&M – Operation & Maintenance
- 20) OEB – Ontario Energy Board
- 21) REG – Renewable Energy Generation
- 22) SCADA – Supervisory Control and Data Acquisition
- 23) TUL – Typical Useful Life

24) TS – Transmission Station or Transformer Station

25) U/G or UG – Underground

26) WNHI / WNH – Waterloo North Hydro Inc.

27) XFMR / Tx – Transformer

EXECUTIVE SUMMARY

WNH's System Supply and Capacity Study (SSCS) provides a consolidated view of WNH's distribution system's ability to supply current and forecasted load customers. The SSCS informs WNH's senior executive team (Executive) and aides in the development of WNH's business plans and budgets. The SSCS also provides key information to allow WNH to develop, manage and maintain its major distribution system assets and provide a safe, secure, reliable, efficient and cost-effective service to its customers.

This SSCS supports WNH's Distribution System Plan (DSP) and compliments information found in the Renewable Energy Generation Investments (REGI) Plan. The information contained in this report is current as of December 31, 2019.

The report examines WNH's historical and forecast growth in electrical demand. In addition, the report also examines the capacity and load supplied by WNH's key infrastructure components including:

- 1) delivery points, both at the transmission and distribution level;
- 2) grid-connected power transformers and feeders;
- 3) DS station transformers and feeders;
- 4) distribution transformers.

Overall, WNH supply and capacity levels are adequate to sustain the forecasted load growth to the end of 2025. Components that are nearing capacity limits are noted and mitigation measures are being taken in the DSP. These measures are mostly about rebalancing of loads to improve utilization of existing assets.

For the period 2020 – 2025, WNH is forecasting an annualized growth rate of 1.0% in summer demand and 0.2% in winter demand. There are no capacity or supply constraints forecast at WNH's major transmission delivery points.

At WNH's transformer stations and feeders, one capacity issue has been identified. The utilization of HMSTS "B" capacity is significantly higher and growing at a higher rate than that of other WNH stations. This is mainly due to the impact of urban intensification in the

central areas of Waterloo. Load rebalancing between stations having the same operating voltage is a normal part of system operations; however, feeder length, voltage drop and reliability have started to limit opportunities. WNH is taking advantage of voltage conversion measures, during System Renewal projects in the Lakeshore area of Waterloo, to move load away from HMSTS “B”. Other feeder load rebalancing efforts that are likely to occur are expected to be minor and will be addressed on a case by case basis. No capacity expansion at the transformer station level is forecast before 2025.

The replacement of HMSTS “A” T1 and T2 transformers, due to condition, is also expected to be sometime after 2025. It is recommended that options of increasing the rating of the replacement transformers and the ability to integrate that additional capacity into the distribution system, be studied.

Two of WNH’s three < 50 kV delivery points are near capacity. Although not a major point of supply, the 09M4 27.6 kV feeder from KWHI is strategically important to WNH due to its geographic location and needs to be maintained. WNH is taking advantage of voltage conversion measures during System Renewal projects in the Wellesley West area to move load to its own 27.6 kV system and prevent overloading of the delivery point. The 21M25 27.6 kV feeder from Energy+ is also strategically important to WNH due to its geographic location. WNH is working with the IESO and Energy+ in the latest round of the KWCG IRRP to find a regional solution to supply issues in this area of Woolwich Township and the City of Cambridge. Further information can be found in **Appendix F - KWCG IRRP Scoping Assessment Outcome Report (2019)**.

WNH’s third < 50 kV delivery point is the 73M7 feeder from HONI Dx. This is WNH’s only 44 kV delivery point, at the end of a long radial feeder and has had relatively poor historical reliability. Load being supplied by the 73M7 is gradually being migrated over to WNH’s 27.6 kV system as a result of voltage conversion measures during System Renewal projects in the Woolwich East area.

WNH’s 8 kV distribution system is undergoing a gradual but planned transformation, as System Renewal investments replace assets that are inefficient and in poor condition with new assets operating at 27.6 kV. As the 8 kV system downsizes, interconnectivity options

are reduced making WNH more reliant on the use of its Mobile Unit Substation (MUS) in the case of a distribution station transformer failure. WNH does not forecast any significant constraints or lack of capacity on the 8 kV system over the 2021 – 2025 forecast period.

WNH forecasts sufficient capacity in its population of distribution transformers over the 2021 - 2025 forecast period to serve the growing load, including the connection of electric vehicles. Some localized constraints may occur over time and will be addressed on a case by case basis.


1. OVERVIEW OF WNH's DISTRIBUTION SYSTEM

Waterloo North Hydro Inc. (WNH) is an Electricity Distribution Company (LDC) licensed by the OEB in accordance with its Distribution License ED-2002-0575. With a service area of 683 sq. km, WNH provides all regulated electricity distribution services to approximately 58,000 customers mostly within the City of Waterloo, the Township of Woolwich and the Township of Wellesley. Due to service area boundary amendments since 2017, WNH also provides distribution services to approximately 127 customers in the Township of Perth East, the Township of Mapleton, the Township of Centre Wellington, the Township of Guelph/Eramosa, and the City of Cambridge. A breakdown of WNH's customers and service area can be found in **Table 1-1**. **Figure 1-1** provides a map illustrating the extent of WNH's service area.

Table 1-1: WNH Customer & Service Area Demographics

MUNICIPALITY	CUSTOMERS	%	SERVICE AREA (sq. km)	%	CUSTOMER DENSITY (per sq. km)
City of Waterloo	44,507	76.9%	65	9.5%	685
Township of Woolwich	9,806	16.9%	328	48.2%	30
Township of Wellesley	3,484	6.0%	269	39.4%	13
Wellington County	67	0.1%	13	1.9%	5
Perth County	10	0.0%	7	1.0%	1
Cambridge	1	0.0%	0	0.0%	7
Total	57,875	100%	683	100%	85

Figure 1-1: WNH Service Area



2. WNH SYSTEM DEMAND

2.1. Overview

WNH has been a summer peaking utility since 1996 and weather still remains the main factor impacting volatility in WNH's peak demand. Although the Region of Waterloo has been and continues to be a growing community, the growth in annual peak demand (MW) has moderated over the past decade. From 1992 to 2011, WNH's annualized growth rate in Summer System Peak Demand stood at 2.2%. Since 2015 WNH's annualized summer Peak Demand growth rate has declined to 1.0%.

Similarly, but to a greater extent, WNH's annualized growth rate in Winter System Peak Demand has declined from 1.1% to approximately 0.2%.


The main contributing factors leading to the decline in demand are believed to be a decline in customer growth rate, load shifting due to time-of-use rates, contributions from embedded generation, Conservation & Demand Management programs (CDM) and other conservation measures. WNH believes that the current factors influencing demand will continue with embedded generation having an even greater impact over the forecast period. For the period 2020 – 2025, WNH is forecasting an annualized growth rate of 1.0% in Summer System Peak Demand and 0.2% in Winter System Peak Demand. WNH's historical and forecast peak demands are illustrated in **Figure 2-1**.

2.2. Impact of Embedded Generation

As of December 31, 2019, WNH had connected 655 generators to its distribution system for a total of capacity of 19,968 kW.

Referring to **Figure 2-1**, WNH's forecast peak demand is expected to grow at an annual rate of 1%. This load forecast is based on WNH's load growth projections, persistence of historical conservation initiatives and forecasted growth in embedded generation. It can be seen that the spread between the summer net demand (purchased through the IESO) and gross demand (total needed to supply WNH customers) has and continues to increase over time.

Figure 2-1: WNH Historical and Forecast Peak Demand




This spread is due to the growing amount of embedded generation connected to WNH's distribution system.

In 2019, WNH experienced a gross summer system peak of 275.6 MW. At the time, total embedded generation contributed an estimated 9.1 MW (3.3%) while the remainder of the load was supplied through IESO wholesale supply points. Overall, it is estimated that generation was operating at approximately 45% of name plate capacity.

Figure 2-2 illustrates WNH's historical and forecast growth of embedded generation. More information on generation can be found in the DSP, **Appendix H - WNH Renewable Energy Generation (REG) Investment Plan**.

Figure 2-2: Historical and Forecast Growth in Generation



3. WNH ELECTRICAL SUPPLY

WNH's electrical supply is sourced from four major areas:

1. HONI 230 kV Transmission
2. HONI 115 kV Transmission
3. < 50 kV 27.6 kV & 44 kV Feeders
4. Embedded Generation

Table 3-1 illustrates the division of load through each of these four areas with 96.7% being supplied by IESO Wholesale points and 3.3 % coming from embedded generation.

Table 3-1: WNH Gross Summer Peak Load MW (2019)

Supply Voltage (kV)	2019 Load (MW)	% Total Load by Supply
230	177.3	64.3%
115	76.1	27.6%
< 50 kV Load	13.1	4.7%
Embedded Gen.	9.1	3.3%
TOTAL	275.6	100%

Table 3-2 provides a breakdown of WNH's transmission and distribution Delivery Points (DP) and 2019 Gross Summer Peak Load (non coincident).

Table 3-2: WNH Peak Load by Delivery Point (2019)

Supply Point	Supply Voltage (kV)	HMSTS (MW)	MTS #3 (MW)	ERTS (MW)	ELTS (MW)	< 50 kV (MW)	Total Tx (MW)	% Total Load by Delivery Point
D6V	230	63.1	25.6				88.7	32.3%
D7V	230	63.1	25.6				88.7	32.3%
D8S	115			21.4			21.4	7.8%
D10H	115			21.4	33.3		54.7	19.9%
73M7 PME	44					3.2	3.2	1.2%
09M4 PME	27.6					4.5	4.5	1.6%
21M25 PME	27.6					13.4	13.4	4.9%
TOTAL		126.1	51.2	42.8	33.3	21.1	274.5	100%
% Tx Load		45.9%	18.6%	15.6%	12.1%	7.7%	100%	

Approximately 92% of WNH’s electrical supply comes directly from four Hydro One Network Inc.’s (HONI) 230 kV and 115 kV transmission lines. **Table 3-3** provides the same information utilizing 2016 – 2019 average loading at each delivery point.

Table 3-3: WNH Average Peak Load by Delivery Point (2016 - 2019)

Supply Point	Supply Voltage (kV)	HMSTS (MW)	MTS #3 (MW)	ERTS (MW)	ELTS (MW)	< 50 kV (MW)	Total Tx (MW)	% Total Load by Delivery Point
D6V	230	64.8	27.0				91.8	32.4%
D7V	230	64.8	27.0				91.8	32.4%
D8S	115			22.3			22.3	7.9%
D10H	115			22.3	33.1		55.4	19.5%
73M7 PME	44					3.2	3.2	1.1%
09M4 PME	27.6					5.4	5.4	1.9%
21M25 PME	27.6					13.7	13.7	4.8%
TOTAL		129.6	54.0	44.6	33.1	22.3	283.6	100%
% Total Load		45.7%	19.0%	15.7%	11.7%	7.9%	100%	0%

Table 3-4 provides a breakdown of embedded generation’s total contribution of 9.1 MW (3.3%) at time of system peak.

Table 3-4: WNH Embedded Generation (2019)

Generation Type	Connections	Total Capacity (MW)	Total Output at System Peak (MW)
MicroFIT	567	4.7	2.4
FIT	40	11.2	4.7
Net Metering	44	1.0	0.5
Load Displacement	3	3.0	1.5
Total	654	19.9	9.1

Overall, WNH supply levels are adequate to sustain the forecasted load growth to the end of 2025.

4. WNH CAPACITY UTILIZATION

4.1. HONI Transmission Lines (230 kV & 115 kV)

From 2016 – 2019 approximately 92% of WNH’s average peak load is directly (80.5%) or indirectly (11.7%) supplied by the four HONI transmission lines identified in **Table 3-3**. Approximately 64.7% is supplied at 230 kV, 27.4% at 115 kV with the remaining 8% from < 50 kV feeders.

Table 4-1: WNH Transmission Supply

HONI Tx	kV	WNH Capacity
D6V	230	No Constraints
D7V	230	No Constraints
D10H	115	No Constraints
D8S	115	No Constraints

Based on past and current Regional Planning analysis, there does not appear to be any constraints on the HONI 230 kV and 115 kV transmission system that would negatively impact WNH over the forecast years.

HONI’s 115 kV D10H and D8S transmission lines are near capacity, however WNH does not anticipate this to lead to any constraints in supplying customer load within the 2021 – 2025 forecast period.

4.2. WNH Transmission Connected Stations (230 kV & 115 kV)

Five grid connected Dual Element Spot Network (DESN) Transformer Stations as listed in **Table 4-2** feed the bulk of WNH's distribution system. Four of these stations are owned and operated by WNH. One station, Elmira Transformer Station (ELTS), is owned and operated by HONI and is embedded inside of WNH's service territory. WNH owns 2 feeders and portions of the third feeder emanating from the ELTS. Approximately 80% of the ELTS load is supplied to WNH customers with the remaining load supplied to HONI customers in nearby Wellington County.

Table 4-2: WNH Transmission Connected Stations

	Transformer Station	Station Location	Owned & Operated by	Supplied By	HV (kV)	LV (kV)	Transformer ONAF/OFAF Rating (MVA)	Station Summer LTR (MVA)	LTR (%)
1	HMSTS "A"	Waterloo	WNH	HONI Tx	230	13.8 / 27.6	2 x 50	69	138%
2	HMSTS "B"	Waterloo	WNH	HONI Tx	230	13.8	2 x 83	110	133%
3	MTS #3	Waterloo	WNH	HONI Tx	230	27.6 / 13.8	2 x 67	85	127%
4	ERTS (Note1)	Waterloo	WNH	HONI Tx	115	13.8	2 x 50	75	150%
5	ELTS	Woolwich Twp.	HONI	HONI Tx	115	27.6	2 x 42	62	148%

(Note1) – ERTS is currently limited by the thermal rating of the station transformers' secondary cables to a summer LTR of 69 MVA. The LTR of the power transformers is 75 MVA. Percent utilization is calculated based on 69 MVA.

The limitation at ERTS is not expected to restrict WNH's ability to supply customers over the 2021 – 2025 forecast period.

Operating as a DESN station, each of the two main power transformers divide the station load equally through a normally closed secondary bus tie system. The loss of one power transformer or transmission line, referred to as an N-1 event, requires the remaining transformer to immediately carry all of the station load without interruption.

WNH prepares for such contingencies by purchasing station transformers with overload capabilities known as a Limited Time Rating (LTR). WNH uses 10-day summer LTR's in its capacity and contingency planning. A loss of transformer life of 2% per day is borne by the overloaded transformer during this scenario until the excess load can be transferred to other stations. WNH maintains a margin of capacity at its other stations to accept the excess load during such contingencies and to ensure individual transformers operate at or below their normal full load rating.

Table 4-3 provides the capacities, average peak loading and percent utilization for the grid connected stations supplying WNH.

Table 4-3: Capacity Utilization - Station Transformers

#	Transformer Station	Tx ID	Transformer ONAF/OFAF Rating (MVA)	Available Capacity (MW)	2016 - 2019 Avg. Peak Demand (MW)	% Capacity Utilization
1	HMSTS 'A'	T1	50	62	41	66%
2		T2	50			
3	HMSTS 'B'	T3	83	99	89	90%
4		T4	83			
5	MTS #3	T1	67	77	54	71%
6		T2	67			
7	ERTS	T1	50	68	45	67%
8		T2	50			
9	ELTS (Note 2)	T1	42	45	33	74%
10		T2	42			

(Note 2) - ELTS Summer LTR is 55.8 MW or 62 MVA at 0.9 power factor. WNH has historically utilized approximately 80% of the available station capacity. WNH's percent utilization is calculated based on 80% of the ELTS capacity.

WNH's planning strategy for operating its DESN stations is to limit the station loading to the Summer 10 Day LTR Rating and, under normal conditions, operate individual station transformers only up to their full cooled rating. To that end WNH continually reviews loading data and trends to forecast when capacity limits will be reached and additional supply is needed.

WNH believes there is sufficient existing supply and capacity to serve load and generation customers over the 2021 - 2025 forecast period. Some localized constraints within the distribution system may occur over time and will be addressed on a case by case basis.

WNH is looking beyond 2025 to determine when additional supply may be required. This possibility has been identified in the IESO's Scoping Assessment Outcome Report (2019) as part of the second cycle of regional planning which is underway for the Kitchener-Waterloo-Cambridge-Guelph (KWCG) Region. More information on this can be found in **Appendix F - KWCG IRRP Scoping Assessment Outcome Report (2019)**.

The replacement of HMSTS "A" T1 and T2 transformers, due to condition, is also expected to be sometime after 2025. It is recommended that options in increasing the rating of the transformers and the ability to integrate that additional capacity into the distribution system, be studied.

4.3. Transformer Station Feeders (27.6 kV and 13.8 kV)

From the transmission connected transformer stations, WNH distributes electricity to its customers through its 47 feeders at distribution voltages of 13.8 kV and 27.6 kV. WNH's 13.8 kV and 27.6 kV feeder capacities are rated at 600A, the limiting factor being the rating of the station feeder cables and overhead line conductors. All of WNH's station feeder breakers are rated for 1,200 amperes and do not present a limiting factor in supplying load.

WNH uses a planning criterion of 400A (66.7%) for average feeder loading. This allows for the load of a feeder that is planned or forced out of service to be moved to a minimum of 2 adjacent feeders and remain within loading limits. The installation of automated switching as part of WNH's grid modernization investments are assisting in WNH meeting this goal.

WNH also receives approximately 7.9% of its electrical supply at < 50 kV (Dx) through feeders from 3 neighbouring LDCs; Hydro One Distribution (HONI Dx), Kitchener-Wilmot Hydro Inc. (KWHI) and Energy Plus (Energy+).

From 2016 – 2019, WNH experienced an overall station feeder utilization of approximately 40% and a maximum peak utilization of approximately 75%. Although not in an overload state, summer loads do push feeder peak utilization above WNH's 66.7% planning criteria target. Excess feeder capacity is not available in every combination of feeder contingencies. Care must be taken by WNH in terms of system configuration and planned equipment outages during these times. WNH regularly reviews feeder loading and rebalances the system when needed. When rebalancing is not possible within the existing configuration parameters, Contingency Enhancement solutions are proposed and evaluated. WNH grid modernization investments over the historic period have allowed for better utilization of feeder capacity. WNH believes there is sufficient station feeder capacity during the 2021 – 2025 forecast period.

The following tables in this section provide capacity utilizations for WNH's 47 TS feeders by delivery point.

Table 4-4: Station Feeder Utilization HMSTS"A" (2016 – 2019)

Facility	Feeder	Rating (Amps)	Average Peak (Amps)	Average Utilization (%)	Max Peak (Amps)	Peak Utilization (%)
HMSTS"A" Station	HS07	600	332	55%	513	85%
	HS08	600	186	31%	525	88%
	HS09	600	163	27%	475	79%
	HS10	600	279	47%	383	64%
	HS11	600	286	48%	577	96%
	HS12	600	286	48%	437	73%
	HS13	600	278	46%	576	96%
	HS14	600	261	44%	552	92%
Average Feeder Loading	8	600	263	44%	514	86%

Table 4-5: Station Feeder Utilization HMSTS"B" (2016 – 2019)

Facility	Feeder	Rating (Amps)	Average Peak (Amps)	Average Utilization (%)	Max Peak (Amps)	Peak Utilization (%)
HMSTS"B" Station	HS15	600	261	44%	562	94%
	HS16	600	153	25%	440	73%
	HS17	600	220	37%	465	77%
	HS18	600	101	17%	455	76%
	HS19	600	182	30%	344	57%
	HS20	600	302	50%	534	89%
	HS21	600	307	51%	537	89%
	HS22	600	316	53%	536	89%
	HS23	600	234	39%	383	64%
	HS24	600	321	53%	524	87%
	HS25	600	191	32%	491	82%
	HS26	600	261	43%	495	82%
	HS27	600	364	61%	529	88%
	HS28	600	373	62%	584	97%
	HS29	600	349	58%	561	94%
	HS30	600	226	38%	491	82%
	HS31 *	600	0	0	0	0%
	HS32 *	600	0	0	0	0%
Average Feeder Loading	18	600	260	43%	496	83%

(*) HS31 & HS32 are currently used in a back up role.

Table 4-6: Station Feeder Utilization MTS#3 (2016 – 2019)

Facility	Feeder	Rating (Amps)	Average Peak (Amps)	Average Utilization (%)	Max Peak (Amps)	Peak Utilization (%)
MTS#3	3F60	600	40	7%	69	11%
	3F61	600	234	39%	397	66%
	3F62 (3F50)	600	283	47%	513	86%
	3F63	600	233	39%	545	91%
	3F64	600	0	0%	0	0%
	3F65	600	65	11%	284	47%
	3F66	600	19	3%	126	21%
	3F67 (3F51)	600	343	57%	590	98%
	3F68	600	287	48%	457	76%
	3F69	600	0	0%	0	0%
Average Feeder Loading	10	600	150	25%	298	50%

Table 4-7: Station Feeder Utilization ERTS (2016 – 2019)

Facility	Feeder	Rating (Amps)	Average Peak (Amps)	Average Utilization (%)	Max Peak (Amps)	Peak Utilization (%)
ERTS	ER41	600	175	29%	548	91%
	ER42	600	327	55%	508	85%
	ER43	600	85	14%	428	71%
	ER44	600	311	52%	544	91%
	ER45	600	369	62%	576	96%
	ER46	600	196	33%	454	76%
	ER47	600	284	47%	537	90%
	ER48	600	202	34%	348	58%
Average Feeder Loading	8	600	244	41%	493	82%

Table 4-8 provides a summary of ELTS feeder utilization. The 33M1 and 33M3 feeders are dedicated to WNH. The 33M2 feeder is shared with HONI Dx.

Table 4-8: Station Feeder Utilization ELTS (2016 – 2019)

Facility	Feeder	Rating (Amps)	Average Peak (Amps)	Average Utilization (%)	Max Peak (Amps)	Peak Utilization (%)
ELTS	33M1	525	297	57%	488	93%
	33M2	525	272	52%	466	89%
	33M3	525	265	50%	488	93%
Average Feeder Loading	3	525	280	53%	506	96%

WNH's three, < 50 kV delivery points are listed in **Table 4-9**. These feeders are not dedicated to WNH and their capacity must be shared with the host utility. Discussions occur between WNH and the host utility whenever a change in capacity or load is anticipated. The information in **Table 4-9** which is based on current and historical loading, is subject to change over time. WNH's contingency capabilities at each of these delivery points is improving over time as System Renewal Investments rebuild the areas supplied by these feeders.

Table 4-9: Delivery Point Feeder Utilization (< 50 kV) (2016 – 2019)

Host LDC	Feeder	Feeder Voltage (kV)	Capacity Available to WNH (Amps)	Capacity Available to WNH (MVA)	Average Peak (Amps)	Average Utilization (%)	Max Peak (Amps)	Peak Utilization (%)
HONI Dx	73M7	44	105	8	30	29%	42	40%
KWHI	09M4	27.6	126	6	75	60%	113	90%
Energy +	21M25	27.6	299	14	215	72%	288	96%
Average Feeder Loading	3		177	9	107	53%	148	75%

4.4. Municipal and Distribution Station (DS) Capacity Utilization

Table 4-10, provides a listing of WNH's DS stations in service at the end of 2019. Also included in the table are the capacities and peak station demands from 2016 - 2019. WNH prepares for the loss of a significant element such as a transformer or feeder by having interconnectivity with other feeders or stations. Alternatively, WNH's mobile unit substation (MUS) can be moved into place and supply load until a repair or replacement can be made.

Over the historic period WNH's System Renewal plans have retired 6 MS/DS stations and loads at the remaining stations have decreased as more distribution lines are rebuilt at 27.6 kV. As a result of this work, interconnectivity options between DS feeders have been reduced making WNH more reliant on the use of its MUS in the case of a transformer failure.

WNH does not forecast any significant constraints or lack of capacity over the 2021 – 2025 forecast period.

Table 4-10: WNH DS Station Capacity Utilization

#	Station	Owned & Operated by	Supplied By	Location	HV (kV)	LV (kV)	Tx ID	Tx Full Cooled Rating (MVA)	2016 - 2019 Peak Demand (MW)	% Capacity Utilization
1	DS#26	WNH	WNH Dx	Wellesley	27.6	8.32	T1	5.6	2.1	38%
2	DS#27	WNH	WNH Dx	Wallenstein	27.6	8.32	T1	3.6	2.0	56%
3	DS#28	WNH	WNH Dx	Floradale	27.6	8.32	T1	5.0	2.2	44%
4	DS#29	WNH	WNH Dx	St Jacobs	27.6	8.32	T1	3.6	0.5	14%
5					27.6	8.32	T2	3.6	2.2	61%
6	DS#30	WNH	WNH Dx	Zubers Corners	44	8.32	T1	5.0	3.2	64%
7	DS#31	WNH	WNH Dx	Bloomingtondale	27.6	8.32	T1	5.0	1.3	26%
					7		Avg.	4.5	1.9	43%

4.5. Distribution Feeder (8 kV) Capacity Utilization

Table 4-11, provides a listing of WNH's DS feeders in service at the end of 2019. Included in the table are the feeder capacities, average and peak feeder loading and percent utilization from 2016 - 2019.

WNH uses a planning criterion of 200A for maximum feeder loading. This allows for the load of a feeder that is planned or forced out of service to be moved to adjacent feeders and remain within loading limits. WNH does not forecast any significant constraints or lack of capacity over the 2016 – 2020 forecast period.


Table 4-11: WNH DS Station Feeder Capacity Utilization

Facility	Feeder	Rating (Amps)	Average Peak (Amps)	Average Utilization (%)	Max Peak (Amps)	Peak Utilization (%)
DS 26	1	200	0	0%	0	0%
	2	200	107	54%	153	77%
	3	200	46	23%	148	74%
DS 27	1	200	70	35%	131	66%
	2	200	85	43%	122	61%
DS 28	1	200	93	47%	128	64%
	2	200	82	41%	150	75%
DS 29	1	200	41	21%	179	90%
	2	200	0	0%	0	0%
	3	200	114	57%	152	76%
	4	200	55	28%	147	74%
DS 30	1	200	29	15%	81	41%
	2	200	42	21%	116	58%
	3	200	22	11%	57	29%
DS 31	1	200	61	31%	99	50%
	2	200	84	42%	149	75%
	3	200	93	47%	174	87%
Average Feeder Loading	17	200	60	30%	117	58%

4.6. Distribution Transformers

WNH has approximately 7,900 pole and pad mounted distribution transformers connected to its system. WNH calculates a rolling average of 24 consecutive monthly peaks (kW) for each distribution transformer in its system. **Figure 4-1** summarizes WNH's distribution transformer population loading profile.

Figure 4-1: WNH Distribution Transformer Utilization (%)



WNH's planning limit for distribution transformer loading is for the average peak load not to exceed 125% of name plate rating. During annual reviews, transformers with average peak loads above 120% are investigated for replacement. Transformers with peak loads greater than 125% and a high capacity factor will be flagged for upgrading in size. Transformers with a peak load greater than 125% and a low capacity factor may remain in service. Each case is examined on an individual basis.


WNH forecasts sufficient capacity in its population of distribution transformers to serve the growing load, including the connection of electric vehicles, over the 2021 - 2025 forecast period. Some localized constraints may occur over time and will be addressed on a case by case basis.

Appendix K:

WNH Distribution System Reliability Report

2019

Distribution System Reliability Report



June 21, 2020

(Page Intentionally left blank)

CONTENTS

CONTENTS.....	3
LIST OF TABLES	5
LIST OF FIGURES	7
GLOSSARY	8
1. EXECUTIVE SUMMARY.....	10
1.1. Purpose of this Report.....	10
1.2. Overview	10
1.3. Description of the Utility Company.....	12
1.4. Conclusions and Recommendations	12
2. Sustained Interruptions	15
2.1. Customer Minutes of Interruption (CMI) (Overview).....	15
2.2. Customer Minutes of Interruption Saved (CMIS)	19
2.3. Major Event Days (MED).....	19
2.4. Top Contributing Interruption Events	21
3. Sustained Interruption Cause Codes.....	25
3.1. Overview	25
3.2. Cause Code 0: Unknown / Other.....	27
3.3. Cause Code 1: Scheduled Interruptions	29
3.4. Cause Code 2: Loss of Supply	31
3.4.1. Overview	31
3.4.2. HONI Transmission Circuit D10H Reliability	33
3.5. Code 3 – Tree Contacts	35
3.6. Code 4 – Lightning Contacts	37
3.7. Code 5 – Defective Equipment.....	39
3.8. Code 6 – Adverse Weather	41
3.9. Code 7 – Adverse Environment.....	43
3.10. Code 8 – Human Element	44
3.11. Code 9 – Foreign Interference.....	46
4. Operational Effectiveness – System Reliability.....	49
4.1. Reliability Targets.....	49
4.2. Reliability Performance Overview (2016 – 2019).....	49
4.3. System Average Interruption Duration Index (SAIDI).....	50
4.4. System Average Interruption Frequency Index (SAIFI).....	51
4.5. Momentary Interruptions (MAIFI).....	52
5. Impact of Grid Modernization on Reliability	54

6.	Electrical Safety Authority Serious Electrical Incidents	56
7.	2019 Worst Performing Feeders	58

LIST OF TABLES

Table 1-1: WNH Reliability Performance (2016 - 2019)	11
Table 2-1: Sustained Interruptions (2016 - 2019).....	15
Table 2-2: Customer & Event Data (2016 - 2019)	16
Table 2-3: Historical Sustained Interruptions (2016 - 2019)	17
Table 2-4: Customer Minutes of Interruption Savings	19
Table 2-5: MED 2016 - 2019.....	20
Table 2-6: Top Contributing Sustained Events 2019	21
Table 2-7: Top Contributing Sustained Events 2018	22
Table 2-8: Top Contributing Sustained Events 2017	23
Table 2-9: Top Contributing Sustained Events 2016	24
Table 3-1: Interruption Events Trending.....	25
Table 3-2: CMI Trending (2016 – 2019)	26
Table 3-3: Reliability Event Causes by Rank (2016 - 2019)	26
Table 3-4: Unknown Cause (2016 - 2019)	28
Table 3-5: Scheduled Interruptions (2016 - 2019).....	30
Table 3-6: WNH Loss of Supply	31
Table 3-7: WNH Loss of Supply/ MED	32
Table 3-8: WNH Loss of Supply by Delivery Point	32
Table 3-9: WNH Tree Contacts (2016-2019)	35
Table 3-10: WNH Tree Contacts and MEDs (2016-2019)	36
Table 3-11: Lightning Events (2016-2019)	38
Table 3-12: WNH Lightning Events and MEDs (2016-2019)	38
Table 3-13: Defective Equipment (2016-2019).....	40
Table 3-14: Defective Equipment and MEDs (2016-2019)	40
Table 3-15: Adverse Weather (2016-2019).....	42
Table 3-16: Adverse Weather and MEDs (2016-2019)	42
Table 3-17: Adverse Environment (2016-2019)	43
Table 3-18: Human Element (2016-2019).....	45
Table 3-19: Foreign Interference (2016-2019)	47
Table 3-20: Foreign Interference and MEDs (2016-2019).....	47
Table 3-21: Foreign Interference by Subcause (2016-2019)	48

Table 4-1: WNH Reliability Performance 2011-2015.....	49
Table 4-2: WNH Historical CMI, SAIDI, SAIFI, MAIFI (All Inclusive).....	49
Table 4-3: WNH Historical CMI, SAIDI, SAIFI, MAIFI (Excluding LOS & MED).....	50
Table 4-4: Momentary Interruption Events (2016 – 2019)	52
Table 6-1: Serious Incidents 2015 – 2019.....	56
Table 7-1: Worst Performing Feeders (2019).....	58
Table 7-2: Worst Performing Feeder Action Plans (2019).....	59
Table 7-3a: WNH Feeder Performance Excluding Planned & Major Event Days	60
Table 7-3b: WNH Feeder Performance Excluding Planned & Major Event Days	61

LIST OF FIGURES

Figure 1-1: WNH Service Territory	14
Figure 2-1: CMI Trending (2016 – 2019).....	15
Figure 2-2: CMI / Customer Trending (2016 – 2019).....	16
Figure 2-3: Interruption Events Trending (2016 – 2019).....	17
Figure 3-1: Unknown / Other Cause Trending	27
Figure 3-2: Scheduled Interruptions Cause Trending.....	29
Figure 3-3: Scheduled Interruptions (2019).....	30
Figure 3-4: WNH Loss of Supply/ MED.....	32
Figure 3-5: Tree Contact Trending	35
Figure 3-6: Lightning Events Cause Trending	37
Figure 3-7: Defective Equipment (2016 – 2019).....	39
Figure 3-8: Adverse Weather (2016 – 2019).....	41
Figure 3-9: Adverse Environment (2016-2019)	43
Figure 3-10: Human Element (2016 – 2019).....	44
Figure 3-11: Foreign Interference (2016 – 2019)	46
Figure 3-12: Foreign Interference Causes (2016 – 2019)	48
Figure 4-1: SAIDI (2016 – 2019).....	51
Figure 4-2: SAIFI (2016 – 2019)	52
Figure 4-3: MAIFI (2016-2019)	53
Figure 6-1: Serious Incidents	56

GLOSSARY

- 1) ACA – Asset Condition Assessment
- 2) AM – Asset Management
- 3) AMP – Asset Management Plan
- 4) CAIDI – Customer Average Interruption Duration Index
- 5) CC – Cause Codes
- 6) CEA – Canadian Electrical Association
- 7) CI – Customers Interrupted
- 8) CHI – Customer Hours Interrupted
- 9) CMI – Customer Minutes of Interruption
- 10) CMIS – Customer Minutes of Interruption Saved
- 11) CSA – Canadian Standard Association
- 12) DS – Distribution Station
- 13) DSC – Distribution System Code
- 14) DSP – Distribution System Plan
- 15) EOL – End-of-Life
- 16) ESA – Electrical Safety Authority
- 17) FLISR – Fault Location, Isolation and Service Restoration
- 18) GIS – Geographic Information System
- 19) GM – Grid Modernization
- 20) HONI – Hydro One Networks Inc.
- 21) IESO – Independent Electricity System Operator
- 22) KPI – Key Performance Indicator
- 23) KWCG – Kitchener – Waterloo – Cambridge – Guelph
- 24) KWHI – Kitchener-Wilmot Hydro Inc.

- 25) LDC – Local Distribution Company
- 26) LOS – Loss of Supply
- 27) LRT – Light Rail Transit
- 28) LTLT – Long Time Load Transfer customer
- 29) MAIFI – Momentary Average Interruption Frequency Index
- 30) MED – Major Event Day
- 31) MS – Municipal Station
- 32) MVA Motor Vehicle Accident
- 33) O/H or OH - Overhead
- 34) O&M – Operation & Maintenance
- 35) OEB – Ontario Energy Board
- 36) OMS – Outage Management System
- 37) REG – Renewable Energy Generation
- 38) RRFE – Renewed Regulatory Framework for Electricity Distributors
- 39) SAIDI – System Average Interruption Duration Index
- 40) SAIFI – System Average Interruption Frequency Index
- 41) SCADA – Supervisory Control and Data Acquisition
- 42) SEI – Serious Electrical Incidents
- 43) TUL – Typical Useful Life
- 44) TS – Transmission Station or Transformer Station
- 45) U/G or UG – Underground
- 46) WNHI / WNH – Waterloo North Hydro Inc.
- 47) WPF - Worst Performing Feeder
- 48) XFMR / Tx – Transformer

1. EXECUTIVE SUMMARY

1.1. Purpose of this Report

Good reliability performance is consistently at or near the top of WNH's customers' stated preferences. It is one of WNH's top two Strategic Imperatives and Asset Management Objectives. Good reliability also helps support the achievement of the OEB's key performance outcome of Operational Effectiveness as established in the Renewed Regulatory Framework for Electricity (RRFE).

Waterloo North Hydro's "Distribution System Reliability Report" provides a consolidated view of WNH's reliability performance over the period covering 2016 – 2019 inclusive. This report provides historical data and trends in reliability performance. The performance of all WNH feeders are reviewed annually and the worst performing feeders, based on three year rolling CMI averages, are identified and flagged for action. Reliability issues, including leading causes, are identified and recommendations for action are provided.

The information in this report informs WNH's senior executive team (Executive) and aides in the development of WNH's business plans, budgets and Distribution System Plan (DSP). This report also informs the system reliability portion of the OEB's RRR filing and has been prepared to support WNH's 2021 Cost of Service Application (Application).

All information contained in this report is current as of December 31, 2019.

1.2. Overview

Table 1-1 provides a summary of WNH's reliability performance from 2016 and 2019 inclusive. WNH's most recent OEB reliability targets of SAIDI (0.62) and SAIFI (1.16) were set in 2016 and based on WNH's 2011- 2015 reliability performance. WNH's 2019 reliability performance for SAIDI (0.85) and for SAIFI (1.29) were an improvement over 2018; however, WNH did not meet the OEB's reliability targets.

Table 1-1: WNH Reliability Performance (2016 - 2019)

Measures	2016	2017	2018	2019
Events	811	739	786	791
Customers Interrupted	166,343	91,189	106,501	105,869
CMI (Total)	9,580,465	2,930,075	7,156,980	3,891,102
CMIS	1,619,153	1,225,090	2,006,050	1,707,082
CMI (excluding LOS & MED) (OEB)	2,370,254	2,584,671	3,151,181	2,936,432
SAIDI + CMIS	3.35	1.22	2.67	1.61
SAIDI All	2.87	0.86	2.09	1.13
SAIDI (excluding LOS & MED) (OEB)	0.71	0.76	0.92	0.85
SAIFI + CFIS			2.10	1.98
SAIFI All	2.99	1.61	1.86	1.84
SAIFI (excluding LOS & MED) (OEB)	1.15	1.50	1.32	1.29
MAIFI All	8.16	4.02	4.79	3.19
MAIFI (excluding LOS & MED)	5.34	3.98	3.94	2.97

Notwithstanding, WNH made a number of positive achievements in reliability;

- WNH experienced a pronounced downward trend in total CMI and MED minutes. A slight downward trend in LOS minutes can also be observed;
- Total number of sustained interruption events have remained relatively consistent since 2016. While scheduled interruptions for capital and O&M work have been increasing since 2017, unplanned interruptions have continued a downward trend;
- An estimated 1.7 million CMIS resulted in 2019 due to grid modernization technologies; a 30% reduction in total interruption minutes. This translates to a 0.49 reduction in overall SAIDI when the CMIS is applied across the entire customer base; however, CMIS also represents a 0.72 reduction in SAIDI to the approximately 66% of WNH's customers which are connected to feeders where the technologies have been implemented;
- Fewer events are being categorized as unknown;
- Loss of Supply minutes continued to improve;
- MAIFI performance has improved significantly since 2016;

Points of note include;

- Although down slightly in 2019, CMI excluding LOS and MED has been on an upward trend since 2016.
- The most significant interruption event in 2019 was a 2-day event that began on July 20th when extreme wind (>90km/h) and heavy rain caused tree limbs to fall throughout WNH's territory. CMI totaled 798,799 and accounted for 20.5% of the 2019 total CMI. Both days were classified as Major Event Days (MED) by OEB definition. More detail is available within this report.
- Of the 791 sustained interruption events in 2019, 452 (57%) were due to scheduled interruptions representing 15.6% of total CMI. This has been relatively consistent since 2016.
- In 2019, Adverse Weather ranked 1st, (25.6%) in sustained interruption causes and since 2016 has contributed 7,287,685 or 30% of WNH's total CMI, ranking it 1st overall.

1.3. Description of the Utility Company

A current map of WNH's Service Area is provided in **Figure 1-1**. Please refer to WNH's Distribution System Plan, **Section 1.38** for a complete description of the utility.


1.4. Conclusions and Recommendations

In spite of not meeting OEB reliability targets as previously mentioned, analysis of the 2016 – 2019 reliability data indicates that the incremental grid modernization investments WNH has made are positively impacting customer reliability. Given that WNH's customers have placed a high value on the reliability of their electrical supply, it would be prudent for WNH to continue to explore cost effective investments in this area.

Approximately one-third of WNH's customer base does not yet fully benefit from the reliability improvements made by WNH's grid modernization investments. Opportunities for improvement exist with further rollout of these technologies.

WNH's distribution system will evolve over time with development, changing load and generation. Even where grid modernization technologies have been implemented, regular re-examination of feeder performance will identify further opportunities for improvement.

Figure 1-1: WNH Service Territory



2. Sustained Interruptions


2.1. Customer Minutes of Interruption (CMI) (Overview)

Table 2-1 provides a breakdown of WNH's sustained interruption data, over the historical period. Illustrated further in **Figure 2-1**, WNH experienced a pronounced down trend in total CMI and MED. A slight downward trend in LOS minutes can also be observed.

Table 2-1: Sustained Interruptions (2016 - 2019)

Year	Total CMI (All Inclusive)	Total LOS Minutes	Total LOS Minutes (not MED)	Total MED Minutes	Total Customer Minutes of Interruptions (CMI - LOS - MED)
2016	9,580,465	887,578	94,969	7,115,242	2,370,254
2017	2,930,075	11,136	11,136	334,268	2,584,671
2018	7,156,980	866,247	22,054	3,983,745	3,151,181
2019	3,891,102	161,848	155,871	798,799	2,936,432
Total	23,558,622	1,926,809	284,030	12,232,054	11,042,538
Average	5,889,656	481,702	71,008	3,058,014	2,760,635

Figure 2-1: CMI Trending (2016 – 2019)



The downward trend in CMI is attributed to an overall downward trend in unscheduled events including MED events, improved LOS minutes and WNH's adaptation of Grid Modernization. More detailed information is provided in **Section 2.2**, **Section 4.4** respectively.


Table 2-2 provides a breakdown of CMI on a customer and event basis. The annual average customer count is calculated consistent with the OEB's RRR filing requirements. Values for customer count are calculated differently for OEB reliability purposes and may differ slightly from values presented elsewhere in the DSP.

Consistent with the data in **Table 2-1**, both CMI per customer and event ratios improved over the forecast period.

Table 2-2: Customer & Event Data (2016 - 2019)

Year	Average # of Customers (OEB RRR)	# Events	Customer Minutes of Interruption (CMI) all inclusive	CMI / Customer	CMI / Event
2016	55,703	811	9,580,465	172	11,813
2017	56,578	739	2,930,075	52	3,965
2018	57,196	786	7,156,980	125	9,106
2019	57,584	791	3,891,102	68	4,919
Total		3,127	23,558,622		29,803
Average (2016-2019)	56,765	782	5,889,656	104	7,534

Figure 2-2: CMI / Customer Trending (2016 – 2019)




The number of sustained events remained consistent over the historic period. **Table 2-3** provides a breakdown of scheduled and unscheduled events over that historic period. **Figure 2-3** illustrates that unscheduled events exhibited a slight downward trend, whereas scheduled events to facilitate Capital and O&M programs have shown an increase over the historic period. Scheduled interruptions were slightly higher than normal in 2016 due to the LRT work. Scheduled interruptions in 2019, and to a lesser extent in 2018, were elevated due to increased amounts of switching required for the capital program, specifically the 4 kV underground rebuild program in Elmira. Switching interruptions tend to be of relatively short duration and did not have a significant impact on total CMI. As this program ended in 2019, scheduled interruptions are expected to decrease to levels experienced in 2017.

Table 2-3: Historical Sustained Interruptions (2016 - 2019)

Year	Scheduled	Unscheduled	Total	% Scheduled
2016	422	389	811	52%
2017	368	371	739	50%
2018	403	383	786	51%
2019	452	339	791	57%
Total	1,645	1,482	3,127	
Average	411	371	782	53%

Figure 2-3: Interruption Events Trending (2016 – 2019)



More detailed information is provided in **Section 4** of this report.

Although it can be seen from **Figure 2-1** that the historic period experienced a downward trend in loss of supply and MED minutes, the adjusted CMI, excluding LOS and MED experienced an increasing trend. WNH expects that both trends are due to the effects of grid modernization investments that are helping reduce customer interruption minutes.

Analysis of the results suggests the following;

- a) WNH implemented a number of grid modernization technologies over the historical period. Survalent's Fault Location, Isolation, and Service Restoration (FLISR) software application that combines with SCADA, OMS, and automated switching devices that reroute power in the event of a fault to restore power to as many customers as possible, as quickly as possible. These technologies provide automatic self-healing on the portions of the system unaffected by the fault, ultimately improving restoration times. Since 2016, in areas where these technologies have been implemented, WNH customers have saved approximately 6.6 million customer minutes of interruption, averaging 1.64 million customer minutes saved annually. In 2019 WNH estimates 1.7 million customer minutes were saved; a 30% reduction in interruption minutes. More detailed information is provided in **Section 2.2**.
- b) WNH's outage management system (OMS) went into service in 2015. This technology has improved the accuracy of recording both CI and CMI over the historical period. WNH suspects that this has also worsened its baseline reliability performance measures by capturing more data.
- c) The implementation of grid modernization technology by WNH has saved approximately 1.64 million customer interruption minutes annually. This has also had the effect in some interruption events to reduce the CMI below the major event day (MED) threshold. Where in the past, the entire CMI for such an event would have fallen under a MED event and not contributed to the overall performance record, dropping below the MED threshold results in a step increase in customer interruption minutes that are added to the performance record. WNH suspects that this has also worsened its baseline reliability performance measures.
- d) WNH has made a conscious decision to increase the number of line safety patrols prior to restoring power during an unplanned interruption. This was as a result of safety concerns where incidents of foreign interference or damaged equipment created situations where the public could have come in contact with energized conductors. The patrols increase public

safety; however, they also result in longer interruption durations. This change in operating practice has also worsened WNH's baseline reliability performance measures.

2.2. Customer Minutes of Interruption Saved (CMIS)

Since 2016, WNH began to realize significant benefits from Grid Modernization investments such as reclosers, OMS, and FLISR. In an effort to quantify these benefits, WNH began to use the new reliability measure of Customer Minutes of Interruption Saved (CMIS). CMIS is calculated by taking the difference between the CMI calculated for an event by the OMS, and an estimate based on what the CMI would have been without the grid modernization technologies in service. This calculation is performed on a case by case basis.

Table 2-4 illustrates the estimated savings in CMI and SAIDI.

Table 2-4: Customer Minutes of Interruption Savings

Year	Total CMI (All Inclusive)	CMIS	CMI without Grid Modernization Technologies	% Savings	SAIDI Savings
2016	9,580,465	1,619,153	11,199,618	14%	0.48
2017	2,930,075	1,225,090	4,155,165	29%	0.36
2018	7,156,980	2,006,050	9,163,030	22%	0.58
2019	3,891,102	1,707,082	5,598,184	30%	0.49
Total	23,558,622	6,557,375	30,115,997	22%	1.92
Average	5,889,656	1,639,344	7,528,999	22%	0.48

2.3. Major Event Days (MED)

Table 2-5 illustrates a summary of WNH's Major Event Days (MED's) from 2016 - 2019. The majority of MEDs are driven by adverse weather conditions of ice and extreme wind.

Table 2-5: MED 2016 - 2019

Day of Year	Customer Minutes of Sustained Interruptions Today	Customers Affected by Sustained Interruptions Today	Number of Events	Total Customers Served	SAIDI	MED Descriptoin
2.58 T(MED) for 2016 is 0.0674 SAIDI/day						
2016-03-24	4,604,875	34,868	47	55,509	1.38	ADVERSE WEATHER
2016-03-25	1,140,722	41,653	15	55,509	0.34	ADVERSE WEATHER
2016-03-26	694,357	13,160	5	55,509	0.21	LOSS OF SUPPLY
2016-07-25	249,453	4,092	15	55,707	0.07	LIGHTNING
2016-08-19	425,835	3,966	6	55,782	0.13	LIGHTNING
	7,115,242	97,739	88	MED	2.14	
	9,580,465			All Incl	2.87	
	2,465,223			Excl MED	0.73	
2.58 T(MED) for 2017 is 0.0709 SAIDI/day						
2017-03-30	334,268	4,788	5	56,351	0.10	TREE CONTACT
	334,268	4,788	5	MED	0.10	
	2,930,075			All Incl	0.86	
	2,595,807			Excl MED	0.76	
2.58 T(MED) for 2018 is 0.0695 SAIDI/day						
2018-04-15	631,713	8,711	3	57,052	0.18	ADVERSE WEATHER - FREEZING RAIN
2018-05-04	3,352,032	16,623	15	57,065	0.98	ADVERSE WEATHER - EXTREME WIND
	3,983,745	25,334	18	MED	1.16	
	7,156,980			All Incl	2.09	
	3,173,235			Excl MED	0.93	
2.58 T(MED) for 2019 is 0.0643 SAIDI/day						
2019-07-20	383,414	6,260	9	57,569	0.11	ADVERSE WEATHER - EXTREME WIND
2019-07-21	415,385	4,738	6	57,569	0.12	ADVERSE WEATHER - EXTREME WIND
	798,799	10,998	15	MED	0.23	
	3,891,102			All Incl	1.13	
	3,092,303			Excl MED	0.90	

2.4. Top Contributing Interruption Events

WNNH reviews the top interruption events each year in order to understand their nature and cause.

Table 2-6: Top Contributing Sustained Events 2019

ID	Event Date	2.5B MED	Feeder Impact	Cause	CMI	SAIDI	Comments
57910	2019-07-21	Yes	HS14	Adverse Weather - Extreme Winds	408,680	0.118	During Extreme Winds (>90km/h) a broken tree branch damaged a 3 phase switch and overhead primary conductors at 340 University Avenue East, Waterloo.
57894	2019-07-20	Yes	HS14	Adverse Weather - Extreme Winds	358,025	0.104	During Extreme Winds (>90km/h) a tree branch broke and contacted primary overhead conductor at Ellis Crescent and Lincoln Road, Waterloo.
58031	2019-08-20	No	HS22	Lightning	223,692	0.065	An electronic vacuum recloser device was struck by lightning during a severe storm on Bluevale Street North, Waterloo.
58011	2019-08-17	No	HS11	Human Element - Protection Setting	179,411	0.052	Y Bus lockout at Howard Scheifele Station A due to lightning strike at a load break on the HS-11 feeder.
58540	2019-12-08	No	HS22	Equipment Failure- Defective Equipment/Material	153,972	0.045	A flashover between two overhead circuits caused a feeder lockout near Scheifele Transformer Station. FLISR operation was performed which partially sectionalized the feeder and restored the South end of HS-22.
57125	2019-02-15	No	3F68	Tree Contacts- Broken branch	144,518	0.042	Broken tree branch shorting out a primary insulator, caused pole fire on Kressler, Wellesley, resulted in the hanging primary coming in contact with the neutral conductor.
58350	2019-10-31	No	3F50	Adverse Weather - Extreme Winds	128,081	0.037	During Extreme Winds (>90km/h), 3F50 and an adjacent circuit tripped open. The cause was found to be a broken tree branch contacting a primary overhead conductor on Lonelm Court, Waterloo.
57790	2019-07-03	No	HS-26	Foreign Inference- Wildlife	114,644	0.033	Feeder lockout on HS-26 as a result of a bird contact with 3 phase switch on University Avenue East, Waterloo.
58584	2019-12-18	No	ER46	Equipment Failure- Corrosion	112,710	0.033	An electronic vacuum recloser locked out on Roslin Avenue South in Waterloo due to internal corrosion.
57968	2019-08-03	No	ER46	Foreign inference- Wildlife	109,760	0.032	Animal contact across a load break switch that ties two feeders.

Table 2-7: Top Contributing Sustained Events 2018

ID	Event Date	2.5ß MED	Feeder Impact	Cause	CMI	Comments
55874	2018-05-04	Yes	3F68	Tree Contact	1,448,932	Fallen trees from high winds throughout Wellesley Township caused multiple primary lines down and broken poles.
55890	2018-05-04	Yes	73M7	Loss of Supply	426,196	Loss of Supply from 73M7. HONI reports high winds and falling trees.
55888	2018-05-04	Yes	HS11	Tree Contact	421,926	Fallen tree on Woolwich St required Supporting Guarantee from Kitchener Wilmot Hydro before tree could be removed.
55765	2018-04-15	Yes	D10H	Loss of Supply	417,997	Loss of supply on D10H, HONI reports shield-wire failed east of Kressler Rd, Wellesley caused by ice buildup.
55891	2018-05-04	Yes	21M25	Tree Contact	372,718	Fallen tree on Shantz Station Rd. Energy+ was unable to support restoration in Breslau.
55873	2018-05-04	Yes	ER44	Tree Contact	302,562	Tree fell breaking pole on Erb St, Waterloo.
55999	2018-05-26	No	HS22	Foreign Interference	229,748	Wildlife caused the breaker to open. Full patrol was completed before a manual close attempt on the breaker.
55767	2018-04-15	Yes	3F68	Adverse Weather - Freezing Rain	213,598	Tree contacted O/H primary lines on Maplewood Rd., Wellesley. Ice buildup caused limbs to hang into O/H primary conductor.
56380	2018-08-05	No	HS21	Foreign Interference- Wildlife	213,467	Squirrel found during feeder patrol after lockout on HS23 & HS21. Caused damage to LB requiring repair at later date. Full patrol was completed before a manual close attempt on the breaker.
56159	2018-06-24	No	ER44	Defective Equipment	196,000	Broken switch found at transformer during feeder patrol after failed close attempt on EVR-14-4896.

Table 2-8: Top Contributing Sustained Events 2017

ID	Event Date	2.5ß MED	Feeder Impact	Cause	CMI	Comments
54119	2017-03-30	Yes	3F61	Tree Contact	306,103	Tree on primary on Wilmot Line, Waterloo due to freezing rain. Part of a Major Event Day.
54000	2017-03-07	No	HS20	Defective Equipment	164,722	Circuit Breaker Failure - HS20 breaker did not operate. HSTS J Bus Backup operated causing interruptions on 4 feeders.
55044	2017-10-15	No	3F61	Foreign Interference	149,583	During a wind storm a customer reported tree arcing and on fire on Wilmot Line, Waterloo. Mid Feeder EVR on 3F61 was opened to isolate for public safety.
54170	2017-04-14	No	HS22	Foreign Interference	105,554	MVA caused broken pole. Margaret Avenue South x Erb St E, Waterloo.
54013	2017-03-08	No	HS19	Defective Equipment	87,622	WNH pole failed at base due to ant infestation and fell in to tree causing arcing/fire in tree. King St N x Bathurst Dr.
54132	2017-04-03	No	3F61	Tree Contact	85,895	Planned tree clearing on Wilmot Line, Waterloo after March 30 interruption resulted in a tree related incident and another feeder interruption.
53967	2017-02-24	No	HS22	Defective Equipment	82,319	Broken switch at Loc 12287 on Dearborn Place, Waterloo.

Table 2-9: Top Contributing Sustained Events 2016

ID	Event Date	2.5B MED	Feeder Impact	Cause	CMI	Comments
90 SC's	2016-03-24	Yes	32 Feeders	Adverse Weather	6,440,155	Severe Ice Storm. 4-day event, March 24 - March 27.
7 SC's	2016-08-19	Yes	4 Feeders	Lightning	425,835	Severe lightning storm. Catastrophic damage to N.O. tie EVS-27-3512 (tripping HS26 and HS19)
17 SC's	2016-07-25	Yes	13 Feeders	Lightning	249,453	Severe lightning storm.
52805	2016-06-15	No	HS15	Human Element	148,904	Pole fire caused by improper cover up on WNH construction project. Woolwich Street in Waterloo.
53440	2016-10-10	No	HS24	Unknown	133,405	WNH patrol after feeder trip. No cause found. Closed and held.
53306	2016-09-14	No	HS20	Foreign Interference	106,460	WNH feeder patrol after feeder trip. Squirrel found.
52940	2016-07-09	No	3F63	Defective Equipment	105,055	Failed porcelain switch caused pole fire. Hawkesville Road, Woolwich Township.
52757	2016-06-04	No	ER44	Foreign Interference	100,266	Squirrel caused EVR-14-4896 to trip open. EVR controller misoperated and was repaired.

3. Sustained Interruption Cause Codes

3.1. Overview

The CEA Service Continuity Reporting System defines customer interruptions in terms of their primary cause. The CEA has standardized on ten categories of primary causes by which utilities can collect, report and analyze their interruption data. These causes codes are defined and detailed in the following sections.

Table 3-1 provides data on WNH's average customer interruptions by cause code and ranking from 2016 - 2019. WNH logs and tracks sustained interruption events data by cause code. Each event is logged with geographic coordinates in order to perform spatial analysis and gain additional insights from the data.

Table 3-1: Interruption Events Trending

	Interruption	2016	2017	2018	2019	TOTAL	AVG	%
	Cause Code	Events	Events	Events	Events	2016-2019	2016-2019	2016-2019
0	Unknown/Other	27	19	20	20	86	22	2.8%
1	Scheduled Interruption	422	368	403	452	1,645	411	52.6%
2	Loss of Supply	10	5	6	12	33	8	1.1%
3	Tree Contacts	19	19	28	11	77	19	2.5%
4	Lightning	30	11	8	12	61	15	2.0%
5	Defective Equipment	97	111	132	107	447	112	14.3%
6	Adverse Weather	69	27	20	25	141	35	4.5%
7	Adverse Environment	3	1	2	-	6	2	0.2%
8	Human Element	9	5	6	9	29	7	0.9%
9	Foreign Interference	125	173	161	143	602	151	19.3%
Total		811	739	786	791	3,127	782	100.0%
AVG		81	74	79	79	313	78	10.0%

Since WNH last filed its DSP, some of the leading negative drivers of system reliability have changed in their relative impact. Those of significance are:

- Adverse Weather has increased from 19% to 30%
- Loss of Supply has decreased from 39% to 8.2%
- Foreign Interference has increased from 9% to 16.6%
- Defective Equipment has decreased from 20% to 9.3%

- Scheduled Interruptions for capital & maintenance work decreased slightly from 13% to 11.1%

Table 3-2: CMI Trending (2016 – 2019)

	Interruption	2016	2017	2018	2019	TOTAL	AVG	%
	Cause Code	CMI	CMI	CMI	CMI	2016-2019	2016-2019	2016-2019
0	Unknown/Other	299,768	83,912	363,938	30,183	777,801	194,450	3.3%
1	Scheduled Interruption	677,430	612,599	714,075	605,952	2,610,056	652,514	11.1%
2	Loss of Supply	887,578	11,136	866,247	161,848	1,926,809	481,702	8.2%
3	Tree Contacts	46,713	473,567	2,843,234	240,397	3,603,911	900,978	15.3%
4	Lightning	678,066	13,540	44,907	323,456	1,059,969	264,992	4.5%
5	Defective Equipment	266,817	535,964	803,865	576,266	2,182,912	545,728	9.3%
6	Adverse Weather	5,578,173	116,104	388,697	994,459	7,077,433	1,769,358	30.0%
7	Adverse Environment	54,778	26	4,969	-	59,773	14,943	0.3%
8	Human Element	168,725	3,016	4,607	185,340	361,688	90,422	1.5%
9	Foreign Interference	922,417	1,080,211	1,122,441	773,201	3,898,270	974,568	16.5%
	Total	9,580,465	2,930,075	7,156,980	3,891,102	23,558,622	5,889,655	100.0%
	Avg.	958,047	293,008	715,698	389,110	2,355,862	588,966	10.0%


Table 3-3: Reliability Event Causes by Rank (2016 - 2019)

	Interruption	2016	2017	2018	2019	TOTAL	AVG	%
	Cause Code	CMI	CMI	CMI	CMI	2016-2019	2016-2019	2016-2019
6	Adverse Weather	5,578,173	116,104	388,697	994,459	7,077,433	1,769,358	30.0%
9	Foreign Interference	922,417	1,080,211	1,122,441	773,201	3,898,270	974,568	16.5%
3	Tree Contacts	46,713	473,567	2,843,234	240,397	3,603,911	900,978	15.3%
1	Scheduled Interruption	677,430	612,599	714,075	605,952	2,610,056	652,514	11.1%
5	Defective Equipment	266,817	535,964	803,865	576,266	2,182,912	545,728	9.3%
2	Loss of Supply	887,578	11,136	866,247	161,848	1,926,809	481,702	8.2%
4	Lightning	678,066	13,540	44,907	323,456	1,059,969	264,992	4.5%
0	Unknown/Other	299,768	83,912	363,938	30,183	777,801	194,450	3.3%
8	Human Element	168,725	3,016	4,607	185,340	361,688	90,422	1.5%
7	Adverse Environment	54,778	26	4,969	-	59,773	14,943	0.3%
	Total	9,580,465	2,930,075	7,156,980	3,891,102	23,558,622	5,889,655	100.0%
	Avg.	958,047	293,008	715,698	389,110	2,355,862	588,966	10.0%

The following sections provide greater detail on sustained interruptions by cause code.

3.2. Cause Code 0: Unknown / Other

Figure 3-1: Unknown / Other Cause Trending



Cause Code 0: Unknown / Other - are customer interruptions with no apparent cause that contributed to the outage. **Figure 3-1** illustrates the trend in CMI for all interruptions logged with an unknown cause.


WNI continues to work at determining a cause for all sustained interruptions and reducing the percentage of unknown interruptions. In 2019 Unknown ranked 9th (0.8%) of the 10 causes for sustained interruptions. WNI suspects that most interruptions of unknown origin are caused by Foreign Interference, namely wildlife; however, it is not always possible to find evidence to allow for this categorization. Unless an animal carcass is found at or downstream of the protective device, the interruption is logged as an unknown cause. Increased patrolling of lines during sustained interruptions has helped find more interruption causes, keeping the number that would have been coded to Unknown low.

Table 3-4: Unknown Cause (2016 - 2019)

Year	Total CMI (All Inclusive)	Non MED CMI	MED	Total CC "0" CMI	% CMI	Total Events	CC "0" Events	% Events
2016	9,580,465	299,744	24	299,768	3.1%	811	27	3.3%
2017	2,930,075	57,212	26,700	83,912	2.9%	739	19	2.6%
2018	7,156,980	363,719	219	363,938	5.1%	786	20	2.5%
2019	3,891,102	30,183	0	30,183	0.8%	791	20	2.5%
Total	23,558,622	750,858	26,943	777,801		3,127	86	
Avg.	5,889,656	187,715	8,981	194,450	3.3%	782	22	2.8%

3.3. Cause Code 1: Scheduled Interruptions

Figure 3-2: Scheduled Interruptions Cause Trending



Cause Code 1: Scheduled Outage – are customer interruptions due to the disconnection at a selected time for the purpose of construction or preventive maintenance.

Scheduled interruptions are required to perform capital and O&M work. Customers are notified in advance of the interruption to make them aware of the extent of the interruption and make appropriate arrangements. Scheduled interruptions normally rank 3rd or 4th in causes of sustained interruptions.


Table 3-5 illustrates that scheduled interruptions were slightly higher than normal in 2016 due to the LRT work. Even though scheduled events were up in 2019, scheduled CMI was the lowest over the historical period. Switching interruptions tend to be of relatively short duration and did not have a significant impact on total CMI.

Table 3-5: Scheduled Interruptions (2016 - 2019)

Year	Total CMI (All Inclusive)	NON MED	MED	CC "1" CMI	% CMI	Total Events	CC "1" Events	% Events
2016	9,580,465	672,785	4,645	677,430	7.1%	811	422	52.0%
2017	2,930,075	611,633	966	612,599	20.9%	739	368	49.8%
2018	7,156,980	713,599	476	714,075	10.0%	786	403	51.3%
2019	3,891,102	605,082	870	605,952	15.6%	791	452	57.1%
Total	23,558,622	2,603,099	6,957	2,610,056		3,127	1,645	
Avg.	5,889,656	650,775	1,739	652,514	11.1%	782	411	52.6%

Scheduled interruptions in 2019, and to a lesser extent in 2018, were elevated due to increased amounts of switching required for the capital program. WNH's 2018 and 2019 capital construction work contained a significant amount of 4 kV and 8 kV renewal projects. The majority of the interruption locations shown in **Figure 3-3** coincide directly with the planned construction areas.

Figure 3-3: Scheduled Interruptions (2019)



3.4. Cause Code 2: Loss of Supply

3.4.1. Overview

Cause Code 2: Loss of Supply – are customer interruptions due to problems associated with assets owned and/or operated by another party, and/or in the bulk electricity supply system. For this purpose, the bulk electricity supply system is distinguished from the distributor's system based on ownership demarcation.

In 2019, loss of Supply CMI ranked 8th in causes for sustained interruptions, down from an average ranking of 4th during the 2016 – 2018 time frame.

HONI's 230 kV transmission lines, D6V and D7V, provide approximately 67% of WNH's total electrical supply. No 230 kV LOS events occurred between 2016 and 2019.

HONI's 115 kV transmission lines, D10H and D8S provide approximately 29% of WNH's total electrical supply with the D10H being the single largest contributor of LOS minutes to WNH customers over the last four years. The repeated reliability issues that have occurred with these lines are discussed in detail further in this section.

HONI's 44 kV supply has been the second largest contributor of LOS minutes to WNH over the historical period mainly due to a single MED event in 2018. The loss of the 44 kV, 73M7 radial circuit from Fergus TS on May 4, 2018 was due to extreme winds (>90km/hr) and falling trees.

In 2019, the most impactful LOS interruption was on June 29th, when the HONI Elmira Transformer Station, Bus "B" isolated under fault conditions. This affected 4,979 customers for 11 minutes contributing 54,769 CMI. HONI reported the suspected cause to be an animal contact in the station.

Table 3-6: WNH Loss of Supply

Year	Total CMI (All Inclusive)	Cause Code "2" Total LOS CMI	LOS as a % of Total CMI	Total Events	LOS Total Events	% Events
2016	9,580,465	887,578	9%	811	10	1.2%
2017	2,930,075	11,136	0%	739	5	0.7%
2018	7,156,980	866,247	12%	786	6	0.8%
2019	3,891,102	161,848	4%	791	12	1.5%
Total	23,558,622	1,926,809		3,127	33	
Average	5,889,656	481,702	8%	782	8	1.1%

Table 3-7: WNH Loss of Supply/ MED

Year	Excl. MED	MED Only	Cause Code "2" Total LOS CMI	% MED
2016	94,969	792,609	887,578	89%
2017	11,136	0	11,136	0%
2018	22,054	844,193	866,247	97%
2019	155,871	5,977	161,848	4%
Total	284,030	1,642,779	1,926,809	
Average	71,008	410,695	481,702	85%

Figure 3-4: WNH Loss of Supply/ MED




Table 3-8: WNH Loss of Supply by Delivery Point

Year	HONI – 230 kV	HONI 115 kV	HONI Dx 44 kV	HONI Dx 27.6 kV	HONI Dx 8.32 kV (LTLT)	KWH Dx 27.6 kV	Energy+ Dx 27.6 kV	Total Loss of Supply
2016	-	688,762	6,670	-	73,496	104,938	13,712	887,578
2017	-	-	1,260	-	5,652	-	4,224	11,136
2018	-	417,997	432,235	-	-	7,270	8,745	866,247
2019	-	-	2,694	81,734	-	6,608	70,812	161,848
Total	-	1,106,759	442,859	81,734	79,148	118,816	97,493	1,926,809
Avg.	-	276,690	110,715	20,434	19,787	29,704	24,373	481,702
	0%	57%	23%	4%	4%	6%	5%	100%

3.4.2. HONI Transmission Circuit D10H Reliability

The D10H circuit feeding the Elmira Transformer Station (ELTS) is a 115 kV transmission circuit that connects Detweiler TS and Hanover TS. All of these assets are owned and operated by Hydro One Networks Inc. (HONI). Approximately 80% of the ELTS load supplies WNH customers.

Since 2013, there have been five unplanned interruptions on the D10H circuit impacting the ELTS and WNH customers. Three of these interruptions were caused by shield-wire failures between the Waterloo and Wallenstein Junction. The remaining two interruptions were attributed to a loose cross brace and a tree contact, respectively. After each of these interruptions, repairs were completed at the affected line section and the D10H circuit was returned to service.

2016 HONI D10H

In 2016 a loss of supply event occurred on March 26th when a shield-wire failed under heavy ice load during a severe ice storm. The problem was detected via helicopter patrol and located near the Wallenstein Junction. WNH implemented a contingency plan to pick up load from alternate 27.6 kV sources with all 8,147 customers restored within 14 to 148 minutes equaling 684,365 CMI vs 1,393,137 if WNH had waited for HONI to restore the D10H.

2018 HONI D10H

In 2018 the loss of supply event occurred on April 15th when a shield-wire failed under heavy ice load during a storm. WNH implemented a contingency plan to pick up load from alternate 27.6 kV sources with all 5,936 customers restored within 5 to 191 minutes equaling 417,997 CMI vs 1,573,480 if WNH had waited for HONI to restore the D10H.

Follow-up

After each LOS event HONI provides WNH with information on the event and the remediation taken. Periodically, at WNH's request, meetings are held with HONI to discuss the reliability issues in greater detail and actions that can be taken to prevent further occurrences.

The April 15, 2018 shield-wire failure was a culminating event and WNH insisted that more needed to be done to prevent what had now been the third shield-wire LOS event in five years. HONI launched an internal investigation to improve D10H's reliability which was completed in the fourth quarter (Q4) of 2018.

The investigation consisted of multiple activities that included: a detailed helicopter inspection, foot patrol on the sub-sections where helicopter inspection could not be carried out due to flying restrictions, and an engineering design review of the shield-wire. The shield-wire on D10H line section was installed in 1994, and it was determined that it is designed to sustain the mechanical and electrical loadings as per HONI standards.

However, during the inspections which covered approximately 50 km's of the D10H's length, the following deficiencies were observed:


- Broken or damaged bond wires and/or down grounds leading to the shield-wire;
- Broken /damaged /missing shield-wire dampers;
- A non-concerning loose shield-wire clamp;
- Two non-concerning loose cross braces.

2019 Q4 Update

Hydro One has completed the corrective work to address these deficiencies. The work was attempted to be completed earlier however there were potential D10H loading and thermal issues in the spring and summer months of 2019. Hydro One and WNH will monitor the performance of D10H and ensure that the remedial actions taken by HONI prove effective.

3.5. Code 3 – Tree Contacts

Figure 3-5: Tree Contact Trending



Cause Code 3: Tree Contacts – are customer interruptions caused by faults resulting from tree contact with energized circuits.

In 2019, tree contacts ranked 6th (6.2%), in sustained interruption causes, down from an average ranking of 2nd from 2016 – 2018. The majority of customer minutes due to tree contact (82.6%) between 2016 – 2019 were due to MEDs.

Table 3-9: WNH Tree Contacts (2016-2019)

Year	Total CMI	Cause Code "3" Total CMI	% CMI	Total Events	Cause Code "3" Total Events	% Events
2016	9,580,465	46,713	0.5%	811	19	2.3%
2017	2,930,075	473,567	16.2%	739	19	2.6%
2018	7,156,980	2,843,234	39.7%	786	28	3.6%
2019	3,891,102	240,397	6.2%	791	11	1.4%
Total	23,558,622	3,603,911		3,127	77	
Avg.	5,889,656	900,978	15.3%	782	19	2.5%

In 2018, a May 4th high wind MED event caused tree limbs to fall into WNH primary lines throughout the territory creating multiple sustained interruptions. The largest single contributor was a 3F68 feeder interruption which contributed 1,448,932 CMI.

Table 3-10: WNH Tree Contacts and MEDs (2016-2019)


Year	Cause Code "3" Total CMI	Excl. MED	Excl. % CMI	MED Only	MED % CMI
2016	46,713	45,210	96.8%	1,503	3.2%
2017	473,567	167,464	35.4%	306,103	64.6%
2018	2,843,234	173,933	6.1%	2,669,301	93.9%
2019	240,397	240,397	100.0%	0	0.0%
Total	3,603,911	627,004		2,976,907	
Avg.	900,978	156,751	17.4%	744,227	82.6%

The CEA defines an Adverse Weather-Extreme Wind condition when wind speeds exceed 90km/hr. Under these conditions, WNH categorizes a tree contact as an Adverse Weather Event.

WNH attempts to strike a balance between customer's stated desires to limit the amount of tree trimming due to aesthetics and tree trimming practices to minimize contact with energized lines.

3.6. Code 4 – Lightning Contacts

Figure 3-6: Lightning Events Cause Trending



Cause Code4: Lightning – are customer interruptions due to lightning striking the distribution system, resulting in an insulation breakdown and/or flash-overs.

In 2019, Lightning related events ranked 5th (8.3%) in sustained interruption causes, up from an average ranking of 7th from 2016 – 2018. An Electronic Vacuum Recloser was struck by lightning during a severe storm causing the device to open along with the feeder breaker.

Although lighting event history has remained relatively constant, CMI related to lightning remains highly variable. In 2016, WNH experienced an active summer storm season with higher than average lightning activity. A single event accounted for nearly 50% of the total lightning related CMI for the year. A recloser was destroyed and two circuits were out for over 4.5 hours. This culminated in a MED.

Table 3-11: Lightning Events (2016-2019)

Year	Total CMI	Cause Code "4" Total CMI	% CMI	Total Events	Cause Code "4" Total Events	% Events
2016	9,580,465	678,066	7.1%	811	30	3.7%
2017	2,930,075	13,540	0.5%	739	11	1.5%
2018	7,156,980	44,907	0.6%	786	8	1.0%
2019	3,891,102	323,456	8.3%	791	12	1.5%
Total	23,558,622	1,059,969		3,127	61	
Avg.	5,889,656	264,992	4.5%	782	15	2.0%


MEDs accounted for 38.7% between 2016 – 2019.

Table 3-12: WNH Lightning Events and MEDs (2016-2019)

Year	Cause Code "4" Total CMI	Excl. MED	Excl. % CMI	MED Only	MED % CMI
2016	678,066	8,990	1.3%	669,076	98.7%
2017	13,540	13,540	100.0%	0	0.0%
2018	44,907	44,907	100.0%	0	0.0%
2019	323,456	323,049	99.9%	407	0.1%
Total	1,059,969	390,486		669,483	
Avg.	264,992	97,622	36.8%	167,371	63.2%

3.7. Code 5 – Defective Equipment

Figure 3-7: Defective Equipment (2016 – 2019)



Cause Code 5: Defective Equipment – are customer interruptions resulting from distributor equipment failures due to deterioration from age, incorrect maintenance, or imminent failures detected by maintenance.

In 2019, Defective Equipment ranked 4th, (14.8%) in CMI causes, up from an average ranking of 5th from 2016 – 2018. The largest contributors to this category were:

- HS22 underground cable riser failed at the termination causing a large interruption to an already worse performing feeder. (153,972 CMI affecting 2,324 customers.);
- EVR-27-2680 on Roslin Avenue failed internally, taking part of ER46 feeder out of service. (112,710 CMI affecting 663 customers);
- 30 distribution transformers failed at various locations.

Table 3-13: Defective Equipment (2016-2019)


Year	Total CMI	Cause Code "5" Total CMI	% CMI	Total Events	Cause Code "5" Total Events	% Events
2016	9,580,465	266,817	2.8%	811	97	12.0%
2017	2,930,075	535,964	18.3%	739	111	15.0%
2018	7,156,980	803,865	11.2%	786	132	16.8%
2019	3,891,102	576,266	14.8%	791	107	13.5%
Total	23,558,622	2,182,912		3,127	447	
Avg.	5,889,656	545,728	9.3%	782	112	14.3%

Table 3-14: Defective Equipment and MEDs (2016-2019)

Year	Cause Code "5" Total CMI	Excl. MED	Excl. % CMI	MED Only	MED % CMI
2016	266,817	265,998	99.7%	819	0.3%
2017	535,964	535,465	99.9%	499	0.1%
2018	803,865	684,589	85.2%	119,276	14.8%
2019	576,266	576,266	100.0%	0	0.0%
Total	2,182,912	2,062,318		120,594	
Avg.	545,728	515,580	94.5%	30,149	5.5%

3.8. Code 6 – Adverse Weather

Figure 3-8: Adverse Weather (2016 – 2019)



Cause Code 6: Adverse Weather – are customer interruptions resulting from rain, ice storms, snow, winds, extreme temperatures, freezing rain, frost, or other extreme weather conditions (exclusive of Code 3 and Code 4 events).

In 2019, Adverse Weather ranked 1st, (25.5%) in sustained interruption causes and since 2016 has contributed 7,287,685 or 30% of WNH's total CMI, ranking it 1st overall.

The most significant interruption event in 2019 was a 2-day MED event that began on July 20th when extreme wind (>90km/h) and heavy rain caused tree limbs to fall throughout WNH service territory. Most Service Calls were coded to Adverse Weather totaling 8,842 customers and 785,710 CMI

On March 24th, 25th and 26th of 2016, WNH experienced an MED event with a wide spread freezing rain storm impacting approximately 17,000 or 31% of WNH's customers. The 3-day total of 5,521,516 CMI resulted in 99% of the total Adverse Weather CMI for 2016.

Table 3-15: Adverse Weather (2016-2019)


Year	Total CMI	Cause Code "6" Total CMI	% CMI	Total Events	Cause Code "6" Total Events	% Events
2016	9,580,465	5,578,173	58.2%	811	69	8.5%
2017	2,930,075	116,104	4.0%	739	27	3.7%
2018	7,156,980	388,697	5.4%	786	20	2.5%
2019	3,891,102	994,459	25.6%	791	25	3.2%
Total	23,558,622	7,077,433		3,127	141	
Avg.	5,889,656	1,769,358	30.0%	782	35	4.5%

Table 3-16: Adverse Weather and MEDs (2016-2019)

Year	Cause Code "6" Total CMI	Excl. MED	Excl. % CMI	MED Only	MED % CMI
2016	5,578,173	55,155	1.0%	5,523,018	99.0%
2017	116,104	116,104	100.0%	0	0.0%
2018	388,697	75,120	19.3%	313,577	80.7%
2019	994,459	208,749	21.0%	785,710	79.0%
Total	7,077,433	455,128		6,622,305	
Avg.	1,769,358	113,782	6.4%	1,655,576	93.6%

3.9. Code 7 – Adverse Environment

Figure 3-9: Adverse Environment (2016-2019)



Cause Code 7: Adverse Environment – are customer interruptions due to distributor equipment being subject to abnormal environments, such as salt spray, industrial contamination, humidity, corrosion, vibration, fire, or flowing.

Adverse Environment caused interruptions do not typically impact WNH's annual CMI. From 2016 – 2018, Adverse Environment ranked 10th, (0.3%) in sustained interruption causes.


In 2016 there were two calls misreported, both were broken porcelain switches that failed causing the poles to catch fire and represent 49,243 CMI. The sustained interruptions were actually due to equipment failure. Since 2016, all pole fire events have been reported based on the root cause of the fire. There were no MED minutes due to Adverse Environment.

Table 3-17: Adverse Environment (2016-2019)

Year	Total CMI	Cause Code "7" Total CMI	% CMI	Total Events	Cause Code "7" Total Events	% Events
2016	9,580,465	54,778	0.6%	811	3	0.4%
2017	2,930,075	26	0.0%	739	1	0.1%
2018	7,156,980	4,969	0.1%	786	2	0.3%
2019	3,891,102	0	0.0%	791	0	0.0%
Total	23,558,622	59,773		3,127	6	
Avg.	5,889,656	14,943	0.3%	782	2	0.2%

3.10. Code 8 – Human Element

Figure 3-10: Human Element (2016 – 2019)



Cause Code 10: Human Element – are customer interruptions due to the interface of distributor staff with the distribution system.

In 2019, Human Element causes ranked 7th, (4.8%) in sustained interruption causes, up from an average ranking of 9th from 2016 – 2018.

In 2019, one of the 9 events account for 179,411 or 97% of the 185,340 CMI

- On August 17th, a severe lightning storm across much of WNH's territory caused a fault on HS11. Miscoordination between the feeder and bus backup protections resulted in the Y Bus and feeders HS11, HS12, HS13 and HS14 tripping off. This affected 4,129 urban customers for up to 71 minutes. After an in depth investigation it was found that the bus protection settings were not correct for a very narrow range of possible fault currents. Stations Engineering prepared new protection settings for the bus backup which were immediately commissioned in the field to rectify the issue.

In 2016, two of the nine events make up 166,928 or 99% of the 168,725 CMI.

- On June 15th, a WNH pole fire on Woolwich Street in Waterloo was caused by insufficient rubber cover up insulation on a WNH construction project. High winds were a contributing factor. This contributed 148,904 CMI.
- On May 19th, a switching error was made involving an underground Vista switchgear unit. The crew closed in to a grounded Vista switchgear unit and tripped ER45, this contributed 18,024 CMI.


Both incidents received formal reviews under WNH's Health and Safety program.

Table 3-18: Human Element (2016-2019)

Year	Total CMI	Cause Code "8" Total CMI	% CMI	Total Events	Cause Code "8" Total Events	% Events
2016	9,580,465	168,725	1.8%	811	9	1.1%
2017	2,930,075	3,016	0.1%	739	5	0.7%
2018	7,156,980	4,607	0.1%	786	6	0.8%
2019	3,891,102	185,340	4.8%	791	9	1.1%
Total	23,558,622	361,688		3,127	29	
Avg.	5,889,656	90,422	1.5%	782	7	0.9%

3.11. Code 9 – Foreign Interference

Figure 3-11: Foreign Interference (2016 – 2019)



Cause Code 9: Foreign Interference – are customer interruptions beyond the control of the distributor, such as those caused by animals, vehicles, dig-ins, vandalism, sabotage, and foreign objects.

In 2019, Foreign Interference causes ranked 2nd, (19.9%) in sustained interruption causes, up from an average ranking of 3rd from 2016 – 2018. The biggest contributors to Foreign Interference CMI were:

- A bird landed on switch FC-27-3714 located on University Avenue East near Lexington Road, Waterloo. The resulting fault caused damage to the switch resulting in 114,644 CMI affecting 1,939 customers.
- A bird landed on switch LB-14-35 located on Dietz Avenue North in Waterloo. The resulting fault caused damage to the switch resulting in 109,760 CMI affecting 1,120 customers.

Table 3-19: Foreign Interference (2016-2019)


Year	Total CMI	Cause Code "9" Total CMI	% CMI	Total Events	Cause Code "9" Total Events	% Events
2016	9,580,465	922,417	9.6%	811	125	15.4%
2017	2,930,075	1,080,211	36.9%	739	173	23.4%
2018	7,156,980	1,122,441	15.7%	786	161	20.5%
2019	3,891,102	773,201	19.9%	791	143	18.1%
Total	23,558,622	3,898,270		3,127	602	
Avg.	5,889,656	974,568	16.5%	782	151	19.3%

Table 3-20: Foreign Interference and MEDs (2016-2019)

Year	Cause Code "9" Total CMI	Excl. MED	Excl. % CMI	MED Only	MED % CMI
2016	922,417	798,869	86.6%	123,548	13.4%
2017	1,080,211	1,080,211	100.0%	0	0.0%
2018	1,122,441	1,085,738	96.7%	36,703	3.3%
2019	773,201	767,366	99.2%	5,835	0.8%
Total	3,898,270	3,732,184		166,086	
Avg.	974,568	933,046	95.7%	41,522	4.3%

Animal contact has consistently been the leading cause of Foreign Interference sustained interruptions (61%) followed by Motor Vehicle Accidents (21%). WNH has an active animal guarding program in an attempt to mitigate momentary and sustained events. Animal guarding is installed at incident locations and in known problematic areas. New construction standard incorporate animal guarding at vulnerable locations such as transformers and load break switches.

Figure 3-12: Foreign Interference Causes (2016 – 2019)



To ensure public safety, WNH dispatches a crew to all reported dig-in's and Motor Vehicle Accident's (MVA) when related to WNH infrastructure. WNH follows a protocol for investigating and reporting such dig-in incidents to the Electrical Safety Authority (ESA) and/or the Ministry of Labour (MOL) as required.

Table 3-21: Foreign Interference by Subcause (2016-2019)

Year	Animal	MVA	Cable Dig-ins Primary	Cable Dig-ins Secondary	Other (Various)	Total
2016	71	29	0	7	18	125
2017	103	41	1	4	24	173
2018	109	23	2	2	25	161
2019	83	31	0	8	21	143
Total	366	124	3	21	88	602
%	61%	21%	0%	3%	15%	100%

4. Operational Effectiveness – System Reliability

4.1. Reliability Targets

WNH's reliability targets for 2016 – 2020, SAIDI and SAIFI, are presented in **Table 4-1**. These targets were set in 2016 and based on WNH's 2011- 2015 reliability performance. In addition, WNH set its own range targets for SAIDI and SAIFI to be no more than that of the previous 2011-2015 period; SAIDI (0.47-0.75) and SAIFI (0.85-1.59).

Table 4-1: WNH Reliability Performance 2011-2015

	OEB TARGET	DEAD BAND RANGE	
Exclusive of LOS and MED	5 YR AVG. (1) 2011 - 2015	MIN	MAX
SAIDI (Duration)	0.62	0.47	0.75
SAIFI (Frequency)	1.16	0.85	1.59

4.2. Reliability Performance Overview (2016 – 2019)

Table 4-2 provides the results of WNH's 2016-2019 reliability performance including all interruptions.

Table 4-2: WNH Historical CMI, SAIDI, SAIFI, MAIFI (All Inclusive)

Date	CMI	SAIDI	SAIFI	MAIFI
2016	9,580,465	2.87	2.99	8.16
2017	2,930,075	0.86	1.61	4.02
2018	7,156,980	2.09	1.86	4.79
2019	3,891,102	1.13	1.84	3.19
Average	5,889,656	1.74	2.08	5.04

Table 4-3 provides the results of WNH's 2015-2019 reliability performance exclusive of Loss of Supply and Major Event Days.

Table 4-3: WNH Historical CMI, SAIDI, SAIFI, MAIFI (Excluding LOS & MED)

Date	CMI	SAIDI	SAIFI	MAIFI
2016	2,370,254	0.71	1.15	5.34
2017	2,584,671	0.76	1.50	3.98
2018	3,151,181	0.92	1.32	3.94
2019	2,936,432	0.85	1.29	2.97
Average	2,760,635	0.81	1.31	4.06

Comparing WNH's performance results in **Table 4-2** to the targets in **Table 4-1** it can be observed that WNH's reliability performance did not meet the OEB target for SAIDI and SAIFI. Please refer to **Section 2.1** of this report for further details.

4.3. System Average Interruption Duration Index (SAIDI)


SAIDI is defined as the system average sustained interruption duration for customers served per year (hours/year). It is calculated as follows:

$$\text{SAIDI} = \frac{\text{sum of all customer interruption durations}}{\text{total number of customers served}}$$

Figure 4-1 illustrates WNH's annual SAIDI from 2016 – 2019. WNH's SAIDI+CMIS represents the gross overall SAIDI without the benefits of grid modernization technology. SAIDI (ALL) represents WNH's all inclusive system SAIDI. Both can be seen having a downward trend over the historical period.

SAIDI (OEB) which is filed with WNH's OEB RRR report, represents a version of SAIDI excluding Loss of supply and Major Event Day events. This normalized version is tracked against WNH's OEB targets.

Figure 4-1: SAIDI (2016 – 2019)



4.4. System Average Interruption Frequency Index (SAIFI)

SAIFI is defined as the average number of sustained interruptions per customer per year. It is calculated as follows:


$$\text{SAIFI} = \frac{\text{total number of customer interruptions}}{\text{total number of customers served}}$$

Figure 4-2 illustrates WNH's annual SAIFI from 2016 – 2019. WNH's SAIFI+CFIS represents the gross overall SAIFI without the benefits of grid modernization technology. SAIFI (ALL) represents WNH's all inclusive system SAIFI. Both can be seen having a downward trend over the historical period.

SAIFI (OEB) which is filed with WNH's OEB RRR report, represents a version of SAIFI excluding Loss of supply and Major Event Day events. This normalized version is tracked against WNH's OEB targets.

In 2018, WNH began to quantify and track the benefits to SAIFI arising from grid modernization investment. WNH developed a new reliability measure to capture the Customer Frequency of Interruptions Saved (CFIS). The solid orange in **Figure 4-2** represents what SAIFI would have been without these investments.

Figure 4-2: SAIFI (2016 – 2019)



4.5. Momentary Interruptions (MAIFI)


A momentary interruption is defined as an interruption with a duration of less than one (1) minute. In 2019, WNH customers experienced 200 momentary interruptions. **Table 4-4** provides a summary WNH's annual momentary interruptions over the historic period.

Table 4-4: Momentary Interruption Events (2016 – 2019)

Date	# Momentary Operations (All Inclusive)	# Momentary Operations (Excluding LOS & MED)
2016	389	247
2017	230	228
2018	236	204
2019	200	189
Avg.	264	217

Momentary Average Interruption Frequency Index (MAIFI) represents the average number of momentary interruptions that a customer would experience annually. **Figure 4-3** illustrates WNH’s annual MAIFI and the progress that WNH has made in that regard.

Figure 4-3: MAIFI (2016-2019)



Although not an OEB Target, WNH monitors its momentary interruption performance (MAIFI) due to its impact on customers. From **Table 4-3**, it can be observed that MAIFI has been reduced substantially over the historical period. WNH believes this is a result of the grid modernization investments and having an active animal guarding program.

5. Impact of Grid Modernization on Reliability

As mentioned previously in **Section 2.1a** and **Section 2.2**, WNH's investments in grid modernization have saved an average of 1.64 million minutes annually. In 2019, WNH estimates 1.7 million customer minutes were saved; a 30% reduction in interruption minutes.

WNH has not yet fully implemented grid modernization technologies on all of its feeders; as such, system SAIDI, being a global parameter, does not accurately reflect the impact that grid modernization investments have made on customer reliability. The following analysis more accurately reflects the potential impacts of these investments.

1) 2019 SAIDI - All Customers

Indices	All Customers	Customer Count	Notes
SAIDI + SAIDI Saved	1.62	57,584	Gross SAIDI without grid modernization technologies
SAIDI Saved	0.49	57,584	Savings (CMIS) only experienced by customers with grid modernization technologies but savings applied across the entire customer base.
SAIDI	1.13	57,584	Net SAIDI all inclusive. grid modernization technologies in service for 39,493 customers.
SAIDI Excl. MED / LOS	0.85	57,584	SAIDI excluding MED and LOS customer interruption minutes. (OEB reporting)

2) 2019 SAIDI – Approximately 38,687 customers were supplied by feeders where grid modernization technologies had been implemented.

Indices	Feeders with Grid Modernization Technologies in place	Customer Count	Notes
SAIDI + SAIDI Saved	1.62	38,687	Gross SAIDI without grid modernization technologies
SAIDI Saved	0.74	38,687	Savings (CMIS) only experienced by customers with grid modernization technologies but savings applied across the entire customer base.
SAIDI	0.89	38,687	Net SAIDI all inclusive. grid modernization in service for 39,687 customers.
SAIDI Excl. MED / LOS	0.82	38,687	SAIDI excluding MED and LOS customer interruption minutes for grid modernization feeder customers only.

- 3) 2019 SAIDI Performance – Only customers supplied by feeders where grid modernization has not been implemented.

Indices	Feeders without Grid Modernization Technologies in place	Customer Count	Notes
SAIDI + SAIDI Saved	1.62	18,897	Gross SAIDI without grid modernization technologies
SAIDI Saved	0.00	18,897	No grid modernization technology applied
SAIDI	1.62	18,897	Net SAIDI for customers connected to feeders without grid modernization technologies
SAIDI Excl. MED / LOS	0.92	18,897	SAIDI excluding MED and LOS customer interruption minutes for customers connected to feeders without grid modernization technologies.

4) Impact of Grid Modernization

Overall in 2019, WNH recorded a SAIDI of 1.13 and benefited from a reduction of approximately 1.7 million CMI or 0.49 SAIDI due to grid modernization technologies. Without grid modernization technologies in place, WNH would have experienced an overall SAIDI of 1.62.

Customers connected to feeders with grid modernization technologies experienced an average SAIDI of 0.89; a SAIDI reduction of 0.74.

The remaining customers connected to feeders without full benefit of grid modernization technologies experienced an average SAIDI of 1.62. Applying the same level of gains made in SAIDI, over WNH's entire customer base, could see overall SAIDI reduced from 1.13 to 0.96 and SAIDI (excluding LOS & MED) reduced from 0.85 to 0.66.

The analysis also identifies a downward trend in MAIFI since 2016 and a downward trend in SAIFI since 2017.


6. Electrical Safety Authority Serious Electrical Incidents

From 2016 through to 2019, WNH reported 15 serious incidents to the Electrical Safety Authority (ESA). **Table 6-1** provides a breakdown of the 15 serious incidents by cause and **Figure 6-1** provides a map with their locations.

Table 6-1: Serious Incidents 2015 – 2019

Number of Incidents	Symbol	Type of Incident
8	●	Foreign Inference - MVA
1	●	Foreign Inference - Customer
6	✕	WNH - Defective Equipment
15		Total

Figure 6-1: Serious Incidents



Foreign Interference accounted for 9 (60%) out of the total 15 reported incidents meaning they were not within WNH's direct control.

Of the remaining 6 incidents, all were caused by WNH Defective Equipment in the form of a fallen primary or primary neutral conductor. None of the incidents involving Defective Equipment involved an electrical contact or personal injury.

WNH's distribution system in Wellesley Township contributed to 5 Defective Equipment events. As of Q4 2019, the lines involved in these incidents have been inspected and where needed, sections of the lines were rebuilt.

WNH has gone on to perform more detailed inspections of small sized overhead conductor in the rural area and found that more conductor in poor condition exists. The rebuilding of overhead lines with failing conductor has been identified and incorporated into WNH's System Renewal program. More detail can be found in WNH's DSP, **Section 4.4.2 Material Investments**.

7. 2019 Worst Performing Feeders

Annually, WNH reviews the reliability performance of all feeders. WNH identifies the top 5 Worst Performing Feeders and performs a focused examination to determine the root causes of the interruptions and to look for opportunities to improve reliability.

Table 7-1 provides a listing of WNH's 5 worst performing feeders at the end of 2019. On average over the last 3 years, the 5 worst performing feeders represent 9.3% of the feeder population and 28.4% of the total CMI.

Table 7-1: Worst Performing Feeders (2019)

Ranking	Feeder #	Distribution Voltage (kV)	# Customers	2017 CMI	2018 CMI	2019 CMI	3 Year Average CMI	% of Total CMI
1	HS22	13.8	2,393	305,471	238,730	461,425	335,209	11.6%
2	3F68	27.6	3,200	86,750	132,500	208,966	142,739	4.9%
3	HS20	13.8	1,922	209,727	127,745	12,766	116,746	4.0%
4	ER44	13.8	3,116	73,862	268,720	5,130	115,904	4.0%
5	3F61	27.6	1,585	315,902	15,915	1,173	110,997	3.8%
5 WPF CMI			12,216	991,712	783,610	689,460	821,594	28.4%
Total CMI				2,584,671	3,151,181	2,936,432	2,890,761	100.0%
% WPF CMI				38.4%	24.9%	23.5%	28.4%	

Worst Performing Feeder Ranking

Rank	1	2	3	4	5
------	---	---	---	---	---

Table 7-2 provides a listing of action plans developed for the 2019 worst performing feeders.

Table 7-2: Worst Performing Feeder Action Plans (2019)

Feeder	Completion Timeline	Plan
HS22	2020	Install an additional recloser on Marsland Drive in 2020 to reduce number of customers exposed to a single event.
	2020	Replace failed cable (one phase) from breaker to D-14-2660 (riser). Investigated and other two phases show no signs of deterioration.
3F68	Completed in 2019	Feeder has been reconfigured to balance load and circuit kilometers with other feeders. Sections of feeder were transferred onto 3F61 and 3F63.
	Completed in 2019	Two additional reclosers were installed for additional tie points to other feeders, increasing interruption contingency options.
	2019 / 2020	3F68 patrolled for locations at high risk for tree contact during ice and wind storms. Regularly scheduled tree trimming to occur in 2020.
HS20	2020	Add protection settings to EVS-14-2965 to enable it to act as a Recloser.
	N /A	EVR-14-5584 was installed in 2018. Performance in 2019 improved. No further action at this time. Monitor and re-evaluate at end of 2020.
ER44	N/A	Worst performer because of one event in 2018. Performance in 2019 improved substantially. No further action at this time. Monitor and re-evaluate at end of 2020.
3F61	N/A	Feeder was reconfigured and has not been a worst performer since. No further action at this time. Monitor and re-evaluate at end of 2020.

Tables 7-3a and **7-3b** provide a listing of all WNH feeders and 2016-2019 performance history. Feeders are ranked by their highest 3-year average of CMI excluding Scheduled, Loss of Supply and Major Event Day events.

Table 7-3a: WNH Feeder Performance Excluding Planned & Major Event Days

Feeder #	Distribution Voltage (kV)	Customers	Circuit Length (km)	2016 CMI	2017 CMI	2018 CMI	2019 CMI	3 Year Average CMI
HS22	13.8	2393	35.36	51,053	305,471	238,730	461,425	335,209
3F68	27.6	3200	95	23,116	86,750	132,500	208,966	142,739
HS20	13.8	1922	13.77	115,669	209,727	127,745	12,766	116,746
ER44	13.8	3116	53.89	137,184	73,862	268,720	5,130	115,904
3F61	27.6	1585	122	7,216	315,902	15,915	1,173	110,997
HS30	13.8	1003	11.14	104,853	49,010	176,985	91,083	105,693
HS26 (T6)	27.6	2199	68.54	2,912	15,267	130,647	156,246	100,720
ER46	13.8	1139	15.20	9,273	23,424	10,705	227,705	87,278
HS21	13.8	344	6.78	32,482	1,432	213,713	13,916	76,354
HS11	13.8	2005	32.65	1,454	3,801	41,681	182,161	75,881
33M1	27.6	1768	114	57,318	51,397	31,956	112,212	65,188
21M25	27.6	1563	88	37,522	87,619	69,248	27,486	61,451
3F62 - 3F50 (T3)	13.8	1576	22.91	18,216	40,993	3,651	138,313	60,986
ER48	13.8	2223	44.60	11,135	19,376	104,301	50,561	58,079
HS17	13.8	1470	36.52	51,742	92,597	26,501	49,164	56,087
HS19 (T5)	27.6	1396	25.66	3,225	126,875	37,987	506	55,123
R26	8.32	576	55.70	51,343	3,528	154,573	3,199	53,767
R27	8.32	420	49.47	46,955	27,236	43,782	68,105	46,374
ER42	13.8	1219	17.44	13,888	28,532	92,441	14,303	45,092
HS16	13.8	222	3.73	6,364	24,059	68,178	42,813	45,017
HS23	13.8	2549	41.61	96,736	72,984	42,183	14,748	43,305
HS15	13.8	1409	28.63	240,594	7,327	14,860	93,182	38,456
ER45	13.8	2145	26.53	53,769	31,033	51,684	14,387	32,368
HS28	13.8	628	7.14	12,332	33,196	58,763	2,159	31,373
R28	8.32	295	52.19	61,144	47,858	34,813	5,272	29,314
33M3	27.6	3303	65.20	6,485	61,813	16,766	8,044	28,874
HS27	13.8	1942	21.85	21,842	5,898	15,574	58,164	26,545
R30	8.32	675	91	3,160	38,463	18,367	15,150	23,993
HS10	13.8	1221	31.49	10,032	90	14,071	51,592	21,918
HS25	13.8	682	10.91	4,939	360	55,828	0	18,729
R32	8.32	11	7.50	41,498	11,506	23,983	2,443	12,644
HS12	13.8	641	6.06	2,592	3,382	4,683	24,029	10,698

Table 7-3b: WNH Feeder Performance Excluding Planned & Major Event Days

Feeder #	Distribution Voltage (kV)	Customers	Circuit Length (km)	2016 CMI	2017 CMI	2018 CMI	2019 CMI	3 Year Average CMI
R31	8.32	649	63.80	16,886	7,649	17,721	5,894	10,421
HS24	13.8	1240	18.55	136,687	10,352	12,032	7,853	10,079
9M4	27.6	743	30.40	23,365	611	14,288	11,720	8,873
HS7	13.8	189	5.87	2,049	9,075	5,744	1,472	5,430
ER47	13.8	427	11.94	0	14,288	0	1,424	5,237
33M2	27.6	119	19.87	1,558	282	13,948	977	5,069
3F63	27.6	1408	70.70	122,684	461	8,099	4,939	4,500
R29	8.32	562	26.40	1,022	948	94	11,649	4,230
HS29	13.8	1310	16.06	3,170	8,407	1,378	2,095	3,960
ER43	13.8	472	15.32	0	2,148	5,624		3,886
HS9	13.8	3	1.72	0	0	837	7,592	2,810
ER41	13.8	422	14.41	0	118	7,360	684	2,721
3F66	27.6	921	15.80	0	0	0	8,133	2,711
HS13	13.8	411	8.24	8,446	4,174	1,142	1,180	2,165
HS14	13.8	164	6.86	0	0	0	2,229	743
HS18	13.8	24	3.35	0	1,290	0	79	456
HS8	13.8	26	6.24	0	130	892	14	345
3F60	27.6	252	3.71	3,936	0	0	0	0
3F67 - 3F51 (T4)	13.8	101	5.80	0	0	0	0	0
3F65	27.6	31	7.08	25	0	0	0	0
3F64	27.6	-	0.91	0	0	0	0	0
3F69	27.6	-	1.28	0	0	0	0	0

Appendix L:

WNH Customer Engagement Reports

Waterloo North Hydro Inc.

2018 Electric Utility Customer Satisfaction Survey





The purpose of this report is to profile the connection between Waterloo North Hydro Inc. (Waterloo North Hydro) and its customers.

The primary objective of the Electric Utility Customer Satisfaction Survey is to provide information to support discussions about improving customer care at every level in your utility.

The UtilityPULSE Report Card® and survey analysis contained in this report is intended to capture the state of mind or perceptions about your customers' need and wants – the information contained in this report will help guide your discussions for making meaningful improvements.

This survey report is privileged and confidential material, and no part may be used outside of Waterloo North Hydro Inc. without written permission from UtilityPULSE, the electric utility survey division of Simul Corporation.

All comments and questions should be addressed to:

Sid Ridgley, UtilityPULSE division, Simul Corporation

Toll free: 1-888-291-7892 or Local: 905-895-7900

Email: sidridgley@utilitypulse.com or sridgley@simulcorp.com





Feedback, Information & Insights

Eighteen months ago, customers were very angry about the quickly increasing costs of electricity over the previous 5 or more years. In fact, some years were double-digit increases while wages and inflation hovered around the 2% mark. We know this because the number of survey respondents in the Ontario benchmark survey who said they ‘sometimes worry about paying their bill’ grew from 21% to 31% and the number of At Risk customers grew from 11% to 17%.

Data from the Waterloo North Hydro and Ontario benchmark surveys show the level of “anger” has dramatically reduced. Whether changes in perception were created by the Liberal Government’s Spring 2016 reduction by 25% in electricity prices, or the change to a Conservative government June 2018, or the promise of further reductions in electricity prices, or improvements in the economy, or improvements that LDCs have made in managing outages while improving customers service, or all of the above - a major shift towards a more positive view has taken place. Customers who have a positive view of their LDC and the industry exhibit less resistance to change.

For Waterloo North Hydro in the Fall 2018 survey 14% of respondents and 21% of the Ontario benchmark respondents said they ‘sometimes worry about paying their bill.’ Also, the At Risk customer respondent levels were 4% for Waterloo North Hydro and 13% for the Ontario benchmark. To be clear, customers are still concerned about the costs of electricity as shown by very low scores in the attribute “The cost of electricity is reasonable when compared to other utilities such as gas, cable or telephone.”





Your survey was conducted from September 17 - October 17, 2018, and is based on 403 one-on-one telephone interviews with residential and small commercial customers who pay or look after the electricity bill. Also, survey findings for Waterloo North Hydro are enhanced with the inclusion of data from our UtilityPULSE database and the independently produced Ontario and National Benchmarks.

Helping the LDC generate higher levels of customer satisfaction, or maintaining their current high level, will be based on doing the core job as promised by being professional, efficient and cost-effective. But expectations continue to change. For Fall 2018, three key observations emerge from examining the trends in data from the UtilityPULSE database. They are: customers want to know they have been heard, they have reasonable access to services, and, their LDC is pro-actively communicating – especially during emergency situations.

83%

Pro-actively
communicates changes
and issues

89%

Provides excellent
quality services

92%

Standard of reliability
meets expectations

90%

Delivers on its service
commitments



Base: total respondents:
Top 2 Boxes: "Strongly agree + agree"



The Core Responsibilities

Waterloo North Hydro survey respondents agree strongly + agree somewhat (Top 2 boxes), their LDC: Provides consistent, reliable electricity 94%, Quickly handles outages and restores power 94%, Accurate billing 92% and Makes electricity safety a top priority for employees, contractors, and the public 87%.

Issues: Billing and Blackouts, the “Killer B’s”

In a world, which is becoming more complex, and where people are time-pressed, outage and billing issues are likely to motivate customers to contact their LDC.

Problems: Blackouts

Percentage of Respondents indicating that they had a Blackout or Outage problem in the last 12 months			
	Waterloo North Hydro	National	Ontario
2018	37%	39%	44%

Base: total respondents



Problems: Billing issues

Percentage of Respondents indicating that they had a Billing problem in the last 12 months			
	Waterloo North Hydro	National	Ontario
2018	5%	9%	9%

Base: total respondents



While it is true, Waterloo North Hydro receives very good operational scores, it also has a responsibility to professionally and quickly deal with issues customers contact them about. In a complex electricity industry world, this puts additional strain on the skills and competencies of everyone who interacts with customers.





Customer Service

Satisfaction with Customer Service			
Top 2 Boxes: 'very + fairly satisfied'	Waterloo North Hydro	National	Ontario
The time it took to contact someone	86%	66%	64%
The time it took someone to deal with your problem	88%	72%	65%
The helpfulness of the staff who dealt with you	91%	70%	64%
The knowledge of the staff who dealt with you	89%	70%	64%
The level of courtesy of the staff who dealt with you	95%	78%	70%
The quality of information provided by the staff who dealt with you	88%	73%	61%

Base: total respondents who contacted the utility

Traditionally LDCs handle inbound, or customer initiated communications when there are issues. However, more and more customers have an expectation their LDC will also be proficient with outbound communications regarding the important issues.

Communication channels preferred by customers

Most, if not all, of our LDC clients, expect that customers will utilize the electronic channels for getting information or dealing with issues. By doing so, costs for the LDC should decrease. However, in a world where customers expect some outbound contact, they expect their LDC to use those channels to communicate directly with them. Therefore, when problems do occur, and the LDC must initiate contact with their customer, it would be beneficial to the process if customers were contacted via channels they most prefer.





Primary Source of Information

Primary Source for getting information on ...					
	Corporate website	Twitter	Facebook	Bill Inserts	eBlasts
A power outage	39%	6%	3%	5%	3%
An issue with your bill	35%	0%	1%	10%	3%
General corporate news	35%	2%	3%	16%	3%
Electricity safety information	42%	1%	2%	19%	3%
Energy conservation tips	38%	2%	3%	24%	3%
Changes in electricity rates	34%	1%	2%	31%	4%

Base: total respondents

Communication about Billing issues

Waterloo North Hydro customers' preferred or primary method for Waterloo North Hydro to contact them about billing issues are as follows:

Preferred method of communication to receive notice of a billing issue		
	Ontario LDCs	Waterloo North Hydro
Telephone	56%	59%
Voice Mail	2%	2%
Text	7%	4%
Email	34%	34%
Don't know	1%	1%








Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility





Communication during Unplanned Outages

In times of emergency, be they extreme weather events or major equipment failures that cause blackouts and unplanned outages, customer communication can help customers understand what to expect next and when disrupted electricity service might be restored. Early and effective communication helps increase confidence in and credibility of the electricity service provider.

Method of communication Customers prefer their LDC uses during an UNPLANNED OUTAGE						
Recorded Telephone Message	Email Notice	Posted on the Website	Social Media	Local Radio	Local TV	Text Message
						
36%	25%	5%	3%	8%	3%	19%

Base: total respondents

Notice the difference in the preferred channel based on subject matter. Waterloo North Hydro shouldn't, for example, assume a customer who prefers email for a billing issue will want an email for outage issues. These added variables add complexity to capturing and then using each customers' preferences. Getting the most out of your CRM system is becoming increasingly important.





Preferred Communication Platforms

Which communication platform or platforms would you prefer Waterloo North Hydro use ...	
Social media	16%
Newspaper	14%
Radio	16%
Bill inserts	27%
Website	27%
Email / eBlasts	48%
Other	8%

Base: total respondents

Which of the following methods would you most like to see Waterloo North Hydro contact you by...	
Live chat	2%
Phone call	45%
Email	41%
Text/SMS Message	9%
In-person visit	2%

Base: total respondents

Providing communication platforms that are effective and meet customers' needs is key to improving the customer experience. To do this, Waterloo North Hydro must understand how customers communicate with you, and how they would like Waterloo North Hydro to communicate with them in future. Knowing this will allow Waterloo North Hydro to: allocate resources where they are most needed; tailor services to meet customers' needs; and, identify where improvements can be made.

However, while most customers appear to have capacity and willingness to use digital channels, there are also customers who do not for a variety of reasons, such as a lack of ability or resources, or due to a preference for other channels. Waterloo North Hydro will need to consider how these customers can be supported and encouraged to use digital services in the future.





Customers were asked about their level of satisfaction with the information provided by Waterloo North Hydro on the following:

Satisfaction with information provided		
Top 2 Boxes: 'very + fairly satisfied'	Ontario LDCs	Waterloo North Hydro
The amount of information available to you about energy conservation	82%	82%
The quality of information available when outages occur	73%	78%
The electricity safety education provided to the public	74%	75%
The timeliness and relevance of information for things such as planned outages, construction activity, tree trimming.	78%	77%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

While providing information is important, one must ensure that it is neither overwhelming the audience to the point of turning them off, or not providing enough information causing recipients to feel you have not adequately looked after them.

Amount of Information received is ...			
	LESS than you would like	About the RIGHT amount	MORE than you need
Safety	7%	81%	5%
Energy Efficiency	12%	77%	7%
Billing and Account Questions	4%	86%	4%
Outages	13%	75%	4%
Construction projects and planning	15%	69%	7%

Base: total respondents





Communication Score – New for 2018

The pressure to communicate via multiple communication platforms continues to increase. There is also an expectation the utility will, from an outbound perspective, contact the customer via their preferred channel.



Communication Score		
	Ontario LDCs	Waterloo North Hydro
Communication Score	79%	80%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

Future Communication Efforts

Respondents were asked on which topics Waterloo North Hydro should focus their future communication efforts.

Future Communication Efforts should focus on ...	
	Waterloo North Hydro
Safety	15%
Energy Efficiency	30%
Billing and Account Questions	10%
Outages	10%
Construction projects and planning	8%

Base: total respondents





Respondents were asked: ***“Is there a topic other than the ones we’ve talked about that you would like Waterloo North Hydro to provide more information about?”*** Base: total respondents



14%
wanted **additional**
information.



85%
Required **no further**
information.



ADDITIONAL TOPICS mentioned:

- Prices/costs/fees
- Communication with customers
- Rebates
- Payment options
- My usage/my neighbour’s consumption
- Potential mergers
- SMART meters
- Outage map





The Convenience of Services Score – New for 2018

Rising customer expectations and demands means customers expect to be able to contact you 24 hours a day, seven days a week using various communication avenues, i.e. Telephone, your website and/or even social media. Customers expect flexible and more personalized services. Providing customers with clear, easy to access services and information which is easy to understand has a significant impact on the customer experience.



Providing customers with clear, easy to access services and information which is easy to understand has a significant impact on the customer experience.

Access to services		
Top 2 Boxes: 'very + somewhat satisfied'	Ontario LDCs	Waterloo North Hydro
The availability of call-centre staff Monday to Friday from 8:30 am to 4:30 pm	76%	75%
The 24/7 availability of system operators to respond to outages	77%	80%
The online self-serve options for managing your account	63%	67%
The online self-serve options for request services	56%	61%
The 24/7 availability of outage map on the website	n/a	66%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility



Convenience of Services Score

Based on customer responses, Waterloo North Hydro has rated 81% for Convenience of Services while Ontario LDCs rated 79%.



Use of Technology

Technology is fundamentally reshaping customer care in both the short and longer terms. The expectation is, technology will reduce the number of inbound calls by empowering customers to get the technical or service support they need to solve many of the problems which exist.

Respondents were asked whether they used the following forms of technology:

Use of technology			
	Yes	No	Don't know/Refusal
Access the internet for information	83%	17%	0%
Have a social media account	54%	44%	1%
Use online banking services	71%	25%	3%
Shop online	64%	34%	2%

Base: total respondents

Social Media

Social media is evolving, and it gives companies the opportunity to proactively identify customer issues which will help the utility address problems quickly thereby minimizing the impact on the broader customer base. 54% of Waterloo North Hydro customers indicated they had a social media account.





Which social media accounts do you have ...	
Facebook	58%
Twitter	24%
YouTube	34%
LinkedIn	38%

Base: total respondents who claimed to have social media accounts

Do you follow Waterloo North Hydro in ...			
	Yes	No	Don't know
Facebook	5%	95%	0%
Twitter	29%	70%	1%
YouTube	3%	97%	0%
LinkedIn	4%	95%	1%

Base: total respondents who claimed to have social media accounts



Credibility & Trust Index

As society becomes more complicated and complex, the opportunities for failure increase. A key to healthy relationships with customers is to be trusted, trustworthy and credible.


Waterloo North Hydro Credibility & Trust score is 87% while the Ontario benchmark is 81% and the National benchmark is 82%.





Customer Experience Performance rating (CEPr)

Do customers believe they will have a good experience if/when they do contact their LDC? Or do they believe they must prepare for 'war'? Of course, subject matter and customer affinity levels play a role in determining how a customer might prepare for interaction with a professional at Waterloo North Hydro.



Customer Experience Performance rating (CEPr)			
	Waterloo North Hydro	National	Ontario
CEPr: all respondents	89%	84%	83%

Base: total respondents

Ensuring that the customer experience is a good one, requires high quality services and well-trained people. Survey respondents gave Waterloo North Hydro excellent operational and representative scores.

Operational Attributes			
	Waterloo North Hydro	National	Ontario
Provides consistent, reliable energy	94%	89%	90%
Quickly handles outages and restores power	94%	87%	86%
Accurate billing	92%	86%	87%

Base: total respondents with an opinion





Representative Attributes			
	Waterloo North Hydro	National	Ontario
Deals professionally with customers' problems	89%	83%	82%
Is 'easy to do business with'	90%	82%	82%
Customer-focused and treats customers as if they're valued	83%	80%	79%

Base: total respondents with an opinion

Customer Centric Engagement Index

The term “customer engagement” is used by many but understood by few. The purpose of customer engagement is to have two-way interactions which build understanding between the stakeholders and stronger professional business-like relationships. Customers who are highly engaged are more inclined to look past costs and money issues and be more supportive of what the LDC wants to do or accomplish.

As we have stated in previous reports: Customer Engagement is about how customers think, feel and act towards the organization. Ensuring customers respond positively requires they be rationally satisfied with the services provided AND emotionally connected to the LDC and its brand.

Utility Customer Centric Engagement Index (CCEI)			
	Waterloo North Hydro	National	Ontario
CCEI	86%	81%	80%

Base: total respondents





Customer Satisfaction

By itself, this metric is not good enough to gain a picture of how well an LDC is doing but it is a measure about whether the LDC is “doing the job” as expected. However, without satisfaction, there is no gateway to loyalty.


SATISFACTION SCORES – Electricity customers’ satisfaction			
Top 2 Boxes: ‘very + fairly satisfied’	Waterloo North Hydro	National	Ontario
PRE: Initial Satisfaction Scores	96%	91%	91%
POST: End of Interview	96%	91%	89%

Base: total respondents


The real prize is in the development of a relationship with customers. More good things exist when a customer has a high affinity for the LDC than when they dislike it. At Risk customers are more likely to complain than other customers when there are issues. Secure customers are more likely to support the direction of their LDC.

Electricity bill payers who are 'very or fairly' satisfied with ...

■ Waterloo North Hydro



Waterloo North Hydro





Loyalty Groups

Customer Loyalty Groups				
Waterloo North Hydro	Secure	Favorable	Indifferent	At Risk
2018	34%	19%	43%	4%

Base: total respondents

In the monopoly world of the LDC, loyalty is an attitudinal metric. In private industry, it is a behavioural metric.

Customer Commitment

Electricity customers' loyalty – ... Is a company that you would like to continue to do business with			
	Waterloo North Hydro	National	Ontario
Top 2 Boxes: 'Definitely + Probably' would continue	90%	80%	78%

Base: total respondents

Customer Advocacy

Electricity customers' loyalty – ... is a company that you would recommend to a friend or colleague			
	Waterloo North Hydro	National	Ontario
Top 2 boxes: 'Definitely + Probably' would recommend	87%	76%	70%

Base: total respondents





UtilityPULSE Report Card®

The purpose of the UtilityPULSE Report Card is to provide electric utilities with a snapshot of performance – on the things customers deem to be important.

Waterloo North Hydro's UtilityPULSE Report Card®

Performance

	CATEGORY	Waterloo North Hydro	National	Ontario
1	Customer Care	A	B+	B+
	Price and Value	B+	B	B
	Customer Service	A	A	B+
2	Company Image	A	B+	B+
	Company Leadership	A	B+	B+
	Corporate Stewardship	A	A	B+
3	Management Operations	A+	A	A
	Operational Effectiveness	A+	A	A
	Power Quality and Reliability	A+	A	A
OVERALL		A	A	B+

Base: total respondents



Looking to the future, where to from here?

Technological advances, social disruptions, and other issues will continue for everyone in the LDC industry. Fixing the ills of yesterday are not possible, but instilling confidence that the LDC can handle future customer needs & wants strengthens the customer-supplier relationship. By engaging stakeholders and obtaining their input in undertaking a priority planning process helps to build "prepared minds"—that is, to make sure that the LDC decision makers have a solid understanding of customer priorities, and what the business might need to change or make investments in.

High priority items based on information taken from our UtilityPULSE database include: 'Pro-actively maintaining and upgrading equipment,' 'Reducing response times to outages,' and 'Investing more in the electricity grid to reduce outages and to increase reliability and safety.'

The high scoring attributes demonstrate Waterloo North Hydro's operational effectiveness, while the low scoring attributes point to a need for more marketing communications and/or PR types of activities.

Highest scoring attributes

High scoring attributes			
Top 2 Boxes: 'Strongly + Somewhat agree'	Waterloo North Hydro	National	Ontario
Provides consistent, reliable electricity	94%	89%	90%
Makes electricity safety a top priority for employees and contractors	87%	87%	86%
Quickly handles outages and restores power	94%	87%	86%
Has a standard of reliability that meets expectations	92%	88%	88%

Base: total respondents with an opinion



Lowest scoring attributes

Low scoring attributes			
Top 2 Boxes: 'Strongly + Somewhat agree'	Waterloo North Hydro	National	Ontario
Spends money prudently	84%	73%	66%
Operates a cost-effective electricity system	78%	70%	71%
Provides good value for your money	79%	72%	71%
Cost of electricity is reasonable when compared to other utilities	70%	66%	61%

Base: total respondents with an opinion

Paying for electricity

Fall 2018 data shows dramatic changes in customers' ability to pay. Whether the change is due to price reductions, or anticipated price reductions, or a better economy, is unclear. Ability to pay is highly correlated to satisfaction. The number one billing problem, for 20 years, is "the amount is too high."

Is paying for electricity a worry or a major problem?				
	Not a worry	Sometimes	Often	Depends
Waterloo North Hydro	78%	14%	5%	1%
National	71%	18%	7%	0%
Ontario	68%	21%	8%	1%

Base: total respondents





Numbers at a Glance

	Waterloo North Hydro	National	Ontario
Customer Satisfaction: Initial	96%	91%	91%
Customer Satisfaction: Post	96%	91%	89%
Communication Score	80%	--	79%
Overall Satisfaction with the most recent experience	95%	78%	77%
Convenience of Services Score	81%	--	79%
Customer Experience Performance Rating (CEPr)	89%	84%	83%
Customer Centric Engagement Index (CCEI)	86%	81%	80%
Credibility & Trust Index	87%	82%	81%
UtilityPulse Report Card®	A	A	B+

Over the past 5-6 years LDCs have witnessed their customers move from being concerned about costs, to worried about cost, to being upset about costs and being angry about costs – and now returning to what we believe is a concern about costs. From a human nature point-of-view, when people are angry, they tend to look back in time to find someone or something to blame for their predicament. Now that customers have returned to being concerned, they are more apt to be looking forward while putting more focus on identifying and determining how they might handle future issues. The data from our Fall 2018 interviews with over 9,000+ customers shows there is support for making pro-active investments in reliability, outage restoration, outage management, and communications.





We believe, for many in society, from 2008 to mid-2017 survival was the key goal, less so in 2018. The outlook for the economy is better; wages are improving and, job openings are more plentiful – therefore putting more focus on the future.

The good news is Waterloo North Hydro remains what we call an influential brand company. The safe, reliable distribution of electricity to homes and businesses is a job which makes life better, more interesting and meaningful for consumers and customers. As a company which affects the daily life of people and businesses – an influential brand – it must consistently demonstrate that it is credible, trusted, future-oriented, cares about customers, cares about safety, cares about the environment, is professional, has high standards and is a valued corporate citizen.



The industry is far more complex today than it was 20 years ago when we conducted the 1st Annual Customer Satisfaction survey for electric utilities. Data shows that being customer-centric is important for ensuring future success of the LDC. Customers want respect.

We recommend leveraging the results from your 2018 customer satisfaction survey by having meaningful conversations with everyone about your customers' – satisfaction, concerns, wants, etc. LDCs with a constructive employee culture with high levels of employee engagement and empowerment will have an easier time defining a future path forward.



Sid Ridgley

Simul/UtilityPULSE

Email: sidridgley@utilitypulse.com or sridgley@simulcorp.com

November 2018



Table of contents

	Page		Page
Executive summary	3	Communication Channels	44
Satisfaction (pre & post)	27	- Primary source of information	44
Customer Service	32	- Communication re: billing issue	45
- Overall satisfaction with most recent experience	34	- Communication re: unplanned outage	46
Bill payers' Problems and Problem Resolution	36	- Preferred communication platforms	47
- Outages & Standard of Reliability	37	Information and Communication	48
- Billing problems	38	- Satisfaction with information provided	49
- Types of Billing Problems	39	- Amount of information received	49
- Problem solved rating	40	- Communication Score	50
Use of Technology	41	- Future communication efforts	51
Social Media	42	Convenience of Services Score	52
		- Access to services	52
		- Convenience of Services Score	53





	Page		Page
Customer Experience Performance rating (CEPr)	54	What do customers think about electricity costs	84
Customer Centric Engagement Index (CCEI)	56	What do small commercial customers think?	87
UtilityPULSE Report Card®	59	Method	95
- Waterloo North Hydro's Report Card® Scores	64	About Simul	98
The Loyalty Factor	67		
- Customer commitment	73		
- Word of mouth	76		
Corporate Image	79		
Corporate Credibility & Trust	80		
How can service to customers be improved?	82		


Satisfaction (pre & post)

As stated multiple times over many years, measuring satisfaction is an important starting point, for the creation of loyal customers. However, it is a misnomer to conclude that highly satisfied customers are also customers with a high affinity or loyalty quotient. One can be satisfied but not necessarily loyal. But it is true to conclude that the LDC (its people) must do the job as expected and required before there can be a positive emotional connection.

We've stated in the past, a focus on satisfaction prompts an organization to continue to evolve in ways which make sense to those who pay the bills. A focus on satisfaction is a focus on effectiveness in the delivery of service to the customer. Satisfied customers who trust their LDC may be more likely to seek advice, i.e. energy efficiency methods and may be more receptive to important messages, i.e. safety, new capital projects, etc.

About ratings/measures:

- Satisfaction is not a program; it is an outcome.
- **Efficiency** is about achieving objectives with the minimum amount of people, time, money and other resources.
- **Effectiveness** ratings are measures keeping the organization and its people more future focused than efficiency ratings




Finding the right balance between efficiency and effectiveness measures is difficult.

Efficiency ratings won't lead to satisfaction, but they can lead to dissatisfaction. Taking 90 seconds to answer the phone will create an agitated customer who, for the most part starts off being dissatisfied with the service – before you've even had a chance to deal with or solve their problem. Answering the phone in 20 seconds but not solving the customer's problem is not going to ameliorate the customer's perception about the transaction.

Customer expectations of their electricity LDC have evolved past the “provide electricity reliably, safely and billed both accurately with fair pricing”. They do expect their LDC to be ethical, forward-thinking, competent and trustworthy.

- **Satisfaction** happens when utility core services meet or exceed customer's needs, wants, or expectations.
- **Loyalty** occurs when a customer makes an emotional connection with their electric utility on a diverse range of expectations beyond core services.



Base: total respondents

Satisfaction alone does not make a customer loyal; a willingness to commit and advocate for a company along with satisfaction identifies the three basic customer attitudes which underpin loyalty profiles. While satisfaction is


an important component of loyalty, the loyalty definition needs to incorporate more attitudinal and emotive components.

Electricity bill payers who are 'very or fairly' satisfied with...					
	2018	2017	2016	2015	2014
Waterloo North Hydro	96%	-	95%	-	95%
National	91%	90%	86%	89%	89%
Ontario	91%	85%	81%	86%	83%

Base: total respondents / (-) not a participant of the survey year


In the Simul/UtilityPULSE Customer Satisfaction survey, the overall satisfaction question is asked both at the beginning (PRE) and the end (POST). Asking the general satisfaction question at the start of the survey avoids bias, and we obtain a spontaneous rating. This allows measurement of customers' overall impressions of the utility before prompting them to think of specific aspects of the relationship. After we have asked about specific aspects of the customer experience, we gain a more *considered* (or conditioned) response.

Waterloo North Hydro



Base: total respondents

As with any enterprise, Waterloo North Hydro has an obligation to satisfy its customers. But the rewards for satisfying customers go far beyond “obligation”. Customers with high levels of satisfaction handle problems far better than customers with low satisfaction. Stronger relationships with customers generate higher levels of involvement and participation. For employees, serving customers who are very satisfied are more enjoyable interactions than with customers who are very dissatisfied. Satisfied and engaged employees who work in an organizational culture which promotes service excellence with empowerment is an important key for completing the job both efficiently and effectively.



SATISFACTION SCORES – Electricity customers' satisfaction			
Top 2 Boxes: 'very + fairly satisfied'	Waterloo North Hydro	National	Ontario
PRE: Initial Satisfaction Scores	96%	91%	91%
POST: End of Interview	96%	91%	89%

Base: total respondents

A mutual correlation exists between employee and customer attitudes and loyalty. Employees who are trained well, have the right tools and are focused on successful outcomes for customers contribute greatly to the customers' perception of their utility. There is a direct, irrefutable link between empowered and engaged employees and customer satisfaction – after all -- *your employees are part of your brand and they deliver the promises you make.*

Waterloo North Hydro

SATISFACTION SCORES – Electricity customers' satisfaction		
Top 2 Boxes: 'very + fairly satisfied'	Residential	Commercial
Satisfaction Scores	96%	95%

Base: total respondents

SATISFACTION SCORES – Electricity customers' satisfaction [kwh usage]			
Top 2 Boxes: 'very + fairly satisfied'	kWh Group 1	kWh Group 2	kWh Group 3
Satisfaction Scores	98%	95%	94%

Base: total respondents

SATISFACTION SCORES – Electricity customers' satisfaction [Income]			
Top 2 Boxes: 'very + fairly satisfied'	<\$30K	\$30 – 75K	\$75K +
Satisfaction Scores	94%	96%	98%

Base: total respondents

Customer Service

As written in previous years, given the rapidly expanding availability and use of technology finding an appropriate balance between automated self-service and human-interactive service is a huge challenge for all involved in providing service to customers. Customer Service is about the experience your customers have with your utility, your products, and your service – regardless of the channel for used for delivering customer service. The goal is to ensure each of your customers receives high-quality customer service and an experience which meets or exceeds their expectations - on each and every interaction with the LDC.

Given the increased complexity for delivery customer service, we have seen a shift towards a stronger focus on the touch points which create the customer experience.

Most of us want the same things when we are customers: We want to be treated with respect. We want to be listened to. We don't want to be bounced around or ignored or treated as inferior. The customer experience is largely defined by the outcomes generated when customers have a need, want to solve a problem, or simply want answers to issues/concerns they face.

With more technology there will be more shifting of calls away from the call centre. However, the volume of calls which remain are and will be more complex and challenging. We're already witnessing the fact that calls are taking longer to deal with customer issues.



Customers are more concerned about outcomes, and they want their issue, problem or concern to be dealt with in a professional, knowledgeable, and timely manner. Respondents were asked about six aspects of their most recent experience with a representative from Waterloo North Hydro.

- Information – the quality of information provided
- Staff attitude – the level of courtesy
- Professionalism – the knowledge of staff
- Delivery – helpfulness of staff
- Timeliness – the length of time it took to get what they needed
- Accessibility – how easy it was to contact someone



Base: total respondents who contacted the utility

Satisfaction with Customer Service			
Top 2 Boxes: 'very + fairly satisfied'	Waterloo North Hydro	National	Ontario
The time it took to contact someone	86%	66%	64%
The time it took someone to deal with your problem	88%	72%	65%
The helpfulness of the staff who dealt with you	91%	70%	64%
The knowledge of the staff who dealt with you	89%	70%	64%
The level of courtesy of the staff who dealt with you	95%	78%	70%
The quality of information provided by the staff who dealt with you	88%	73%	61%

Base: total respondents who contacted the utility

Overall satisfaction with most recent experience			
	Waterloo North Hydro	National	Ontario
Top 2 Boxes: 'very + fairly satisfied'	95%	78%	77%

Base: total respondents who contacted the utility

Every interaction with a customer is an opportunity to generate higher levels of affinity. It is fool-hardy to view the ratings shown above as ratings for the “call-centre” because every person in Waterloo North Hydro interacts with a customer or supports those who do have person-to-person contact with a customer. Empowerment is the backbone of the service recovery principle. In the face of error or problems, acting quickly and decisively, being empowered and turning a dissatisfied customer into a satisfied one tends to have a positive impact.

Customer Focus – Service Quality

Current measures in the LDC scorecard are: New Residential Services Connected on Time; Scheduled Appointments Met on Time; and, Telephone Calls Answered on Time. These are good examples of efficiency measures as all are time-based. Showing up on time may not create satisfaction; not showing up on time will cause dissatisfaction.



UtilityPULSE findings from working with many LDCs over the past few years indicate it is much harder to get great ratings from customers who may not know much about their LDC's standards for service. Despite this, service quality ratings for Waterloo North Hydro are very good and above the Ontario benchmark.

Other dimensions of Service Quality which customers value include:

Customer Service Quality			
Top 2 boxes, 'strongly + somewhat agree'	Waterloo North Hydro	National	Ontario
Deals professionally with customers' problems	89%	83%	82%
Customer-focused and treats customers as if they're valued	83%	80%	79%
Is a company that is 'easy to do business with'	90%	82%	82%

Base: total respondents with an opinion

We live in an imperfect world, so mistakes are bound to happen. In the LDC world, not all customer problems are mistakes, some are externally driven. None-the-less customers expect professionalism when interacting with "their" LDC.

Bill Payers' Problems and Problem Resolution


As previously written over multiple years, we call blackouts (outages) and billing problems, the “Killer B’s”, the two issues which are most likely to cause grief to utility customers.

At one time, if the power went off for a few minutes, it was considered annoying and inconvenient. However, with the onset of computers and smart appliances in homes and businesses, a power outage is now unbearable. Customers have little tolerance for an interruption in their flow of electricity.

LDCs have certainly been putting more energy into disseminating information to customers about outages. Many have installed an “outage map” on their website. However, our UP database shows only 13% of customers who accessed their LDC’s website did so to get information about an outage or look at the outage map!

37% of Waterloo North Hydro respondents claimed they experienced an outage problem in the past 12 months.


Like it or not, there will be times when the power goes off – and for reasons beyond the control of the LDC.



Percentage of Respondents indicating that they had a Blackout or Outage problem in the last 12 months			
	Waterloo North Hydro	National	Ontario
2018	37%	39%	44%
2017	-	37%	38%
2016	38%	46%	46%
2015	-	53%	51%
2014	46%	47%	49%

Base: total respondents / (-) not a participant of the survey year

92% of Waterloo North Hydro respondents agree ('strongly + somewhat') the utility's standard of reliability is consistent with their expectations.



Base: total respondents

For nearly every business, the simple act of collecting payments from customers is quite complex. Organizations want to make it easy and convenient for customers to pay, so they offer multiple choices of payment types and channels. However, making it easy for the customer often makes it more complex—and costly—for the business and is certainly not without its problems or flaws.

Percentage of Respondents indicating that they had a Billing problem in the last 12 months			
	Waterloo North Hydro	National	Ontario
2018	5%	9%	9%
2017	-	12%	15%
2016	20%	15%	25%
2015	-	9%	15%
2014	9%	16%	25%

Base: total respondents / (-) not a participant of the survey year



The impact of poor billing on a utility's business is considerable, in terms of costs incurred handling customer queries and complaints. The quality of billing remains a driving force behind managing customer satisfaction and can help utilities reduce costs associated with customer service. Through reducing the total number of calls to a utility by providing accurate bills which are easily understood, a utility stems the flow of billing-related complaints into its call-centre. However, customers have a different definition than their utility as to what constitutes a billing problem.

Types of Billing Problems	
Waterloo North Hydro	
The amount owed was too high	50%
Complaint about rates or charges	25%
The bill arrived late	5%
Wrong information on the bill	5%
Did not receive bill	5%

Base: total respondents with billing problems



20% of Waterloo North Hydro respondents with an outage problem did contact the utility;
25% of Waterloo North Hydro respondents with a billing problem did contact the utility.

First Contact Resolution (FCR) rates are an important metric for improving call center performance. The first step in improving “FCR” is to survey your front-line customer touch-points and understand what kind of assistance and information customers are seeking in these situations. Once you clearly understand what kinds of interactions are taking place at each of your initial customer touch-points, you can then take steps to improve those interactions.

Percentage of Respondents who contacted their utility and had their problem solved in the last 12 months	
Waterloo North Hydro	
Yes	86%
No	9%

Base: total respondents with a problem who contacted their utility



Interestingly when customers do have a problem and contact their LDC, and get the problem solved their satisfaction ratings are very similar to the overall level of satisfaction that exists if not slightly higher, however, failing to deal or resolve a customer's problem causes satisfaction levels to drop.

SATISFACTION SCORES – Electricity customers' satisfaction			
Waterloo North Hydro	Overall	Problems Solved	Problems Not Solved
Top 2 Boxes: 'very + fairly satisfied'	96%	96%	80%

Base: total respondents with a problem who contacted their utility

We believe a major challenge for most LDCs is about increasing their knowledge about their customers and how they prefer communications to take place. Most CRM systems seem to be inadequate for providing this information about preferences.

Use of Technology

Technology is moving fast, and rapid developments in innovation are playing an essential part in customer service expectations. Today, customers have a low tolerance for slow answers and anything less than outstanding service. Their expectations far exceed anything they would have wanted a decade ago, and businesses must keep up.



Respondents were asked whether they used the following forms of technology:

Use of technology			
Waterloo North Hydro	Yes	No	Don't know
Access the internet for information	83%	17%	0%
Have a social media account	54%	44%	1%
Use online banking services	71%	25%	3%
Shop online	64%	34%	2%

Base: total respondents



Shifting activity to the online world, certainly for many of the basic problems and issues makes sense. While this certainly can help with efficiency, we must be mindful of the reality that CSRs will actually be fielding more calls that are more complex which may require CSRs (and others in the LDC) to develop a more important array of competencies and skills. However, the march towards more online activity and problem resolution should continue at a very quick pace.


Social Media

Internet forums, user communities, and social-networking sites are the new ways people are talking to each other and getting some of the answers they need. Twitter is fast becoming the go-to medium for customer support. Have a question – tweet it – and wait sometimes less than an hour for a quick fix, recommended remedy, or information on where to go next. Twitter and Facebook are increasingly being used as tools to not only disseminate information, organizations of all types can use the channels to push out news and pull prospects into their websites.

Social media is evolving, and it gives companies the opportunity to proactively identify customer issues which will help the utility address problems quickly thereby minimizing the impact on the broader customer base.

Which social media accounts do you have ...	
Waterloo North Hydro	
Facebook	58%
Twitter	24%
YouTube	34%
LinkedIn	38%

Base: total respondents who claimed to have social media accounts



Do you follow Waterloo North Hydro in ...			
	Yes	No	Don't know
Facebook	5%	95%	0%
Twitter	29%	70%	1%
YouTube	3%	97%	0%
LinkedIn	4%	95%	1%

Base: total respondents who claimed to have social media accounts



Do you follow Waterloo North Hydro in ... RESPONSE=YES			
	Income: <\$30K	Income: \$30K < \$75K	Income: \$75K+
Facebook	7%	5%	6%
Twitter	17%	18%	30%
YouTube	11%	4%	2%
LinkedIn	11%	0%	5%

Base: total respondents who claimed to have social media accounts

Do you follow Waterloo North Hydro in ... RESPONSE=YES			
	Age: 18-34	Age: 35-54	Age: 55+
Facebook	10%	3%	2%
Twitter	25%	31%	16%
YouTube	8%	0%	2%
LinkedIn	8%	2%	3%

Base: total respondents who claimed to have social media accounts

Communication Channels

Utilities need to know the response they are seeking from customers when planning their communications and outreach. Sending inserts with monthly bills which provide information to a customer is passive and not very effective. Although your customer audience is captive, a poorly targeted message is often ignored. Posting information on a website—unless a customer is actively searching for it—will likely not be found. Email blasts, and social media campaigns will reach customers, but may not lead to action. Such messages are typically read when in transit or multitasking, making them an afterthought. So, it often takes several pushes for these messages to resonate before action is taken. Successful marketing and messaging is simple, consistent, and continually reinforced.

Primary Source of Information

Primary Source for getting information on ...					
Waterloo North Hydro	Corporate website	Twitter	Facebook	Bill Inserts	eBlasts
A power outage	39%	6%	3%	5%	3%
An issue with your bill	35%	0%	1%	10%	3%
General corporate news	35%	2%	3%	16%	3%
Electricity safety information	42%	1%	2%	19%	3%
Energy conservation tips	38%	2%	3%	24%	3%
Changes in electricity rates	34%	1%	2%	31%	4%

Base: total respondents

Communication to notify about a Billing Issue

Billing issues have long been a major cause of customer enquiry and complaint. Not only are bills a key part of an LD's revenue management processes, but they're also an essential element and touchpoint in their relationship with their customers. For many customers, it is one of the very few touchpoints they have with their LDC. Yet because of its nature, the bill is usually viewed by customers as a wholly negative communication. Therefore, when problems do occur and the LDC must initiate contact with their customer it would be beneficial to the process if customers were contacted via channels they most prefer.

Waterloo North Hydro customers' preferred or primary method for Waterloo North Hydro to contact them about billing issues are as follows:

Preferred method of communication to receive notice of a billing issue		
	Ontario LDCs	Waterloo North Hydro
Telephone	56%	59%
Voice Mail	2%	2%
Text	7%	4%
Email	34%	34%
Don't know	1%	1%








Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

Effective communication is essential in order to provide good customer service, improve efficiency and reduce costs. LDCs must maximize the effectiveness of their communications and improve customer interactions consistently across a number of media channels and customer touch points.

Communication during Unplanned Outages

In times of emergency, be they extreme weather events or major equipment failures that cause blackouts and unplanned outages, customer communication can help customers understand what to expect next and when disrupted electricity service might be restored. Early and effective communication helps increase confidence in and credibility of the electricity service provider.

Respondents were asked which communication channel they most preferred Waterloo North Hydro to use during an unplanned outage.

Method of communication Customers prefer their LDC uses during an UNPLANNED OUTAGE						
Recorded Telephone Message	Email Notice	Posted on the Website	Social Media	Local Radio	Local TV	Text Message
						
36%	25%	5%	3%	8%	3%	19%

Base: total respondents

Preferred Communication Platforms

Which communication platform or platforms would you prefer Waterloo North Hydro use ...	
Social media	16%
Newspaper	14%
Radio	16%
Bill inserts	27%
Website	27%
Email / eBlasts	48%
Other	8%

Base: total respondents

Which of the following methods would you most like to see Waterloo North Hydro contact you by...	
Live chat	2%
Phone call	45%
Email	41%
Text/SMS Message	9%
In-person visit	2%

Base: total respondents

Providing communication platforms that are effective and meet customers' needs is key to improving the customer experience. To do this, Waterloo North Hydro must understand how customers communicate with you, and how they would like Waterloo North Hydro to communicate with them in future. Knowing this will allow Waterloo North Hydro to: allocate resources where they are most needed; tailor services to meet customers' needs; and, identify where improvements can be made.



However, while most customers appear to have capacity and willingness to use digital channels, there are also customers who do not for a variety of reasons, such as a lack of ability or resources, or due to a preference for other channels. Waterloo North Hydro will need to consider how these customers can be supported and encouraged to use digital services in the future.

Information and Communication

LDCs across the province are increasingly seeing the need to invest in aging infrastructure, new technologies, regulatory requirements, and a skilled workforce. They are addressing these needs to uphold their public service duty, all the while keeping in mind the need to communicate with their customers. Part of communication is the requirement of providing information and/or education to the public in order to raise the level of understanding surrounding an issue or topic that may be of practical concern to residents.

Consumer information is meant to attune consumers to certain problems [i.e. outage problems, etc.], create awareness and educate [i.e. electricity safety, etc.] or even guide (influence) their

behaviour [i.e. energy conservation, etc.]. Individuals and stakeholders are then able to properly assess and evaluate the impacts of various policies and initiatives proposed by the LDC.



Customers were asked about their level of satisfaction with the information provided by Waterloo North Hydro on the following:

Satisfaction with information provided		
Top 2 Boxes: 'very + fairly satisfied'	Ontario LDCs	Waterloo North Hydro
The amount of information available to you about energy conservation	82%	82%
The quality of information available when outages occur	73%	78%
The electricity safety education provided to the public	74%	75%
The timeliness and relevance of information for things such as planned outages, construction activity, tree trimming.	78%	77%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

While providing information is important, one has to ensure that it is neither overwhelming the audience to the point of turning them off, or not providing enough information causing recipients to feel you have not adequately looked after them.

Amount of Information received from Waterloo North Hydro is ...			
	LESS than you would like	About the RIGHT amount	MORE than you need
Safety	7%	81%	5%
Energy Efficiency	12%	77%	7%
Billing and Account Questions	4%	86%	4%
Outages	13%	75%	4%
Construction projects and planning	15%	69%	7%

Base: total respondents

Communication Score		
	Ontario LDCs	Waterloo North Hydro
Communication Score	79%	80%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility



Based on customer responses, Waterloo North Hydro has rated 80% for a Communication Score.

Future Communication Efforts

Respondents were asked on which topics Waterloo North Hydro should focus their future communication efforts.

Future Communication Efforts should focus on ...	
Safety	15%
Energy Efficiency	30%
Billing and Account Questions	10%
Outages	10%
Construction projects and planning	8%

Base: total respondents

Respondents were asked: ***“Is there a topic other than the ones we’ve talked about that you would like Waterloo North Hydro to provide more information about?”*** Base: total respondents



14%
wanted **additional**
information.



85%
Required **no further**
information.



ADDITIONAL TOPICS mentioned:

- Prices/costs/fees
- Communication with customers
- Rebates
- Payment options
- My usage/my neighbour's consumption
- Potential mergers
- SMART meters
- Outage map

Convenience of Services Score

Rising customer expectations and demands means customers expect to be able to contact you 24 hours a day, seven days a week using various communication avenues i.e. telephone, your website and/or even social media. Customers expect flexible and more personalized services. Gauging customers' satisfaction levels with access to various services allows Waterloo North Hydro to use this customer intelligence to inform and shape your service delivery so that you can better understand what your customers need and so that you can respond better.



Access to services		
Top 2 Boxes: 'very + somewhat satisfied'	Ontario LDCs	Waterloo North Hydro
The availability of call-centre staff Monday to Friday from 8:30 am to 4:30 pm	76%	75%
The 24/7 availability of system operators to respond to outages	77%	80%
The online self-serve options for managing your account	63%	67%
The online self-serve options for request services	56%	61%
The 24/7 availability of outage map on the website	n/a	66%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

When customers have a high level of satisfaction with access to services, it is much easier for LDCs to forge a new kind of relationship with its customers which, in turn, helps all parties successfully deal with the issues and opportunities of the new energy world.

Digital exclusion – some people may not have access to the internet at home, and that may mean that they would not have access to information and/or services online. Waterloo North Hydro needs to continue to recognize this and ensure that customers may access services via alternate formats where necessary and feasible.

Convenience of Services Score		
	Ontario LDCs	Waterloo North Hydro
Convenience of Services Score	79%	81%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

Providing customers with clear, easy to access services and information which is easy to understand has a significant impact on the customer experience.



Convenience of Services Score

Based on customer responses, Waterloo North Hydro has achieved a score of 81% for Convenience of Service while Ontario LDCs rated 79%.


Customer Experience Performance rating (CEPr)

The CEPr score is an effectiveness rating and is affected by many dimensions of service. Every touch point with customers on the phone, website or in-person influences what customers think and feel about the organization. While an excellent transaction today creates a positive experience today, the perception created is future transactions will be excellent too. Of course, a negative transaction creates the perception future transactions will be negative.

When the customer experience is strong, the opportunity to build loyalty is great. When the experience is a negative one, customers often conclude the organization doesn't care. When a customer believes the organization doesn't care, outrage and anger are a very real possibility.

Understanding your customer's expectations for service is the first step in providing an amazing customer experience. It is essential customer care call centers develop a comprehensive understanding of what

At the heart of the CEPr are 4 central questions:

- 
1. Are interactions with the organization professional and productive?
 2. Is the organization 'easy to deal with'?
 3. Does the organization effectively meet your needs?
 4. Does the organization provide high quality services?

customers expect from them, whether or not their needs are being met and how they can improve their service to meet their expectations.

Some of the factors which contribute to the overall customer experience:

- Delivering accessible and consistent customer service (multi-channel)
- Understanding customer expectations
- Maintaining timely resolution timelines
- Providing effective communication(s) according to customer needs
- Demonstrating responsiveness
- Speeding up problem resolution
- Conducting problem analysis to prevent recurring issues
- Easy to do business with
- Seeking customer feedback and following through on recommendations



Customer Experience Performance rating (CEPr)			
	Waterloo North Hydro	National	Ontario
CEPr: all respondents	89%	84%	83%

Base: total respondents

The CEPr for Waterloo North Hydro is 89%. This rating would suggest that a very large majority of customers have a belief they will have a good to excellent experience dealing with Waterloo North Hydro professionals.


Customer Centric Engagement Index (CCEI)

Customer engagement and customer satisfaction are very different measures. We believe generating high scores in customer engagement is more difficult than customer satisfaction. For example, a customer can be highly satisfied when the LDC reliability delivers electricity, bills the customer properly and quickly deals with outages. Essentially when the LDC does what it promises to do, then satisfaction follows.

Customer engagement is about connecting with customers in ways to demonstrate the LDC has heard the customer, understands the customer's needs, wants, desires and issues. When the LDC does demonstrate hearing and understanding, the result is higher levels of emotional connection, i.e., feelings that the people at the LDC care, respect and value their customers or are prepared to go-out-of-their-way (if necessary) to help.

Customer engagement is often thought of as a series of activities involving the customer such as conducting a survey, holding town hall type meetings, focus groups, etc. One could call these types of activities as the behaviour side of engagement. However, there is an emotional side to engagement.

UtilityPULSE has identified the six key dimensions of what defines customer engagement. They are: empowered, valued, connected,



inspired, future-oriented and performance oriented. Customer-centric engagement is a measure of “goodwill” towards the utility. The UP database does show Secure customers believe they are more highly engaged with their LDC than customers who are At Risk.

This survey also provides you with an emotional look at engagement. The UtilityPULSE CCEI is a gauge of the amount of goodwill which has been generated. High numbers in CCEI suggest there is a high level of goodwill amongst your customers – this is important for two reasons. First, when something goes awry for the utility, goodwill helps the utility to be resilient. Second, goodwill encourages active participation in requests to participate in engagement activities or program offerings from the utility.

The CCEI is a metric designed to get a more in-depth look at the attachment a customer has with your LDC and its brand. High levels of customer engagement (emotional) correlate strongly to high levels of Secure and Favourable customer numbers.

Engagement is how customers think, feel and act

towards the organization. As such, ensuring customers respond in a positive way requires they are rationally satisfied with the services provided AND emotionally connected to your LDC and its brand. The more frequently



and consistently an organization’s products and services can connect with a customer, especially on an emotional level, the stronger and deeper the customer becomes engaged with the organization.

Utility Customer Centric Engagement Index (CCEI)			
	Waterloo North Hydro	National	Ontario
CCEI	86%	81%	80%

Base: total respondents

Customers who are less engaged, as measured by the CCEI are more likely to let costs and/or price impact their perceptions of their LDC. Customers who are highly engaged are more inclined to look past costs and money issues and use a rational approach to make values-based decisions. Highly engaged customers have a stronger emotional connection to your utility. It’s this emotional connection which will drive commitment, loyalty, and advocacy.

Using the measures of Satisfaction and Engagement the LDCs relationship with its customers would fall into one of four quadrants: Q1- low satisfaction/low engagement; Q2- high satisfaction/low engagement; Q3- low satisfaction/high engagement and Q4- high satisfaction/high engagement. Most LDCs would agree to have customers fall into the Q1 quadrant isn’t good and having customers fall into Q4 is ideal.

When LDCs have candid conversations with customers and employees about their joint and different needs & perspectives the better, the LDC can be for creating an excellent place to do business with and to work.

UtilityPULSE Report Card®


Simul's UtilityPULSE Report Card® is based on tens of thousands of customer interviews gathered over eighteen years. The purpose of the UtilityPULSE Report Card® is to provide electric utilities with a snapshot of performance – on the things customers deem to be important. Research has identified over 20 attributes, sorted into six topic categories (we call these drivers), which customers have used to describe their utility when they have been satisfied or very satisfied with their utility. These attributes form the nucleus, or base, from which “scores” are assigned. Customer satisfaction and loyalty also play a major role in the calculations.

There are two main dimensions of the UtilityPULSE Report Card® the first is customer psyche and the other is customer perceptions about how the utility executes its business.

The Psyche of Customers

Every utility has virtually the same responsibility – provide safe and reliable electricity – yet not all customers are the same. The following chart shows the weight or significance of each category to the customer when forming their overall impression of the utility. Three major themes, each with two major categories make up the UtilityPULSE Report Card®. In effect, the Report Card provides feedback about your customers' perception of the importance of each category and driver – as it relates to the benchmark.

UtilityPULSE Report Card® for Waterloo North Hydro



Base: total respondents

The UtilityPULSE Report Card® also provides customer perceptions about how your utility executes or performs its responsibilities. This is different, very different, from what a customer might say about a major concern or worry they have about electricity. As our survey has shown since its inception, the primary suggestion for improvement is “reduce prices”, which is also a major concern which your customers have about municipal taxes, gas for the vehicle, and other utilities.

Readers of this report should note that the categories and drivers are interdependent. Which means, for example, failure to provide high levels of power quality and reliability will have a negative impact on customer perceptions as it relates to customer service. Customer care, when it doesn't meet customer expectations has a negative impact on Company Image, etc.

Defining the categories and major drivers:

Category: Customer Care

Drivers: Price and Value; Customer Service

Just because everyone likes good customer care, that in and by itself, is not a reason to provide it – though it may be important to do so. In highly competitive industries good customer service may be a differentiating factor. The case for electric utilities is simple, high levels of customer care result in less work (hence cost) of responding to customer inquiries and higher levels of acceptance of the utility's actions.

Price and Value:

Customers have to purchase electricity because life and lifestyle depend on it. This driver measures customer perceptions as to whether the total costs of electricity represent good value and whether the utility is seen as working in the best interests of its customers as it relates to keeping costs affordable.

Customer Service:

Customers do have needs, and every now and again have to interface with their utility. How the utility handles various customers' requests, and concerns are what this driver is all about. Promptly answering inquiries, providing sound information, keeping customers informed and doing so in a professional manner are the major components of this driver.

Category: Company Image

Drivers: Company Leadership; Corporate Stewardship

Utilities have an image even if they do not undertake any activities to try to build it. A company's image is both a simple and complex concept. It is simple because companies do create images which are easily described and recognized by their target customers. It is complex because it takes many discrete elements to create an image which includes, but is not limited to: advertising, marketing communications, publicity, service offering, and pricing.

An electric utility trying to manage its image has one more challenge to deal with, and that is the electric industry itself. There are so many players, residential customers (in particular) don't know who does what or who is responsible for what. So, when there are political or regulatory announcements, the local utility is often swept up into the collective reaction of the population.

Company Leadership

This driver is comprised of customer perceptions as it relates to industry leadership, keeping promises and being a respected company in the community.

Corporate Stewardship

Customers rely on electricity and want to know their utility is both a trusted and credible organization which is well managed, accountable, socially responsible and has its financial house in order.

Category: Management Operations

Drivers: Operational Effectiveness; Power Quality and Reliability

Electrical power is the primary product which utilities provide their customers and, they have very high expectations the power will be there when they need it. Customers have little tolerance for outages. The reality is, every utility must get this part right...no excuses. It is the utility's core business. This category and its drivers are clearly the most important for fulfilling the rational needs of a utility's customers.

Operational Effectiveness

This driver measures customers' perceptions as they relate to ensuring their utility runs smoothly. Attributes such as accurate billing and meter reading, completing service work in a professional and timely manner and maintaining equipment in good repair are deemed as important to customers.

Power Quality and Reliability

Power outages are a fact of life – and, customers know it. They expect their utility to provide consistent, reliable electricity, handle outages and restore power quickly and make using electricity safely an important priority.

Waterloo North Hydro's UtilityPULSE Report Card®

Performance

	CATEGORY	Waterloo North Hydro	National	Ontario
1	Customer Care	A	B+	B+
	Price and Value	B+	B	B
	Customer Service	A	A	B+
2	Company Image	A	B+	B+
	Company Leadership	A	B+	B+
	Corporate Stewardship	A	A	B+
3	Management Operations	A+	A	A
	Operational Effectiveness	A+	A	A
	Power Quality and Reliability	A+	A	A
OVERALL		A	A	B+

Base: total respondents

Ontario LDCs get a “C” rating for ‘cost of electricity is reasonable when compared to other utilities such as gas, cable, and telephone’ C+ rating for ‘spends money prudently’.

As the UtilityPULSE Report Card® shows, the total customer experience with an electric utility is defined as more than “keeping the lights on”. Customers deal with your utility every day for a variety of reasons, most likely because they need someone to help them solve a problem, answer a question or take their order for service. All your employees, from customer service representatives to linemen, leave a lasting impression on the customers they interact with. In effect, there are many moments of truth. Moments of truth are every customer touch point a utility has with their customers. Therefore, managing these moments of truth creates higher levels of Secure customers while reducing the number of At Risk customers which exist.


It's the small things done consistently that matter: Things like greeting every customer, whether on the phone or in person, in a friendly and helpful manner. Things like listening to the customer's needs, providing solutions to their problems and showing appreciation to the customer for their business.

Utilities now recognize customer communications as a valuable aspect of their business. The better a utility communicates with customers in a manner which speaks to them; the more satisfied they are with their overall service. “Sending out information” is not the same as having a “conversation” with a customer. We believe it is increasingly important to channel your communications to the various customer segments which exist.

Obviously, employees – in every area – play a critical role in customer service success. Consequently, how they feel about their job responsibilities and role in the company will be communicated indirectly through the level of service which they provide customers with whom they interact. The reality is engaged employees are the key to excellent customer care.

Our survey work with employees shows there are many elements of an organizational culture to support the people model needed to achieve high levels of engagement.

Our research has identified 6 main drivers which promote and support people giving their best:



There are 12 key processes from “attracting employees” to “saying goodbye to employees” are part of your people model to get the best performance from every employee.

We believe taking the time to understand the difference between employee satisfaction and organizational culture is worthwhile from a resourcing perspective and a people development perspective. Every organization has a culture – we believe it is a leadership imperative to install and maintain a culture which ensures you attain the achievements and successes of your utility’s many investments in people, technology and equipment. It is true, organization culture affects everyone, and everyone affects organization culture.

The Loyalty Factor

If a customer is satisfied, it doesn't necessarily mean he or she is loyal. Satisfaction is about fulfilling promises/expectations; loyalty goes way beyond that by creating exceptional experiences and long-lasting relationships. There is a reason why marketing campaigns strive to build brand loyalty, not brand satisfaction. Measuring customer loyalty in an industry where many customers don't have a choice of providers doesn't make sense. Or does it?


The answer depends on how you define "customer loyalty."

Private industry often equates customer loyalty with basic customer retention. If a customer continues to do business with a company, the customer is, by definition, considered to be loyal. If this definition were applied to many companies in the utility industry, all customers would automatically be considered loyal. As such, measuring customer loyalty would appear to be unnecessary.

Natural monopolies (like LDCs) are not really different in what they should measure except that trying to determine which customers are "loyal" or "at risk" is not about their future behaviour but more about their "attitudinal" loyalty (are they advocates?).



Customer Service, when done well, promotes satisfaction which builds the foundation towards loyalty. Whether a customer is loyal and/or satisfied will be determined by three realities: ANTICIPATION – what your customer anticipates or expects; INTERACTION – what actually happened with/to the customer; and REACTION – how did the customer respond and how did it ultimately make the customer feel.



Perhaps a better or more relevant way for utilities to approach the definition of customer loyalty is to further expand how they think about loyalty. Consider the following definition: Customer loyalty is an emotional disposition on the part of the customer which affects the way(s) in which the customer (consistently) interacts, responds or reacts towards the company – its products & services and its brand.

So, what does it mean to respond favourably to a company? At a basic level, this can mean choosing to remain a customer. As previously mentioned, however, this is essentially a non-issue for many utility companies. It then becomes necessary to think beyond just customer retention. One needs to consider other ways in which customers can respond favourably toward a company.

Some Tips to build loyalty:

- ✓ Solve problems quickly
- ✓ Treat customers right
- ✓ Listen to complaints
- ✓ Be personal; create a great experience
- ✓ Friendly customer service
- ✓ Accessible information or help
- ✓ Good reputation
- ✓ Demonstrate your care

Other favourable responses or behaviours can be classified into one of three categories that reflect the concept of customer loyalty:

- Participation
- Compliance or Influence
- Advocacy

Specific examples of potential participatory behaviour in the electric utility industry include:

- Signing up for programs which help the customer reduce or manage their energy consumption
- Using the utility as a consultant when selecting energy products and services from a third party
- Participating in pilot programs or research studies.

Specific examples of potential compliance or influence behaviours utility customers might exhibit include:

- Seeking the utility's advice or expertise on an energy-related issue
- Voluntarily cutting back on electricity usage if the utility advised the customer to do so
- Accepting the utility's energy advice or referrals to energy contractors or equipment
- Being influenced by the utility's opinion regarding energy- management advice, equipment, or technologies
- Providing personal information which enables the utility to better serve the customer
- Paying bills online.

Creating customer advocates can be especially important for a company in a regulated industry. In the absence of customer advocates, or worse, in a situation where customers speak unfavourably about a company or actively work to support issues that are counter to those the company supports, companies can suffer a variety of negative consequences like increased business costs, lawsuits, fines, and construction delays. For an electric utility, specific examples of potential advocacy behaviour include:

- Supporting the utility's positions or actions on energy-related public issues, including the environment
- Supporting the utility's position on the location and construction of facilities
- Providing testimonials about positive experiences with the utility.

In sum, loyal behaviour in the utility industry may not be as evident as it is in a more competitive environment. Measuring customer loyalty in a generally non-competitive industry requires one to think about loyalty in non-traditional ways. Customer loyalty is an intangible asset which has positive consequences or outcomes associated with it no matter what the industry. Properly measuring loyalty among utility customers requires thoughtful probing to thoroughly identify the range of participation, compliance, and advocacy behaviours that will ultimately benefit the company in meaningful ways and foster happier and more loyal customers.

Loyalty is driven primarily by a company's interaction with its customers and how well it delivers on their wants and needs.

Customer Loyalty Model



Loyalty is based on likelihood to:

- **Satisfaction:** overall satisfaction
- **Commitment:** continue as a customer
- **Advocacy:** willingness to recommend

The UtilityPULSE Customer Loyalty Performance Score segments customers into four groups: **Secure** – the most loyal - **Still Favorable**, **Indifferent**, and **At risk**.

Secure customers are “very satisfied” overall with their local electricity utility. They have a very high emotional connection with their utility and definitely would recommend their local utility.


Still favorable customers are “very satisfied” overall, “definitely” or “probably” would recommend their local utility and not switch if they could.

Indifferent customers are less satisfied overall than secure and still-favorable customers and less inclined to recommend their local utility or say they would not switch.

At risk customers, who are “very dissatisfied” with their electric utility, “definitely” would switch and “definitely” would not recommend it.

Customer Loyalty Groups				
	Secure	Favorable	Indifferent	At Risk
Waterloo North Hydro				
2018	34%	19%	43%	4%
2017	-	-	-	-
2016	25%	16%	53%	6%
2015	-	-	-	-
2014	24%	12%	61%	2%

Base: total respondents / (-) not a participant of the survey year




Base: total respondents

Customer Loyalty Groups				
	Secure	Favorable	Indifferent	At Risk
Ontario				
2018	20%	16%	50%	13%
2017	19%	13%	52%	17%
2016	17%	13%	54%	16%
2015	17%	11%	61%	11%
2014	17%	10%	57%	17%
National				
2018	24%	15%	51%	10%
2017	21%	16%	50%	13%
2016	23%	12%	54%	11%
2015	18%	11%	61%	10%
2014	20%	11%	56%	13%

Base: total respondents

Customer commitment

Customer Loyalty Model



Customer loyalty is a term which can be used to embrace a range of customer attitudes and behaviours. One of the metrics used to gauge loyalty is the measure of **retention**, or intention to buy again; this loyalty attitude is termed **commitment**. For LDCs commitment is not about behaviour it is about attitude, i.e., do they want to remain your customer.

Customer commitment is a very important driver of customer loyalty in the electricity service industry. In a similar way to trust, commitment is considered an important ingredient in successful relationships. In simpler terms, commitment refers to the motivation to continue to do business with and maintain a relationship with a business partner, i.e. the local utility.

For electric utilities, this measurement is about identifying the number of customers who feel they “want to” vs. “have to” do business with you. Potential benefits of commitment may include word of mouth communications - an important aspect of attitudinal loyalty. Committed customers have been known to demonstrate a number of beneficial behaviours, for example, committed customers tend to:

- Come to you. One of the key benefits of establishing a good level of customer loyalty is customers will come to you when they need a product or service

- Validate information received from 3rd parties with information and expertise that you have
- Try new products/initiatives
- Perhaps they will even trust you when recommendations are made
- Be more price tolerant
- More receptivity of utility viewpoints on various issues
- More tolerance of errors or issues which inevitably take a swipe at the utility
- Stronger levels of perception regarding how the utility is managed.


Though customers cannot physically leave you, they can emotionally leave you, and when they do, it becomes an extreme challenge to garner their participation or support for utility initiatives.

Electricity customers' loyalty – ... Is a company that you would like to continue to do business with			
	Waterloo North Hydro	National	Ontario
Top 2 Boxes: 'Definitely + Probably' would continue	90%	80%	78%
Definitely would continue	59%	45%	43%
Probably would continue	31%	35%	34%
Might or might not continue	2%	4%	3%
Probably would not continue	2%	5%	6%
Definitely would not continue	2%	5%	6%

Base: total respondents

Electricity customers' loyalty – ... Is a company that you would like to continue to do business with					
Waterloo North Hydro	2018	2017	2016	2015	2014
Top 2 boxes: 'Definitely + Probably' would continue	90%	-	84%	-	86%


Base: total respondents / (-) not a participant of the survey year



Base: total respondents

Word of mouth

Customer Loyalty Model




Advocacy is one of the metrics measured in determining customer loyalty. Essentially, companies believe a loyal customer is one who is spreading the value of the business to others, leading new people to the business and helping the company grow. Customer referrals, endorsements and spreading the word are extremely important forms of customer behaviour. For LDCs this is about generating positive referants about the LDC

as a relevant and valuable enterprise.



When customers are loyal to a company, product or service, they not only are more likely to purchase from the company again, but they are more likely to recommend it to others – to openly share their positive feelings and experiences with others. In today's world, thanks to the Internet, they can tell and influence millions of people. The same holds true, if not more, when customers are disloyal. Disgruntled customers could share their negative experiences with an ever-widening audience, jeopardizing a company's reputation and resulting in fewer engaged customers and/or customers who are Favourable or Secure. Secure customers, typically are advocates and they are deeply connected and brand-involved.

Would you tell me if you agree or disagree with the following statement? Waterloo North Hydro is a company that you would recommend to a friend or colleague ...



Base: total respondents

Word of mouth communication is a very powerful form of communication and influence. When customers are speaking to other customers (or their peers) it is more credible, goes through less perceptual filters and can enhance the view of services or products better than marketing communication.

There are two forms of word of mouth which utilities need to understand. The first is *Experience-based* word of mouth which is the most common and most powerful form. It results from a customer's direct experience with the utility or the re-statement of a direct experience from a trusted source.

The second is *Relay-based* word of mouth. This is when customers pass along important messages to others based on what they have learned through the more traditional forms of communications. For example, if the utility was communicating an offer for "free LED lights" chances are high the offer will be "relayed" to others through word of mouth.

For an electric utility, specific examples of potential positive advocacy behaviour include:

- Recommending other customers specifically locate in the geographic area which is serviced by that utility
- Supporting the utility's positions or actions on energy-related public issues, including the environment
- Supporting the utility's position on the location and construction of facilities
- Providing testimonials about positive experiences with the utility

Electricity customers' loyalty – ... is a company that you would recommend to a friend or colleague			
	Waterloo North Hydro	National	Ontario
Top 2 boxes: 'Definitely + Probably' would recommend	87%	76%	70%
Definitely would recommend	51%	41%	37%
Probably would recommend	35%	35%	33%
Might or might not recommend	2%	6%	5%
Probably would not recommend	3%	7%	9%
Definitely would not recommend	4%	4%	8%

Base: total respondents

Electricity customers' loyalty – is a company that you would recommend to a friend or colleague					
Waterloo North Hydro	2018	2017	2016	2015	2014
Top 2 boxes: 'Definitely + Probably' would recommend	87%	-	76%	-	80%

Base: total respondents / (-) not a participant of the survey year

Our survey research as well as theory backs up the fact that if your customers are willing to endorse you and put their reputation on the line to recommend you, they also trust you and are satisfied with the service you are providing.

Corporate image

Although reputation is an intangible concept, a strong corporate image makes it easier to capture the attention of more customers – more often. Also, to be seen as an independent organization thereby making it easier to introduce new ideas. Employees appreciate a strong corporate image.

Attributes measured in the annual UtilityPULSE survey which are strongly linked to a utility's image include:

Marketing – Communications			
	Waterloo North Hydro	National	Ontario
Topics which require more pro-active communication			
Cost of electricity is reasonable when compared to other utilities	70%	66%	61%
Provides good value for money	79%	72%	71%
Operates a cost-effective electricity distribution system	78%	70%	71%
Provides information to help customers reduce their costs	80%	78%	78%
Adapts well to changes in customer expectations	79%	73%	72%
Topics that your utility scores very well on			
Delivers on its service commitments	90%	86%	86%
Electricity safety is a top priority	87%	87%	86%
Quickly handles outages and restores power	94%	87%	86%
Standard of reliability delivering electricity that meets expectations	92%	88%	88%
Provides consistent, reliable energy	94%	89%	90%

Base: total respondents with an opinion

Corporate Credibility & Trust

Credibility is a judgment, customers and others make about whether a person or an organization has the competencies and experience to do what they promise to do. Trust, is a feeling or belief, that a person or an organization they are dealing with is doing so in an honest, open manner with no hidden agendas. How customers and other stakeholders respond to your communications is affected by the person's perception. Without credibility and trust, everything you say to customers, employees, and others can be questioned.

Of paramount importance to maintaining credibility & trust is effectively managing expectations—customers, employees and other stakeholders that matter to the business of the LDC. A key to this is open and honest communications. An important benefit of having a high degree of credibility & trust is, authentic collaboration can become a reality. Credibility & trust is a powerful currency for building relationships. Credibility & trust are outcomes based on what the LDC actually does, not what it might be doing.

Attributes strongly linked to Credibility & Trust			
	Waterloo North Hydro	National	Ontario
Overall the utility provides excellent quality services	89%	85%	86%
Keeps its promises to customers and the community	85%	79%	80%
Customer-focused and treats customers as if they're valued	83%	80%	79%
Is a trusted and trustworthy company	89%	83%	82%

Base: total respondents with an opinion

Knowledge is captured by the utility's ability to demonstrate that it is actively aware of industry, regulatory and economic changes within the industry and how these might impact the lives of customers.

Knowledge

Simul/UtilityPULSE research shows the under-pinning components which lead customers to believe an organization has credibility and can be trusted are: Knowledge, Integrity, Involvement and Trust.

Trust — Trust is achieved through a track record of consistent and reliable performance, delivering on commitments and demonstrated accountability.

Trust

Involvement — Corporate Involvement is increasingly important to Canadian communities as it is an opportunity for their local utility to use their resources and man-power to benefit people at the community level. This helps to build credibility as customers see that the organization is acting and delivering on its commitments. This helps customers regard the utility with esteem and respect.

Involvement

Integrity is established by demonstrating adherence to a code of conduct. It requires consistently acting in accordance with the values and goals that have been communicated to customers.

Integrity

Credibility and Trust Index

Waterloo North Hydro 87%

Ontario 81%

National 82%

How can service to customers be improved?

The electric utility industry is in a state of continuous transformation. External factors - including shifts in governmental policies, a global thrust to conserve energy, advances in new technologies and power generation are driving massive changes throughout the industry. LDCs of today and the future can also expect a much more intense level of customer involvement. UtilityPULSE research shows customers want to be heard.

Despite all the talk today centered on quality, new processes and systems, continuous improvement, and costs, unless all of this is aimed at obtaining customer satisfaction it will not be worth much over the longer term.

Qualitative questions typically do not provide the statistical richness which is associated with a quantitative question. However, they do provide words, phrases, insights into the thinking patterns and/or feelings of customers. This means qualitative questions have an interpretive richness that assists in deriving meaning from the survey. The broader range of suggestions we are getting when conducting the survey is a sign the customer base is becoming more and more segmented. Not all customers are the same.

The struggle for electric utilities is finding the right balance between cost-effective, technology-enabled approaches to customer services and person-to-person contact.

Customers want their utility to focus on what matters most; offer products and services which “make a difference in their life”, “gives them peace of mind” and “delivered by trusted and credible people”.

And we are interested in knowing what you think are the one or two most important things Waterloo North Hydro could do to improve service to their customers?

One or two most important things ‘your local utility’ could do to improve service	
Waterloo North Hydro	
Better prices/lower rates	46%
Be more efficient	7%
Information & incentives on energy conservation	7%
Improve/simplify/clarify billing	6%
Better communication with customers	5%
Improve reliability of power	3%
Restore power faster	2%
Eliminate SMART meters	1%
Better information when outages occur	1%

Base: total respondents with suggestions

What do customers think about electricity costs?


At the height of the ‘anger’ stage for many customers, the UtilityPULSE database showed 31% of survey respondents said they sometimes worried about paying their bill. Customers felt they were paying more but not getting more, especially disconcerting when wages and inflation were hovering around the 2% mark. Five years earlier that number was 21%. The 2017 25% reduction in costs, coupled with a promise to further reduce the cost and a better economy has helped to move the number back to 21% in Ontario. This is a huge change.

Next, I am going to read a number of statements people might use about paying for their electricity. Which one comes closest to your own feelings, even if none is exactly right? Paying for electricity is not really a worry, Sometimes I worry about finding the money to pay for electricity, or Paying for electricity is often a major problem?

Is paying for electricity a worry or a major problem?				
	Not a worry	Sometimes	Often	Depends
Waterloo North Hydro	78%	14%	5%	1%
National	71%	18%	7%	0%
Ontario	68%	21%	8%	1%

Base: total respondents

Is paying for electricity a worry or a major problem?



Base: total respondents

Is paying for electricity a worry or a major problem?				
	Not a worry	Sometimes	Often	Depends
Waterloo North Hydro				
<\$30,000	56%	26%	12%	0%
\$30<\$75,000	75%	16%	7%	1%
\$75,000+	91%	7%	2%	1%

Base: total respondents

Is paying for electricity a worry or a major problem?				
	Not a worry	Sometimes	Often	Depends
Ontario				
2018	68%	21%	8%	1%
2017	61%	26%	10%	1%
2016	49%	31%	16%	3%
2015	59%	25%	10%	2%
2014	59%	26%	11%	2%
National				
2018	71%	18%	7%	0%
2017	67%	19%	11%	1%
2016	58%	29%	10%	2%
2015	67%	22%	8%	2%
2014	69%	20%	7%	3%

Base: Ontario and National Benchmarks

What do small commercial customers think?

Based on data in the UtilityPULSE database, small commercial customers have relatively similar views about their utility. The tables associated with this report will contain your specific information as it relates to residential and commercial customers. A word of caution, smaller data samples create greater swings or spreads in the data, hence mitigating the effect of a small data sample by using the UP database.



Small Commercial Customer (General Service < 50kW Demand)

A small commercial customer is defined by the OEB as a non-residential customer in a less than 50 kW demand rate class. These customers are similar to the residential customer in that their bill does not have a demand component to it and their charges are based upon KWH of consumption. Most of these customers would occupy small storefront locations or offices

An area of concern is about the LDC's ability to "target" its communications to the type of business. Beyond having a contact telephone number, company name and address there isn't much "knowledge" about the small commercial customer. In a time when "targeted" communication is important, knowing the type of category of

small commercial account would assist LDCs in delivering meaningful messages in an effective way. This could be particularly important in the area of energy conservation, i.e., pulling together messages and programs for specific types of businesses. After all, a small restaurant is different from a small accounting office.

Satisfaction: Pre & Post		
Satisfaction (Top 2 Boxes: 'very + somewhat satisfied')	Residential	Commercial
Initially	93%	93%
End of Interview	92%	93%

Base: total respondents from the 2018 UtilityPULSE Database



As it relates to the six attributes associated with customer service:

Very or fairly satisfied with...	Residential	Commercial
The time it took to contact someone	73%	78%
The time it took someone to deal with your problem	71%	73%
The helpfulness of the staff who dealt with your problem	75%	81%
The knowledge of the staff who dealt with your problem	74%	77%
The level of courtesy of the staff who dealt with your problem	82%	88%
The quality of information provided by the staff member	74%	75%

Base: total respondents from the 2018 UtilityPULSE Database

Killer B's: Outages & Bills problems		
	Residential	Commercial
Respondents with outage problems	42%	39%
Respondents with billing problems	9%	8%

Base: total respondents from the 2018 UtilityPULSE Database

Overall satisfaction with most recent experience		
	Residential	Commercial
Top 2 Boxes: 'very + somewhat satisfied'	77%	77%
Bottom 2 Boxes: 'somewhat + very dissatisfied'	19%	20%

Base: total respondents from the 2018 UtilityPULSE Database

Comparisons between Residential and Commercial		
Loyalty Groups	Residential	Commercial
Secure	30%	32%
Still Favourable	17%	18%
Indifferent	46%	43%
At risk	7%	7%

Base: total respondents from the 2018 UtilityPULSE Database

Loyalty Model Factors		
	Residential	Commercial
Very/somewhat satisfied	93%	93%
Definitely/probably would continue	86%	87%
Definitely/probably would recommend	79%	83%

Base: total respondents from the 2018 UtilityPULSE Database

Important attributes which describe operational effectiveness		
	Residential	Commercial
Provides consistent, reliable electricity	92%	91%
Delivers on its service commitments to customers	89%	88%
Accurate billing	89%	88%
Quickly handles outages and restores power	91%	91%
Makes electrical safety a top priority	90%	90%
Is efficient at managing the electricity distribution system	86%	87%
Is a company that is 'easy to do business with'	86%	87%
Operates a cost-effective electricity distribution system	74%	74%
Standard of reliability meets expectations	91%	90%

Base: total respondents from the 2018 UtilityPULSE Database with an opinion

Important attributes which shape perceptions about service quality and value		
	Residential	Commercial
Is pro-active in communicating changes and issues which may affect customers	81%	81%
Provides good value for money	74%	75%
Customer-focused and treats customers as if they're valued	84%	83%
Deals professionally with customers' problems	87%	87%
Spends money prudently	82%	81%
Quickly deals with issues that affect customers	86%	85%
Provides information and tools to help manage electricity consumption	83%	79%
Provides information to help customers reduce their electricity costs	79%	75%
The cost of electricity is reasonable when compared to other utilities	64%	60%

Base: total respondents from the 2018 UtilityPULSE Database with an opinion

Important attributes which shape perceptions about corporate image		
	Residential	Commercial
Is a respected company in the community	87%	87%
A leader in promoting energy conservation	79%	79%
Keeps its promises to customers and the community	85%	84%
Is a socially responsible company	84%	85%
Is a trusted and trustworthy company	87%	87%
Adapts well to changes in customer expectations	79%	80%
Overall the utility provides excellent quality services	89%	87%

Base: total respondents from the 2018 UtilityPULSE Database with an opinion

Importance of online access for the following features:		
Top 2 Boxes: 'very + somewhat important'	Residential	Commercial
Reporting or inquiring about an issue	48%	52%
Researching information about energy conservation	40%	45%
Having a web chat feature on the website	20%	28%
Automated alerts when electricity usage exceeds a prearranged threshold	21%	30%
Review and pay your bill online (through utility's website)	44%	48%
Power outage alerts	65%	72%
Tools and calculators to help you manage your electricity consumption	30%	37%
Comparison of your electricity consumption with your neighbours	18%	26%
Automated alert to predict your upcoming bill	33%	37%
Automated alert to remind you of your bill due date	33%	37%

Base: total respondents from the 2018 UtilityPULSE Database

Preferred method of communication to receive notice of a billing issue		
	Residential	Commercial
Telephone	57%	55%
Voice Mail	2%	2%
Text	8%	4%
Email	33%	39%
Don't know	1%	1%

Base: total respondents from the 2018 UtilityPULSE Database

Method of communication Customers prefer their LDC uses during an UNPLANNED OUTAGE		
	Residential	Commercial
Recorded telephone message	34%	31%
Email notice	19%	29%
Posted on utility's website	4%	6%
Social media	5%	5%
Local radio	5%	5%
Local TV	3%	1%
Text message	25%	19%
Alert on APP	2%	2%

Base: total respondents from the 2018 UtilityPULSE Database

Method of communication Customers prefer their LDC uses about general news		
	Residential	Commercial
Recorded telephone message	23%	16%
Email notice	38%	49%
Posted on utility's website	6%	8%
Social media	6%	7%
Local radio	5%	5%
Local TV	5%	4%
Text message	10%	7%
Alert on APP	1%	2%

Base: total respondents from the 2018 UtilityPULSE Database

Satisfaction with information provided		
Top 2 Boxes: 'very + fairly satisfied'	Residential	Commercial
The amount of information available to you about energy conservation	82%	80%
The quality of information available when outages occur	73%	77%
The electricity safety education provided to the public	74%	76%
The timeliness and relevance of information for things such as planned outages, construction activity, tree trimming.	77%	80%

Base: total respondents from the 2018 UtilityPULSE Database

Access to services		
Top 2 Boxes: 'very + somewhat satisfied'	Residential	Commercial
The availability of call-centre staff Monday to Friday	58%	66%
The 24/7 availability of system operators to respond to respond to outages	78%	88%
The online self-serve options for managing your account	56%	72%
The online self-serve options for request services	48%	70%

Base: total respondents from the 2018 UtilityPULSE Database



Method

The findings in this report are based on telephone interviews conducted for Simul Corp. / UtilityPULSE by Logit Group between September 17 - October 17, 2018, with 403 respondents who pay or look after the electricity bills from a list of residential and small and medium-sized business customers supplied by Waterloo North Hydro.

The sample of phone numbers chosen was drawn randomly to ensure each business or residential phone number on the list had an equal chance of being included in the poll.

The sample was stratified so that 85% of the interviews were conducted with residential customers and 15% with commercial customers.

In sampling theory, in 19 cases out of 20 (95% of polls in other words), the results based on a random sample of 403 residential and commercial customers will differ by no more than ± 4.90 percentage points where opinion is evenly split.

This means you can be 95% certain that the survey results do not vary by more than 4.90 percentage points in either direction from results that would have been obtained by interviewing all Waterloo North Hydro residential and small

and medium-sized commercial customers if the ratio of residential to commercial customers is 85%:15%.

The margin of error for the sub-samples is larger. To see the error margin for subgroups, use the calculator at <http://www.surveysystem.com/sscalc.htm>.

Interviewers reached 2,662 households and businesses from the customer list supplied by Waterloo North Hydro. The 403 who completed the interview represent a 15% response rate.

The findings for the Simul/UtilityPULSE National Benchmark of Electric Utility Customers are based on telephone interviews conducted with adults throughout the country who are responsible for paying electric utility bills. The ratio of 85% residential customers and 15% small and medium-sized business customers in the National study reflects the ratios used in the local community surveys. The margin of error in the National poll is ± 2.95 percentage points at the 95% confidence level.

For the National study, the sample of phone numbers chosen was drawn by recognized probability sampling methods to ensure each region of the country was

represented in proportion to its population and by a method that gave all residential telephone numbers, both listed and unlisted, an equal chance of being included in the poll.

The data were weighted in each region of the country to match the regional shares of the population.

The margin of error refers only to sampling error; other non-random forms of error may be present. Even in true random samples, precision can be compromised by other factors, such as the wording of questions or the order in which questions were asked.

Random samples of any size have some degree of precision. A larger sample is not always better than a smaller sample. The important rule in sampling is not how many respondents are selected but how they are selected. A reliable sample selects poll respondents randomly or in a manner which ensures that everyone in the population being surveyed has an equal chance of being selected.

How can a sample of only several hundred truly reflect the opinions of thousands or millions of electricity customers within a few percentage points?

Measures of sample reliability are derived from the science of statistics. At the root of statistical reliability is probability, the odds of obtaining a particular outcome by chance alone.

For example, the chances of having a coin come up heads in a single toss are 50%. A head is one of only two possible outcomes.

The chance of getting two heads in two coin tosses is less because two heads are only one of four possible outcomes: a head/head, head/tail, tail/head and tail/tail.

But as the number of coin tosses increases, it becomes increasingly more likely to get outcomes that are either close to or exactly half heads and half tails because there are more ways to get such outcomes. Sample survey reliability works the same way but on a much larger scale.

As in coin tosses, the most likely sample outcome is the true percentage of whatever we are measuring across the total customer base or population surveyed. Next most likely are outcomes very close to this true percentage. A statement of the potential margin of error or sample precision reflects this.

Some pages in the computer tables also show the standard deviation (S.D.) and the standard error of the estimate (S.E.) for the findings. The standard deviation embraces the range where 68% (or approximately two-thirds) of the respondents would fall if the distribution of answers were a normal bell-shaped curve. The spread of responses is a way of showing how much the result deviates from the "standard mean" or

average. In the Waterloo North Hydro data on corporate image, Simul converted the answers to a point scale with 4 meaning agree strongly, 3 meaning agree somewhat and so on (see in the computer tables).

For example, the mean score is 3.74 for providing consistent, reliable electricity. The average is 3.20 for providing information to help customers reduce their energy costs.

For reliable electricity, the standard deviation is 0.49. For providing information to help customers reduce their energy costs, the S.D. is 0.86. These findings mean there is a wider range of opinion – meaning less consensus – about whether help to reduce energy costs than about whether Waterloo North Hydro energy supplies are reliable.

Beneath the S.D. in the tables is the standard error of the estimate. The S.E. is a measure of confidence or reliability, roughly equivalent to the error margin cited for sample sizes. The S.E. measures how far off the sample's results are from the standard deviation. The smaller the S.E., the greater the reliability of the data.

In other words, a low S.E. indicates the answers given by respondents in a certain group (such as residential bill payers or women) do not differ much from the probable

spread of the answers "predicted" in sampling and probability theory.

In certain instances, all of the sub-datasets from the entire UtilityPULSE database for 2018 were concatenated in order to use the average of all the control samples for comparison. The cumulated population base for these questions was in excess of 9,000.

Copyright © 2018 Simul/UtilityPULSE. All rights reserved. Brand, logos and product names referred to in this document are the trademarks or registered trademarks of their respective companies.



Good things happen when workplaces work. You'll receive both strategic and pragmatic guidance about how to improve Customer satisfaction & Employee engagement with leaders who lead and a front-line which is inspired. We provide training, consulting, surveys, diagnostic tools, and keynotes. The electric utility industry is a market segment we specialize in. Both large and small utilities have received actionable insights. For 20 years we have been talking to 1000's of utility customers in Ontario and across Canada and we have expertise which is beneficial to every utility.

**Culture, Leadership & Performance –
Organizational Development**

Leadership development

Strategic Planning

Teambuilding

Organizational Culture Transformation

**Focus Groups, Surveys, Polls,
Diagnostics**

Diagnostics ie. Change Readiness, Leadership
Effectiveness, Managerial Competencies

Surveys & Polls

Customer Satisfaction and Loyalty
Benchmarking Surveys

Organization Culture Surveys

Customer Service Excellence

Service Excellence Leadership

Telephone Skills

Customer Care

Dealing with
Difficult Customers

Benefit from our expertise in Customer Satisfaction, Leadership development, Strategy development or review, and Front-line & Top-line driven-change. We're experts in helping you assess and then transform your organization's culture to one where achieving goals while creating higher levels of customer satisfaction is important. Anyone can present data, or design programs – we believe having an understanding of the industry before doing so is crucial. Call us when creating an organization where more employees satisfy more customers more often, is important.

Your personal contact is:

Sid Ridgley, CSP

Phone: (905) 895-7900 x 29 E-mail: sridgley@simulcorp.com



Waterloo North Hydro Inc.

2018 Electric Utility Customer Satisfaction Survey





The purpose of this report is to profile the connection between Waterloo North Hydro Inc. (Waterloo North Hydro) and its customers.

The primary objective of the Electric Utility Customer Satisfaction Survey is to provide information to support discussions about improving customer care at every level in your utility.

The UtilityPULSE Report Card® and survey analysis contained in this report is intended to capture the state of mind or perceptions about your customers' need and wants – the information contained in this report will help guide your discussions for making meaningful improvements.

This survey report is privileged and confidential material, and no part may be used outside of Waterloo North Hydro Inc. without written permission from UtilityPULSE, the electric utility survey division of Simul Corporation.

All comments and questions should be addressed to:

Sid Ridgley, UtilityPULSE division, Simul Corporation

Toll free: 1-888-291-7892 or Local: 905-895-7900

Email: sidridgley@utilitypulse.com or sridgley@simulcorp.com





Feedback, Information & Insights

Eighteen months ago, customers were very angry about the quickly increasing costs of electricity over the previous 5 or more years. In fact, some years were double-digit increases while wages and inflation hovered around the 2% mark. We know this because the number of survey respondents in the Ontario benchmark survey who said they ‘sometimes worry about paying their bill’ grew from 21% to 31% and the number of At Risk customers grew from 11% to 17%.

Data from the Waterloo North Hydro and Ontario benchmark surveys show the level of “anger” has dramatically reduced. Whether changes in perception were created by the Liberal Government’s Spring 2016 reduction by 25% in electricity prices, or the change to a Conservative government June 2018, or the promise of further reductions in electricity prices, or improvements in the economy, or improvements that LDCs have made in managing outages while improving customers service, or all of the above - a major shift towards a more positive view has taken place. Customers who have a positive view of their LDC and the industry exhibit less resistance to change.

For Waterloo North Hydro in the Fall 2018 survey 14% of respondents and 21% of the Ontario benchmark respondents said they ‘sometimes worry about paying their bill.’ Also, the At Risk customer respondent levels were 4% for Waterloo North Hydro and 13% for the Ontario benchmark. To be clear, customers are still concerned about the costs of electricity as shown by very low scores in the attribute “The cost of electricity is reasonable when compared to other utilities such as gas, cable or telephone.”





Your survey was conducted from September 17 - October 17, 2018, and is based on 403 one-on-one telephone interviews with residential and small commercial customers who pay or look after the electricity bill. Also, survey findings for Waterloo North Hydro are enhanced with the inclusion of data from our UtilityPULSE database and the independently produced Ontario and National Benchmarks.

Helping the LDC generate higher levels of customer satisfaction, or maintaining their current high level, will be based on doing the core job as promised by being professional, efficient and cost-effective. But expectations continue to change. For Fall 2018, three key observations emerge from examining the trends in data from the UtilityPULSE database. They are: customers want to know they have been heard, they have reasonable access to services, and, their LDC is pro-actively communicating – especially during emergency situations.

83%

Pro-actively
communicates changes
and issues

89%

Provides excellent
quality services

92%

Standard of reliability
meets expectations

90%

Delivers on its service
commitments



Base: total respondents:
Top 2 Boxes: "Strongly agree + agree"



The Core Responsibilities

Waterloo North Hydro survey respondents agree strongly + agree somewhat (Top 2 boxes), their LDC: Provides consistent, reliable electricity 94%, Quickly handles outages and restores power 94%, Accurate billing 92% and Makes electricity safety a top priority for employees, contractors, and the public 87%.

Issues: Billing and Blackouts, the “Killer B’s”

In a world, which is becoming more complex, and where people are time-pressed, outage and billing issues are likely to motivate customers to contact their LDC.

Problems: Blackouts

Percentage of Respondents indicating that they had a Blackout or Outage problem in the last 12 months			
	Waterloo North Hydro	National	Ontario
2018	37%	39%	44%

Base: total respondents



Problems: Billing issues

Percentage of Respondents indicating that they had a Billing problem in the last 12 months			
	Waterloo North Hydro	National	Ontario
2018	5%	9%	9%

Base: total respondents



While it is true, Waterloo North Hydro receives very good operational scores, it also has a responsibility to professionally and quickly deal with issues customers contact them about. In a complex electricity industry world, this puts additional strain on the skills and competencies of everyone who interacts with customers.





Customer Service

Satisfaction with Customer Service			
Top 2 Boxes: 'very + fairly satisfied'	Waterloo North Hydro	National	Ontario
The time it took to contact someone	86%	66%	64%
The time it took someone to deal with your problem	88%	72%	65%
The helpfulness of the staff who dealt with you	91%	70%	64%
The knowledge of the staff who dealt with you	89%	70%	64%
The level of courtesy of the staff who dealt with you	95%	78%	70%
The quality of information provided by the staff who dealt with you	88%	73%	61%

Base: total respondents who contacted the utility

Traditionally LDCs handle inbound, or customer initiated communications when there are issues. However, more and more customers have an expectation their LDC will also be proficient with outbound communications regarding the important issues.

Communication channels preferred by customers

Most, if not all, of our LDC clients, expect that customers will utilize the electronic channels for getting information or dealing with issues. By doing so, costs for the LDC should decrease. However, in a world where customers expect some outbound contact, they expect their LDC to use those channels to communicate directly with them. Therefore, when problems do occur, and the LDC must initiate contact with their customer, it would be beneficial to the process if customers were contacted via channels they most prefer.





Primary Source of Information

Primary Source for getting information on ...					
	Corporate website	Twitter	Facebook	Bill Inserts	eBlasts
A power outage	39%	6%	3%	5%	3%
An issue with your bill	35%	0%	1%	10%	3%
General corporate news	35%	2%	3%	16%	3%
Electricity safety information	42%	1%	2%	19%	3%
Energy conservation tips	38%	2%	3%	24%	3%
Changes in electricity rates	34%	1%	2%	31%	4%

Base: total respondents

Communication about Billing issues

Waterloo North Hydro customers' preferred or primary method for Waterloo North Hydro to contact them about billing issues are as follows:

Preferred method of communication to receive notice of a billing issue		
	Ontario LDCs	Waterloo North Hydro
Telephone	56%	59%
Voice Mail	2%	2%
Text	7%	4%
Email	34%	34%
Don't know	1%	1%








Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility





Communication during Unplanned Outages

In times of emergency, be they extreme weather events or major equipment failures that cause blackouts and unplanned outages, customer communication can help customers understand what to expect next and when disrupted electricity service might be restored. Early and effective communication helps increase confidence in and credibility of the electricity service provider.

Method of communication Customers prefer their LDC uses during an UNPLANNED OUTAGE						
Recorded Telephone Message	Email Notice	Posted on the Website	Social Media	Local Radio	Local TV	Text Message
						
36%	25%	5%	3%	8%	3%	19%

Base: total respondents

Notice the difference in the preferred channel based on subject matter. Waterloo North Hydro shouldn't, for example, assume a customer who prefers email for a billing issue will want an email for outage issues. These added variables add complexity to capturing and then using each customers' preferences. Getting the most out of your CRM system is becoming increasingly important.





Preferred Communication Platforms

Which communication platform or platforms would you prefer Waterloo North Hydro use ...	
Social media	16%
Newspaper	14%
Radio	16%
Bill inserts	27%
Website	27%
Email / eBlasts	48%
Other	8%

Base: total respondents

Which of the following methods would you most like to see Waterloo North Hydro contact you by...	
Live chat	2%
Phone call	45%
Email	41%
Text/SMS Message	9%
In-person visit	2%

Base: total respondents

Providing communication platforms that are effective and meet customers' needs is key to improving the customer experience. To do this, Waterloo North Hydro must understand how customers communicate with you, and how they would like Waterloo North Hydro to communicate with them in future. Knowing this will allow Waterloo North Hydro to: allocate resources where they are most needed; tailor services to meet customers' needs; and, identify where improvements can be made.

However, while most customers appear to have capacity and willingness to use digital channels, there are also customers who do not for a variety of reasons, such as a lack of ability or resources, or due to a preference for other channels. Waterloo North Hydro will need to consider how these customers can be supported and encouraged to use digital services in the future.





Customers were asked about their level of satisfaction with the information provided by Waterloo North Hydro on the following:

Satisfaction with information provided		
Top 2 Boxes: 'very + fairly satisfied'	Ontario LDCs	Waterloo North Hydro
The amount of information available to you about energy conservation	82%	82%
The quality of information available when outages occur	73%	78%
The electricity safety education provided to the public	74%	75%
The timeliness and relevance of information for things such as planned outages, construction activity, tree trimming.	78%	77%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

While providing information is important, one must ensure that it is neither overwhelming the audience to the point of turning them off, or not providing enough information causing recipients to feel you have not adequately looked after them.

Amount of Information received is ...			
	LESS than you would like	About the RIGHT amount	MORE than you need
Safety	7%	81%	5%
Energy Efficiency	12%	77%	7%
Billing and Account Questions	4%	86%	4%
Outages	13%	75%	4%
Construction projects and planning	15%	69%	7%

Base: total respondents





Communication Score – New for 2018

The pressure to communicate via multiple communication platforms continues to increase. There is also an expectation the utility will, from an outbound perspective, contact the customer via their preferred channel.



Communication Score		
	Ontario LDCs	Waterloo North Hydro
Communication Score	79%	80%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility

Future Communication Efforts

Respondents were asked on which topics Waterloo North Hydro should focus their future communication efforts.

Future Communication Efforts should focus on ...	
	Waterloo North Hydro
Safety	15%
Energy Efficiency	30%
Billing and Account Questions	10%
Outages	10%
Construction projects and planning	8%

Base: total respondents





Respondents were asked: ***“Is there a topic other than the ones we’ve talked about that you would like Waterloo North Hydro to provide more information about?”*** Base: total respondents



14%
wanted **additional**
information.



85%
Required **no further**
information.



ADDITIONAL TOPICS mentioned:

- Prices/costs/fees
- Communication with customers
- Rebates
- Payment options
- My usage/my neighbour’s consumption
- Potential mergers
- SMART meters
- Outage map





The Convenience of Services Score – New for 2018

Rising customer expectations and demands means customers expect to be able to contact you 24 hours a day, seven days a week using various communication avenues, i.e. Telephone, your website and/or even social media. Customers expect flexible and more personalized services. Providing customers with clear, easy to access services and information which is easy to understand has a significant impact on the customer experience.



Providing customers with clear, easy to access services and information which is easy to understand has a significant impact on the customer experience.

Access to services		
Top 2 Boxes: 'very + somewhat satisfied'	Ontario LDCs	Waterloo North Hydro
The availability of call-centre staff Monday to Friday from 8:30 am to 4:30 pm	76%	75%
The 24/7 availability of system operators to respond to outages	77%	80%
The online self-serve options for managing your account	63%	67%
The online self-serve options for request services	56%	61%
The 24/7 availability of outage map on the website	n/a	66%

Base: An aggregate of respondents from 2018 participating LDCs / total respondents from the local utility



Convenience of Services Score

Based on customer responses, Waterloo North Hydro has rated 81% for Convenience of Services while Ontario LDCs rated 79%.



Use of Technology

Technology is fundamentally reshaping customer care in both the short and longer terms. The expectation is, technology will reduce the number of inbound calls by empowering customers to get the technical or service support they need to solve many of the problems which exist.

Respondents were asked whether they used the following forms of technology:

Use of technology			
	Yes	No	Don't know/Refusal
Access the internet for information	83%	17%	0%
Have a social media account	54%	44%	1%
Use online banking services	71%	25%	3%
Shop online	64%	34%	2%

Base: total respondents

Social Media

Social media is evolving, and it gives companies the opportunity to proactively identify customer issues which will help the utility address problems quickly thereby minimizing the impact on the broader customer base. 54% of Waterloo North Hydro customers indicated they had a social media account.





Which social media accounts do you have ...	
Facebook	58%
Twitter	24%
YouTube	34%
LinkedIn	38%

Base: total respondents who claimed to have social media accounts

Do you follow Waterloo North Hydro in ...			
	Yes	No	Don't know
Facebook	5%	95%	0%
Twitter	29%	70%	1%
YouTube	3%	97%	0%
LinkedIn	4%	95%	1%

Base: total respondents who claimed to have social media accounts



Credibility & Trust Index

As society becomes more complicated and complex, the opportunities for failure increase. A key to healthy relationships with customers is to be trusted, trustworthy and credible.


Waterloo North Hydro Credibility & Trust score is 87% while the Ontario benchmark is 81% and the National benchmark is 82%.





Customer Experience Performance rating (CEPr)

Do customers believe they will have a good experience if/when they do contact their LDC? Or do they believe they must prepare for 'war'? Of course, subject matter and customer affinity levels play a role in determining how a customer might prepare for interaction with a professional at Waterloo North Hydro.



Customer Experience Performance rating (CEPr)			
	Waterloo North Hydro	National	Ontario
CEPr: all respondents	89%	84%	83%

Base: total respondents

Ensuring that the customer experience is a good one, requires high quality services and well-trained people. Survey respondents gave Waterloo North Hydro excellent operational and representative scores.

Operational Attributes			
	Waterloo North Hydro	National	Ontario
Provides consistent, reliable energy	94%	89%	90%
Quickly handles outages and restores power	94%	87%	86%
Accurate billing	92%	86%	87%

Base: total respondents with an opinion





Representative Attributes			
	Waterloo North Hydro	National	Ontario
Deals professionally with customers' problems	89%	83%	82%
Is 'easy to do business with'	90%	82%	82%
Customer-focused and treats customers as if they're valued	83%	80%	79%

Base: total respondents with an opinion

Customer Centric Engagement Index

The term “customer engagement” is used by many but understood by few. The purpose of customer engagement is to have two-way interactions which build understanding between the stakeholders and stronger professional business-like relationships. Customers who are highly engaged are more inclined to look past costs and money issues and be more supportive of what the LDC wants to do or accomplish.

As we have stated in previous reports: Customer Engagement is about how customers think, feel and act towards the organization. Ensuring customers respond positively requires they be rationally satisfied with the services provided AND emotionally connected to the LDC and its brand.

Utility Customer Centric Engagement Index (CCEI)			
	Waterloo North Hydro	National	Ontario
CCEI	86%	81%	80%

Base: total respondents





Customer Satisfaction

By itself, this metric is not good enough to gain a picture of how well an LDC is doing but it is a measure about whether the LDC is “doing the job” as expected. However, without satisfaction, there is no gateway to loyalty.


SATISFACTION SCORES – Electricity customers’ satisfaction			
Top 2 Boxes: ‘very + fairly satisfied’	Waterloo North Hydro	National	Ontario
PRE: Initial Satisfaction Scores	96%	91%	91%
POST: End of Interview	96%	91%	89%

Base: total respondents


The real prize is in the development of a relationship with customers. More good things exist when a customer has a high affinity for the LDC than when they dislike it. At Risk customers are more likely to complain than other customers when there are issues. Secure customers are more likely to support the direction of their LDC.

Electricity bill payers who are 'very or fairly' satisfied with ...

■ Waterloo North Hydro



Waterloo North Hydro





Loyalty Groups

Customer Loyalty Groups				
Waterloo North Hydro	Secure	Favorable	Indifferent	At Risk
2018	34%	19%	43%	4%

Base: total respondents

In the monopoly world of the LDC, loyalty is an attitudinal metric. In private industry, it is a behavioural metric.

Customer Commitment

Electricity customers' loyalty – ... Is a company that you would like to continue to do business with			
	Waterloo North Hydro	National	Ontario
Top 2 Boxes: 'Definitely + Probably' would continue	90%	80%	78%

Base: total respondents

Customer Advocacy

Electricity customers' loyalty – ... is a company that you would recommend to a friend or colleague			
	Waterloo North Hydro	National	Ontario
Top 2 boxes: 'Definitely + Probably' would recommend	87%	76%	70%

Base: total respondents





UtilityPULSE Report Card®

The purpose of the UtilityPULSE Report Card is to provide electric utilities with a snapshot of performance – on the things customers deem to be important.

Waterloo North Hydro's UtilityPULSE Report Card®

Performance

	CATEGORY	Waterloo North Hydro	National	Ontario
1	Customer Care	A	B+	B+
	Price and Value	B+	B	B
	Customer Service	A	A	B+
2	Company Image	A	B+	B+
	Company Leadership	A	B+	B+
	Corporate Stewardship	A	A	B+
3	Management Operations	A+	A	A
	Operational Effectiveness	A+	A	A
	Power Quality and Reliability	A+	A	A
OVERALL		A	A	B+

Base: total respondents



Looking to the future, where to from here?

Technological advances, social disruptions, and other issues will continue for everyone in the LDC industry. Fixing the ills of yesterday are not possible, but instilling confidence that the LDC can handle future customer needs & wants strengthens the customer-supplier relationship. By engaging stakeholders and obtaining their input in undertaking a priority planning process helps to build "prepared minds"—that is, to make sure that the LDC decision makers have a solid understanding of customer priorities, and what the business might need to change or make investments in.

High priority items based on information taken from our UtilityPULSE database include: 'Pro-actively maintaining and upgrading equipment,' 'Reducing response times to outages,' and 'Investing more in the electricity grid to reduce outages and to increase reliability and safety.'

The high scoring attributes demonstrate Waterloo North Hydro's operational effectiveness, while the low scoring attributes point to a need for more marketing communications and/or PR types of activities.

Highest scoring attributes

High scoring attributes			
Top 2 Boxes: 'Strongly + Somewhat agree'	Waterloo North Hydro	National	Ontario
Provides consistent, reliable electricity	94%	89%	90%
Makes electricity safety a top priority for employees and contractors	87%	87%	86%
Quickly handles outages and restores power	94%	87%	86%
Has a standard of reliability that meets expectations	92%	88%	88%

Base: total respondents with an opinion





Lowest scoring attributes

Low scoring attributes			
Top 2 Boxes: 'Strongly + Somewhat agree'	Waterloo North Hydro	National	Ontario
Spends money prudently	84%	73%	66%
Operates a cost-effective electricity system	78%	70%	71%
Provides good value for your money	79%	72%	71%
Cost of electricity is reasonable when compared to other utilities	70%	66%	61%

Base: total respondents with an opinion

Paying for electricity

Fall 2018 data shows dramatic changes in customers' ability to pay. Whether the change is due to price reductions, or anticipated price reductions, or a better economy, is unclear. Ability to pay is highly correlated to satisfaction. The number one billing problem, for 20 years, is "the amount is too high."

Is paying for electricity a worry or a major problem?				
	Not a worry	Sometimes	Often	Depends
Waterloo North Hydro	78%	14%	5%	1%
National	71%	18%	7%	0%
Ontario	68%	21%	8%	1%

Base: total respondents





Numbers at a Glance

	Waterloo North Hydro	National	Ontario
Customer Satisfaction: Initial	96%	91%	91%
Customer Satisfaction: Post	96%	91%	89%
Communication Score	80%	--	79%
Overall Satisfaction with the most recent experience	95%	78%	77%
Convenience of Services Score	81%	--	79%
Customer Experience Performance Rating (CEPr)	89%	84%	83%
Customer Centric Engagement Index (CCEI)	86%	81%	80%
Credibility & Trust Index	87%	82%	81%
UtilityPulse Report Card®	A	A	B+

Over the past 5-6 years LDCs have witnessed their customers move from being concerned about costs, to worried about cost, to being upset about costs and being angry about costs – and now returning to what we believe is a concern about costs. From a human nature point-of-view, when people are angry, they tend to look back in time to find someone or something to blame for their predicament. Now that customers have returned to being concerned, they are more apt to be looking forward while putting more focus on identifying and determining how they might handle future issues. The data from our Fall 2018 interviews with over 9,000+ customers shows there is support for making pro-active investments in reliability, outage restoration, outage management, and communications.





We believe, for many in society, from 2008 to mid-2017 survival was the key goal, less so in 2018. The outlook for the economy is better; wages are improving and, job openings are more plentiful – therefore putting more focus on the future.

The good news is Waterloo North Hydro remains what we call an influential brand company. The safe, reliable distribution of electricity to homes and businesses is a job which makes life better, more interesting and meaningful for consumers and customers. As a company which affects the daily life of people and businesses – an influential brand – it must consistently demonstrate that it is credible, trusted, future-oriented, cares about customers, cares about safety, cares about the environment, is professional, has high standards and is a valued corporate citizen.



The industry is far more complex today than it was 20 years ago when we conducted the 1st Annual Customer Satisfaction survey for electric utilities. Data shows that being customer-centric is important for ensuring future success of the LDC. Customers want respect.

We recommend leveraging the results from your 2018 customer satisfaction survey by having meaningful conversations with everyone about your customers' – satisfaction, concerns, wants, etc. LDCs with a constructive employee culture with high levels of employee engagement and empowerment will have an easier time defining a future path forward.



Sid Ridgley

Simul/UtilityPULSE

Email: sidridgley@utilitypulse.com or sridgley@simulcorp.com

November 2018



Good things happen when workplaces work. You'll receive both strategic and pragmatic guidance about how to improve Customer satisfaction & Employee engagement with leaders who lead and a front-line which is inspired. We provide training, consulting, surveys, diagnostic tools, and keynotes. The electric utility industry is a market segment we specialize in. Both large and small utilities have received actionable insights. For 20 years we have been talking to 1000's of utility customers in Ontario and across Canada and we have expertise which is beneficial to every utility.

**Culture, Leadership & Performance –
Organizational Development**

Leadership development

Strategic Planning

Teambuilding

Organizational Culture Transformation

**Focus Groups, Surveys, Polls,
Diagnostics**

Diagnostics ie. Change Readiness, Leadership
Effectiveness, Managerial Competencies

Surveys & Polls

Customer Satisfaction and Loyalty
Benchmarking Surveys

Organization Culture Surveys

Customer Service Excellence

Service Excellence Leadership

Telephone Skills

Customer Care

Dealing with
Difficult Customers

Benefit from our expertise in Customer Satisfaction, Leadership development, Strategy development or review, and Front-line & Top-line driven-change. We're experts in helping you assess and then transform your organization's culture to one where achieving goals while creating higher levels of customer satisfaction is important. Anyone can present data, or design programs – we believe having an understanding of the industry before doing so is crucial. Call us when creating an organization where more employees satisfy more customers more often, is important.

Your personal contact is:

Sid Ridgley, CSP

Phone: (905) 895-7900 x 29 E-mail: sridgley@simulcorp.com



BRICKWORKS

COMMUNICATIONS 



Customer Satisfaction Survey Report

March 2019

Table of Contents

Methodology & Logistics	2
Respondent Profile	3
Keeping the Lights On	4
Customer Preferences	5
Electric Vehicles	6
Rooftop Solar	7
Community Solar	8
Onsite Power Storage	9
Electricity Usage Tracking & Alerts	10
Smart Home	11

Methodology & Logistics

Background & Overview:

Brickworks Communications was commissioned by Waterloo North Hydro to conduct a satisfaction survey of its customers. This report contains an executive summary of the results, while separate Excel reports include the results by individual question.

Survey Method:

All surveys were completed online using Computer Assisted Web Interviewing (CAWI). This was a self-selection survey where respondents connected with the link to the survey site to complete their interview.

Waterloo North Hydro promoted the survey and issues with an e-blast to its customer base advising them of the project. As an incentive, participants completing the survey and filling out personal information were eligible for a prize draw.

Study Sample:

In total, N=4355 customers fully completed online questionnaires. In addition, there were N=471 partially completed surveys where respondents filled out at least one question.

Logistics:

Surveys were completed online from the days of February 5th through February 22nd, 2019.

Confidence:

It is not customary to assign online samples a margin of error to self-selection samples. However, a probability sample of N=4355 has a margin of error or is considered accurate $\pm 1.5\%$, 19 times out of 20.

Respondent Profile

Q1. Please identify your customer type.



96% Residential (N=4184)



3% Small business (N=136)



1% Large business (N=35)

Q2. What type of home do you live in?




Detached single family 64% (N=2674)

Attached single family 18% (N=762)

Multiple unit 18% (N=748)

Q3. What is your employment status?

 Employment	Working	N=2657	64%
	Retired	N=1065	25%
	Student	N=272	7%
	At home	N=149	4%
	Unemployed	N=14	<1%
	Disability	N=25	1%



Q5. In which community is your WNH customer account located?

Waterloo	79%	(N=3427)
Woolwich – Urban	13%	(N=585)
Wellesley – Urban	4%	(N=184)
Woolwich – Rural	2%	(N=101)
Wellesley – Rural	1%	(N=58)

Keeping the Lights On

The first series of three questions asked respondents about outages. They were displayed descriptive preambles or scenarios before each indicator and were asked about the importance of each.

“WNH strives to keep the lights on at all times. However, there are occasions (due to storms, vehicle accidents, and equipment failure) when we experience a power outage. On average, power is out about 9.5 minutes per month per customer.”

Q6. How important is minimizing power outages to you?

Not important	11%	87% Total important
Important, & willing to pay more to keep the lights on (less than \$1 extra per month on bill)	29%	
Important but at no additional cost	58%	
Don't know	2%	

A Smart Grid senses problems on the power grid and reroutes power automatically, preventing some outages and reducing the length of those that occur by not having to send out a hydro crew to inspect and fix the problem. It can also provide detailed information on outages, such as when your power is anticipated to be back on.

Q7. How important is this to you?

Not important	8%	89% Total important
It is important, and I am willing to pay more for it (less than \$1 extra per month on my bill)	31%	
It is important but at no additional cost	58%	
Don't know	3%	

“Poles, wires and transformers typically last 40 to 50 years. In order to ensure an uninterrupted supply of electricity to you, we need to maintain and replace these assets when their useful life has expired. If assets are not replaced on a timely basis, outages can occur due to equipment failure.”


Q8. How important is this to you?

Not important	3%	95% Total important
Very important, & willing to pay more to replace them (\$1 to \$2 extra per month on my bill)	31%	
It is important but at no additional cost	64%	
Don't know	2%	

A very high level of importance was placed for each area, especially for the replacement of assets at 95% – however, this question also saw a higher number that wanted it done at no extra cost (64%). The importance of the Smart Grid followed at 89% importance, then by the importance of minimizing outages. Most respondents (58%) in each instance want this done at no additional cost.


Customer Preferences

Respondents were asked to rank in order five preference areas in terms of importance to them as customers. The ranking of one (1) was highest and five (5) the lowest, with the mean scores ranked from highest to lowest below.



Your needs and preferences are important to us in planning our investments over the next five years.

Q9. Please rank the following in order of importance.

- 
- 2.2** WNH provides electricity that is “Reliable” (fewer outages)
 - 2.4** WNH provides electricity that is “Safe”
 - 3.2** WNH provides electricity at low cost (at the expense of reliability and customer service)
 - 3.4** WNH invests in innovative solutions such as smart grid, battery storage, solar, and smart home technologies
 - 3.7** WNH provides excellent customer service


The highest importance with a mean score of 2.2 was for providing reliable electricity, closely followed by safe electricity at 2.4. A mid-point ranking of 3.2 was accorded to providing electricity at a low cost – this at the expense of customer service. Lower scored by customers was for investing in innovating solutions (3.4), while the lowest ranked was for the area of providing excellent customer service (3.7).

Electric Vehicles


All respondents were first probed if they currently have an electric or hybrid vehicle and then about their intention to purchase one. The residential and business cohorts were asked the question separately with a slight modification in the wording.

Q10. The next questions are about electric vehicles.

CURRENT ELECTRIC VEHICLES AT RESIDENCE OR BUSINESS



CONSIDERING PURCHASE OF ELECTRIC VEHICLES



Current ownership remains low but there is significant interest, or at least consideration, especially among the residential cohort, to purchase one over the next five years. A lesser number of residents (47%) answered “no” in relation to businesses (60%), while more than a quarter (26%) of non-businesses were unsure (21% of businesses).

Rooftop Solar

Respondents were shown the following statement that described Rooftop Solar or Solar Photovoltaic (PV) systems and explained net metering. Businesses and residents were then asked separately if they have rooftop solar systems (Q12) and if they did not, a follow-up question was asked about their future intent to install a system (Q13).

"Rooftop Solar or Solar Photovoltaic (PV) systems can be installed on your rooftop to generate electricity for the [RESIDENTIAL – home] [BUSINESS – business]. When the PV system produces more electricity than you use, the excess flows back into the electric system grid, and your electricity meter credits your bill for the electricity you have added to the grid. This is called "net metering." A rooftop solar PV system could significantly reduce your electricity bill, depending on the amount of power your system generates."

Q12. Do you have a rooftop solar system on your home?



The 97%
that do
not
have
rooftop
solar
were
asked
Q13

Q13. Which of the following statements best reflects your intent about installing a solar system on your home?

I will install one if the payback is 5 to 7 years	19%
I will install one if the payback is 8 to 10 years	5%
I will install one regardless of the payback	6%
I will not install one in the next five years	43%
Don't know	28%

Q12. Do you have a rooftop solar system on your business?



The 99%
that do
not
have
rooftop
solar
were
asked
Q13

Q13. Which of the following statements best reflects your intent about installing a solar system on your business?

I will install one if the payback is 5 to 7 years	4%
I will install one if the payback is 8 to 10 years	1%
I will install one regardless of the payback	2%
I will not install one in the next five years	93%

A very low number of residents (3%) and only 1% of businesses currently have rooftop solar systems.

Most businesses or 93% are not considering installing a system, while interest is higher among residents. Only 43% of residents said they will not install a system and almost three in ten were unsure. Twenty-four percent will consider this option based on the payback (5-7 or 8-10 years) and 6% will do so regardless of the financial aspect.

Community Solar

Next, an explanation of community solar was provided, after which respondents were asked about their investment interest.

"The primary purpose of community solar is to allow members of a community the opportunity to share the benefits of solar power even if they cannot or prefer not to install solar panels on their property. Participants benefit from the electricity generated by the community solar farm, which could cost less than the price they would ordinarily pay to their utility."

Q14. Would you be interested in purchasing a share in a community or "shared" solar installation?




Investment interest is at four in ten, while less than a quarter said outright that they would not purchase a share. A high level or 37% are unsure or do not know.


On-Site Power Storage

The following description of on-site power storage was provided and then both the residential and business cohorts were asked about demand.

"On-site power storage enables you to store electricity at your [RES – home / BUS – business] using batteries. The battery can be a wall unit, or you could use the battery in an electric vehicle. This technology can provide backup power in the case of a power outage."

Q15. Would you consider installing battery storage in the next five years?

RESIDENTIAL		
	Will consider installing one in the next five years	36%
	Will not consider installing one in the next five years	28%
	Don't know	36%

BUSINESS		
	Will consider installing one in the next five years	40%
	Will not consider installing one in the next five years	19%
	Don't know	41%

The appeal for on-site storage was slightly higher among businesses, while more residential customers were indifferent to the energy solution saying they will not consider it over the next five years.

Electricity Usage Tracking & Alerts

Electricity Usage Tracking was explained and then both business and residential cohorts were asked about their interest.

"Electricity Usage Tracking and Alerts provides real-time information and tips on reducing your usage to help you manage your electric bill and reduce costs where possible. You will receive updates on your [RES – home's / BUS – businesses] current electric usage and estimated bill amounts via email, phone, or text message. You could choose to receive these alerts on a daily or weekly basis or check your usage at any time on WNH's website (customer portal)."

Q16. If you were offered an electricity usage tracking and alert, how interested would you be in signing up for it?




Total interest was strong among both businesses and residents.

Smart Home

The final service description was about Smart Homes. All customers were then asked about their interest.

“A Smart Home connects to the electricity grid via a smart meter and provides better and more frequent information regarding your electricity usage. It offers better control over how and when you use your home’s appliances, heating and cooling system, lighting, and other devices, which is especially useful as electricity costs vary throughout the day. It also serves as an energy resource, as it helps WNH better manage the supply and demand for electricity in our community.”

Q17. How interested are you in making your home a Smart Home?



Three-quarters of online survey respondents answered that they were somewhat (47%) or very interested (28%) in Smart Home technology.



Customer Engagement Survey Report



BRICKWORKS
COMMUNICATIONS ■

Dec 2019 / Jan 2020

Table of Contents

Background & Overview	2
Methodology & Logistics – Online Survey	3
Methodology & Logistics – Telephone Survey	4
Telephone Survey Results	5
Online Survey Results	18
Summary & Highlights	35

Background & Overview

Waterloo North Hydro commissioned Brickworks Communications to conduct an engagement survey of its customers. The purpose of this survey process was to obtain customer input regarding Waterloo North Hydro's business plans for the period 2021 to 2025, and to gather information from them about service and cost. Feedback from this survey process will be used to help shape capital and operating plans, which will be presented to the Ontario Energy Board (OEB) when Waterloo North Hydro (WNH) files its rate application for 2021.

There were two main approaches used in this process including an open online survey forum that resulted in N=2393 completes and a random telephone survey of N=600 customers. Customers were assured that all responses to this survey would be confidential, and as such only overall or aggregate results are reported. No financial incentives were provided for the telephone poll, while customers who completed the online survey were offered the option of being entered into a draw to win six VISA gift cards worth \$250 each.

In addition, there was an open house held by WNH on November 28, 2019, where small business customers were allowed to complete surveys using a written paper survey form. In total N=32 completed surveys using a questionnaire that was modified from the online version and included different indicators.

Reporting Notes

This report contains an executive summary of the results from both the telephone and online components, while a separate Excel report includes the results by individual question for each. Results are presented in the order that they were asked in each survey. In addition, the descriptive preambles along with graphic displays are also shown in relation to each question. Methodologically, the background information contained is considered to be associated with the questions that follow and is presented as such.

Results from the M=32 small business surveys are included in an Excel report and findings are referenced in the Summary & Highlights section of this report. Given the small sample size, we represent findings by count or N rather than in percentages.

Methodology & Logistics – Online Survey

Survey Method

All surveys were completed online using Computer Assisted Web Interviewing (CAWI). This was a self-selection survey where respondents connected with the link to the survey site to complete their interview. Waterloo North Hydro promoted the survey with e-blasts to its customer base advising them of the project.

Study Sample

In total, N=2393 customers fully completed online questionnaires.

Logistics

Surveys were completed online from the days of November 14th and November 29th, 2019.

Confidence

It is not customary to assign online self-selection samples a margin of error. However, a probability sample of N=2393 has a margin of error or is considered accurate $\pm 2.0\%$, 19 times out of 20.

Methodology & Logistics – Telephone Survey

Study Sample

Waterloo North Hydro provided Brickworks with a database of their residential and business customers to be surveyed. A total of N=550 residential customers and N=50 business customers were randomly selected from the database and surveyed by telephone using person to person live telephone interviewing.

Respondents were screened to ensure that they were 18 years of age or older, a WNH customer and were one of the persons either at the business or residence that was a decision maker as it relates to reviewing utility bills and making payments.

Survey Method

The survey was conducted using computer-assisted techniques of telephone interviewing (CATI) and random number selection. A total of 20% of all interviews were monitored and the Brickworks management supervised 100%.

Logistics

Interviews were completed between the days of November 14th to November 24th, 2019. Initial calls for the residential component were made between the hours of 5 p.m. and 9 p.m. Subsequent call backs of no-answers and busy numbers were made on a (staggered) daily rotating basis up to 5 times (from 10 a.m. to 9 p.m.) until contact was made. In addition, telephone interview appointments were attempted with those respondents unable to complete the survey at the time of contact. At least one attempt was made to contact respondents on a weekend. Calls to business customers were first made from 8:30 a.m. to 5:30 p.m. during weekdays. There was at least one follow up call after 5:30 p.m. and one on a weekend. In addition, telephone appointments were accepted and made as per the respondent's time preference.

Confidence

The margin of error for the N=600-respondent survey is $\pm 4.0\%$, 19/20 times.

Telephone Survey Results

Introductory Preamble

Customers were first read the following introductory statement prior to the commencement of the questionnaire.

"Ontario's electricity system is owned and operated by public, private, and municipal corporations across the province. It's made up of three major components: generation, transmission, and distribution. WNH is a distribution company that carries the electricity from the transformer stations to your homes.

WNH manages its spending in two ways—an operating budget and a capital budget.


- WNH's operating budget covers recurring expenses, such as the maintenance of distribution system infrastructure, equipment, vehicles, buildings, properties and tools, as well as insurance and corporate income taxes.*
- WNH's capital budget covers items that have benefits over many years. This includes distribution system equipment such as poles, wires, cables, transformers, computers and information systems, vehicles, and facilities.*

Managing the distribution system requires considerable investments in replacing aging equipment, connecting new customers, maintenance, and day-to-day operations. WNH's portion of the average [residential bill is 29%] [small business bill is 23%] of the total bill. This portion is used to maintain and rebuild the system and includes a regulated rate of return that is used to reinvest in the system. WNH does not mark up the cost of electricity. What customers pay to WNH is paid directly to the Independent Electricity System's Operator (IESO)."

Understanding Role of WNH

All N=600 customers were then asked the first indicator of the questionnaire about their awareness of the role that WNH plays in the electricity system.

Q1. "How well do you feel you understand the role that Waterloo North Hydro plays in the electricity system, including where revenue comes from and what portion of your bill relates to WNH? Would you say you understand completely, somewhat, not very well,




Most or 97% claimed to understand, with a split between those that completely (49%) or somewhat (48%) understood.

Cost Versus Service

Customers were read the following statement about cost and service, after which they were asked which of three possible options they preferred.

"In a previous customer engagement survey from earlier this year, some WNH customers said they want service enhancements like electricity usage tracking and alerts. Those enhancements are not currently in the WNH plan and will increase costs slightly. Other customers have placed a lower priority on customer service and higher priority on low cost alternatives."

Q2. "Which of the following do you prefer?"
READ / ROTATE LIST




Almost seven in ten or 69% of customers prefer a continuation of current service levels, while only 21% want to see decreased costs with lower levels of service. A low 6% said they prefer increased customer service with increased costs and 4% were unsure.

The following statement about service levels was next read to respondents. They were then asked if they would be willing to see a decrease in service level to reduce cost increases.

"Currently, WNH customer service levels exceed regulated provincial standards, with 92.72% of calls being answered within 30 seconds by WNH. The OEB has set this service requirement level at 65%."

Q3. "Would you be willing to see a decrease in these service levels in order to reduce cost increases by \$0.15 per month or \$1.80 per year?"



Two-thirds of customers surveyed said that they are not willing to see a decrease in service levels in order to reduce monthly costs. Only slightly more than a quarter or 26% are willing to decrease service levels to decrease costs and 7% did not know or were unsure.

Renewables

The next question asked about preferences for renewables and new technologies in relation to traditional infrastructure.

"In the February survey, customers also said they are looking to WNH to provide environmental alternatives and focus on connecting or investing in renewable energy solutions or new technologies. However, the costs for these types of upgrades are higher than traditional infrastructure."

Q4. Which of the following do you prefer?

Invest more money in renewable energy at an additional cost (e.g. include solar and electric vehicle stations)	26%
Invest more money in new technologies at an additional cost (e.g. include online customer service tools or grid)	6%
Both investing in renewables & new technologies at an additional cost	33%
Continue investing in traditional infrastructure	26%
Unsure	10%

Only 26% want WNH to continue investing in traditional infrastructure, while most customers (65% total) want more money invested in renewables (26%), new technologies (6%) or both renewables and new technologies (33%) at additional costs. Ten percent did not know or were unsure.

Overhead & Underground Wires

A question on overhead versus underground wires was asked after the following statement was read.

"Underground lines cost approximately 5-10 times more than overhead lines. WNH installs underground lines in certain situations where the requesting party (example - developers) would directly pay for the cost difference."

Q5. Would you support WNH installing more underground lines than they do today if it meant an increase in customer rates?

Yes, I am willing to pay more for WNH to increase the amount of underground distribution	26%
No, I am NOT willing to pay more for WNH to increase the amount of underground distribution	56%
Unsure	19%

A majority of 56% are not willing to pay more to increase the amount of underground distribution, while 26% are willing, but almost two in ten or 19% are undecided.

Improvements & Upgrades

Respondents were asked to rate their level of interest in ten improvement or upgrade areas, also being advised there would be a cost associated for each. The table below ranks the areas from highest to lowest – the total merged responses of somewhat and very.

Q6. “Thinking about the next five years, please rate your interest in the following improvements or upgrades, keeping in mind that there will be a cost impact to you as a customer associated with them.”

	Unsure	Not at all important	Not very important	Somewhat important	Very important	TOTAL COMBINED IMPORTANT
<i>Educating customers and the public about electrical safety</i>	1%	8%	11%	42%	38%	80%
<i>Educating customers and the public about energy conservation</i>	1%	9%	11%	43%	36%	79%
<i>An automated outage notification system (automatically sends messages)</i>	1%	11%	14%	37%	37%	74%
<i>Reporting issues or making inquiries through an interactive website</i>	1%	9%	18%	47%	25%	72%
<i>Comparing your electricity consumption with others in the area</i>	1%	18%	26%	40%	15%	55%
<i>Automated alerts when electricity usage exceeds a prearranged threshold</i>	1%	21%	25%	38%	15%	53%
<i>Having an online chat feature on the WNH website during business hours</i>	1%	22%	33%	31%	13%	44%
<i>Automated alerts to remind you of your bill due date</i>	1%	30%	26%	25%	18%	43%
<i>Automated alerts estimating what your upcoming bill might be</i>	1%	32%	32%	27%	8%	35%
<i>Extended office hours (current hours are Monday-Friday 8:30 am – 4:30 pm)</i>	2%	45%	34%	13%	5%	18%

Total interest in terms of importance was highest for two areas of education, one about electrical safety (80%) and the other with respect to energy conservation (79%). The next highest level of interest was for an automated outage notification system at 74% and being able to report or make inquiries through an automated website at 72%.


Roughly half expressed interest in being able to compare their consumption with others (55%) and for having automated usage alerts (53%), while it dropped to 44% for an online chat feature and 43% for automated bill reminders.

The lowest interest related to having automated bill estimates (35%) and especially for extended office hours (18%).

Electronic & Paper Bills

All N=600 customers were asked if they currently receive an E-bill from Waterloo North Hydro of which 38% said they do. The 62% (N=374) that do not were then asked a follow-up question about what is preventing them from signing up for an E-bill.

Q7. "Do you currently receive an E-bill from WNH?"



Q8. "The cost of receiving a paper bill is \$1.05 per month per customer or \$12.60 per year. What is preventing you from registering to receive an E-bill?"

<i>I was not aware that the cost savings of e-billing help offset future cost increases</i>	31%
<i>It is more convenient to receive the bill by mail</i>	29%
<i>Receiving the bill by mail is a reminder to pay</i>	20%
<i>I am not comfortable with technology</i>	7%
<i>I am concerned about online security from receiving electronic bill</i>	5%
<i>Prefer paper copy</i>	3%
<i>Have not gotten to it yet</i>	2%
<i>Not aware option existed</i>	2%
<i>I do not have regular access to the internet</i>	1%

The main mentions for preventing customers from receiving an E-bill related to not being aware of the cost savings (31%), closely followed by the perceived convenience of receiving a bill by mail (29%) and that a hard copy by mail serves as a reminder to pay.

Tree Trimming

Customers were described the actions taken by WNH related to tree trimming and were then read three options being asked to identify which one came closest to their opinion on the issue.

"Waterloo North Hydro must trim trees in proximity to overhead lines to avoid trees contacting lines for safety and reliability. Currently, WNH will trim frequently to be able to maintain safe clearances with minimal trimming to a tree."

Q9. "Which of the following statements best aligns with your view on tree trimming by WNH?"

READ OPTIONS

65% I support the current WNH process of more frequent tree trimming with appropriate clearance to balance reliability, aesthetic, and environmental concerns

24% I would like trees trimmed less frequently where possible with branches cut back more than today, regardless of aesthetic or environmental concerns, so that fewer power outages occur and there are shorter wait times to restore power after storms, and costs are reduced

4% I prefer trees trimmed with less clearance and more frequency than current practice because of aesthetic or environmental reasons, and will accept more power outages, longer wait times to restore power after storms and increase in costs for tree trimming and to respond to outages

7% Unsure

Most or 65% support the current process of more frequent tree trimming with enough clearance to balance reliability, aesthetic, and environmental concerns. Twenty-four percent want less frequent trimming, but more branches cut to ensure fewer outages or lower wait times to restore power, while only 4% want less trimming because of aesthetic or environmental reasons. Seven percent were unsure.

System Access & System Renewal

The following description about capital investments and investment categories was first read to respondents.

I'm going to read a bit more information for you before the next question. WNH is developing a new Distribution System Plan ("the Plan") which will guide capital Investments for the period 2021 – 2025. Capital investments cover items including distribution equipment such as poles, wires, and transformers, and support items such as information systems, vehicles, and facilities. The final investment portfolio will be comprised of prioritized investments paced to achieve an acceptable balance between meeting infrastructure needs and the impact on customer rates.

From 2015 to 2019, WNH invested approximately \$22.4 million annually. WNH's current proposed Plan is similar and is focused on replacing assets in poor condition before they fail (causing reliability and safety issues). While keeping costs in line, this Plan incorporates new innovative technologies to improve reliability and customer service. It allows the distribution system to connect new load customers, as well as renewable energy generation, electric vehicles, and battery storage devices. WNH's Plan involves investing approximately \$19.7 million annually between 2021 and 2025. This represents an annual reduction of \$2.7 million in capital expenditures from previous years, while still maintaining investments in the infrastructure needs of WNH and its customers.

Capital investments fall into four investment categories as set out by the Ontario Energy Board. The background and drivers for the proposed capital investments over the years 2021 - 2025 are discussed in the following categories:


- A. System Access
- B. System Renewal
- C. System Service
- D. General Plant

System access investments are primarily additions and modifications to the distribution system driven by external requesting parties (customers, developers, and road authorities). WNH is mandated to respond to these requests with the appropriate investments. From 2015 to 2019, WNH invested approximately \$9.5 annually in System Access projects. WNH forecasts investments from 2021 – 2025 will average approximately \$6.1 million, a reduction of \$3.3 million annually from previous years. These investments represent approximately 31% of annual capital investments.

System Renewal investments involve replacing existing assets based on age, condition, risk, and reliability metrics. From 2015 to 2019, WNH invested approximately \$9.6 million annually in System Renewal projects. WNH forecasts investments from 2021 – 2025 will average approximately \$9.2 million, a reduction of \$0.46 million annually from previous years. These investments represent approximately 47% of annual capital investments.

Respondents were then asked about their perception of the level of future system renewal expenditures.

Q10. "In your opinion, is this proposed overall level of future system renewal expenditures too low, just right, or too high to meet the objectives of safety, reliability, and cost?"




Slightly more than six in ten or 61% feel the level of expenditures is just right to meet the objectives of safety reliability and cost. Only 6% said it is too low, 11% too high, while 22% were unsure.

System Service

The next area covered system service projects and customers were asked how important they felt it was for WNH to modernize the grid.

"From 2015 to 2019, WNH invested approximately \$0.9 million annually in System Service projects. This included constructing additional distribution lines, smart grid automation to improve reliability and distribution system loss reduction. WNH forecasts investments from 2021 – 2025 will average approximately \$1.4 million, an increase of \$0.51 million annually. These investments represent approximately 7% of annual capital investments."

Q11. "How important do you feel it is for WNH to invest in modernizing the grid?"



Customers ranked in order of preference from 1-highest to 5-lowest, five areas related to reliability. Below are the mean scores ranked in priority.

Q12. Please rank in order of priority preference the following five reliability outcomes. One ("1") represents your highest priority through to five ("5") being lowest priority.

Highest priority	2.63	Reducing the length of time to restore power during extreme weather events
	2.71	Reducing the number of outages during extreme weather events
	2.73	Reducing the overall number of outages
	2.79	Reducing the overall length of outages
Lowest priority	4.14	Improving the quality of power, as judged by momentary interruptions in power that can result in the flickering or dimming of lights


Highest scored was reducing the time to restore power during extreme weather (2.63), next by reducing outages during extreme weather (2.71), outages overall (2.73) and then their overall length (2.79). Lowest scored was improving the quality of power – judged by momentary interruptions (4.14).

General Plant

A descriptive of general plant capital investments was read and customers were asked their opinion about the level of future expenditures.

"Capital investments in the General Plant category are driven by the need to add, modify, or replace assets that support WNH's everyday business operations and administration. These investments improve employee safety, worker productivity, and operating efficiency. From 2015 to 2019, WNH invested approximately \$2.4 million annually in General Plant projects. WNH forecasts investments from 2021 – 2025 will average approximately \$2.9 million, an increase of \$0.54 million annually. This increase is influenced by the replacement of an obsolete Enterprise Resource Planning (ERP) Software System. These investments represent approximately 15% of annual capital investments."

Q13. "In your opinion, is this proposed overall level of future general plant expenditures too low, just right, or too high to meet the objectives of safety, reliability, and cost?"




Two-thirds of customers feel the current level of expenditures is just right. Only 3% said too low, 10% too high, while two in ten were unsure.

Overall Future Capital Expenditures

Customers were then questioned about the overall level of capital expenditures.

Q14. "Now that you have more information on the capital expenditures for WNH, in your opinion, is this proposed overall level of future capital expenditures too low, just right, or too high to meet the objectives of safety, reliability, and cost?"


Results are consistent with 68% saying the overall level is just right, 7% too high, 7% too low, while 18% did not know or were unsure.



Right Focus

All N=600 customers were asked if they felt WNH has focused on the right areas for capital investment. If they answered no (3%, N=19%) or unsure (27%, N=160) they were probed about the areas that need addressing in a follow-up question.

Q15. "In your opinion, has WNH focused on the right areas for capital investments?"



Seven in ten feel WNH has focused on the right areas, only 3% do not. A significant 27% answered do not know.

Q16. "What areas of capital investment do you believe need to be addressed?"

Most customers were or 82% did not know, with those unsure in Q15 being most likely to have no comment (88%) in relation to those that said no (26%). Those with comments relayed areas from renewables, equipment / general upgrades, to lower costs and website improvements.

Don't know / unsure / no comment	N=147	82%
Renewable energy	N=7	4%
Equipment upgrades	N=4	2%
Lower prices / costs	N=3	2%
Web site upgrades	N=3	2%
General upgrades	N=3	2%
Outsourcing	N=2	1%
Eliminate carbon footprint	N=2	1%
Hire more staff	N=1	1%
Billing improvements	N=1	1%
Big business should be charged more	N=1	1%
Lower upper management salaries	N=1	1%
WNH should provide more education / information	N=1	1%
Need to be better prepared	N=1	1%
Underground upgrades	N=1	1%
Reliability	N=1	1%

Rate Increase

Rate increases were described to respondents with details provided for both residential and commercial customers. They were then asked about their opinion on the increases, being asked which of three statements best reflected their view.

"For residential customers / small business customers, WNH receives a standard increase annually that is less than inflation, but changes based on current cost levels every five years (2021). The last full cost application was in 2016. The preliminary monthly rate impact to the average residential customer distribution portion is \$1.96 [small business customer \$4.59] and the total bill increase is 1.5% in 2021 [small business 1.3%], holding other things constant (TOU Rates, Ontario Electricity Rebate). Please note that these are preliminary estimates and are subject to change as the rate application process continues."

Q17. "Which of the following best represents your point of view on this rate increase?"

READ / ROTATE LIST

The rate increase is reasonable, 32%

I don't like the idea of a rate increase, but it is necessary, 51%

The rate increase is unreasonable, 13%


Unsure, 4%

A slim 51% majority said they do not like the idea of a rate increase but feel it is necessary (54% business & 51% residential), while almost a third or 32% said it is reasonable (26% business & 32% residential). Only 13% claimed the increase is unreasonable (16% business & 13% residential), while 4% were unsure (4% business & 4% residential).

Planning for the Future


In the final two rating questions, customers were asked if WNH's investment plan is on the right track and then to rate the utility in planning for the future.

Q18. "In your opinion, is Waterloo North Hydro's investment plan headed in the right direction or the wrong direction?"



Eighty-four percent are of the opinion WNH's investment plan is headed (44%) or somewhat headed (40%) in the right direction, compared to only 4% that think it is somewhat (3%) or headed (1%) in the wrong direction. Twelve percent were unsure.

Q19. "Overall, how would you rate Waterloo North Hydro in planning for the future? Please respond using a scale of very poor, poor, good or very good."



Most customers or 88% rated WNH good (67%) or very good (21%) in planning for the future. A very low 3% held they are doing a poor (2%) or very poor job (1%), while 9% answered do not know.

Final Questions

Below are the coded responses from a final verbatim probe that asked for additional comments.

Q20. “Do you have any comments or feedback you would like to share?”

No/none	N=517
Good service / no problems / satisfied	N=24
Too expensive / costly / rates too high	N=18
Improvements to customer service	N=6
Underground infrastructure	N=6
Renewable energy	N=4
Promote Energy Saving equipment / vehicles	N=3
Need more details on bill	N=3
Salaries too high	N=3
Improvements needed to online / website	N=3
Too many breaks given to corporations	N=2
Quicker response to outages	N=1
Encourage paperless billing	N=1
Billing is not accurate / time of use	N=1
Cut down dead trees	N=1
Should be a private company	N=1
Dislike renewable energy	N=1
WNH should notify us of outages	N=1
Upgrade hardware	N=1
Dislike time of use	N=1
Expensive to switch from Hydro	N=1
Eliminate management	N=1

The last survey question asked customers about their community.

Q21. In which community is your WNH customer account located?			
Waterloo	N=483	81%	
Woolwich-Urban (Breslau, Conestoga, Elmira, St. Jacobs)	N=78	13%	
Woolwich-Rural	N=11	2%	
Wellesley-Urban (Heidelberg, St. Clements, Wellesley)	N=20	3%	
Wellesley-Rural	N=8	1%	
Total	600	100.0	

Online Survey Results

Question 1 verified that respondents were customers of Waterloo North Hydro. They were then presented with the following information after which they were asked two demographic questions.

The purpose of this Customer Engagement Survey is to obtain your input regarding our business plans for the period 2021 to 2025, and how these plans will affect you in terms of service and cost. Your feedback will be used to help shape our capital and operating plans, which will be presented to the Ontario Energy Board (OEB) when Waterloo North Hydro (WNH) files its rate application for 2021.

Each year, as our electricity distribution system ages and parts of it deteriorate, continued investments must be made to replace the most vulnerable parts of the system. WNH also serves a growing community and investments must be made to connect new customers.

This plan looks at capital infrastructure investments, system maintenance, customer service, administration, and emergency power restoration efforts as a result of storms and other outages, all which comprise WNH's portion of the delivery line on your electricity bill.

In February 2019, WNH customers completed an online survey to gauge customer needs and preferences. WNH built a plan and budget based on the results of that survey as well as distribution system needs.

We are once again asking for your feedback to ensure we have your input right in our plan.

Customers who complete this survey will be entered in a draw to win one of six VISA gift cards worth \$250 each. Winners will be drawn at random and will be notified by December 6th, 2019.



Section 1. Introductory Questions

Q2. Will you be completing this survey as a residential customer or a business customer?

Residential	2326	97.2
Business	67	2.8
Total	2393	100.0

Q3. In which community is your WNH customer account located?


Waterloo	N=1889	79%
Woolwich-Urban (Breslau, Conestoga, Elmira, St. Jacobs)	N=316	13%
Wellesley-Urban (Heidelberg, St. Clements, Wellesley)	N=110	5%
Woolwich-Rural	N=54	2%
Wellesley-Rural	N=24	1%
Total	2393	100.0

Section 2. Electricity Distribution System


Next, online participants were presented with the following overview of the electricity system, the role of WNH and reason for gathering their input – namely the business plan.

Ontario's electricity system is owned and operated by public, private, and municipal corporations across the province. It's made up of three components: **generation**, **transmission**, and **distribution**.

The purpose of this Customer Engagement Survey is to obtain your input regarding our business plans for the period 2021 to 2025, and how these plans will affect you in terms of service and cost. Your feedback will be used to help shape our capital and operating plans, which will be presented to the Ontario Energy Board (OEB) when Waterloo North Hydro (WNH) files its rate application for 2021.



WNH provides electricity to over 58,000 customers residing or owning a business in the City of Waterloo, the Township of Wellesley, and the Township of Woolwich, covering an area of 683 square kilometers. WNH is owned by the City of Waterloo, the Township of Wellesley, and the Township of Woolwich.



WNH's Service Area is 8% larger than Toronto Hydro's, but with 92% less customers. As in the past, WNH needs to look for efficient and resourceful ways to continue providing a strong and reliable infrastructure covering a large service area with fewer customers to shoulder the costs.

What does it cost to run WNH's distribution system?

Like most businesses, WNH manages its spending in two budgets – an operating budget and a capital budget.

- WNH's operating budget covers recurring expenses, such as the maintenance of tools, equipment, assets, and the payroll for employees.


- WNH's capital budget covers items that, once purchased, have lasting benefits over many years. This includes much of the equipment that is part of the distribution system, including poles, wires, cables, transformers, computers and information systems, vehicles, and facilities.

Managing the distribution system requires millions of dollars in maintenance, system renewal, and '24/7, 365 days a year' operations.

The only source of revenue for WNH is from the delivery portion of monthly bills.

WNH's portion of the average residential bill is 29% of the total bill. WNH's portion of the average small business bill is 23% of the total. These portions are used to maintain and rebuild the system and include a regulated rate of return that is used to reinvest in the system.

WNH does not mark up the cost of electricity. What customers pay to us is paid directly to the IESO.



This section further explained the costs to run the distribution system and clarified issues raised in a previous online customer survey.

What does it cost to run WNH's distribution system? Feedback comments provided in the first online customer survey (this past February) revealed some misconceptions that require further clarification. Here, we'll clarify and better explain some of that information:



Fixed Delivery: WNH's delivery fee (for residential only) is mandated by the OEB to be fully fixed. This is because whether you use a lot of power or a little bit of power, the cost to service your home (set up a transformer, poles and wires to your home, and provide billing and customer service) does not change based on your usage.



Costs: Some customers noted that delivery cost should already include capital investment costs, ongoing maintenance, and repairs to the system. This is true; WNH's delivery cost does already include capital investments, maintenance and repairs. However, these costs increase each year due to quantity of assets in the field as well as inflation.



Time-of-use Pricing: Some customers wanted to see changes in Time-of-Use (TOU) pricing, or different pricing for students and/or seniors. This is a provincial price plan in which WNH has no control. WNH implements and supports all government mandates.




Billing: Some customers requested to revert back to bi-monthly billing, do not want smart meters, or do not like the deposit amount required. Again, these are provincially mandated billing and customer service rules. WNH works with customer when flexibility allows, but follows all of the OEB rules.

All N=600 customers were then asked the first indicator of the questionnaire about their awareness of the role that WNH plays in the electricity system.

Understanding Role of WNH

Q4. "Based on the information provided, how well do you feel you understand the role that Waterloo North Hydro plays in the electricity system, including where revenue comes from and what portion of your bill relates to WNH?"



Almost all or 98% have an understanding, with more than half or 53% that completely and 45% that somewhat understand. Only 2% do not understand and 1% were unsure.

Cost Versus Service


The following was displayed to respondents outlining the opposing preferences as provided in the February 2019 online customer survey. They were then provided with three options related to cost and service and were asked which one they preferred.

Opposing Preferences from First Engagement

Based on our first engagement done in February 2019, there were results and priorities were opposing preferences. WNH would like to further dive into these to help guide our direction. Some customers have told us they want service enhancements like electricity usage tracking and alerts, which are not currently in the WNH plan and will increase costs slightly. Other customers have placed a lower priority on customer service and higher priority on low cost alternatives.

Q5. "Which of the following do you prefer?"

READ / ROTATE LIST




A 65% majority of online participants prefer a continuation of current service levels, while slightly less than a quarter or 24% want to see decreased costs with lower levels of service. A low 6% said they prefer increased customer service with increased costs and 5% were unsure.

Next, they were shown the following and were then asked if they would be willing to see a decrease in service level to reduce cost increases.

Currently WNH customer service levels exceed regulated provincial standards, e.g. 92.72% of calls are answered within 30 seconds by WNH. The OEB has set this service requirement levels at 65%.

Q6. "Would you be willing to see a decrease in these service levels in order to reduce cost increases by \$0.15 per month or \$1.80 per year?"



Sixty-three percent answered that they are not willing to see a decrease in service levels in order to reduce monthly costs. Almost three in ten or 28% are willing to decrease service levels to decrease costs and 9% did not know or were unsure.

Renewables

The next question asked about preferences for renewables and new technologies in relation to traditional infrastructure after the following preamble.

Customers said they are looking to WNH to provide environmental alternatives and focus on connecting or investing in renewable energy solutions or new technologies. However, the costs for these types of upgrades are higher than traditional infrastructure.

Q7. Which of the following do you prefer?

Invest more money in renewable energy at an additional cost (e.g. include solar and electric vehicle stations)	25%
Invest more money in new technologies at an additional cost (e.g. include online customer service tools or grid)	5%
Both investing in renewables & new technologies at an additional cost	31%
Continue investing in traditional infrastructure	28%
Unsure	11%

Among online participants there is a demand for investing in new technologies and renewables at additional costs – 64%. This includes 31% that want investment in both renewables and new technologies, 25% in renewables and 5% in new technologies. Only one-quarter want to continue investing in traditional infrastructure and 11% were unsure.

Overhead & Underground Wires

A question on overhead versus underground wires was asked after the following statement was presented.

Underground lines cost approximately 5-10 times more than overhead lines. WNH installs underground lines in certain situations where the requesting party (developers) directly pay for the cost difference. Would you support WNH installing more underground lines than they do today if it meant an increase in customer rates?

Q8. Would you support WNH installing more underground lines than they do today if it meant an increase in customer rates?

Yes, I am willing to pay more for WNH to increase the amount of underground distribution	25%
No, I am NOT willing to pay more for WNH to increase the amount of underground distribution	59%
Unsure	16%

Almost six in ten (59%) are not willing to pay more to increase the amount of underground distribution, compared to one-quarter that are willing. Sixteen percent did not know.

Improvements & Upgrades

Online respondents were asked to rate their level of interest in ten improvement or upgrade areas, also being advised there would be a cost associated for each. The table below ranks the areas from highest to lowest – the total merged responses of somewhat and very.

Q6. “Thinking about the next five years, please rate your interest in the following improvements or upgrades, keeping in mind that there will be a cost impact to you as a customer associated with them.

	Unsure	Not at all important	Not important	Somewhat important	Very important	TOTAL COMBINED IMPORTANT
<i>Educating customers and the public about energy conservation</i>	1%	7%	10%	45%	37%	82%
<i>Educating customers and the public about electrical safety</i>	2%	7%	12%	40%	39%	79%
<i>An automated outage notification system (automatically sends messages)</i>	1%	10%	12%	39%	38%	77%
<i>Reporting issues or making inquiries through an interactive website</i>	1%	8%	16%	52%	23%	75%
<i>Automated alerts when electricity usage exceeds a prearranged threshold</i>	1%	20%	23%	37%	19%	56%
<i>Comparing your electricity consumption with others in the area</i>	1%	20%	24%	38%	16%	54%
<i>Automated alerts to remind you of your bill due date</i>	<1%	31%	24%	26%	19%	45%
<i>Having an online chat feature on the WNH website during business hours</i>	1%	26%	30%	32%	11%	43%
<i>Automated alerts estimating what your upcoming bill might be</i>	<1%	31%	33%	26%	10%	36%
<i>Extended office hours (current hours are Monday-Friday 8:30 am – 4:30 pm)</i>	1%	48%	34%	13%	4%	17%

Total interest was highest for two areas of education, one about electrical safety (80%) and the other with respect to energy conservation (79%). The next highest level of interest was for an automated outage notification system at 74% and being able to report or make inquiries through and automated website at 72%.


More than half expressed interest in being able to compare their consumption with others (55%) and for having automated usage alerts (53%), while it dropped to 44% for an online chat feature and 43% for automated bill reminders.

The lowest interested related to having automated bill estimates (35%) and especially for extended office hours (18%).

Electronic & Paper Bills

Online respondents were asked if they currently receive an E-bill from Waterloo North Hydro of which 75% said they do. The 23% (N=549) that do not and the 2% unsure (N=46) were then asked a follow-up question about what is preventing them from signing up for an E-bill.

Q10. "Do you currently receive an E-bill from WNH?"



Q11. "The cost of receiving a paper bill is \$1.05 per month per customer or \$12.60 per year. What is preventing you from registering to receive an E-bill?"

<i>Receiving the bill by mail is a reminder to pay</i>	31%
<i>I was not aware that the cost savings of e-billing help offset future cost increases</i>	26%
<i>It is more convenient to receive the bill by mail</i>	20%
<i>I am concerned about online security from receiving electronic bill</i>	6%
<i>I am not comfortable with technology</i>	3%
<i>Prefer / need paper copy</i>	3%
<i>Haven't gotten to it yet</i>	2%
<i>I want to register for e-bill / email bill</i>	2%
<i>I do not have regular access to the internet</i>	2%
<i>Was not aware of option</i>	2%
<i>Offer a rebate to switch</i>	1%
<i>Had in past but there were problems</i>	1%
<i>Don't have WNH account / paid in condo fees</i>	1%

The main mentions for preventing customers from receiving an E-bill related to a hard copy by mail serving as a reminder to pay (31%), closely followed by not being aware of the cost savings (26%) and the perceived convenience of receiving a bill by mail (20%).

Tree Trimming

Customers were displayed the actions taken by WNH related to tree trimming and were then read three options being asked to identify which one came closest to their opinion on the issue.

Waterloo North Hydro must trim trees in proximity to overhead lines to avoid trees contacting lines for safety and reliability. Currently, WNH will trim frequently to be able to maintain safe clearances with minimal trimming to a tree.

Q12. “Which of the following statements best aligns with your view on tree trimming by WNH?”

READ OPTIONS

63% I support the current WNH process of more frequent tree trimming with appropriate clearance to balance reliability, aesthetic, and environmental concerns

27% I would like trees trimmed less frequently where possible with branches cut back more than today, regardless of aesthetic or environmental concerns, so that fewer power outages occur and there are shorter wait times to restore power after storms, and costs are reduced

4% I prefer trees trimmed with less clearance and more frequency than current practice because of aesthetic or environmental reasons, and will accept more power outages, longer wait times to restore power after storms and increase in costs for tree trimming and to respond to outages

6% Unsure

Sixty-three percent support the current process of more frequent tree trimming with enough clearance to balance reliability, aesthetic, and environmental concerns. Twenty-seven percent want less frequent trimming, but more branches cut to ensure fewer outages or lower wait times to restore power, while only 4% want less trimming because of aesthetic or environmental reasons and 7% percent were unsure.


Section 3. Capital Investment Plan

Next, online participants were provided with background information about Waterloo North Hydro's Capital Investment Plan.

An Overview on Waterloo North Hydro's Distribution System Plan

WNH is developing a new Distribution System Plan ("the Plan") which will guide capital Investments for the period 2021 – 2025. Capital investments cover items that have lasting benefits over many years, including distribution equipment such as poles, wires, transformers, and support items such as information systems, vehicles, and facilities.

Corporate strategic imperatives, asset management objectives, and mandated investments form the high-level framework for the Plan. It is also shaped by customer feedback and preferences. The final investment portfolio will be comprised of prioritized investments paced to achieve an acceptable balance between meeting infrastructure needs and the impact on customer rates. During the initial customer engagement survey in February 2019, customers indicated their primary priorities as follows, with safety, reliability, and cost being most important.



With customers focused on price, but not at the risk of safety and reliability, WNH has developed a draft Plan that sets out to meet these criteria.

Section 4. Capital Investment Information

Further information and a breakdown about Waterloo North Hydro's planned capital investments were also provided before questioning.

Overall Capital Investment Plan

From 2015 to 2019, WNH invested approximately \$22.4 million annually. WNH's current proposed Plan is similar to the previous plan and is focused on replacing assets in poor condition before they fail (causing reliability and safety issues).

While keeping costs in line, this Plan incorporates new innovative technologies to improve reliability and customer service. It allows the distribution system to connect new load customers as well as renewable energy generation, electric vehicles and battery storage devices. WNH's Plan involves investing approximately \$19.7 million annually between 2021 and 2025. This represents an annual reduction of \$2.7 million in capital expenditures from previous years while still maintaining investments in the infrastructure needs of WNH and its customers.

Capital investments fall into four investment categories as set out by the Ontario Energy Board. The background and drivers for the proposed capital investments over the years 2021 - 2025 are discussed in the following categories:

1. System Access
2. System Renewal
3. System Service
4. General Plant

2 SYSTEM RENEWAL

System Renewal investments involve replacing existing assets based on age, condition, risk, and reliability metrics. WNH has developed a comprehensive Asset Management System to capture and examine asset data, estimate replacement times, identify the consequences of failure, and forecast replacement plans and costs. These investments must be paced in combination with other capital needs to find the right balance between safety, system performance, risk, and cost. Not completing this work within determined timeframes will lead to increased safety concerns, increased risk of outages, expensive reactive maintenance and replacements. Areas of major investment (2021 – 2025):

- WNH's distribution system has more than 685 km of underground cable, 135 km of which is at or nearing end of life (35 to 50 years old) – the Plan involves replacing approximately 8.5 km of this cable annually
- WNH's distribution system has approximately 21,500 poles, 3,700 poles of which are in 'poor' or 'very poor' condition – the Plan involves replacing approximately 500 poles annually
- Replacement of small overhead primary conductors (which are more likely to break) will be replaced with large conductors, increasing safety and reliability
- Selected transformer station equipment, protection, and communication systems will be upgraded to improve reliability and cyber security




From 2014 to 2019, WNH invested approximately \$9.6 million annually in System Renewal projects. WNH forecasts investments from 2021 – 2025 will average approximately \$9.2 million, a reduction of 0.46 million annually from previous years. These investments represent approximately 47% of annual capital investments.

System Access & System Renewal

Respondents were then asked about their perception of the level of future system renewal expenditures.

Q13. "In your opinion, is this proposed overall level of future system renewal expenditures too low, just right, or too high to meet the objectives of safety, reliability, and cost?"




Almost six in ten or 58% feel the level of expenditures is just right to meet the objectives of safety, reliability and cost. Only 5% said it is too low, 14% too high, while 23% were unsure.

3 SYSTEM SERVICE

System Service investments are made to meet performance-based objectives such as safety, reliability, power quality, system efficiency, cyber security, and other mandated objectives. These investments allow better utilization of WNH's existing electricity assets. Investments in this area from 2015 – 2018 (inclusive) have saved WNH customers approximately 5.26 million minutes of interrupted power. Not completing this work will lead to reduction in system performance, supply constraints preventing the connection of load or generation customers, and more expensive reactive maintenance and capital replacements. Areas of major investment (2021 - 2025):

- Constructing additional distribution lines to relieve load transfer constraints within the distribution system and between WNH transformer stations
- Smart grid automation to reduce customer restoration times, improve operational visibility and control, and improve reliability
- Distribution system loss reduction

From 2014 to 2019, WNH invested approximately \$9.6 million annually in System Renewal projects. WNH forecasts investments from 2021 – 2025 will average approximately \$9.2 million, a reduction of 0.46 million annually from previous years. These investments represent approximately 47% of annual capital investments.




From 2015 to 2019, WNH invested approximately \$0.9 million annually in System Service projects. WNH forecasts investments from 2021 – 2025 will average approximately \$1.4 million, an increase of \$0.51 million annually. These investments represent approximately 7% of annual capital investments.

System Service

At the end of the information section, respondents were asked how important they felt it was for WNH to modernize the grid.

Q14. "How important do you feel it is for WNH to invest in modernizing the grid?"



Customers ranked in order of preference from 1-highest to 5-lowest, five areas related to reliability. Below are the mean scores ranked in priority.

Q15. Please rank in order of priority preference the following five reliability outcomes. One ("1") represents your highest priority through to five ("5") being lowest priority.

Highest priority	2.61	Reducing the length of time to restore power during extreme weather events
	2.75	Reducing the number of outages during extreme weather events
	2.76	Reducing the overall number of outages
	2.82	Reducing the overall length of outages
Lowest priority	4.04	Improving the quality of power, as judged by momentary interruptions in power that can result in the flickering or dimming of lights

Highest scored was reducing the time to restore power during extreme weather (2.61), next by reducing outages during extreme weather (2.75), outages overall (2.76) and then their overall length (2.82). Lowest scored was improving the quality of power – judged by momentary interruptions (4.04).

4 GENERAL PLANT

Capital investments in the General Plant category are driven by the need to add, modify, or replace assets that support WNH's everyday business operations and administration. These investments improve employee safety, worker productivity, and operating efficiency. Areas of major investment (2021 - 2025):

Computer Software & Hardware

- Replacement of Enterprise Resource Planning (ERP) Software
- Enhancements to various corporate systems and hardware

Fleet Vehicles / Rolling Stock


- Replace vehicles reaching end of life

Tools, Equipment & Furniture

- Replace 30-year-old Forklift Truck
- Replace various tools and test equipment

Facilities & Other

- Replace aging building equipment
- Retirement of eight municipal stations
- Obtain Land rights/easements to facilitate construction of lines




From 2015 to 2019, WNH invested approximately \$2.4 million annually in General Plant projects. WNH forecasts investments from 2021 – 2025 will average approximately \$2.9 million, an increase of \$0.54 million annually. This increase is influenced by the replacement of an obsolete Enterprise Resource Planning (ERP) software system. These investments represent approximately 15% of annual capital investments.

General Plant

Online participants were then queried about their opinion on the general level of future plant expenditures.

Q16. "In your opinion, is this proposed overall level of future general plant expenditures too low, just right, or too high to meet the objectives of safety, reliability, and cost?"




There are 65% that are of the opinion the level of general plant expenditures is just right, while 7% feel it is too low. Nine percent stated it is too high, while 19% were unsure.

Overall Future Capital Expenditures

Customers were then questioned about the overall level of future capital expenditures.

Q17. "In your opinion, is this proposed overall level of future capital expenditures too low, just right, or too high to meet the objectives of safety, reliability, and cost?"




With respect to future capital expenditures, 64% said the proposed spending is just right, 7% that it is too low, 8% too high and 21% were unsure.

Right Focus

All online participants were asked if they felt WNH has focused on the right areas for capital investment. If they answered no (4%, N=92) or unsure (32%, N=766) they were probed in a follow-up question (Q19) about the areas that need addressing.

Q18. "In your opinion, has WNH focused on the right areas for capital investments?"



Sixty-four percent feel WNH has focused on the right areas, while only 4% do not. However, more than three in ten or 32% answered do not know.

Those answered NO (4%, N=92) or UNSURE (32%, N=766) in Q18 were asked Q19.

Q19. "What areas of capital investment do you believe need to be addressed?"

Most online respondents or 86% did not know or were unsure of what needs to be addressed. Those with opinions tended to name more renewable energy or environmental upgrades, lower prices and comments related to general upgrades or improvements.


Unsure	N=739	86%
Renewable energy	N=36	4%
Lower prices / costs	N=18	2%
Reliability (less outages, etc.)	N=12	1%
Infrastructure	N=7	1%
Environmental improvements	N=7	1%
Move / more lines underground	N=5	1%
Lower upper management salaries	N=4	<1%
Upgrade technology	N=4	<1%
Equipment upgrades	N=3	<1%
Upgrade ERP system	N=3	<1%
Quit selling hydro to the U.S.	N=3	<1%
General upgrades	N=2	<1%
Underground upgrades	N=2	<1%
Upgrade lines / poles	N=2	<1%
Less smart technology	N=2	<1%
Less using contractors / outsourcing	N=2	<1%
Sustainable growth	N=2	<1%
Wind turbine energy	N=1	<1%
Outsourcing	N=1	<1%
Billing improvements	N=1	<1%
The building	N=1	<1%
Merge with other utilities	N=1	<1%

Section 5. Capital Investments & Monthly Bill

The following was displayed after which customers were asked which of three statements best reflected their view on rate increases.

PACING INVESTMENTS

The overall amount WNH invests in capital projects remains similar over the 2021 – 2025 period, but what changes is where these investments are made. WNH carefully plans and paces spending to ensure it stays consistent and the impact to customer rates is minimal. The chart below outlines WNH's spending in past years, plus proposed spending for the upcoming 5-year period (2021 – 2025).



The Impact on Your Bill

WNH believes that the Plan achieves a balance between the needs and priorities of our customers and our infrastructure, maintains system performance, and allows the community to grow while keeping bill impacts manageable over the long-term. WNH receives a formulaic increase annually that is less than inflation but resets based on current cost levels every five years (2021). The last full cost application was in 2016. The preliminary monthly rate impact to the average residential customer distribution portion is \$1.96 and the total bill increase is 1.5% in 2021, holding other things constant (TOU Rates, Ontario Electricity Rebate). The preliminary monthly rate impact to the average small business customer distribution portion is \$4.59 and the total bill increase is 1.3% in 2021, holding other things constant (TOU Rates, Ontario Electricity Rebate). Please note that these are preliminary estimates and are subject to change as the rate application process continues. Rate impacts are estimated for an average residential household that consumes 700 kWh per month.

Rate Increase

Q20. "Which of the following best represents your point of view on this rate increase?"

READ / ROTATE LIST

The rate increase is reasonable, 31%

I don't like the idea of a rate increase, but it is necessary, 53%

The rate increase is unreasonable, 14%


Unsure, 2%

A total of 53% said they do not like the idea of a rate increase but feel it is necessary, while 31% said it is reasonable. There were 14% that claimed the increase is unreasonable, while 2% were unsure.

Planning for the Future


In the final two scaled questions customers were asked if WNH's investment plan is on the right track and they then rated the utility in planning for the future.

Q21. "In your opinion, is Waterloo North Hydro's investment plan headed in the right direction or the wrong direction?"



Eighty-three percent of online participants held the view that WNH's investment plan is headed (46%) or somewhat headed (37%) in the right direction, compared to 6% that think it is somewhat (5%) or headed (1%) in the wrong direction. Eleven percent did not know.

Q22. "Overall, how would you rate Waterloo North Hydro in planning for the future? Please respond using a scale of very poor, poor, good or very good."



Nine in ten customers responding to the online survey (90%) rated WNH good (66%) or very good (24%) in planning for the future. There were only 4% that said they are doing a poor (3%) or very poor job (1%), while 6% did not know.

Summary & Highlights

Results from both the online and telephone survey components reveal similar opinions with respect to most indicators. This despite the extensive background information contained in the online survey in relation to the abridged text read in the telephone survey.

For instance, findings from both surveys reveal a high level of understanding (somewhat & completely) of the role that Waterloo North Hydro plays in the electricity system, including where revenue comes from and what portion of their bill relates to WNH – including 98% of online and 97% of telephone respondents. However, more online participants said they were completely aware (53%) than telephone respondents (49%), while more phone customers said somewhat aware (48%) in relation to those online (45%). Among the N=32 small businesses that completed paper questionnaires, N=18 said they were completely aware and N=14 somewhat aware.

In a question only asked to the N=32 small businesses, N=18 answered they somewhat and N=14 very well understand the cost drivers that Waterloo North Hydro is responding to.

Customers were presented with choosing among three options, including (a) service enhancements that they were told would increase costs, (b) having a lower priority on service while favoring lower cost alternatives and (c) continuing with current levels of customer service. Overall, the WNH client base prefers a continuation of current customer service levels, including 69% of telephone and a slightly lower 65% of online respondents. Next most named by 21% of telephone and 24% of online participants was decreasing costs with lower levels of customer service, while only 6% from both surveys want increased service (4% of phone & 6% of online participants were unsure).

As WNH currently exceeds regulated provincial standards as in area of answering calls within 30 seconds, most customers do not want to see service levels decreased in order to save 15¢ per month or \$1.80 per year. This includes two-thirds of telephone and 63% of online survey respondents. Only slightly more than a quarter or 26% of phone and 28% of online survey participants are willing to decrease service levels to lower costs – 7% and 9% respectively did not know or were unsure.



There is demand among customers for WNH to provide environmental alternatives and to focus on connecting or investing in renewable energy solutions or new technologies (at additional costs). Only 26% of telephone survey respondents want WNH to continue investing in traditional infrastructure, while a 65% majority from the phone poll want more money invested in renewables (26%), new technologies (6%) or both renewables and new technologies (33%) at additional costs. Ten percent did not know or were unsure. Among online participants there is a similar demand for investing in new technologies and renewables at additional costs – 64%. This includes 31% that want investment in both renewables and new technologies, 25% in renewables and 5% in new technologies. Only one-quarter want to continue investing in traditional infrastructure and 11% were unsure.

Among the N=32 businesses, N=18 want both investments in renewables and new technologies, N=6 more money in renewables and N=5 investments in new technologies, while only N=2 said to continue investing in traditional infrastructure and N=1 was unsure.

Despite the aforementioned demand for renewables and new technologies, a majority of customers are not willing to pay more for WNH to install more underground lines than they do today, if it means an increase in customer rates. Fifty-six percent of telephone respondents said they are not willing to pay more to increase the amount of underground distribution, while 26% are willing, but almost two in ten or 19% are undecided. Opposition was stronger among online participants as almost six in ten (59%) answered they would not be willing to pay more to increase underground lines, compared to one-quarter that are willing – 16% did not know.

Customers in both the online and telephone surveys rated their interest in ten improvements or upgrades, being told that there would be a cost impact associated with them.

Education rated highest, with more online participants favoring conservation and those by telephone safety. Automated outage notifications also rated highly, followed by an interactive website – with stronger results from the online component. Of mid-level importance was comparing consumption and automated alerts for usage, while results were lower for an online chat feature and alerts for bill due dates. Low importance was attached to automated alerts estimating bills and very low for extended office hours.

		
Educating customers and the public about electrical safety	80%	79%
Educating customers and the public about energy conservation	79%	82%
An automated outage notification system (automatically sends messages)	74%	77%
Reporting issues or making inquiries through an interactive website	72%	75%
Comparing your electricity consumption with others in the area	55%	54%
Automated alerts when electricity usage exceeds a prearranged threshold	53%	56%
Having an online chat feature on the WNH website during business hours	44%	43%
Automated alerts to remind you of your bill due date	43%	45%
Automated alerts estimating what your upcoming bill might be	35%	36%
Extended office hours (current hours are Monday-Friday 8:30 am – 4:30 pm)	18%	17%

More customers responding to the online poll (75%) claimed to receive an E-bill than those to the telephone survey (38%). N=15 of the N=32 businesses get an E-bill. After being told of the cost associated with traditional paper billing, they were asked what is preventing them from registering to receive an E-bill. The main mentions from telephone respondents related to not being aware of the cost savings (31%), closely followed by the perceived convenience of receiving a bill by mail (29%) and that a hard copy by mail serves as a reminder to pay (20%). Among online participants, most named was not being aware of the cost savings (31%), closely followed by the perceived convenience of receiving a bill by mail (26%) and that a hard copy by mail serves as a reminder to pay (20%). Among

businesses, most named by N=5 was not being aware of the cost savings, followed by N=3 that responded convenience and N=3 that it is a reminder to pay.

On the issue of tree trimming, customers support the status quo. Most (65% telephone & 63% online) back the current process of more frequent tree trimming with enough clearance to balance reliability, aesthetic, and environmental concerns. Twenty-four percent of telephone and 27% of online respondents want less frequent trimming, but more branches cut to ensure fewer outages or lower wait times to restore power, while only 4% (both surveys) want less trimming because of aesthetic or environmental reasons.

System Renewal

Slightly more than six in ten or 61% of telephone survey respondents feel the level of system renewal expenditures is just right to meet the objectives of safety reliability and cost. Only 6% said it is too low, 11% too high, while 22% were unsure.

Among online participants, almost six in ten or 58% feel the level of expenditures is just right to meet the objectives of safety, reliability and cost. Only 5% said it is too low, 14% too high, while 23% were unsure.

N=27 of the small businesses said the level is appropriate, N=3 too low and N=2 were unsure.

System Service

Among telephone respondents, 93% feel it is somewhat (46%) or very important (47%) to modernize the grid, compared to only 3% that feel it is unimportant – 4% did not know.

While a similar 92% of online participants said it is important to modernize, more answered very important (51%) compared to the telephone survey, while 41% answered somewhat important and 4% were unsure.

With respect to small businesses, N=23 answered very important and N=9 somewhat important.

When asked to rank in order of priority preference five reliability outcomes, the highest scored (mean) was reducing the time to restore power during extreme weather (2.63 – telephone & 2.61 online), next by reducing outages during extreme weather (2.71 – telephone & 2.75 – online), outages overall (2.73 – telephone & 2.76 online) and then their overall length (2.79 – telephone & 2.82 online). Lowest scored was improving the quality of power, judged by momentary interruptions (4.14 – telephone & 4.04 – online). Among the N=32 small businesses, reducing the overall number of outages ranked first (2.55), followed by the length of outages (2.69), the length of time to restore power during extreme weather (3.03), and the number of outages during extreme weather (3.28). Also scored lowest was improving the quality of power, judged by momentary interruptions (3.34).

General Plant

Two-thirds of customers responding to the phone survey feel the current level of expenditures is just right. Only 3% said too low, 10% too high, while two in ten were unsure. Sixty-five percent of online participants are of the opinion the level of general plant expenditures is just right, while 7% feel it is too low. Nine percent stated it is too high, while 19% were unsure. N=26 businesses claimed it was appropriate, N=3 too low and N=3 did not know.

With respect to future capital expenditures, results show that 68% of telephone and 64% of online participants feel the overall level is just right, 7% phone (8% online) said it is too high, 7% too low (same for both), while 18% of phone and 21% of online respondents were unsure.

Capital Investments

Seven in ten telephone respondents feel WNH has focused on the right areas for capital investments, only 3% do not. A significant 27% answered do not know. The number dips among online respondent's as 64% feel WNH has focused on the right areas, while only 3% do not. However, more than three in ten or 32% answered do not know. N=28 of the N=32 businesses stated WNH is focused on the right areas, while N=4 were unsure.

When those that do not feel WNH is focused on the right areas or did not know were asked in a follow-up about what they think needs to be addressed, most were unsure (82% - phone & 86% online). Among those providing answers, most mentions related to renewables or environmental upgrades, equipment / general upgrades and lower prices.

After being read or presented with a background to rate increases, customers were then asked which of three statements best reflected their view on the topic. There is a sense that while rate increases are disliked they are necessary – 51% from the telephone and 53% from the online survey hold this view. A core segment feel they are reasonable (32% telephone & 31% online), while few consider them unreasonable (13% telephone & 14% online) and the undecideds are low (4% telephone & 2% online). The same pattern held for businesses as N=20 answered that while they don't like the idea, they are necessary, N=10 think them reasonable, only N=1 said it is unreasonable and N=1 was unsure.

Overall, there appears buy-in with the direction being taken by WNH as a strong majority including 84% of telephone and 83% of online participants, feel WNH's investment plan is headed in the right direction. Results are even stronger on the perception among customers of how WNH is preparing for the future. Most of those responding by telephone or 88% said the utility is doing a good job in planning for the future as did 90% of online participants and all N=32 businesses.



Waterloo North Hydro Inc.

FLEET MANAGEMENT PLAN OVERVIEW & FORECAST 2021 - 2025

June 22, 2020



CONTENTS

CONTENTS.....	2
LIST OF TABLES	3
LIST OF FIGURES	4
GLOSSARY	5
1. INTRODUCTION.....	6
1.1. Purpose of this Report.....	6
1.2. Overview	6
2. FLEET ASSET MANAGEMENT PLAN (AMP).....	8
2.1. Strategy.....	8
2.2. Objectives	10
3. ASSETS UNDER MANAGEMENT	12
3.1. Large Vehicles	12
3.2. Medium Sized Vehicles	13
3.3. Small Sized Vehicles	13
3.4. Rolling Stock	15
4. FLEET ASSET CONDITION ASSESSMENTS	16
4.1. Asset Condition Assessment – Large Vehicles.....	18
4.2. Asset Condition Assessment – Medium Vehicles	21
4.3. Asset Condition Assessment – Small Vehicles	24
4.4. Asset Condition Assessment – Rolling Stock	28
5. CAPITAL INVESTMENT PLAN 2021 to 2025	30

LIST OF TABLES

Table 2-1: Inspections	9
Table 2-2: Maintenance	9
Table 2-3 WNH Strategic Imperatives.....	11
Table 3-1: Fleet Inventory – Large Vehicles.....	12
Table 3-2: Fleet Inventory – Medium Vehicles	13
Table 3-3: Fleet Inventory – Small Vehicles	14
Table 3-4: Fleet Inventory - Rolling Stock	15
Table 4-1: Health Index & Replacement Guidelines.....	17
Table 4-2: Fleet Assets TUL & Order Lead-times	17
Table 4-3: Evaluation Framework – Large Vehicles.....	18
Table 4-4: Asset Condition Evaluation Criteria – Large Vehicles.....	19
Table 4-5: Health Condition Index Results – Large Vehicles.....	20
Table 4-6: Evaluation Framework – Medium Vehicles	21
Table 4-7: Asset Condition Evaluation Criteria – Medium Vehicles	22
Table 4-8: Health Condition Index Results – Medium Vehicles	23
Table 4-9: Evaluation Framework – Small Vehicles	24
Table 4-10: Asset Condition Evaluation Criteria – Small Vehicles.....	25
Table 4-11a: Health Condition Index Results – Small Vehicles.....	26
Table 4-11b: Health Condition Index Results – Small Vehicles (continued)	27
Table 4-12: Evaluation Framework – Rolling Stock.....	28
Table 4-13: Asset Condition Evaluation Criteria – Rolling Stock	28
Table 4-14: Health Condition Index Results – Rolling Stock	29
Table 5-1: Historical & Forecast Fleet Capital Expenditures	30
Table 5-2: Forecast Fleet Replacements	31
Table 5-3: Fleet Asset Reduction.....	32

LIST OF FIGURES

Figure 2-1: WNH’s Life Cycle approach to Fleet Management.....8

GLOSSARY

- 1) ACA – Asset Condition Assessment
- 2) AM – Asset Management
- 3) AMP – Asset Management Plan
- 4) CEA – Canadian Electrical Association
- 5) CSA – Canadian Standards Association
- 6) DSC – Distribution System Code
- 7) DSP – Distribution System Plan
- 8) EOL – End-of-Life
- 9) GIS – Geographic Information System
- 10) GUP – Good Utility Practices
- 11) KPI – Key Performance Indicator
- 12) LDC – Local Distribution Company
- 13) MTO - Ministry of Transportation of Ontario
- 14) O/H or OH - Overhead
- 15) O&M – Operation & Maintenance
- 16) OEB – Ontario Energy Board
- 17) TUL – Typical Useful Life
- 18) TS – Transmission Station or Transformer Station
- 19) U/G or UG – Underground
- 20) WNHI / WNH – Waterloo North Hydro Inc.
- 21) XFMR / Tx – Transformer

1. INTRODUCTION

1.1. Purpose of this Report

Waterloo North Hydro's (WNH) fleet services are provided by the Fleet Services section of the Operations Division under the direction of the Vice President of Operations. Services provided include purchasing, rental, inspection, maintenance, repair, and replacement of vehicles and rolling stock equipment.

The purpose of this report is to provide a consolidated view of WNH's fleet management strategy, objectives, assets under management, asset condition assessments and investment plan for the years 2021 to 2025 inclusive. The report includes a summary of asset data, condition evaluation criteria and condition assessments that form the basis on which fleet capital investment plans have been formulated.

The information in this report also informs WNH's senior executive team (Executive) and aides in the development of WNH's Distribution System Plan (DSP) and supports WNH's 2021 Cost of Service Application (Application).

All information contained in this report is current as of December 31, 2019.

1.2. Overview

Fleet assets play a critical role in keeping the WNH staff working efficiently and safely. These assets are required to be reliable and maintained in a safe and efficient manner. Vehicles not available for service when needed results in a slow down of the work program, wasted time and labour in reorganizing and rescheduling work.

WNH's fleet assets consist of 53 vehicles, 16 trailers and 4 specialty-power operated equipment. Fleet assets have been divided into 4 asset groups, each with their own common set of asset condition parameters. A current listing of all WNH fleet assets can be found in **Section 3** of this report.

WNH performs regular inspection and maintenance on all fleet assets. The level of detail and frequency is determined by asset type, regulatory requirements and condition.

Condition data collected feeds into the Fleet Asset Condition Assessments which utilize condition parameters, asset condition scoring and relative weighting for each condition parameter to develop a Health Index (HI) for each vehicle.

The HI scores are ranked and grouped into 5 categories from Very Good to Very Poor. The condition assessments and ranking helps management staff to identify and prioritize worst performing assets, and help develop an action plan for fleet investments. Actions taken may range from increased inspection and maintenance to capital refurbishment or replacement. The current health score for all fleet assets is summarized in **Section 4** of this report.


WNH attempts to pace fleet capital investments in coordination with WNH's overall capital investment plan. This means that fleet investments at times will be lumpy in order to smooth out WNH's overall capital expenditures. A summary of WNH's fleet capital investments proposed for 2021 to 2025 can be found in **Section 5** of this report.

2. FLEET ASSET MANAGEMENT PLAN (AMP)

2.1. Strategy

WNH's Asset Management Strategy for fleet assets is similar to the strategy used for distribution assets which uses a full lifecycle approach to managing its fleet assets. WNH is also focused on evidence-based decision-making.

Figure 2-1: WNH's Life Cycle approach to Fleet Management



Plan - WNH prepares and reviews annually a five-year replacement schedule which is informed by regular asset condition assessments (ACA). Due to the lead time it takes to budget, order, receive and place into service, vehicles are typically planned for replacement when ACA's indicate fair to poor condition. By the time the existing assets are removed from service, they will have normally deteriorated to poor or very poor condition.

Replacement of large vehicles are ordered 18 - 24 months or longer in advance of replacement due to manufacturing wait times. Medium sized work vehicles normally are ordered 12 - 18 months and regular small vehicles such as trucks and vans are usually obtainable within a year.

Acquire – Detailed purchasing specifications are utilized for the largest and costliest assets. Specifications are reviewed and if needed updated before each submittal for tender. The number

and type of vehicles in the fleet at any point in time is determined by the size and scope of WNH's work program.

Operate, Inspect & Maintain – WNH performs regular inspection and maintenance on all assets. Defects or deficiencies are recorded and flagged for action. The level of detail and frequency is determined by asset type, regulatory requirements and condition of the equipment. **Table 2-1** and **Table 2-2** provide a summary of Fleet Inspection and Maintenance schedules.

Table 2-1: Inspections

FLEET / ROLLING STOCK	FREQUENCY
All commercial vehicles (vehicles > 4,500 kg) and all trailers receive an annual MTO safety inspection.	Annual
All commercial vehicles (vehicles > 4,500 kg) receive an inspection.	12 weeks
All small vehicles (< 4,500 kg) receive a full inspection every 36 weeks.	36 weeks
Rolling Stock full inspection.	Annual

Table 2-2: Maintenance

FLEET / ROLLING STOCK	FREQUENCY
All commercial vehicles (vehicles > 4,500 kg) receive a lube, oil, filter.	24 weeks
All aerial devices and cranes have a visual boom inspection and preventative maintenance.	6 weeks
All aerial devices and cranes have a full boom inspection including rotation bearing checks and complete preventative maintenance.	Annual
All small vehicles (< 4,500 kg) receive preventative maintenance of oil/lube.	18 weeks

Vehicle operating and maintenance costs are tracked and reviewed annually. At regular intervals or as operations require, these activities are performed, recorded and inform the vehicle asset condition assessments. Health indices are then developed for each vehicle.

Day to day fleet management is the responsibility of WNH's line superintendent. WNH maintains two licenced vehicle mechanics and a maintenance repair facility to correct deficiencies in a timely

manner. WNH also utilizes external contractors for specialized work or where it has been found to be cost effective.

Disposal – WNH disposes of its fleet assets when they are normally in poor or very poor condition. They are no longer economical, safe or reliable enough to withstand the daily rigors of utility operations or construction on high voltage lines. Vehicles for disposal are normally sold at auction or donated to college programs.

2.2. Objectives

Fleet operations and investments are key elements in facilitating the overall mission of WNH. WNH's Fleet Asset Management Strategy is aligned with and supports four of WNH's corporate strategic imperatives as illustrated in **Table 2-3**.

Cost, risk and performance are balanced through a whole life cycle management strategy that takes the assets from procurement to disposal.

To support the Fleet Asset Management Strategy, the following objectives were developed:

- maximize the operational effectiveness of the workforce by maximizing operational functionality and availability of the vehicles;
- maximize asset longevity through effective purchasing specifications, operational inspections and maintenance;
- minimize total lifecycle costs by tracking operational and maintenance costs as well as downtime costs;
- maximize safety of the fleet by minimizing accidents and incidents.

WNH manages its fleet to ensure these objectives can be achieved consistently and are sustainable over time.

Table 2-3 WNH Strategic Imperatives

Priority	Corporate Strategic Imperatives		Alignment with Fleet Management Plan
1a	Supply	We must ensure an adequate supply of electricity to meet our customers' needs.	
1b	Reliability	We must ensure supply of electricity has the reliability needed to meet our customers' needs.	<input checked="" type="checkbox"/>
2a	Health, Safety	We must continue to make Safety & Loss Prevention a way of life in our utility.	<input checked="" type="checkbox"/>
2b	Environment	We must operate our business with minimal impact on the environment	
3	Customer Service	We must deliver on customer expectations and continue to create value and contribute to making our customers more efficient and successful.	
4	Employee Relations and Development	We must continue to attract and develop talented people in our utility. We must also help our employees to be personally successful.	
5	Productivity and Cost Reduction	We must continue to operate our business efficiently and create a culture of excellence and continuous improvement.	<input checked="" type="checkbox"/>
6	Organizational Effectiveness	We must continue to find ways to leverage technology and adopt best business practices to improve organizational effectiveness.	<input checked="" type="checkbox"/>
7	Financial Performance	We must operate our business in a financially responsible and sustainable manner.	
8	Shareholder and Community relations	We must recognize the contributions of the Shareholders and the Community in the success of WNH, and in turn work to make them successful.	
9	System Aesthetics	We will continue to find ways, where it is feasible, to design and construct our system to improve landscape aesthetics.	

3. ASSETS UNDER MANAGEMENT

Fleet assets under management consist of 53 vehicles, 16 trailers and 4 specialty-power operated equipment. Fleet vehicles have been divided into four asset groups, each with their own common set of asset condition parameters.

3.1. Large Vehicles

WNH normally maintains a fleet of approximately 16 large vehicles equipped with aerial work platforms or lifting devices. These vehicles are equipped with specialized equipment such as articulating insulated booms, rotating turrets, hydraulic systems and more. Designed to safely and quickly lift workers and materials into the air to perform line construction and maintenance functions. In this group are single and double bucket trucks, radial boom derricks and cranes. These vehicles are special ordered, custom made and have long delivery lead times, generally around 18-24 months.

Table 3-1: Fleet Inventory – Large Vehicles

Vehicle	#	Vehicle CODE(1)	Vehicle Type	In Service Year	Life Expect (TUL)	Current Age (2020)
R	40	Derrick	Radial Boom Derrick	2004	14	16
R	61	Bucket	Single Bucket Material Handler Aerial Device	2006	14	14
R	92	Bucket	Double Bucket Double Elevator	2009	14	11
R	90	Bucket	Single Bucket Squirt Boom Service	2009	14	11
R	2	Derrick	Radial Boom Derrick	2010	14	10
R	11	Bucket	Single Bucket Material Handler Aerial Device	2011	14	9
R	12	Bucket	Single Bucket Service	2012	14	8
R	20	Derrick	Radial Room Derrick	2013	14	7
R	41	Bucket	Single Bucket Service	2014	14	6
R	42	Bucket	Single Bucket Material Handler Aerial Device	2014	14	6
R	53	Bucket	Single Elevator Double Bucket Material Handler Aerial Device	2015	14	5
R	55	Bucket	Single Bucket Material Handler Aerial Device	2015	14	5
R	60	Derrick	Radial Boom Derrick	2016	14	4
R	70	Crane	Knuckle Crane	2017	14	3
R	87	Bucket	Single Bucket Material Handler Aerial Device	2018	14	2
R	95	Bucket	Single Bucket Material Handler Aerial Device	2019	14	1

3.2. Medium Sized Vehicles

WNH normally maintains a fleet of approximately 5 vehicles in this category. They are normally larger vehicles used to transport workers, equipment, tools & test equipment to work sites. Used by underground line and stations departments, they do not have any aerial lifting devices or work platforms. These vehicles are special ordered, custom made and have long delivery lead times, generally around 12-18 months.

Table 3-2: Fleet Inventory – Medium Vehicles

Vehicle	#	Vehicle CODE(1)	Vehicle Type	In Service Year	Life Expect (TUL)	Current Age (2020)
O	51	Work	Work Body - Stations	2005	14	15
R	99	Work	Dump Truck	2009	14	11
R	114	Work	Work Body - Underground	2011	14	9
O	19	Work	Work Body - Stations	2012	14	8
R	43	Work	Work Body - Underground	2014	14	6

3.3. Small Sized Vehicles

This category is normally comprised of approximately 32 small vehicles for the transportation of staff, light tools and equipment. Made up of pickup trucks, vans, SUVs and cars, they are normally ordered from local dealerships and have delivery times of less than 12 months. Most however do require special outfitting before they can be placed into service and function in their role as a utility fleet vehicle.

Table 3-3: Fleet Inventory – Small Vehicles

Vehicle	#	Vehicle CODE(1)	Vehicle Type	In Service Year	Life Expect (TUL)	Current Age (2020)
O	172	Van	Full Size Cargo Van	2007	10	13
R	190	SUV	SUV Passenger	2009	10	11
G	111	Van	Full Size Cargo Van	2010	10	10
G	100	Van	Mini Van Cargo	2010	10	10
P	117	Van	Mini Van Passenger	2010	10	10
R	112	SUV	Small SUV	2010	10	10
G	110	Van	Mini Van Cargo	2010	10	10
R	115	Pick Up	4x4 Full Size Crew Cab Pick Up	2011	10	9
R	116	Pick Up	4x4 Full Size Crew Cab Pick Up	2011	10	9
O	118	Van	Full Size Cargo Van	2011	10	9
R	128	Pick Up	4x4 Full Size Crew Cab Pick Up	2012	10	8
R	127	Pick Up	4x4 Full Size Crew Cab Pick Up	2012	10	8
Y	124	Van	Full Size Cargo Van	2012	10	8
Y	125	Van	Full Size Cargo Van	2012	10	8
G	135	Van	Mini Van Cargo	2012	10	8
R	132	Pick Up	4x4 Full Size Crew Cab Pick Up	2012	10	8
G	123	Van	Mini Van Passenger	2012	10	8
B	136	Car	Hybrid Electric Car	2012	10	8
R	130	Pick Up	4x4 Small Pick Up	2012	10	8
G	134	Van	Mini Van Cargo	2012	10	8
R	133	Van	Mini Van Cargo	2012	10	8
R	131	Pick Up	4x4 Full Size Crew Cab Pick Up	2012	10	8
G	144	Van	Full Size Cargo Van	2013	10	7
G	165	Van	Mini Van Passenger + Shelving	2016	10	4
Y	171	Van	Full Size Cargo Van (Tall)	2017	10	3
G	173	Van	Mini Van Passenger + Shelving	2017	10	3
O	192	Van	Full Size Cargo Van	2018	10	2
R	193	Pick Up	4x4 Full Size Crew Cab Pick Up	2019	10	1
R	194	Pick Up	4x4 Small Pick Up	2019	10	1
R	196	Pick Up	4x4 Small Pick Up	2019	10	1
R	197	Pick Up	4x4 Full Size Pick Up	2019	10	1
B	199	SUV	SUV Passenger	2019	10	1

3.4. Rolling Stock

This group makes up the remainder of WNH's Fleet assets and is comprised of an assortment of pole & material trailers, tension stringers and other custom pieces of rolling equipment. The approximately 20 pieces of equipment are special ordered, custom made and each have unique delivery lead times.

Table 3-4: Fleet Inventory - Rolling Stock

Vehicle	#	Vehicle CODE(1)	Vehicle TYPE	Life Expect (TUL)	Current Age (2020)
T	521	Pole	Large pole trailer. Axle front and Rear	40	35
T	538	Lawn	Landscaping trailer, 2 axle	30	32
T	533	Material	Material trailer, 2 axle, open cage	40	31
ME	501	Puller	Diesel Puller	30	30
ME	502	Tensioner	Diesel Tensioner	30	30
T	540	Stringing	Stringing trailer, 2 axle, enclosed	40	21
T	541	Material	Material trailer, 3 axle, open, overhead	30	19
T	542	Material	Material trailer, 3 axle, open, overhead	30	19
T	543	Material	Stringing trailer, 2 axle, enclosed	40	12
T	544	Material	Trailer, small service for Mud Tracks	40	12
T	545	Material	Reel trailer, large 2 axle	30	11
T	546	Material	Material trailer, 3 axle, open, overhead	30	10
T	547	Reel	Reel trailer, small, 2 axle, triple	30	9
T	548	Reel	Reel trailer, small, 2 axle, triple	30	9
T	550	Pole	Pole trailer, 2 Axle, extendable, Service	30	8
ME	504	Pull/Tens	Electric Stringer	16	7
ME	505	Pull/Tens	Electric Stringer	16	7
T	551	Trans	Mobile TX Trailer Carto Trans	40	5
T	552	Pole	Pole trailer, small 1 axle	30	5
T	553	Reel	Reel trailer, large 1 axle	30	1

4. FLEET ASSET CONDITION ASSESSMENTS

In the management of fleet assets, WNH uses an asset condition assessment process similar to that used in the management of its distribution network assets.

Fleet assets are monitored from acquisition through to disposal and detailed records of all condition assessments are kept. WNH's fleet maintenance activities are planned to ensure the operational effectiveness, longevity and safety of fleet assets.

Asset condition evaluation parameters have been developed for each asset class. The criteria are based on degradation conditions that lead to the asset's end of life and fall into 3 data type categories:

Registry Data (R): asset registry details including age, operating conditions, operating environment, and nameplate data; may be current and/or historical in nature.

Measurement Data (M): tests which are usually quantitative in nature and assesses the conditions of the asset.

Inspection Data (I): visual inspection and/or other information which is usually qualitative in nature and assesses the conditions of the asset

Condition parameters were developed by WNH and are a function of manufacturer recommendations, regulatory requirements, industry practices and the expertise and judgment of WNH's licenced vehicle maintenance staff. The evaluation parameters are ranked from A to E and each rank corresponds to a numerical grade. A weighting factor is applied to each criteria indicating the influence the criteria has on the overall asset health. Asset conditions are compared to the evaluation criteria to develop a Health Score which represents a quantified condition score of the asset. Health Scores are normalized and given as a percentage from 0% to 100%.

Table 4-1 illustrates the relationship between the asset health score, overall health category and replacement guidelines.

Table 4-1: Health Index & Replacement Guidelines

Overall Condition	Health Score	Guidelines
Very Good	85 - 100%	Like New. Replacement outside of current 5 year forecast period.
Good	70 - 84%	Normal operation & maintenance. Re-evaluate within 5 years.
Fair	50 - 69%	Normal operation. Increased deterioration and/or maintenance. Expected replacement within current 5 year forecast period.
Poor	30 - 49%	Reduced operation, poor physical condition and/or rapidly escalating maintenance. Order replacement within 12 months.
Very Poor	0 - 29%	Replace as soon as possible. Alternatives may include to restrict operation, rent, lease, or purchase used.

WNH also uses historical information in assessing the condition of the vehicles. From past experience, WNH has found that the typical life expectancy has been 14 years for large and medium vehicles and 10 years for small vehicles. Although vehicles are replaced based on condition and not strictly on schedule, historical typical useful lives(TUL) present a target by which the degradation of vehicle condition can be benchmarked.

Table 4-2: Fleet Assets TUL & Order Lead-times

Overall Condition	TUL (Years)	Lead Time for Replacement (months)	Comments
Large Vehicles	14	18 - 24	
Medium Vehicles	14	12 - 18	
Small Vehicles	10	< 12	
Rolling Stock	15 - 40	12	Depends on type and use

4.1. Asset Condition Assessment – Large Vehicles

Large vehicle condition assessments are based on the eight condition parameters listed in **Table 4-3**.

Table 4-3: Evaluation Framework – Large Vehicles

Data Type	#	Asset Condition Evaluation Parameters	Weight	Ranking	Numerical Grade	Max Grade
R	1	Service Age	25%	A,B,C,D,E	5,4,3,2,1	125
R	2	Service Duty	5%	A,B,C,D,E	5, 3, 1	25
M	3	Mileage TUL	10%	A,B,C,D,E	5,4,3,2,1	50
M	4	Engine Hours	15%	A,B,C,D,E	5,4,3,2,1	75
M	5	Annual Maintenance Costs	15%	A,B,C,D,E	5,4,3,2,1	75
I	6	Chassis Condition	10%	A,B,C,D,E	5,4,3,2,1	50
I	7	Aerial Device Condition	10%	A,B,C,D,E	5,4,3,2,1	50
I	8	Body Condition	10%	A,B,C,D,E	5,4,3,2,1	50
		Total Max Score	100 %			500

In **Table 4-4**, each condition parameter is broken down into five levels of degradation and assigned a value. Each condition parameter is scored and multiplied by the weighting of that parameter. The total of all parameters is normalized and given a percentage health index score.

Table 4-4: Asset Condition Evaluation Criteria – Large Vehicles

Criteria	Weight		Criteria	Weight	
Service Age	25%	Scoring	Annual Maintenance Costs	15%	Scoring
Ranking	Corresponding condition	1.3	Ranking	Corresponding Condition	0.8
A	0 to 3 years	5	A	0 - \$10,000	5
B	3 to 7 years of service	4	B	\$10,001 - \$12,500	4
C	7 to 10 years of service	3	C	\$12,501 - \$15,000	3
D	10 to 14 years of service	2	D	\$15,001 - \$17,500	2
E	> 14 years	1	E	> \$17,501	1
Service Duty	5%	Scoring	Chassis Condition	10%	Scoring
Ranking	Corresponding Condition	0.3	Ranking	Corresponding Condition	0.5
A	Light	5	A	Very Good (New)	5
B			B	Good	4
C	Medium	3	C	Fair	3
D			D	Poor	2
E	Heavy	1	E	Very Poor	1
Mileage TUL	10%	Scoring	Aerial Device Condition	10%	Scoring
Ranking	Corresponding Condition	0.5	Ranking	Corresponding Condition	0.5
A	0 to 50,000 km	5	A	Very Good (New)	5
B	50,001 to 100,000 km	4	B	Good	4
C	100,001 to 150,000 km	3	C	Fair	3
D	150,001 to 200,000 km	2	D	Poor	2
E	> 200,000 km	1	E	Very Poor	1
Engine Hours	15%	Scoring	Body Condition	10%	Scoring
Ranking	Corresponding Condition	0.8	Ranking	Corresponding Condition	0.5
A	0 to 2,500	5	A	Very Good (New)	5
B	2,501 to 5,000	4	B	Good	4
C	5,001 to 7,500	3	C	Fair	3
D	7,501 to 10,000	2	D	Poor	2
E	> 10,000	1	E	Very Poor	1

Table 4-5 provides a summary of all large vehicle conditions assessments based on data up to December 31, 2019. The overall condition rating for WNH's fleet of Large vehicles is 73% or Good.

Table 4-5: Health Condition Index Results – Large Vehicles

Vehicle	#	Vehicle Type	Life Expect (TUL)	Current Age (2020)	% Age	Condition	% Health Index
R	61	Single Bucket Material Handler Aerial Device	14	14	100%	Poor	47%
R	12	Single Bucket Service	14	8	57%	Poor	49%
R	11	Single Bucket Material Handler Aerial Device	14	9	64%	Fair	55%
R	20	Radial Room Derrick	14	7	50%	Fair	61%
R	41	Single Bucket Service	14	7	50%	Fair	61%
R	2	Radial Boom Derrick	14	10	71%	Fair	65%
R	42	Single Bucket Material Handler Aerial Device	14	7	50%	Fair	66%
R	92	Double Bucket Double Elevator	14	11	79%	Fair	66%
R	40	Radial Boom Derrick	14	16	114%	Fair	66%
R	90	Single Bucket Squirt Boom Service	14	11	79%	Fair	69%
R	53	Single Elevator Double Bucket Material Handler Aerial Device	14	6	43%	Good	79%
R	55	Single Bucker Material Handler Aerial Device	14	6	43%	Good	79%
R	87	Single Bucket Material Handler Aerial Device	14	2	14%	Very Good	87%
R	60	Radial Boom Derrick	14	4	29%	Very Good	91%
R	70	Knuckle Crane	14	3	21%	Very Good	96%
R	95	Single Bucket Material Handler Aerial Device	14	2	14%	Very Good	96%
					Overall Rating	Good	71%

4.2. Asset Condition Assessment – Medium Vehicles

Medium vehicle condition assessments are based on the seven condition parameters listed in **Table 4-6**.

Table 4-6: Evaluation Framework – Medium Vehicles

Data Type	#	Asset Condition Evaluation Criteria	Weight	Ranking	Numerical Grade	Max Grade
R	1	Service Age	30	A,B,C,D,E	5,4,3,2,1	150
R	2	Service Duty	5	A,B,C,D,E	5, 3, 1	25
M	3	Mileage TUL	10	A,B,C,D,E	5,4,3,2,1	50
M	4	Engine Hours	15	A,B,C,D,E	5,4,3,2,1	75
M	5	Annual Maintenance Costs	20	A,B,C,D,E	5,4,3,2,1	100
I	6	Chassis Condition	10	A,B,C,D,E	5,4,3,2,1	50
I	7	Body Condition	10	A,B,C,D,E	5,4,3,2,1	50
		Total Max Score	100			500

The same process described in the previous section on large vehicles also applies to medium sized vehicles. In **Table 4-7**, each condition parameter is broken down into five levels of degradation and assigned a value. Each condition parameter is scored and multiplied by the weighting of that parameter. The total of all parameters is normalized and given a percentage health index score.

Table 4-7: Asset Condition Evaluation Criteria – Medium Vehicles

Criteria	Weight		Criteria	Weight	
Service Age	30%	Scoring	Annual Mtce Costs	20%	Scoring
Ranking	Corresponding condition	1.5	Ranking	Corresponding Condition	1.0
A	0 to 3 years	5	A	0 - \$2,999	5
B	3 to 7 years of service	4	B	\$3,000 - \$5,999	4
C	7 to 10 years of service	3	C	\$6,000 - \$8,999	3
D	10 to 14 years of service	2	D	\$9,000 - \$11,999	2
E	> 14 years	1	E	> \$12,000	1
Service Duty	5%	Scoring	Chassis Condition	10%	Scoring
Ranking	Corresponding Condition	0.3	Ranking	Corresponding Condition	0.5
A	Light	5	A	Very Good (New)	5
B	Light Medium	4	B	Good	4
C	Medium	3	C	Fair	3
D	Medium Heavy	2	D	Poor	2
E	Heavy	1	E	Very Poor	1
Mileage	10%	Scoring	Body Condition	10%	Scoring
Ranking	Corresponding Condition	0.5	Ranking	Corresponding Condition	0.5
A	0 to 50,000 km	5	A	Very Good (New)	5
B	50,001 to 100,000 km	4	B	Good	4
C	100,001 to 150,000 km	3	C	Fair	3
D	150,001 to 200,000 km	2	D	Poor	2
E	> 200,000 km	1	E	Very Poor	1
Engine Hours	15%	Scoring			
Ranking	Corresponding Condition	0.8			
A	0 to 2,500	5			
B	2,501 to 5,000	4			
C	5,001 to 7,500	3			
D	7,501 to 10,000	2			
E	> 10,000	1			

Table 4-8 provides a summary of all medium vehicle conditions assessments based on data up to Dec 31, 2019. The overall condition rating for WNH's fleet of Large vehicles is 69% or Fair.

Table 4-8: Health Condition Index Results – Medium Vehicles

Vehicle	#	Vehicle Type	Life Expect (TUL)	Current Age (2020)	% Age	Condition	% Health Index
R	99	Dump Truck	14	11	79%	Fair	58%
R	114	Work Body Underground	14	9	64%	Fair	59%
O	51	Work Body - Stations	14	15	107%	Fair	61%
R	43	Work Body - Underground	14	6	43%	Fair	69%
O	19	Work Body - Stations	14	8	57%	Good	76%
					Overall Rating	Fair	65%

4.3. Asset Condition Assessment – Small Vehicles

Small vehicle condition assessments are based on the seven parameters listed in **Table 4-9**.

Table 4-9: Evaluation Framework – Small Vehicles

Data Type	#	Asset Condition Evaluation Criteria	Weight	Ranking	Numerical Grade	Max Grade
R	1	Service Age	30	A,B,C,D,E	5,4,3,2,1	150
R	2	Service Duty	5	A,B,C,D,E	5, 3, 1	25
M	3	Mileage TUL	10	A,B,C,D,E	5,4,3,2,1	50
M	4	Engine Hours	15	A,B,C,D,E	5,4,3,2,1	75
M	5	Annual Maintenance Costs	20	A,B,C,D,E	5,4,3,2,1	100
I	6	Chassis Condition	10	A,B,C,D,E	5,4,3,2,1	50
I	7	Body Condition	10	A,B,C,D,E	5,4,3,2,1	50
		Total Max Score	100			500

The same process described in the previous sections on large and medium vehicles also applies to small vehicles. In **Table 4-10**, each condition parameter is broken down into five levels of degradation and assigned a value. Each condition parameter is scored and multiplied by the weighting factor of that parameter. The total of all parameters are normalized and given a percentage Health Index score.

Table 4-10: Asset Condition Evaluation Criteria – Small Vehicles

Criteria	Weight		Criteria	Weight	
Service Age	30%	Scoring	Annual Mtce Costs	20%	Scoring
Ranking	Corresponding condition	1.5	Ranking	Corresponding Condition	1.0
A	0 to 3 years	5	A	0 - \$999	5
B	3 to 6 years of service	4	B	\$1,000 - \$1,999	4
C	6 to 8 years of service	3	C	\$2,000 - \$2,999	3
D	8 to 10 years of service	2	D	\$3,000 - \$3,999	2
E	> 10 years	1	E	>\$4,000	1
Service Duty	5%	Scoring	Chassis Condition	10%	Scoring
Ranking	Corresponding Condition	0.3	Ranking	Corresponding Condition	0.5
A	Light	5	A	Very Good (New)	5
B	Light Medium	4	B	Good	4
C	Medium	3	C	Fair	3
D	Medium Heavy	2	D	Poor	2
E	Heavy	1	E	Very Poor	1
Mileage TUL	10%	Scoring	Body Condition	10%	Scoring
Ranking	Corresponding Condition	0.5	Ranking	Corresponding Condition	0.5
A	0 to 50,000 km	5	A	Very Good (New)	5
B	50,001 to 100,000 km	4	B	Good	4
C	100,001 to 150,000 km	3	C	Fair	3
D	150,001 to 200,000 km	2	D	Poor	2
E	> 200,000 km	1	E	Very Poor	1
Engine Hours	15%	Scoring			
Ranking	Corresponding Condition	0.8			
A	0 to 2,500	5			
B	2,501 to 5,000	4			
C	5,001 to 7,500	3			
D	7,501 to 10,000	2			
E	> 10,000	1			

Table 4-11 provides a summary of all small vehicle conditions assessments based on data up to Dec 31, 2019. The overall condition rating for WNH's fleet of small vehicles is 74% or Good.

Table 4-11a: Health Condition Index Results – Small Vehicles

Vehicle	#	Vehicle Type	Life Expect (TUL)	Current Age (2020)	% Age	Condition	% Health Index
R	115	4x4 Full Size Crew Cab Pick Up	10	9	90%	Poor	37%
R	128	4x4 Full Size Crew Cab Pick Up	10	8	80%	Poor	43%
R	127	4x4 Full Size Crew Cab Pick Up	10	8	80%	Poor	43%
R	116	4x4 Full Size Crew Cab Pick Up	10	9	90%	Poor	45%
R	133	Mini Van Cargo	10	8	80%	Poor	47%
G	111	Full Size Cargo Van	10	10	100%	Poor	48%
R	190	SUV Passenger	10	11	110%	Poor	49%
O	172	Full Size Cargo Van	10	13	130%	Fair	53%
R	131	4x4 Full Size Crew Cab Pick Up	10	8	80%	Fair	54%
Y	124	Full Size Cargo Van	10	8	80%	Fair	56%
R	132	4x4 Full Size Crew Cab Pick Up	10	8	80%	Fair	56%
Y	125	Full Size Cargo Van	10	8	80%	Fair	60%
G	110	Mini Van Cargo	10	10	100%	Fair	63%
G	100	Mini Van Cargo	10	10	100%	Fair	63%
G	135	Mini Van Cargo	10	8	80%	Fair	64%
O	118	Full Size Cargo Van	10	9	90%	Fair	67%
R	112	Small SUV	10	10	100%	Fair	68%

Table 4-11b: Health Condition Index Results – Small Vehicles (continued)

Vehicle	#	Vehicle TYPE	Life Expect (TUL)	Current Age (2020)	% Age	Condition	% Health Index
G	165	Mini Van Passenger + Shelving	10	4	40%	Good	70%
B	136	Hybrid Electric Hybrid Car	10	8	80%	Good	73%
Y	171	Full Size Cargo Van (Tall)	10	3	30%	Good	73%
P	117	Mini Van Passenger	10	10	100%	Good	74%
G	144	Full Size Cargo Van	10	7	70%	Good	75%
G	123	Mini Van Passenger	10	8	80%	Good	76%
G	134	Mini Van Cargo	10	8	80%	Good	77%
R	130	4x4 Small Pick Up	10	8	80%	Good	78%
B	199	SUV Passenger	10	1	10%	Very Good	88%
G	173	Mini Van Passenger + Shelving	10	3	30%	Very Good	94%
R	194	4x4 Small Pick Up	10	1	10%	Very Good	96%
R	197	4x4 Full Size Pick Up	10	1	10%	Very Good	96%
O	192	Full Size Cargo Van	10	2	20%	Very Good	99%
R	193	4x4 Full Size Crew Cab Pick Up	10	1	10%	Very Good	100%
R	196	4x4 Small Pick Up	10	1	10%	Very Good	100%
					Overall Rating	Fair	68%

4.4. Asset Condition Assessment – Rolling Stock

Rolling stock is a catchall category for the remainder of WNH's Fleet assets. These units tend to be unique custom ordered, custom made and have varying TULs. WNH's condition assessments are based on four condition parameters listed in **Table 4-12**.

Table 4-12: Evaluation Framework – Rolling Stock

Data Type	#	Asset Condition Evaluation Criteria	Weight	Ranking	Numerical Grade	Max Grade
R	1	Service Age	35	A,B,C,D,E	5,4,3,2,1	175
R	2	Service Duty	10	A,B,C,D,E	5, 3, 1	50
M	3	Annual Maintenance Costs	20	A,B,C,D,E	5,4,3,2,1	100
I	4	Chassis Condition	35	A,B,C,D,E	5,4,3,2,1	175
		Total Max Score	100			500

Table 4-13: Asset Condition Evaluation Criteria – Rolling Stock

Criteria	Weight		Criteria	Weight	
Service Age	35%	Scoring	Annual Mtce Costs	20%	Scoring
Ranking	Corresponding condition	1.8	Ranking	Corresponding Condition	1.0
A	0 to 5 years	5	A	0 - \$500	5
B	5 to 10 years of service	4	B	\$500 - \$1,000	4
C	10 to 15 years of service	3	C	\$1,000 - \$2,000	3
D	15 to 20 years of service	2	D	\$2,000 - \$3,000	2
E	> 20 years	1	E	> \$3,000	1
Service Duty	10%	Scoring	Chassis Condition	35%	Scoring
Ranking	Corresponding Condition	0.5	Ranking	Corresponding Condition	1.8
A	Light	5	A	Very Good (New)	5
B	Light Medium	4	B	Good	4
C	Medium	3	C	Fair	3
D	Medium Heavy	2	D	Poor	2
E	Heavy	1	E	Very Poor	1

Table 4-14: Health Condition Index Results – Rolling Stock

Vehicle	#	Vehicle CODE(1)	Vehicle TYPE	Life Expect (TUL)	Current Age (2020)	% Age	Condition	% Health Index
T	533	Material	Material trailer, 2 axle, open cage	40	31	78%	Fair	51%
T	541	Material	Material trailer, 3 axle, open, overhead	30	19	63%	Fair	53%
T	550	Pole	Pole trailer ,2 Axle, extendable, Service	30	8	27%	Fair	57%
T	538	Lawn	Landscaping trailer, 2 axle	30	32	107%	Fair	57%
T	542	Material	Material trailer, 3 axle, open, overhead	30	19	63%	Fair	59%
T	521	Pole	Large pole trailer. Axle front and Rear	40	35	88%	Fair	59%
T	547	Reel	Reel trailer, small, 2 axle, triple	30	9	30%	Fair	61%
T	548	Reel	Reel trailer, small,2 axle, triple	30	9	30%	Fair	61%
T	546	Material	Material trailer, 3 axle, open, overhead	30	10	33%	Fair	65%
T	543	Material	Stringing trailer, 2 axle, enclosed	40	12	30%	Fair	66%
ME	502	Tensioner	Diesel Tensioner	30	30	100%	Fair	67%
T	544	Material	Trailer, small service for Mud Tracks	40	12	30%	Fair	67%
T	540	Stringing	Stringing trailer, 2 axle, enclosed	40	21	53%	Fair	68%
ME	501	Puller	Diesel Puller	30	30	100%	Fair	69%
ME	505	Pull/Tens	Electric Stringer	16	7	44%	Good	70%
T	551	Trans	Mobile TX Trailer Carto Trans	40	5	13%	Good	70%
ME	504	Pull/Tens	Electric Stringer	16	7	44%	Good	72%
T	545	Material	Reel trailer, large 2 axle	30	11	37%	Good	73%
T	552	Pole	Pole trailer, small 1 axle	30	5	17%	Very Good	91%
T	553	Reel	Reel trailer, large 1 axle	30	1	3%	Very Good	91%
						Overall Rating	Fair	66%

5. CAPITAL INVESTMENT PLAN 2021 to 2025

Table 5-1 summarizes WNH's historical capital expenditures and forecast fleet capital expenditure plan. This program captures the purchase of new and replacement vehicles and equipment, as well as expenditures for major refurbishments that extend the useful service life of vehicles and equipment.

Table 5-1: Historical & Forecast Fleet Capital Expenditures

OEB Investment Category	Historical Period				Bridge Year	Average Annual Investment
	2016	2017	2018	2019	2020	2016-2020
Fleet CAPEX	\$406,938	\$604,043	\$523,423	\$331,589	\$666,740	\$506,547
OEB Investment Category	Test Year	Forecast Period				Average Annual Investment
	2021	2022	2023	2024	2025	2021-2025
Fleet CAPEX	\$735,187	\$856,500	\$937,000	\$670,000	\$832,320	\$806,201

From WNH's Fleet Asset Condition Assessments, a vehicle replacement program is developed based on the combination of health, criticality, performance and delivery lead time for asset replacement. Final adjustments to the plan are made to pace fleet capital investments in coordination with WNH's overall capital investment plan. This means that fleet investments at times will be lumpy in order to smooth out overall capital spending. **Table 5-2** lists the units recommended for replacement over the forecast period.

Vehicle B136 stands out in **Table 5-2** due to its current assessment of being in good condition. B136 is an electric vehicle whose battery system is expected to be at EOL in 2023. Although the vehicle is mechanically in good condition, WNH expects replacement of the battery system in an 11-year-old vehicle will not be cost effective.

Table 5-2: Forecast Fleet Replacements

Vehicle	Vehicle Category	Current Condition	% Health Index	Replacement Year (Plan)	Age in Replacement Year
R61	Large	Poor	47%	2021	15
R127	Small	Poor	43%	2021	9
Y124	Small	Fair	56%	2021	9
G100	Small	Fair	63%	2021	11
R12	Large	Poor	49%	2022	10
R99	Medium	Fair	58%	2022	13
R116	Small	Poor	45%	2022	11
Y125	Small	Fair	60%	2022	10
T543	Rolling Stock	Fair	66%	2023	15
R90	Large	Fair	69%	2023	14
R114	Medium	Fair	59%	2023	12
G135	Small	Fair	64%	2023	11
B136	Small	Good	73%	2023	11
R92	Large	Fair	66%	2024	15
R133	Small	Poor	47%	2024	12
R41	Large	Fair	61%	2025	12
R112	Small	Fair	68%	2025	15
R132	Small	Fair	56%	2025	13

In addition, WNH has forecast a reduction in fleet size over the forecast period. **Table 5-3** lists the fleet vehicles that are expected to be at end-of-life over the forecast period and will not be replaced. This is due to a combination of factors including more effective pooling of small vehicles, reducing the number of line crews by one, and eliminating under utilized rolling stock assets.

Table 5-3: Fleet Asset Reduction

Vehicle	#	Vehicle CODE(2)	Vehicle TYPE	Life Expect (TUL)	Current Age (2020)	Current Condition	% Health Index	Out of Service	Replacement Year (Plan)	Age in Replacement Year
R	40	Large	Radial Boom Derrick	14	16	Fair	66%	2021	DNR	17
G	110	Small	Mini Van Cargo	10	10	Fair	63%	2022	DNR	12
O	172	Small	Full Size Cargo Van	10	13	Fair	53%	2022	DNR	15
R	190	Small	SUV Passenger	10	11	Poor	49%	2022	DNR	13
R	131	Small	4x4 Full Size Crew Pick Up	10	8	Fair	54%	2023	DNR	11
ME	541	Rolling Stock	Material Trailer, 3 axle, open overhead	30	19	Fair	53%	2025	DNR	24
ME	501	Rolling Stock	Diesel Puller	30	30	Fair	69%	2030	DNR	40
ME	502	Rolling Stock	Diesel Tensioner	30	30	Fair	67%	2030	DNR	40

DNR – Do not replace

Appendix N:

WNH Information Technology Management Plan



WATERLOO NORTH HYDRO

IT Management Plan

June 21, 2020

CONTENTS

1. Purpose	3
2. Guiding Principles.....	3
2.1. Self Service	3
2.2. Digital Literacy	4
2.3. Technical Talent Management	4
2.4. Open Standards and Collaboration.....	4
3. Long Term Technology Goals	5
4. Service Delivery and KPIs	5
5. Asset Life Cycle and Resource Requirements	5
5.1. Capital Costs and Asset Life-Cycle Planning.....	5
5.1.1. Inspections and Maintenance.....	5
5.1.2. IT Hardware Asset Life-Cycle.....	7
5.1.3. Major Software Assets	8
5.2. Business Driven Capital Projects.....	10
5.3. Move from CapEx to OpEx and Cloud.....	11

1. Purpose

Waterloo North Hydro's (WNH) Information Technology Services (ITS) include the planning, design, development, application, implementation, support, and management of computer-based information systems in support of WNH's Mission, Vision and Strategic Imperatives.

ITS initiatives service both internal and external WNH customers. These services are provided under the direction of the Vice President of Information and Technology Services.

The purpose of this report is to provide a consolidated view of WNH's information technology management strategy, objectives, assets under management, asset assessments and investment plans for the years 2021 to 2025 inclusive. The information contained in this report forms the basis on which ITS capital investment plans have been formulated.

The information in this report also informs WNH's senior executive team (Executive) and aides in the development of WNH's Distribution System Plan (DSP) and supports WNH's 2021 Cost of Service Application (Application).

All information contained in this report is current as of December 31, 2019.

2. Guiding Principles

WNH is committed to continuous improvement regarding digital technology services and serving customers preferences where possible.

The following is a list of general concepts WNH uses to guide decisions around digital tools and information technology.

2.1. Self Service

WNH believes that end users need smart, efficient and effective self-directed tools in order to accomplish their tasks and extract information from WNH's varied and extensive informational databases. Technology should not require specialized technical knowledge to operate.

The following is a summary of our guiding principles for self-service from WNHs digital strategy.

1. Standard System Architecture (consistent and predictable).

2. Data access and control (subject matter experts should have full control of their data).
3. Data accuracy and integrity (define and value “the system or record”).
4. Reproducible standards and systems.

2.2. Digital Literacy

As digital tools and platforms become integrated into all areas of work, WNH recognizes the potential knowledge gap created in the workforce caused by their adoption. WNH utilizes the following strategies to mitigate the potential knowledge gap:

1. Integrate training with day to day work.
2. Invest in digital safety awareness.
3. Process and design thinking.
4. Expand competence and confidence in technology use.

2.3. Technical Talent Management

The following strategies summarize WNH’s plan to build and maintain a strong information technical team.

1. Maintain a high level of employee engagement.
2. Promote continuous learning.
3. Make room for innovation when possible.

2.4. Open Standards and Collaboration

Open technologies, such as open source software and non-proprietary architecture, foster collaboration through shared practices and enable standard ways of doing work. WNH has demonstrated a preference towards systems of this nature whenever possible in the following ways:

1. Prefer open system and software architecture.
2. Participate in the development, testing and establishment of open systems.
3. Prefer collaboration with other utilities, municipalities and vendors rather than independent development.

3. Long Term Technology Goals

WNH's long term technology goals are:

1. Full self-service customer experience (able to conduct all business online)
2. The move to adopt agile methods for project management, system architecture and continuous improvement.
3. Increase transparency and visibility of all work (increased use of measures, KPIs, real-time displays of work status).

4. Service Delivery and KPIs

The core functions of WNH's technology group which are measured through KPIs:

1. Help Desk for Break/Fix issues
2. Change Management for Projects, features and unplanned work
3. Security operations
4. System operations
5. Project delivery
6. Unplanned work

5. Asset Life Cycle and Resource Requirements

Proper management of staff levels, contract resources and asset life-cycling is the foundation of maintaining strong technical resources. This section will discuss the methodology used to manage cost and asset health.

5.1. Capital Costs and Asset Life-Cycle Planning

WNH maintains technical capital assets such as servers, communications equipment, end user devices and software assets such as core business systems.

5.1.1. Inspections and Maintenance

WNH's methodology and inspection schedule for life-cycling all technology assets are as follows.

Hardware assets are replacement factors

1. Mean time to failure (MTTF) as published by the manufacturer.
2. Health events on specific devices through monitoring.
3. Professional judgment of IT staff.

Software assets replacement or update factors

1. Support availability
2. Cost to maintain vs update
3. Obsolescence
4. Market requirements

All assets follow a common life-cycle;

1. Plan: Map out requirements, business process and future state
2. Acquire and Build: Procure, assemble and conduct make ready work for cutover
3. Operate: Shift new asset into operation and integrate with daily workflow
4. Maintain: Perform maintenance during useful life of asset
5. Retire: Decommission gracefully with responsible processes for data and environmental concerns

Table 5-1: Inspections - Information Technology

Technology or Supporting System	Frequency of Inspection
Network and communications health	Automated Hourly
Storage and Compute systems health	Automated Hourly
Physical inspection of servers and server room	As Needed
HVAC and backup HVAC systems	Quarterly
Generator capacity and function	Quarterly
UPS battery life and function	Automated hourly and quarterly full test
Core business software application performance	Real-time monitoring
Software updates and patches	Automated Hourly
Network traffic and security events	Real-time monitoring

Table 5-2: Maintenance - Information Technology

Technology or Supporting System	Frequency of Maintenance
Audio/Visual Equipment	Quarterly
End user device patching	Between 30 - 45 days
Server OS patching	Between 30 -45 days
Virtual host software version upgrades	Quarterly to Semi-Annually
Server hardware	As needed or part of regular life-cycle
End user device hardware	As needed or part of regular life-cycle

5.1.2. IT Hardware Asset Life-Cycle

A list of hardware assets and WNH's current asset life-cycle plan for each is provided in **Table 5-3**. Replacement practice is based on age, failure and professional judgement. During this plan WNH will be introducing real-time health tracking for all hardware assets to improve this process.

Table 5-3: Information Technology Hardware Assets

Hardware	Description	Quantity	Life Cycle (years)
Physical Servers	Compute infrastructure to run virtual or native applications	25	3 – 5
Firewalls	Network security devices that is first and last point of defense for traffic coming into or out of our facilities	4	3 – 5
Storage Systems	Primary storage for virtual machines, files and other business critical records	5	5 – 7
Network Switches and Routers	Backbone for all network traffic including computer, phone and services	21	7 – 10
Wireless access points	Devices to extend network switch communication to wireless	18	3 – 5
Laptops and Desktops	Primary tool for administrative and mobile work forces	190	3 – 5
Mobile connected devices	Smart phones and other devices connected over cellular (LTE, 5G, etc)	64	2 – 3
Network Printers	Multi-function and standard printer devices	23	3 – 5
Plotters	Large form factor printers	2	5 – 7
AV Equipment	Projectors, smart boards, large presentation screens	11	5 – 7

WNH IT hardware assets are acquired or built using parts sourced using a competitive bidding process. Projects replacing IT hardware assets typically take 2-3 months from the acquisition of new assets to the retirement of the outgoing assets.

When IT hardware is retired, all useful parts are kept as well as all sensitive data is completely destroyed.

5.1.3. Major Software Assets

There are three primary options when it comes to major software products;

1. **Self-managed:** Typically, self-hosted, managed, updated and are capital intensive as they are “owned”. When managed correctly they can be the most efficient and flexible systems. However, if managed poorly they will cause operational issues and reach obsolesce far too soon. WNH prefers this option for internal facing business systems such as a CIS.
2. **Cloud-hosted:** Software as a Service (SaaS) is managed by a 3rd party and 100% operating expense. When managed correctly this option provides very quick go-live software but sacrifices flexibility. If managed poorly this option will create issues with data presentation data, security and cost. WNH prefers this option for external facing systems such as a corporate website.
3. **Hybrid-hosted:** Software that is a combination of both options 1 & 2 above. When managed properly this option can provide all the benefits of both self and cloud hosted. When managed poorly this option typically has poor accountability for results and is the costliest.

WNH considers all options as part of its strategy mix.

Many business functions at WNH depend on software applications. These applications are maintained as long as they continue to be cost effective, are properly supported by their vendor and meet current WNH requirements.

Table 5-4 provides a summary of WNHs major systems by ownership and hosting category.

Table 5-4: Information Technology Software Applications

System	Host Model	Original in Service Date	Last Major Upgrade	Future Direction
Customer Information Systems (CIS)	Hybrid	2017	2017	a) Major Improvements 2020 b) Routines upgrades 2021 – 2024
Enterprise Resource Planning (ERP) including AP/AR, GL, Payroll and Assets	Self	2005	2005	a) Payroll function removed by 2021 b) Replacement for other functions planned for 2022 – 2024 c) New system in production by 2025
Operational Data Store (ODS) to store MDM/R meter data	Self	2009	2015	a) Functions to be moved to CIS during 2020 upgrade b) To be retired by end of 2021
Outage Management System (OMS)	Hybrid	2015	2015	Routine upgrades 2021 – 2024 with major upgrade to be considered and planned
Supervisory control and data acquisition (SCADA)	Self	2011	2014	Routine upgrades 2021 – 2024
Regional Network Interface (RNI)	Hybrid	2009	2014	Major upgrade during 2020 followed by routine upgrades 2021 – 2024
Geographic Information System (GIS)	Self	2005	2013	Major upgrade planned for implementation during 2023
Asset Management Software	Cloud	2019	2019	Routine upgrades 2021 – 2024
Corporate Email	Cloud	2020	2020	Routine upgrades 2021 - 2024
Corporate Website	Cloud	2018	2018	Rebuild planned for 2021
Web presentment for TOU customers	Self	2011	2018	Routine upgrades 2021 - 2024
HR Software	Cloud	2015	2016	To be replaced by 2021
Phone System	Self	2019	2019	Routine upgrades 2021 - 2024
Document management	Self	2009	2015	Major upgrade during 2020

While replacement rationale for software across all hosting models is the same, the logistics of the work differ substantially.

1. Self-hosted replacement and upgrade projects are typically long, capital intensive and infrequent
2. Cloud-hosted replacements and upgrades primarily involve process change often with little or no technical effort beyond integration and security. Upgrades can be as often as daily with no input or consent from WNH.
3. WNH has concluded that hybrid solutions are complicated, taking 2-3 times the effort often requiring more technical effort than self-hosting and more process change than cloud. For this reason, WNH is gradually moving away from hybrid except in special circumstances.

5.2. Business Driven Capital Projects

During recent consultations, WNH customers indicated a preference to complete more of their business transactions through digital methods. Examples of customer preferences for ITS initiatives are listed below:

1. An automated outage notification system (automatically sends messages).
2. Reporting issues or making inquiries through an interactive website.
3. Automated alerts when electricity usage exceeds a prearranged threshold.
4. Having an online chat feature on the WNH website during business hours.

Table 5-4 listed in **Section 5.1.3** outlines WNH's core software business applications. One application in particular, our Enterprise Resource Planning platform (ERP), is in need of replacement due to obsolescence.

WNH's current legacy product is 15 years old and dependent on mainframe technology making it difficult to maintain. In addition, certain modules are beginning to fall behind market requirements. The current ERP system looks after payroll, accounting, work and inventory management as well as procurement. This system has been planned for replacement in the 2022 – 2023 timeframe.

5.3. Move from CapEx to OpEx and Cloud

WNH is monitoring the growing trend from the ownership and self-hosted model to a Software as a Service cloud model (SaaS). Examples of this include platforms such as Adobe creative cloud, Microsoft Office 365 and Compliance science.

FACILITIES BUILDING SYSTEMS PLAN

TABLE OF CONTENTS

BACKGROUND	2
BUILDING SYSTEMS OPERATING, AND MAINTENANCE EXPENSES.....	4
BUILDING SYSTEMS CAPITAL EXPENSES	5
2021	5
2022	5
2023	5
2024	6
2025	6

BACKGROUND

1. Waterloo North Hydro Inc. (WNH) performs all of its distribution and administration functions from a central facility located at 526 Country Squire Road, Waterloo, Ontario. The service centre and head office occupies 105,000 square feet on 35 acres of land on two levels with 18 parking spaces for visitors and 130 employee parking spaces. This facility also includes a warehouse for inventory, a garage for vehicle and equipment storage/repair, trades workshops, control room, administrative offices, and training space. The building was built and occupied in 2011
2. The WNH Facilities department is responsible for operations and maintenance for the WNH head office, three Transformer Stations, five Municipal Stations and nine rural Distribution Stations
3. The most crucial aspect of facilities management is building maintenance. Keeping the buildings operating with minimum unplanned downtime is the goal of every building maintenance programme. WNH's objectives for building maintenance are:
 - To ensure that the buildings and its associated services are in a safe condition
 - To ensure that the buildings are fit for its intended use
 - To ensure that the condition of the building meets all statutory requirements
 - To carry out the work necessary to maintain the value of the physical asset and the quality of the building

However, to achieve these objectives, it is imperative that we maintain the building assets in such a way that problems are identified and resolved before they affect operations. An effective building maintenance programme is clearly defined by the maintenance strategies it employs. In general, building maintenance strategies fall into three categories: reactive, preventive and condition-based. Reactive maintenance, also referred to as “run-to-failure” strategy, focuses on asset repairs only once a failure occurs. This strategy is not effective and results in emergencies, down time and increased cost in the long term. Instead, WNH uses preventative maintenance and condition-based strategies in relation to the building systems to ensure efficient operation and to extend the life of current assets.

Preventive maintenance overcomes the ineffectiveness of a “run-to-failure” strategy by reducing the probability of failures and avoiding down time. Preventive maintenance tasks are performed in accordance with a predetermined plan at regular, fixed intervals such as heating and cooling equipment servicing. In addition, maintenance work can be planned ahead and performed when it is convenient to the building users.

Condition-based maintenance strategy recognizes that a change in condition and/or performance of an item is the principal reason for carrying out maintenance. Therefore, the optimal time to perform maintenance is ascertained from a condition assessment inspection or survey used to determine the actual state of each component item in a building. In this strategy, maintenance tasks are determined and planned by efficiently monitoring the building's principal elements such as parking lots, walls, floors, roof, lighting, and mechanical equipment to identify which element or piece of equipment requires maintenance before a major failure occurs. Condition assessments can vary from simple visual inspections to more advanced inspections using a variety of condition monitoring tools and techniques.

4. The following are the key benefits of this strategy:

- Extending the functional life of an asset by reducing the need for replacements or repairs.
- Optimizing the asset's efficiency and reducing energy costs.
- Minimizing equipment downtime thereby lessening the frequency of large-scale repairs.
- Reducing disruption to operating schedules and production, as the planned work is carried out during downtime or slower periods of the year.
- Improving budget control as the planning, sourcing, and purchasing of materials and services are done in advance.
- Ensuring compliance with health and safety regulations.
- Improving customer service and increases satisfaction via timely, continuous, and efficient operations.

5. The Building System Categories referenced in this document are:

- a. Building Exterior – includes parking lot, storage yard, security systems, fuel pumps, landscape, roof system, storm water management, lighting, and building shell.
- b. Building Interior – includes heating, ventilation, air conditioning, plumbing flooring, paint, furniture, lighting, elevator, audio/visual, building automation system, telephones, information systems.
- c. Building Operations – includes utilities, waste management, janitorial services, and snow removal.

BUILDING SYSTEMS OPERATING, AND MAINTENANCE EXPENSES

The following table shows a schedule of anticipated annual operating expenses for 2021:

#	Building System	Maintenance Component	2021 Budget (\$000s)
1	Exterior	Roof	10
		Septic system	5
		Asphalt	20
		Lighting	5
		Fuel pump	5
		Landscape	25
		Security	15
		Storm water	15
		<i>Subtotal</i>	<i>100</i>
2	Interior	Paint	2
		Furniture	4
		Flooring	2
		A/V + Communications	95
		Building Automation	8
		HVAC	12
		Plumbing	8
		Elevator	10
		<i>Subtotal</i>	<i>141</i>
3	Operations	Waste management	55
		Janitorial	80
		Snow removal	62
		Utilities	140
		Insurance	35
		<i>Subtotal</i>	<i>372</i>
4	All	Total	\$613

BUILDING SYSTEMS CAPITAL EXPENSES

The following tables show the projected capital expenditures for 2021 through to 2025:

2021

#	Building System	Capital Component	CAPEX (\$000s)
1	Exterior	Fuel pump	10
		EV charger	15
		Security	10
		<i>Subtotal</i>	35
2	Interior	A/V + Communications	25
		HVAC	15
		<i>Subtotal</i>	40
3	All	Total	\$75

2022

#	Building System	Capital Component	Expense (\$000s)
1	Exterior	Security	10
		<i>Subtotal</i>	10
2	Interior	Carpet	5
		<i>Subtotal</i>	5
3	All	Total	\$15

2023

#	Building System	Capital Component	Expense (\$000s)
1	Exterior	Sewer	100
		Security	20
		<i>Subtotal</i>	120
2	Interior	HVAC	25
		<i>Subtotal</i>	25
3	All	Total	\$145

2024

#	Building System	Capital Component	Expense (\$000s)
1	Exterior	Security	10
		<i>Subtotal</i>	<i>10</i>
2	Interior	HVAC	10
		<i>Subtotal</i>	<i>10</i>
3	All	Total	\$20

2025

#	Building System	Capital Component	Expense (\$000s)
1	Exterior	Security	25
		<i>Subtotal</i>	<i>25</i>
2	Interior	Carpet	50
		HVAC	25
		Plumbing	25
		<i>Subtotal</i>	<i>100</i>
3	All	Total	\$125



Operations Distribution System Annual Maintenance Report (2019)




CONTENTS

1. Introduction	3
2. Overhead Systems.....	4
2.1. Load Break Switch Maintenance	5
2.2. Pole Testing	5
2.3. Insulator Washing	6
3. Underground Systems.....	6
4. Forestry	7
5. Appendices	8
5.1. Annual Maintenance Program Project Plan	8
5.2. Urgent Repair Report	9
5.3. Service Crew Service Call Sheet – Repair Required	10
5.4. Streetlight Repair Sheet	11
5.5. Feeder Patrol Requirements	12

1. Introduction

For the year 2019, WNH's OEB 3-year visual patrol for urban areas consisted of the Waterloo South West area, and the 6-year visual patrol for rural area consisted of the Wellesley East and Woolwich West area. WNH completed 100% of OEB inspections for these areas using qualified WNH staff.

In addition to the required OEB visual patrols, 8 patrols were completed on poor performing feeders identified by the WNH Control Room. This resulted in preventative maintenance being performed on overhead plant to aid in the reduction of unplanned outage minutes. In addition, 40 feeder patrols were completed prior to energization when an interruption occurred with an unidentified cause.



Included in this report is a summary spreadsheet indicating the types of required tasks with a date range and the group responsible for the inspections. The reports from GIS (Geographic

Information System) indicates actual sites and documentation of deficiencies identified during our inspections. During inspection, all third party attachments and their power supplies are logged as well. This information is archived in our GIS software.

2. Overhead Systems



The visual overhead patrol consisted of the inspection of poles and hardware, transformers, switches, capacitors, regulators, conductors, major road crossings and vegetation. The majority of overhead inspections were completed by qualified WNH staff and contracted Powerline Maintainers. Infrared thermographic inspections were conducted by a contractor on all 3 phase overhead lines in the required inspection areas. There were 20 overhead equipment related issues identified.

Repairs are ongoing and documented in the 2019 Electrical Infrared Thermographic Inspection Report dated January 28 to February 14, 2019.

As part of our OEB inspections, a total of 6,256 poles were inspected with 101 poles and 205 issues requiring follow up; 100 issues were identified in the urban area and 105 in the rural area. The issues identified include poles in very poor condition needing replacement, cross arms in poor condition, grounding and guying issues, vegetation encroachment, animal related damage, hardware replacement, repairs to conductors, and transformers needing attention or replacement.

Inspections of expressway, railway and river crossings, are completed annually and no major deficiencies were found in 2019.

Inspections of overhead plant located in or adjacent to parks, playgrounds and schoolyards are also completed annually and some minor issues were identified and corrective action was taken.

A total of 41 capacitor banks were inspected in 2019 and no deficiencies were identified.

A total of 10 polemount transformers were replaced due failure, damage or poor condition found during inspections.

As part of WNH's overall overhead inspection program, staff ensure proper nomenclature is in place for all major equipment including switches, transformers, capacitors etc. is documented and updated in our GIS system as required. Documented repairs and replacement of identified deficiencies are completed. Necessary repairs are recorded on our Urgent Repair Required Form via Tablet (Attachment 1) and assigned to a crew for repairs.

2.1. Load Break Switch Maintenance

A total of 120 load break switches in the required inspection area were inspected and as a result 5 manually operated load break switches were identified to be replaced under WNH's proactive capital replacement program and 10 required maintenance. The factors determining maintenance versus replacement includes the conditions of switch and pole, damage identified to components of the switch (porcelain insulators, rusted operating devices) and age of switch. All 5 manually operated load break switches were replaced with new SCADA controlled vacuum switches/reclosers (EVRs).

2.2. Pole Testing

In 2019, 4,161 poles were tested for remaining wood fiber strength by G-Tel Engineering, including all poles purchased from Hydro One as a result of the elimination of long term load transfers. The results of the pole testing are used to inform WNH's Asset Condition Assessments. More information on the results can be found in WNH's Distribution System Plan, Appendix A - WNH Asset Condition Assessment (ACA) Report.

2.3. Insulator Washing

Insulator washing is normally completed as part of WNH's annual maintenance program. This is specialized work and in 2019, WNH ran into scheduling difficulties with its contractor. The work was rescheduled for completion in early 2020.

3. Underground Systems

The visual inspection of the underground systems serves to identify obvious structural problems, hazards and is also used in verifying and updating nomenclature. Typical deficiencies identified may include rusting pad-mounted equipment and requirements for painting, faulty locking mechanisms, identification of hot spots using infra-red cameras and mislabeling of nomenclature.

In 2019, 731 transformers and 98 switching cubicles were inspected with 31 issues identified. All annual transformer vault room inspections were completed in conjunction with infrared thermography. Transformer vault room inspections also included inspection of school facility vault rooms and identified issues such as door maintenance/replacement and nomenclature requirements. Documented repairs and replacement of found deficiencies have been completed. In addition, 1 switching cubicle was replaced under proactive capital replacements.

Transformers and switch cubicles were identified during inspections with rust issues or graffiti. In 2019, 99 units were field sandblasted and repainted as part of the annual paint program. In total, 22 padmount transformers were replaced due failure, damage or poor condition found during inspections.




4. Forestry

In 2019, Waterloo East area and Elmira, and Wellesley and Woolwich South portion of WNH's service area was scheduled for tree trimming. The trimming cycle started in the fall of 2019 and will be completed late spring 2020 with 100% of this work being completed by contractors.

Inspections for intrusive vegetation growth around padmount transformers and underground plant were completed and documented. Customers were notified of any required follow up and given the option to remove the vegetation obstructing the transformers themselves, or having a WNH contractor remove any obstructions.


Remedial work to address the documented forestry deficiencies is ongoing. Necessary tree trimming and line clearing locations are recorded on our Urgent Repair Required Form on a tablet and assigned to a contract forestry crew.





5.1. Annual Maintenance Program Project Plan

[illegible]


5.2. Urgent Repair Report





 Service Crew Service Call Sheet	
Date: <u>JUNE 28 / 2019</u>	Work Request Number: <u>11977-1</u>
Customer Name: _____	
Address: <u>3 NORMAN AVE @ WEIGEL AVE.</u>	
City / Township: <u>WOOLWICH</u>	
Work To Be Done: <u>- RETURN 35' POLE TO SHOP</u>	
<u>- PICK-UP OLD CUT-OFF POLE AND DISCARD.</u>	
 <p style="font-size: 2em; transform: rotate(-15deg); position: absolute; right: 50px; bottom: 50px;">Complete July 11 / 2019</p>	
Completed By / Site Left in Safe Condition: _____ Date: <u>JULY 11 / 2019</u>	
Comments (if any): _____	

5.4. Streetlight Repair Sheet



Streetlight Repair Call Sheet

Date: Dec 6 /2019 Stores Material Work Request Number: 2809-1

LED: 35 W

Customer Name : _____ Phone: _____

Address: --- 2 or 4 CENTRO ST.

City/Township: WOLWICH (ELMIRA)

Issue with Lights: NOT WORKING

Customer Comments:

Site Visit Comments/Description of Work Required:

✓ checked S/L - it's working

Completed By / Site Left in Safe Condition: [REDACTED] AND [REDACTED]

Date: Dec. 10/19 TRUCK # R95 Labour & Trucking Work Request # 12760-1

Turn page over to select material and quantity used

If material used is not provided on the list at the back of this page, please indicate the quantity, material, and part number on this form.

5.5. Feeder Patrol Requirements

FEEDER PATROL REQUIREMENTS		
Feeder <u>HS14, HS22, HS24</u>	Maps Provided <input checked="" type="radio"/> Yes <input type="radio"/> No	Date <u>June 1st 2019</u>
Time <u>06:12</u>	Patrolled By <u>[Redacted]</u>	
Requested By <u>[Redacted]</u>	<u>[Redacted]</u>	
Weather Conditions <u>[Redacted]</u>		
Was the total feeder patrolled <input checked="" type="radio"/> Yes <input type="radio"/> No	If no, what section <u>Downstream of BYRS Lincoln & University</u>	
Have You Highlighted Areas Where the Patrol is Complete <input checked="" type="radio"/> Yes <input type="radio"/> No	<u>LB 4901</u>	
OBSERVATIONS AND EQUIPMENT PATROL		
	check ALL	Comments
Insulators intact	<input checked="" type="checkbox"/>	<u>insulators damage red phase</u>
Lightning arrestors blown	<input type="checkbox"/>	
animal carcasses	<input checked="" type="checkbox"/>	<u>Squirrel</u>
Flash marks	<input checked="" type="checkbox"/>	
Switches/loadbreaks intact	<input checked="" type="checkbox"/>	<u>damaged blades/snuffers red/blue phase</u>
Lines galloping/wind conditions	<input type="checkbox"/>	
Conductor supports	<input type="checkbox"/>	
Broken conductors (primary)	<input type="checkbox"/>	
Pole condition	<input type="checkbox"/>	
Trees on or close to lines	<input type="checkbox"/>	
Type of construction/age	<input checked="" type="checkbox"/>	<u>New Vertical</u>
Errors/omissions on map	<input type="checkbox"/>	
Other	<input type="checkbox"/>	
Follow up Required <input checked="" type="checkbox"/> <u>Initial</u>	Control Room Notified and Service Call Generated <u>June 1/19</u>	
Additional Comments <u>No animal guarding</u>		

PLM - Patrols Feeder and Completes Form. Completed Form is Given to Line Superintendent. If a Service Call is Required the PLM Will Deliver a Copy of the Form to the Control Room
 Line Superintendent - After Review the Form is Given to the Operations Clerk
 Operations Clerk - Enter Form In Spreadsheet and File by Feeder #
 Control Room - Complete Service Call if Required and Forward to the Line Superintendent Who Will Assign a Crew

4/3/2013

Appendix Q:

OEB Appendix 5-A Unit Cost Metrics

OEB Table 5A			
Metric Category	Metric	Measures	
		2019	2016-2020 Avg.
Cost	Total Cost per Customer	\$ 478	\$ 506
	Total Cost per km of Line	\$ 16,766	\$ 17,650
	Total Cost per MW	\$ 101,891	\$ 102,954
CAPEX	Total CAPEX per Customer	\$ 343	\$ 372
	Total CAPEX per km of Line	\$ 12,053	\$ 12,963
O&M	Total O&M per Customer	\$ 134	\$ 134
	Total O&M per km of Line	\$ 4,713	\$ 4,687

Appendix R:

OEB Chapter 2 Appendix 2-AA

Appendix 2-AA – Capital Projects Table

Projects	2016 Actual	2017 Actual	2018 Actual	2019 Actual	2020 Bridge	2021 Test
Reporting Basis	MIFRS	MIFRS	MIFRS	MIFRS	MIFRS	MIFRS
System Access						
Non-PSWHA Relocations	10,867,476	1,268,988	466,519	159,113	117,212	424,053
PSWHA Relocations	1,597,270	512,165	1,888,798	517,782	1,411,093	919,660
Customer Connections	3,165,292	2,249,709	2,020,785	2,983,265	2,450,707	2,168,379
Expansions (Subdivisions)	967,227	1,015,261	924,406	782,768	644,645	1,081,946
Expansions (Lines)	313,048	663,572	160,030	943,375	458,889	470,395
Retail Meters	464,804	590,504	621,715	760,887	707,852	664,599
Miscellaneous/Other	253,047	(1,924)	4,703	17,077	48,761	111,230
Sub-Total	17,628,164	6,298,275	6,086,957	6,164,267	5,839,159	5,840,262
System Renewal						
Overhead Line Renewal	179,585	608,222	514,169	1,117,214	235,928	3,181,346
Underground Line Renewal	1,536,029	1,602,516	1,615,007	1,873,000	1,770,943	1,435,447
Overhead Line Renewal - Failing Conductor	30,618	405,673	312,801	647,791	1,245,812	853,987
Overhead Line Renewal (8kV)	1,514,370	1,527,537	2,148,877	1,970,758	3,252,494	703,076
Overhead Line Renewal (4kV)	2,567,067	3,090,030	1,831,507	1,621,924	-	-
Reactive Renewal	716,750	426,202	364,105	335,469	304,485	286,140
Proactive Renewal	681,056	664,943	882,231	913,294	843,109	752,106
Station Equipment Renewal	160,631	816,425	391,418	438,142	497,041	125,503
Miscellaneous/Other	415,072	340,351	356,712	444,514	462,264	758,164
Sub-Total	7,801,178	9,481,900	8,416,827	9,362,107	8,612,076	8,095,769
System Service						
Contingency Enhancement	282,615	275,248	607,147	1,133,913	615,740	291,280
Grid Modernization	1,133,013	125,488	758,099	909,408	856,313	909,220
Grid Resiliency	-	-	-	-	-	200,000
Stations Equipment Upgrades	46,760	138,426	234,815	239,219	442,961	406,567
Miscellaneous/Other	279,679	27,909	233,617	322,035	283,977	486,538
Sub-Total	1,742,066	567,071	1,833,677	2,604,576	2,198,991	2,293,605
General Plant						
Fleet - Trucks	406,938	604,043	523,423	331,589	666,740	735,187
IT Asset Lifecycle	111,028	200,116	212,975	198,469	323,891	327,946
IT System Changes and Improvements	73,514	48,901	194,302	136,405	856,410	71,819
IT New Systems and Services	697,082	776,974	155,355	272,793	204,708	169,479
OT Software	76,913	186,511	285,789	305,680	251,346	281,522
Building & Furniture Improvements	175,148	240,318	248,039	215,018	299,600	250,700
MS/DS Decommissioning	488,315	43,546	16,923	96,624	673,544	462,762
Miscellaneous/Other	259,266	164,262	393,334	253,650	278,340	519,461
Sub-Total	2,288,204	2,264,671	2,030,139	1,810,228	3,554,579	2,818,876
Total	29,459,613	18,611,917	18,367,600	19,941,178	20,204,805	19,048,512
Less Renewable Generation Facility Assets and Other Non-Rate-Regulated Utility Assets (input as negative)	(488,315)	(43,546)	(16,923)	(96,624)	(673,544)	(462,762)
Total	28,971,297	18,568,370	18,350,677	19,844,555	19,531,261	18,585,750