

Appendix 'C'

EPC Approved Combination Transfer Switch Meter Bases & Plug-In Transfer Devices

Enova reserves the right to update this Appendix. Contact Enova for the most updated list prior to ordering.



COMBINATION TRANSFER SWITCH METER BASES (SECTION 3.8.16)				
SERVICE VOLTAGE (PHASE/WIRE)	SERVICE AMPERAGE	SOCKET TYPE	ANSI FORM TYPE	APPROVED MODELS
120/240V (1PH 3W)	<=200A	4 JAW	FORM 2S	<u>EATON</u> : EGSC200AMSE, EGS200AMSE

PLUG IN TRANSFER DEVICES (SECTION 3.8.15)				
SERVICE VOLTAGE (PHASE/WIRE)	SERVICE AMPERAGE	SOCKET TYPE	ANSI FORM TYPE	APPROVED MODELS
120/240V (1PH 3W)	<=200A	4 JAW	FORM 2S	<u>GENERLINK</u> : MA23-N, MA23-S, MA24-N, MA24-S

NOTES:
1. CONSULT ENOVA FOR COMBINATION METER BASE MODELS NOT LISTED ABOVE FOR APPROVAL.

REV.	DESCRIPTION	DATE	INITIALS
1	APPENDIX C CREATED	03/24/2021	BD
2	UPDATED FROM WNH TO EPC	08/19/2024	BD
3	UPDATED PART NUMBERS	07/30/2026	BM